

**STATE OF NEVADA
PUBLIC WATER SYSTEMS
ANNUAL COMPLIANCE REPORT
FOR
THE YEAR 2016**



NEVADA DIVISION OF

**ENVIRONMENTAL
PROTECTION**

**NEVADA DIVISION OF ENVIRONMENTAL PROTECTION
BUREAU OF SAFE DRINKING WATER**

**901 S. STEWART ST., Ste. 4001
CARSON CITY, NV 89701**

TABLE OF CONTENTS

The Drinking Water Program: An Overview	page 1
Nevada Public Water Systems General Information	page 5
2016 Violation Statistics	page 6
2016 Violations Summary Report	page 7
Nevada Public Water Systems And Water Sources	Section 2
Annual Compliance Report by Chemical.....	Appendix A
Annual Compliance Detail Report by Water System	Appendix B
Attachment A: Rule-Specific Violation Criteria	A-1
Attachment V: Violation Type Codes.	V-1

The Drinking Water Program: An Overview

The EPA established the Public Water System Supervision (PWSS) Program under the authority of the 1974 Safe Drinking Water Act (SDWA). Under the SDWA and the 1986 Amendments, EPA sets national limits on contaminant levels in drinking water to ensure that the water is safe for human consumption. These limits are known as Maximum Contaminant Levels (MCLs) and the Maximum Residual Disinfectant Levels (MRDLs). For some regulations, EPA establishes treatment techniques in lieu of an MCL to control unacceptable levels of contaminants in water. The Agency also regulates how often public water systems (PWSs) monitor their water for contaminants and report the monitoring results to the states or EPA. Generally, the larger the population served by a water system, the more frequent the monitoring and reporting (M/R) requirements. In addition, EPA requires PWSs to monitor for unregulated contaminants to provide data for future regulatory development. Finally, EPA requires PWSs to notify their consumers when they have violated these regulations. The 1996 Amendments to the SDWA require consumer notification to include a clear and understandable explanation of the nature of the violation, its potential adverse health effects, steps that the PWS is undertaking to correct the violation and the possibility of alternative water supplies during the violation.

The SDWA applies to the 50 states, the District of Columbia, Indian Lands, Puerto Rico, the Virgin Islands, American Samoa, Guam, and the Commonwealth of the Northern Mariana Islands.

The SDWA allows states and territories to seek EPA approval to administer their own PWSS Programs. The authority to run a PWSS Program is called primacy. For a state to receive primacy, EPA must determine that the state meets certain requirements laid out in the SDWA and the regulations, including the adoption of drinking water regulations that are at least as stringent as the Federal regulations and a demonstration that they can enforce the program requirements. Of the 56 states and territories, all but Wyoming and the District of Columbia have primacy. The EPA Regional Offices administer the PWSS Programs within these two jurisdictions.

The 1986 SDWA Amendments gave Indian Tribes the right to apply for and receive primacy. EPA currently administers PWSS Programs on all Indian lands except the Navaho Nation, which was granted primacy in late 2000.

Annual State PWS Report

Each quarter, primacy states submit data to the Safe Drinking Water Information System (SDWIS/FED), an automated database maintained by EPA. The data submitted include, but are not limited to, PWS inventory information, the incidence of Maximum Contaminant Level, Maximum Residual Disinfectant Level, monitoring, and treatment technique violations; and information on enforcement activity related to these violations. Section 1414(c)(3) of the Safe Drinking Water Act requires states to provide EPA with an annual report of violations of the primary drinking water standards. This report provides the numbers of violations in each of six categories: MCLs, MRDLs treatment techniques, variances and exemptions, significant monitoring violations, and significant consumer notification violations. The EPA Regional Offices report the information for Wyoming, the District of Columbia, and all Indian Lands but the Navaho Nation. EPA Regional offices also report Federal enforcement actions taken. Data retrieved from SDWIS/FED form the basis of this report.

Public Water System

A Public Water System (PWS) is defined as a system that provides water via piping or other constructed conveyances for human consumption to at least 15 service connections or serves an average of at least 25 people for at least 60 days each year. There are three types of PWSs. PWSs can be community (such as towns), non-transient non-community (such as schools or factories), or transient non-community systems (such as rest stops or parks). For this report when the acronym "PWS" is used, it means systems of all types unless specified in greater detail.

Maximum Contaminant Level

Under the Safe Drinking Water Act (SDWA), the EPA sets national limits on contaminant levels in drinking water to ensure that the water is safe for human consumption. These limits are known as Maximum Contaminant Levels (MCLs).

Maximum Residual Disinfectant Level

The EPA sets national limits on residual disinfectant levels in drinking water to reduce the risk of exposure to disinfectant byproducts formed, when public water systems add chemical disinfectant for either primary or residual treatment. These limits are known as Maximum Residual Disinfectant Levels (MRDLs).

Treatment Techniques

For some regulations, the EPA establishes treatment techniques (TTs) in lieu of an MCL to control unacceptable levels of certain contaminants. For example, treatment techniques have been established for viruses, some bacteria, and turbidity.

Variations and Exemptions

A primacy state can grant a PWS a variance from a primary drinking water regulation if the characteristics of the raw water sources reasonably available to the PWS do not allow the system to meet the MCL. To obtain a variance, the system must agree to install the best available technology, treatment techniques, or other means of limiting drinking water contamination that the Administrator finds are available (taking costs into account), and the state must find that the variance will not result in an unreasonable risk to public health. The variance shall be reviewed not less than every 5 years to determine if the system remains eligible for the variance.

A primacy state can grant an exemption temporarily relieving a PWS of its obligation to comply with an MCL, treatment technique, or both if the system's noncompliance results from compelling factors (which may include economic factors) and the system was in operation on the effective date of the MCL or treatment technique requirement. The state will require the PWS to comply with the MCL or treatment technique as expeditiously as practicable, but not later than 3 years after the otherwise applicable compliance date.

Monitoring

A PWS is required to monitor and verify that the levels of contaminants present in the water do not exceed the MCL. If a PWS fails to have its water tested as required or fails to report test results correctly to the primacy agent, a monitoring violation occurs.

Significant Monitoring Violations

For this report, significant monitoring violations are generally defined as any significant monitoring violation that occurred during the calendar year of the report. A Significant monitoring violation, with rare exceptions, occurs when no samples were taken or no results were reported during a compliance period.

Consumer Notification

Every Community Water System is required to deliver to its customers a brief annual water quality report. This report is to include some educational material, and will provide information on the source water, the levels of any detected contaminants, and compliance with drinking water regulations.

Significant Consumer Notification Violations

For this report, a significant public notification violation occurred if a community water system completely failed to provide its customers the required annual water quality report.

Public Notice Violations

The Public Notification Rule requires all PWS to notify their consumers any time a PWS violated a national primary drinking water regulation or has a situation posing a risk to public health. Notices must be provided to persons served (not just billing consumers).

NEVADA PUBLIC WATER SYSTEMS
GENERAL INFORMATION

There are **598 Active Public Water Systems in Nevada:**

200 Community Systems serving 2,626,341 people.

167 systems serve between 25 and 3,300 people.
21 systems serve between 3,301 and 10,000 people.
7 systems serve between 10,001 and 50,000 people.
5 systems serve more than 50,001 people.

24 of the Community Water Systems use surface water and serve 2,397,251 of the 2,626,341 people that are served by Community water systems.

143 Non-Transient Non-Community Systems (NTNC) serving 134,164 people.

131 systems serve between 25 and 3,300 people.
12 systems serve between 3,301 and 10,000 people.

25 of the Non-Transient Non-Community Systems use surface water and serve 97,014 of the 134,164 people served by NTNC systems.

255 Transient Non-Community Systems (NC) serving 31,724 people.

All of the Transient Non-Community Systems serve between 25 and 3,300 people.

2 of the Transient Non-Community Systems use surface water and serve 50 of the 31,724 people served by NC systems.

Where to Obtain the 2015 Annual State Public Water Systems Report

NEVADA publishes their Annual Compliance Report and distributes them to the county libraries in the state. It is also available on the Bureau of Safe Drinking Water web site at: <http://ndep.nv.gov/bsdw/oversight.htm>

2016 VIOLATION STATISTICS FOR NEVADA WATER SYSTEMS

Total number of regulated systems	598
Total number of violations	675
Total number of systems that had one or more violations	208
Total number of systems that returned to compliance	83
Total number of systems still in violation	125

State of Nevada 2016 PWS Compliance Report Violations for Compliance Year 2016

Violations Category	Systems in Violation	Violations
Maximum Contaminant Level Exceedance Violations	22	115
Chemical Contaminant Group Monitoring Violations	84	158
Total Coliform Rule Monitoring Violations	29	37
Revised Total Coliform Rule Monitoring Violations	51	64
Surface Water Treatment Rule, Interim Enhanced Surface Water Treatment Rule and Filter Backwash Recycling Rule	1	1
Lead and Copper Rule	0	0
Consumer Confidence Report	14	20
Disinfection Byproducts Rule – Stage 1	10	12
Disinfection Byproducts Rule – Stage 2	21	47
Ground Water Rule	21	28
Public Notice Violations	12	17
State Secondary Maximum Contaminant Level Exceedance Violations	3	11
State Secondary Chemical Contaminant Group Monitoring Violations	33	83
	43	82

2016 Nevada Annual Compliance Summary Report

Maximum Contaminant Violations							
Epa Region	Primacy Agency Code	Violation Category	Rule Group	Rule Name	# of Viols	# of RTC Viols	# of PWS in Viols
9	NV	Maximum Contaminant Level Violation	Chems	Arsenic	91	70	9
9	NV	Maximum Contaminant Level Violation	Chems	IOC	1	0	1
9	NV	Maximum Contaminant Level Violation	Chems	Nitrates	14	11	1
9	NV	Maximum Contaminant Level Violation	Chems	Rads	4	4	0
9	NV	Maximum Contaminant Level Violation	DBPs	St2 DBP	5	5	0
9	NV	Maximum Contaminant Level Violation	Microbial	TCR	11	11	0
	NV	State Maximum Contaminant Level Violation	Secondaries	Secondaries	83	15	35
Total =					209	116	46

Monitoring and Reporting Violations							
Epa Region	Primacy Agency Code	Violation Category	Rule Group	Rule Name	# of Viols	# of RTC Viols	# of PWS in Viols
9	NV	Monitoring and Reporting	Chems	IOC	57	17	34
9	NV	Monitoring and Reporting	Chems	LCR	17	4	10
9	NV	Monitoring and Reporting	Chems	Nitrates	61	43	18
9	NV	Monitoring and Reporting	Chems	Rads	9	4	3
9	NV	Monitoring and Reporting	Chems	Organics	31	15	15
9	NV	Monitoring and Reporting	DBPs	St1 DBP	46	32	9
9	NV	Monitoring and Reporting	DBPs	St2 DBP	27	13	14
9	NV	Monitoring and Reporting	Microbial	GWR	14	12	2
9	NV	Monitoring and Reporting	Microbial	TCR	26	26	0
9	NV	Monitoring and Reporting	Microbial	RTCR	62	55	4
	NV	State Monitoring and Reporting	Secondaries	Secondaries	82	22	58
Total =					432	243	167

Other Violations							
Epa Region	Primacy Agency Code	Violation Category	Rule Group	Rule Name	# of Viols	# of RTC Viols	# of PWS in Viols
9	NV	Other Violation	Other	St1 DBP	1	1	0
9	NV	Other Violation	Other	St2 DBP	1	1	0
9	NV	Other Violation	Other	SWTR	1	0	1
9	NV	Other Violation	Other	GWR	3	1	1

2016 Nevada Annual Compliance Summary Report

9	NV	Other Violation	Other	CCR	12	2	9
9	NV	Other Violation	Other	PN rule	11	0	3
				Total =	29	5	14

Treatment Technique Violations							
Epa Region	Primacy Agency Code	Violation Category	Rule Group	Rule Name	# of Viols	# of RTC Viols	# of PWS in Viols
9	NV	Treatment Technique Violation	Microbial	RTCR	2	1	1
9	NV	Treatment Technique Violation	Chems	LCR	3	0	2
Total =					5	1	3

Acronym	Description
CCR	Consumer Compliance Rule
GWR	Ground Water Rule
LCR	Lead and Copper Rule
IOC	Inorganic Chemicals
PN Rule	Public Notice Rule
Rads	Radionuclides
St1 DBP	Stage 1 Disinfection By-Products
St2 DBP	Stage 2 Disinfection By-Products
TCR	Total Coliform Rule
RTCR	Revised Total Coliform Rule
SWTR	Surface Water Treatment Rule

Nevada Water Systems and Water Sources

County	Water System Type	Water System ID	Water System Name	Population Served	Primary Water Source	Primary Sources Type	Number of Sources	Additional Source Type	Number of Sources
WASHOE	NC	NV0000735	4TH STREET BISTRO	30	GROUNDWATER		1		WELL(S)
LINCOLN	NC	NV0002563	A COWBOYS DREAM	26	GROUNDWATER		1		WELL(S)
WASHOE	NC	NV0000703	AIR BASE INN	25	GROUNDWATER		1		WELL(S)
WASHOE	NC	NV0000866	AIR SAILING INC GLIDERPORT	25	GROUNDWATER		1		WELL(S)
LINCOLN	C	NV0000005	ALAMO SEWER AND WATER GID	900	GROUNDWATER		2		WELL(S)
NYE	NTNC	NV0002190	AMARGOSA ELEMENTARY SCHOOL	200	GROUNDWATER		1		WELL(S)
NYE	NC	NV0000828	AMARGOSA PARK	25	GROUNDWATER		1		WELL(S)
NYE	NTNC	NV0003061	AMARGOSA SENIOR CENTER	25	GROUNDWATER		1		WELL(S)
NYE	NTNC	NV0005037	AMARGOSA TOWN COMPLEX	25	GROUNDWATER		1		WELL(S)
NYE	NC	NV0000811	AMARGOSA VALLEY VFW POST 6826	25	GROUNDWATER		1		WELL(S)
NYE	C	NV0002558	AMARGOSA WATER COMPANY	54	GROUNDWATER		2		WELL(S)
NYE	C	NV0005033	ANCHOR IN MHP	36	GROUNDWATER		1		WELL(S)
ELKO	NC	NV0002088	ANGEL CREEK CAMPGROUND USFS	75	GROUNDWATER		1		WELL(S)
ELKO	NC	NV0003037	ANGEL LAKE CAMPGROUND USFS	100	GROUNDWATER		1		SPRING(S)
WASHOE	NC	NV0004088	ANIMAL ARK	100	GROUNDWATER		1		WELL(S)
LANDER	NC	NV0004105	ANTELOPE VALLEY MEETINGHOUSE LDS	25	GROUNDWATER		1		WELL(S)
CLARK	NTNC	NV0000379	APEX REGIONAL WASTE MGMT CENTER	107	GROUNDWATER		1		WELL(S)
NYE	NC	NV0002141	AREA 51 DEATH VALLEY TRAVEL CENTER	25	GROUNDWATER		1		WELL(S)
WASHOE	C	NV0000191	ARROWHEAD MHP	65	GROUNDWATER		2		WELL(S)
STOREY	NTNC	NV0000879	ASIA UNION ELECTRONIC CHEMICAL CORP	25	GROUNDWATER		1		WELL(S)
NYE	NC	NV0003010	BAILEYS HOT SPRINGS	25	GROUNDWATER		1		SPRING(S)
WHITE PINE	NC	NV0003052	BAKER CREEK CAMPGROUND NPS	45	GROUNDWATER		1		SPRING(S)
WHITE PINE	C	NV0000863	BAKER WATER AND SEWER GID	85	GROUNDWATER		1		WELL(S)
WHITE PINE	NTNC	NV0000982	BALD MOUNTAIN MINE	110	GROUNDWATER		1		WELL(S)
WASHOE	NC	NV0000720	BAR M BAR	25	GROUNDWATER		1		WELL(S)
LANDER	NTNC	NV0000892	BARRICK CORTEZ GOLD MINES PIPELINE	555	GROUNDWATER		1		WELL(S)
LANDER	NTNC	NV0001097	BARRICK CORTEZ HILLS	611	GROUNDWATER		1		WELL(S)
EUREKA	NTNC	NV0005077	BARRICK GOLDSTRIKE FACILITY	2100	GROUNDWATER		1		WELL(S)
HUMBOLDT	NTNC	NV0002528	BARRICK TURQUOISE RIDGE INC	250	GROUNDWATER		2		WELL(S)
NYE	NC	NV0005038	BEATTY RV PARK	25	GROUNDWATER		1		WELL(S)
NYE	C	NV0000009	BEATTY WATER AND SANITATION DISTRICT	1024	GROUNDWATER		6		WELL(S)
LINCOLN	NC	NV0002120	BEAVER DAM STATE PARK	48	GROUNDWATER		1		WELL(S)
CLARK	NTNC	NV0001117	BELLAGIO RESORT AND CASINO	8171	PURCHASED SURFACE WATER		1		CONSECUTIVE CONNECTION(S)
NYE	NC	NV0002151	BERLIN ICHTHYOSAUR STATE PARK	50	GROUNDWATER		1		WELL(S)
CLARK	C	NV0000147	BERMUDA PALMS MANAGEMENT LLC	60	GROUNDWATER		1		WELL(S)
DOUGLAS	NC	NV0002041	BEST WESTERN TOPAZ LAKE INN	300	GROUNDWATER		1		WELL(S)
CLARK	C	NV0004092	BIG BEND WATER DISTRICT	8800	SURFACE WATER		1		INTAKE(S)
NYE	C	NV0000362	BIG FIVE PARK	65	GROUNDWATER		1		WELL(S)

Nevada Water Systems and Water Sources

County	Water System Type	Water System ID	Water System Name	Population Served	Primary Water Source	Primary Sources Type	Number of Sources	Additional Source Type	Number of Sources
NYE	C	NV0000369	BIG VALLEY MHP	50	GROUNDWATER		2		WELL(S)
WASHOE	NC	NV0000736	BIGLIERI WATER SYSTEM	250	GROUNDWATER		2		WELL(S)
WHITE PINE	NC	NV0003053	BIRD CREEK CAMPGROUND USFS	30	GROUNDWATER		1		WELL(S)
WASHOE	NC	NV0000381	BLACK ROCK STATION	25	GROUNDWATER		1		WELL(S)
CLARK	NC	NV0000323	BLUE DIAMOND SALOON	100	GROUNDWATER		1		WELL(S)
CLARK	NC	NV0000955	BLUE DIAMOND TRAVEL CENTER	33	GROUNDWATER		1		WELL(S)
CLARK	C	NV0000092	BLUE DIAMOND WATER CO OP INC	85	GROUNDWATER		1		SPRING(S)
					PURCHASED				CONSECUTIVE
CLARK	C	NV0000010	BLUE DIAMOND WATER COMPANY	527	GROUNDWATER		1		CONNECTION(S)
LANDER	NC	NV0003066	BOB SCOTT CAMPGROUND USFS	25	GROUNDWATER		1		WELL(S)
CLARK	NTNC	NV0001001	BONNIE SPRINGS OLD NEVADA	500	GROUNDWATER		1		WELL(S)
WASHOE	NTNC	NV0000709	BOOMTOWN HOTEL AND CASINO INC	200	GROUNDWATER		5		WELL(S)
ESMERALDA	NC	NV0002090	BOONIES	50	GROUNDWATER		1		WELL(S)
WHITE PINE	NC	NV0005059	BORDER INN	25	GROUNDWATER		1		WELL(S)
					PURCHASED SURFACE				CONSECUTIVE
CLARK	C	NV0000011	BOULDER CITY	15000	WATER		1		CONNECTION(S)
WASHOE	NC	NV0000710	BOWERS MANSION	100	GROUNDWATER		1		WELL(S)
CLARK	NC	NV0000321	BRANDOS SPORTS BAR	105	GROUNDWATER		1		WELL(S)
WASHOE	NC	NV0001149	BRASSERIE SAINT JAMES	1500	GROUNDWATER		1		WELL(S)
LYON	NC	NV0000389	BUCKBOARD GENERAL STORE	25	GROUNDWATER		1		WELL(S)
NYE	C	NV0002538	C VALLEY MHP	54	GROUNDWATER		2		WELL(S)
LINCOLN	C	NV0000013	CALIENTE PUBLIC UTILITIES	1100	GROUNDWATER		3		WELL(S)
ELKO	NC	NV0001091	CALIFORNIA NATIONAL HISTORIC TRAILS CTR	178	GROUNDWATER		1		WELL(S)
NYE	C	NV0000408	CALVADA MEADOWS UICN	77	GROUNDWATER		1		WELL(S)
DOUGLAS	NC	NV0004033	CAMP GALILEE	30	GROUNDWATER		1		WELL(S)
CLARK	NC	NV0002509	CAMP LADY OF THE SNOWS	60	GROUNDWATER		1		WELL(S)
ELKO	NC	NV0004050	CAMP LAMOILLE LIONS CLUB	50	GROUNDWATER		1		WELL(S)
CLARK	NC	NV0005009	CAMP LEE CANYON CCPR	30	GROUNDWATER		1		WELL(S)
CLARK	NC	NV0002502	CAMP POTOSI CCPR	26	GROUNDWATER		1		WELL(S)
					PURCHASED				CONSECUTIVE
CLARK	NC	NV0004024	CAMP STIMSON LDS	100	GROUNDWATER		1		CONNECTION(S)
STOREY	C	NV0005056	CANYON GID	1310	GROUNDWATER		2		WELL(S)
NYE	NC	NV0000405	CARBERRY SQUARE	25	GROUNDWATER		1		WELL(S)
ELKO	NTNC	NV0002524	CARLIN HONOR CAMP NDOC	147	GROUNDWATER		1		WELL(S)
ELKO	C	NV0000014	CARLIN UTILITIES	2500	GROUNDWATER		1	SPRING(S)	1
LYON	NC	NV0000341	CARMENS MEXICAN RESTAURANT	25	GROUNDWATER		1		WELL(S)
CARSON CITY	NC	NV0000958	CARSON CAR CENTER	25	GROUNDWATER		1		WELL(S)

Nevada Water Systems and Water Sources

County	Water System Type	Water System ID	Water System Name	Population Served	Primary Water Source	Primary Sources Type	Number of Sources	Additional Source Type	Number of Sources
CARSON CITY	C	NV0000015	CARSON CITY PUBLIC WORKS	56000	SURFACE WATER		31 WELL(S)	INTAKE (S)	3
CHURCHILL	C	NV0003068	CARSON RIVER ESTATES	90	GROUNDWATER		3 WELL(S)		
NYE	NC	NV0002140	CARVERS CAFE	50	GROUNDWATER		1 WELL(S)		
NYE	C	NV0000218	CARVERS SMOKEY VALLEY RV AND MHP	250	GROUNDWATER		1 WELL(S)		
CHURCHILL	C	NV0000059	CASEY ROAD MHP	30	GROUNDWATER		1 WELL(S)		
WHITE PINE	NC	NV0004035	CAVE LAKE STATE PARK	2000	GROUNDWATER		1 SPRING(S)		
DOUGLAS	C	NV0000259	CAVE ROCK SKYLAND	1267	SURFACE WATER		1 INTAKE(S)		
WHITE PINE	NC	NV0000301	CAVE SPRINGS WATER SYSTEM NPS	1000	GROUNDWATER		3 SPRING(S)		
NYE	NTNC	NV0001095	CEDAR PASS WATER SYSTEM	250	GROUNDWATER		1 WELL(S)		
CLARK	NTNC	NV0000364	CERTAIN TEED GYPSUM	85	GROUNDWATER		2 WELL(S)		
LYON	NC	NV0002128	CG BAR	25	GROUNDWATER		1 WELL(S)		
NYE	NC	NV0002555	CHAMPIONS	25	GROUNDWATER		1 WELL(S)		
WHITE PINE	NC	NV0002165	CHERRY CREEK WATER DISTRICT	25	GROUNDWATER		1 WELL(S)		
NYE	NC	NV0003060	CHERRY PATCH LOVE RANCH	25	GROUNDWATER		1 WELL(S)		
NYE	NC	NV0004085	CHICKEN RANCH	25	GROUNDWATER		2 WELL(S)		
DOUGLAS	NTNC	NV0005078	CHINA SPRINGS YOUTH CAMP	92	GROUNDWATER		1 WELL(S)		
NYE	C	NV0002554	CHIPMUNK RETREAT	44	GROUNDWATER		1 WELL(S)		
CLARK	NTNC	NV0002533	CHUCK LENZIE GENERATING STATION	54	GROUNDWATER		4 WELL(S)		
WASHOE	NC	NV0004079	CHUCKS CIRCLE C MARKET	25	GROUNDWATER		1 WELL(S)		
LYON	NC	NV0005020	CHURCHILL BUTTE COMPLEX	25	GROUNDWATER		1 WELL(S)		
CLARK	NTNC	NV0001113	CIRCUS CIRCUS CASINO	2668	PURCHASED SURFACE WATER		1 CONNECTION(S)	CONSECUTIVE	
CLARK	NTNC	NV0001106	CITY CENTER HOTELS	8900	PURCHASED SURFACE WATER		1 CONNECTION(S)	CONSECUTIVE	
CLARK	C	NV0001109	CITY CENTER RESIDENCES	808	PURCHASED SURFACE WATER		1 CONNECTION(S)	CONSECUTIVE	
PERSHING	NTNC	NV0003076	COEUR ROCHESTER INC	32	GROUNDWATER		1 WELL(S)		
CLARK	C	NV0004000	COLD CREEK CANYON HOMEOWNERS	180	GROUNDWATER		2 WELL(S)		
WHITE PINE	C	NV0005057	COLD CREEK MHP	35	GROUNDWATER		1 WELL(S)		
WASHOE	NC	NV0004103	COLD SPRINGS MEETINGHOUSE LDS	25	GROUNDWATER		1 WELL(S)		
CHURCHILL	NC	NV0002017	COLD SPRINGS STATION	25	GROUNDWATER		1 WELL(S)		
HUMBOLDT	NC	NV0002113	COMMUNITY HALL PARADISE VALLEY	72	GROUNDWATER		1 WELL(S)		
WASHOE	C	NV0000277	CONESTOGA MHP	120	GROUNDWATER		1 WELL(S)		
CLARK	NC	NV0001024	CORN CREEK FIELD STATION FWS	25	GROUNDWATER		1 WELL(S)		
LANDER	NTNC	NV0002570	CORTEZ MILL 1 POTABLE WATER SYSTEM	83	GROUNDWATER		1 WELL(S)		
CLARK	NTNC	NV0001137	COSMOPOLITAN HOTEL	5534	PURCHASED SURFACE WATER		1 CONNECTION(S)	CONSECUTIVE	

Nevada Water Systems and Water Sources

County	Water System Type	Water System ID	Water System Name	Population Served	Primary Water Source	Primary Sources Type	Number of Sources	Additional Source Type	Number of Sources
CARSON CITY	C	NV0000017	COTTONWOOD MHP	250	GROUNDWATER		3		WELL(S)
NYE	C	NV0005032	COUNTRY VIEW ESTATES UICN	1292	GROUNDWATER		3		WELL(S)
NYE	NC	NV0000385	COYOTE CORNER III	25	GROUNDWATER		1		WELL(S)
NYE	NC	NV0002565	COYOTE CORNER MARKET	25	GROUNDWATER		1		WELL(S)
CLARK	NTNC	NV0001081	CREECH AIR FORCE BASE	300	GROUNDWATER		3		WELL(S)
NYE	NTNC	NV0000418	CRESCENT DUNES SOLAR ENERGY	40	GROUNDWATER		2		WELL(S)
EUREKA	C	NV0000043	CRESCENT VALLEY WATER SYSTEM	340	GROUNDWATER		2		WELL(S)
WASHOE	NC	NV0000717	CROSBYS LODGE	25	GROUNDWATER		1		WELL(S)
WASHOE	NC	NV0000718	CRYSTAL PEAK PARK	30	GROUNDWATER		1		WELL(S)
WASHOE	C	NV0000193	CRYSTAL TP	80	GROUNDWATER		1		WELL(S)
ELKO	NC	NV0002068	CURRIE STORE	25	GROUNDWATER		1		WELL(S)
WASHOE	NC	NV0000719	DAVIS CREEK PARK	100	GROUNDWATER		1		WELL(S)
LYON	C	NV0000032	DAYTON VALLEY WATER SYSTEM	15005	GROUNDWATER		8	CONSECUTIVE CONNECTION(S)	1
CLARK	NC	NV0001078	DEER CREEK SPRING	150	GROUNDWATER		1		SPRING(S)
HUMBOLDT	NC	NV0000001	DENIO JUNCTION	25	GROUNDWATER		1		WELL(S)
HUMBOLDT	NC	NV0004062	DENIO MERCANTILE AND BED AND BREAKFAST	25	GROUNDWATER		1		WELL(S)
MINERAL	NTNC	NV0001156	DENTON RAWHIDE MINE	75	GROUNDWATER		2		WELL(S)
NYE	NC	NV0002196	DESERT CENTER PLAZA	25	GROUNDWATER		1		WELL(S)
NYE	C	NV0000831	DESERT MIRAGE HOMEOWNERS ASSOCIATION	230	GROUNDWATER		2		WELL(S)
CLARK	C	NV0000149	DESERT PARADISE MHP	70	GROUNDWATER		1		WELL(S)
CLARK	NC	NV0001008	DESERT SOUTHWEST CONFERENCE	30	GROUNDWATER		1		WELL(S)
NYE	C	NV0000300	DESERT UTILITIES	1086	GROUNDWATER		3		WELL(S)
EUREKA	C	NV0002574	DEVILS GATE GID DISTRICT 1	65	GROUNDWATER		1		WELL(S)
EUREKA	C	NV0002573	DEVILS GATE WATER SYSTEM GID 2	70	GROUNDWATER		1	CONSECUTIVE CONNECTION(S)	1
HUMBOLDT	NTNC	NV0001148	DIAMOND PLASTICS	38	GROUNDWATER		1		WELL(S)
ELKO	NC	NV0004096	DOUBLE D BAR & GRILL	25	GROUNDWATER		1		WELL(S)
DOUGLAS	NC	NV0002043	DOUGLAS COUNTY LAMPE PARK	200	GROUNDWATER		1		WELL(S)
DOUGLAS	NC	NV0002044	DOUGLAS COUNTY TOPAZ PARK	100	GROUNDWATER		1		WELL(S)
ELKO	NC	NV0000949	DOVETAIL RANCH	25	GROUNDWATER		1		WELL(S)
LYON	NC	NV0002593	DRESSLER PARK	25	GROUNDWATER		1		WELL(S)
PERSHING	C	NV0000809	DUTCHMAN ACRES	121	GROUNDWATER		2		WELL(S)
ESMERALDA	NTNC	NV0002184	DYER ELEMENTARY SCHOOL	70	GROUNDWATER		1		WELL(S)
STOREY	NTNC	NV0003075	EAGLE PICHER MINERALS	50	GROUNDWATER		1		WELL(S)
LINCOLN	NC	NV0000188	EAGLE VALLEY RESORT	25	GROUNDWATER		2		WELL(S)
LYON	NC	NV0003098	EAST 50 BAR	25	GROUNDWATER		1		WELL(S)
DOUGLAS	NC	NV0002218	EAST PEAK LODGE	2000	GROUNDWATER		1		WELL(S)

Nevada Water Systems and Water Sources

County	Water System Type	Water System ID	Water System Name	Population Served	Primary Water Source	Primary Sources Type	Number of Sources	Additional Source Type	Number of Sources
DOUGLAS	C	NV0002216	EAST VALLEY WATER SYSTEM	4030	PURCHASED GROUNDWATER		3	CONSECUTIVE CONNECTION(S) WELL(S)	1
CLARK	C	NV0000106	EASTLAND HEIGHTS WATER ASSOCIATION	400	GROUNDWATER		2	WELL(S)	
LINCOLN	NC	NV0002123	ECHO CANYON STATE PARK	196	GROUNDWATER		1	WELL(S)	
DOUGLAS	NTNC	NV0000235	EDGEWOOD WATER COMPANY	3800	SURFACE WATER		1	CONSECUTIVE INTAKE(S) CONNECTION(S)	1
CLARK	NC	NV0004111	EL DORADO CANYON MINE TOURS	25	GROUNDWATER		1	WELL(S)	
DOUGLAS	C	NV0000271	ELK POINT COUNTRY CLUB	325	GROUNDWATER		2	WELL(S)	
ELKO	C	NV0000272	ELKO CITY OF	18000	GROUNDWATER		17	WELL(S)	
ELKO	C	NV0002075	ELKO RV PARK AT RYNDON	357	GROUNDWATER		2	WELL(S)	
NYE	NC	NV0000923	ELKS LODGE PAHRUMP	25	GROUNDWATER		1	WELL(S)	
WHITE PINE	NTNC	NV0004083	ELY CONSERVATION CAMP NDOC	150	GROUNDWATER		1	WELL(S)	
WHITE PINE	C	NV0005071	ELY MAXIMUM SECURITY PRISON NDOC	1099	GROUNDWATER		2	WELL(S)	
WHITE PINE	C	NV0000038	ELY MUNICIPAL WATER DEPARTMENT	5000	GROUNDWATER		7	WELL(S)	
WASHOE	C	NV0000042	EMPIRE MINING COMPANY	350	GROUNDWATER		2	WELL(S)	
CHURCHILL	NTNC	NV0004120	EP MINERALS FERNLEY PLANT	41	GROUNDWATER		1	WELL(S)	
CLARK	C	NV0000109	EQUESTRIAN ESTATES CO OP WATER ASSOC	108	GROUNDWATER		2	WELL(S)	
NYE	C	NV0002552	ESCAPEE CO OP OF NEVADA	200	GROUNDWATER		2	WELL(S)	
ESMERALDA	NC	NV0000890	ESMERALDA MARKET	100	GROUNDWATER		2	WELL(S)	
EUREKA	NC	NV0004104	EUREKA MEETINGHOUSE LDS	25	GROUNDWATER		1	WELL(S)	
EUREKA	C	NV0000044	EUREKA WATER ASSOCIATION	450	GROUNDWATER		2	WELL(S) SPRING(S)	10
CLARK	NTNC	NV0001114	EXCALIBUR RESORT AND CASINO	2607	PURCHASED SURFACE WATER		1	CONSECUTIVE CONNECTION(S)	
DOUGLAS	C	NV0002540	FAIRGROUNDS/SUNRISE ESTATES	911	GROUNDWATER		3	WELL(S)	
CHURCHILL	C	NV0000045	FALLON CITY OF	8500	GROUNDWATER		4	CONSECUTIVE WELL(S) CONNECTION(S)	1
CHURCHILL	NC	NV0002594	FALLON LIVESTOCK EXCHANGE	25	GROUNDWATER		1	WELL(S)	
CHURCHILL	C	NV0000350	FALLON NAVAL AIR STATION	3000	GROUNDWATER		3	CONSECUTIVE WELL(S) CONNECTION(S)	1
CHURCHILL	NC	NV0002534	FALLON RV PARK	25	GROUNDWATER		1	WELL(S)	
LYON	C	NV0000062	FERNLEY PUBLIC WORKS	18000	SURFACE WATER		6	WELL(S)	
WHITE PINE	NC	NV0002170	FIRESIDE INN	50	GROUNDWATER		1	WELL(S)	
ESMERALDA	NC	NV0000916	FISH LAKE VALLEY SALOON	25	GROUNDWATER		1	WELL(S)	
PERSHING	NTNC	NV0000884	FLORIDA CANYON MINING INC	180	GROUNDWATER		1	WELL(S)	
CLARK	NC	NV0001053	FLOYD LAMB PARK	100	GROUNDWATER		1	WELL(S)	
WASHOE	C	NV0000200	FOOTHILL TRAILER PARK	35	GROUNDWATER		1	WELL(S)	
DOUGLAS	C	NV0000959	FOOTHILL WATER SYSTEM	346	GROUNDWATER		3	WELL(S)	
NYE	NC	NV0000155	FORT AMARGOSA RV PARK	25	GROUNDWATER		1	WELL(S)	

Nevada Water Systems and Water Sources

County	Water System Type	Water System ID	Water System Name	Population Served	Primary Water Source	Primary Sources Type	Number of Sources	Additional Source Type	Number of Sources
LYON	NC	NV0002132	FORT CHURCHILL HISTORIC STATE PARK	207	GROUNDWATER		1		
LYON	NTNC	NV0000806	FORT CHURCHILL POWER PLANT	37	GROUNDWATER		2		
WASHOE	NC	NV0000893	FRANKTOWN MEADOWS	25	GROUNDWATER		2		
NYE	C	NV0000063	GABBS WATER SYSTEM	411	GROUNDWATER		2		
DOUGLAS	C	NV0000066	GARDNERVILLE RANCHOS GID	9500	GROUNDWATER		7		
DOUGLAS	C	NV0000065	GARDNERVILLE TOWN WATER	4500	GROUNDWATER		7	CONSECUTIVE CONNECTION(S)	1
CHURCHILL	NC	NV0002587	GAS STORE WEST	25	GROUNDWATER		1		
CLARK	NTNC	NV0000327	GAYE HAVEN CARE HOME	50	GROUNDWATER		1		
CLARK	NTNC	NV0000372	GEORGIA PACIFIC GYPSUM LLC	100	GROUNDWATER		1		
WASHOE	C	NV0000071	GERLACH GID	180	GROUNDWATER		2		
CLARK	NC	NV0003029	GIRL SCOUTS NV CAMP FOXTAIL	250	GROUNDWATER		1		
DOUGLAS	C	NV0000356	GLENBROOK HOMEOWNERS ASSOCIATION	1000	SURFACE WATER		1		
HUMBOLDT	C	NV0005029	GOLCONDA GID	300	GROUNDWATER		2	SPRING(S)	1
LYON	NC	NV0000881	GOLD CANYON CAFE	25	GROUNDWATER		1		
HUMBOLDT	C	NV0003079	GOLD COUNTRY ESTATES	1695	GROUNDWATER		4	CONSECUTIVE CONNECTION(S)	1
PERSHING	NC	NV0001124	GOLD DIGGERS SALOON & GRUBB HOUSE	25	GROUNDWATER		1		
WASHOE	NTNC	NV0000751	GOLD RANCH CASINO	1000	GROUNDWATER		1		
WASHOE	NC	NV0004064	GOLDEN VALLEY PARK	25	GROUNDWATER		1		
ESMERALDA	C	NV0000072	GOLDFIELD TOWN WATER	350	GROUNDWATER		2		
CLARK	NTNC	NV0001045	GOODSPRINGS SCHOOL CCSD	25	GROUNDWATER		1		
CLARK	NTNC	NV0001144	GRANDVIEW AT LAS VEGAS	5750	PURCHASED SURFACE WATER		1	CONSECUTIVE CONNECTION(S)	
WASHOE	C	NV0000035	GRANDVIEW TERRACE WATER DISTRICT	328	GROUNDWATER		3		
WASHOE	NTNC	NV0002202	GRANITE CONSTRUCTION	50	GROUNDWATER		1		
WASHOE	NC	NV0004109	GRANITE HILLS BAPTIST CHURCH	94	GROUNDWATER		1		
WASHOE	C	NV0000207	GREAT BASIN WATER CO COLD SPRINGS	7962	GROUNDWATER		5		
WASHOE	C	NV0001086	GREAT BASIN WATER CO SPANISH SPRINGS	2030	GROUNDWATER		2		
ELKO	C	NV0000036	GREAT BASIN WATER CO SPRING CREEK	6708	GROUNDWATER		9		
ELKO	C	NV0005027	GREAT BASIN WATER CO SPRING CREEK	3645	GROUNDWATER		3		
NYE	C	NV0000270	GREAT BASIN WATER COMPANY	8538	GROUNDWATER		5		
WHITE PINE	NTNC	NV0001142	GRP PAN LLC	100	GROUNDWATER		1		
EUREKA	NTNC	NV0001131	HALLIBURTON DUNPHY MILL	90	GROUNDWATER		1		
CHURCHILL	NC	NV0002580	HARMON JUNCTION	150	GROUNDWATER		1		
CLARK	C	NV0001080	HARRIS SPRINGS RANCH	40	GROUNDWATER		1		
MINERAL	C	NV0000357	HAWTHORNE ARMY DEPOT	300	SURFACE WATER		1	WELL(S)	2

Nevada Water Systems and Water Sources

County	Water System Type	Water System ID	Water System Name	Population Served	Primary Water Source	Primary Sources Type	Number of Sources	Additional Source Type	Number of Sources
MINERAL	C	NV0000073	HAWTHORNE UTILITIES	2900	GROUNDWATER		5 WELL(S)		
CLARK	C	NV0000076	HENDERSON CITY OF	275000	SURFACE WATER		1 INTAKE(S)	CONSECUTIVE CONNECTION(S)	2
LYON	NC	NV0004037	HEYDAY INN	25	GROUNDWATER		1 WELL(S)		
WHITE PINE	NC	NV0000961	HIDDEN CANYON RANCH	140	GROUNDWATER		1 WELL(S)		
CLARK	C	NV0000145	HILLCREST MANOR WATER USERS ASSOCIATION	450	GROUNDWATER		2 WELL(S)		
CLARK	NTNC	NV0001160	HILTON GRAND VACATIONS CONVENTION	982	PURCHASED SURFACE WATER		1 CONNECTION(S)	CONSECUTIVE	
CLARK	NTNC	NV0001143	HILTON GRAND VACATIONS ELARA	712	PURCHASED SURFACE WATER		1 CONNECTION(S)	CONSECUTIVE	
CLARK	NTNC	NV0001136	HILTON GRAND VACATIONS FLAMINGO	712	PURCHASED SURFACE WATER		1 CONNECTION(S)	CONSECUTIVE	
CLARK	NTNC	NV0001150	HILTON GRAND VACATIONS LAS VEGAS BLVD	2488	PURCHASED SURFACE WATER		1 CONNECTION(S)	CONSECUTIVE	
CLARK	C	NV0000146	HITCHIN POST MOTEL AND RV PARK	350	GROUNDWATER		2 WELL(S)		
LYON	NTNC	NV0004053	HODGES TRANSPORTATION CO	160	GROUNDWATER		3 WELL(S)		
DOUGLAS	C	NV0002046	HOLBROOK STATION RV AND MHP	180	GROUNDWATER		2 WELL(S)		
CHURCHILL	NC	NV0002586	HOLLYWOOD SKATE	25	GROUNDWATER		1 WELL(S)		
CLARK	NTNC	NV0003006	HOOVER DAM	3000	SURFACE WATER		2 INTAKE(S)		
CLARK	NTNC	NV0001083	HOOVER DAM LODGE DBA HACIENDA	250	PURCHASED SURFACE WATER		1 CONNECTION(S)	CONSECUTIVE	
NYE	NC	NV0000833	HORIZON C-STORES LLC	25	GROUNDWATER		1 WELL(S)		
NYE	NC	NV0000918	HORIZON MARKET III	25	GROUNDWATER		1 WELL(S)		
HUMBOLDT	NTNC	NV0005069	HUMBOLDT CONSERVATION CAMP NDOC	140	GROUNDWATER		1 WELL(S)		
PERSHING	NC	NV0001125	HUMBOLDT RIVER RANCH ASSOCIATION	150	GROUNDWATER		1 WELL(S)		
HUMBOLDT	NTNC	NV0000864	HYCROFT RESOURCES & DEVELOPMENT	921	GROUNDWATER		1 WELL(S)		
CLARK	NC	NV0004073	IDLE SPURS LOUNGE AND RESTAURANT	58	GROUNDWATER		1 WELL(S)		
PERSHING	C	NV0000226	IMLAY WATER SYSTEM	200	GROUNDWATER		2 WELL(S)		
WASHOE	C	NV0000158	INCLINE VILLAGE GID	9313	SURFACE WATER		1 INTAKE(S)		
DOUGLAS	C	NV0000355	INDIAN HILLS GID	5900	GROUNDWATER		3 WELL(S)	CONSECUTIVE CONNECTION(S)	2
CLARK	NTNC	NV0005006	INDIAN SPGS AIR FORCE PT BRAVO	50	GROUNDWATER		1 WELL(S)		
CLARK	NC	NV0000378	INDIAN SPRINGS AFB SILVER FLAG ALPHA	35	GROUNDWATER		1 WELL(S)		
CLARK	C	NV0000082	INDIAN SPRINGS WATER CO INC	900	GROUNDWATER		2 WELL(S)		

Nevada Water Systems and Water Sources

County	Water System Type	Water System ID	Water System Name	Population Served	Primary Water Source	Primary Sources Type	Number of Sources	Additional Source Type	Number of Sources
NYE	NC	NV0002143	IONE WATER SYSTEM	25	GROUNDWATER		1		WELL(S)
ELKO	NC	NV0002069	JACK CREEK LODGE	25	GROUNDWATER		1		WELL(S)
ELKO	C	NV0000088	JACKPOT WATER SYSTEM	1240	GROUNDWATER		5		WELL(S)
ELKO	C	NV0002070	JARBIDGE WATER SYSTEM	200	SURFACE WATER		2		INTAKE(S)
CLARK	C	NV0000089	JEAN UTILITY SERVICES INC	560	GROUNDWATER		3		WELL(S)
ELKO	NTNC	NV0003013	JERRITT CANYON GOLD MINE	125	GROUNDWATER		2		WELL(S)
ELKO	NTNC	NV0000313	JERRITT CANYON GOLD SSX MINE	125	GROUNDWATER		1		WELL(S)
ELKO	NC	NV0002071	JIGGS BAR	25	GROUNDWATER		1		WELL(S)
WASHOE	NC	NV0000731	JOHNNY CASSINARIS RESTAURANT	150	GROUNDWATER		1		WELL(S)
CLARK	NTNC	NV0001107	KAPEX WATER SYSTEM CITY OF NLV	25	GROUNDWATER		1		WELL(S)
WASHOE	C	NV0000199	KE TA MOBILE HOME PARK	60	GROUNDWATER		2		WELL(S)
CHURCHILL	NTNC	NV0002024	KENAMETAL INC	75	GROUNDWATER		1		WELL(S)
LINCOLN	NC	NV0002121	KERSHAW RYAN STATE PARK	25	GROUNDWATER		1		WELL(S)
CLARK	NC	NV0000932	KEYSTONE CENTER	30	GROUNDWATER		1		WELL(S)
HUMBOLDT	NTNC	NV0002198	KINGS RIVER ELEMENTARY SCHOOL	27	GROUNDWATER		1		WELL(S)
CLARK	C	NV0000287	KINGS ROW TP	555	GROUNDWATER		1	CONSECUTIVE CONNECTION(S)	1
DOUGLAS	C	NV0000004	KINGSBURY GID	3839	SURFACE WATER		1		INTAKE(S)
LANDER	C	NV0000265	KINGSTON TOWN WATER UTILITIES	350	GROUNDWATER		2		WELL(S)
ELKO	NTNC	NV0000349	KLONDEX HOLLISTER MINE INC	150	GROUNDWATER		1		WELL(S)
ELKO	NTNC	NV0000908	KLONDEX MIDAS OPERATIONS INC	80	GROUNDWATER		2		WELL(S)
WHITE PINE	C	NV0002174	KOA OF ELY CAMPGROUND	80	GROUNDWATER		2		WELL(S)
CLARK	C	NV0000142	KYLE CANYON WATER DISTRICT	1040	GROUNDWATER		4		WELL(S)
CHURCHILL	NC	NV0002028	LAHONTAN DAM STATE PARK	26	WATER	GROUNDWATER UNDER INFLUENCE OF SURFACE	2		SPRING(S)
LYON	NC	NV0002133	LAHONTAN DAM STATE PARK BEACH 3	25	GROUNDWATER		1		WELL(S)
LYON	NC	NV0005021	LAHONTAN DAM STATE PARK BEACH 7	305	GROUNDWATER		1		WELL(S)
CLARK	NC	NV0000942	LAKER PLAZA INC	25	GROUNDWATER		1	CONSECUTIVE CONNECTION(S)	1
NYE	NTNC	NV0000834	LAKESIDE CASINO AND RV PARK	25	GROUNDWATER		1		WELL(S)
ELKO	NTNC	NV0000928	LAMOILLE VALLEY PLAZA	351	GROUNDWATER		1		WELL(S)
ELKO	C	NV0000273	LAMOILLE WATER USERS ASSOC	200	GROUNDWATER		2		WELL(S)
LANDER	C	NV0000008	LANDER CO SEWER AND WATER DIST 1 BM LANDER CO SEWER AND WATER DIST 2	3635	GROUNDWATER		3		WELL(S)
LANDER	C	NV0000006	AUSTIN	350	GROUNDWATER		2	SPRING(S)	1
WHITE PINE	NC	NV0004055	LANES TRAVEL CENTER	50	GROUNDWATER		1		WELL(S)
CLARK	NC	NV0000307	LAS VEGAS SKI AND SNOWBOARD RESORT	1005	GROUNDWATER		2		WELL(S)

Nevada Water Systems and Water Sources

County	Water System Type	Water System ID	Water System Name	Population Served	Primary Water Source	Primary Sources Type	Number of Sources	Additional Source Type	Number of Sources
HUMBOLDT	NTNC	NV0001103	MARIGOLD MINE POTABLE WATER SYSTEM	300	GROUNDWATER		1		
STOREY	NTNC	NV0000878	MARS PETCARE US INC	140	GROUNDWATER		1		
HUMBOLDT	C	NV0000162	MCDERMITT WATER SYSTEM	200	GROUNDWATER		2		
WHITE PINE	C	NV0000163	MCGILL WATER AND SEWER DIST	1200	GROUNDWATER		2		
CLARK	NC	NV0002508	MCWILLIAMS WATER SYSTEM	25	GROUNDWATER		1	CONSECUTIVE CONNECTION(S)	1
WASHOE	NC	NV0000757	MELS DINER	1000	GROUNDWATER		1		
WASHOE	NC	NV0000950	MEMORIAL POINT STATE PARK	25	GROUNDWATER		1		
CLARK	NTNC	NV0001121	MGM GRAND HOTEL AND CASINO	7500	PURCHASED SURFACE WATER		1	CONSECUTIVE CONNECTION(S)	
ELKO	NC	NV0003071	MIDAS WATER COOPERATIVE	25	GROUNDWATER		2		
CHURCHILL	NC	NV0002027	MIDDLEGATE STATION	25	GROUNDWATER		1		
CARSON CITY	NC	NV0002006	MILL HOUSE INN MOTEL	50	GROUNDWATER		1		
MINERAL	C	NV0000074	MINA LUNING WATER SYSTEM	300	GROUNDWATER		3		
ESMERALDA	NTNC	NV0001151	MINERAL RIDGE MINE	60	GROUNDWATER		2		
CLARK	NTNC	NV0001120	MIRAGE RESORT AND CASINO	4400	PURCHASED SURFACE WATER		1	CONSECUTIVE CONNECTION(S)	
WASHOE	NC	NV0004116	MOANA NURSERY	25	GROUNDWATER		1		
CLARK	C	NV0000160	MOAPA VALLEY WATER DISTRICT	8500	GROUNDWATER		4	SPRING(S)	2
DOUGLAS	C	NV0002564	MONTANA	330	GROUNDWATER		2	CONSECUTIVE CONNECTION(S)	1
CLARK	NTNC	NV0001118	MONTE CARLO RESORT AND CASINO	1980	PURCHASED SURFACE WATER		1	CONSECUTIVE CONNECTION(S)	
ELKO	C	NV0000169	MONTELLO WATER SYSTEM	287	GROUNDWATER		2	SPRING(S)	
NYE	NC	NV0002142	MOOSE LODGE 808	25	GROUNDWATER		1		
WASHOE	C	NV0000732	MOUNT ROSE BOWL PROPERTY OWNERS WATER CO	40	GROUNDWATER		1	SPRING(S)	
ELKO	C	NV0000170	MOUNTAIN CITY WATER AND SEWER	30	GROUNDWATER		1	SPRING(S)	
NYE	C	NV0000920	MOUNTAIN FALLS WATER SYSTEM UICN	1718	GROUNDWATER		2		
CLARK	NC	NV0001082	MOUNTAIN SPRINGS BAR INC	75	GROUNDWATER		1		
DOUGLAS	C	NV0003081	MOUNTAIN VIEW MHP	45	GROUNDWATER		1		
NYE	C	NV0005067	MOUNTAIN VIEW MHP UICN	65	GROUNDWATER		1		
WASHOE	NC	NV0000789	MSJK PROPERTIES LLC	50	GROUNDWATER		1		
CLARK	NC	NV0001010	MT CHARLESTON RESTAURANT AND LODGE	450	GROUNDWATER		1		
CLARK	C	NV0001015	MT CHARLESTON WATER COMPANY	535	GROUNDWATER		1		
WASHOE	NC	NV0000743	MT ROSE CAMPGROUND USFS	25	GROUNDWATER		1		

Nevada Water Systems and Water Sources

County	Water System Type	Water System ID	Water System Name	Population Served	Primary Water Source	Primary Sources Type	Number of Sources	Additional Source Type	Number of Sources
WASHOE	NC	NV0000744	MT ROSE SKI AREA SKI RENO	800	GROUNDWATER		1	SPRING(S)	
LINCOLN	NC	NV0000876	NARCONON NEVADA RAINBOW CANYON	44	GROUNDWATER		1	WELL(S)	
CHURCHILL	NTNC	NV0002541	NAS CENTROID EW RANGE	80	GROUNDWATER		1	WELL(S)	
WASHOE	NTNC	NV0000869	NATCHEZ GYM	175	GROUNDWATER		1	WELL(S)	
WASHOE	NTNC	NV0000774	NATCHEZ SCHOOL	200	GROUNDWATER		1	WELL(S)	
EUREKA	NC	NV0002214	NDOT BEOWAWE ROADSIDE PARK RP802 EU	100	GROUNDWATER		1	WELL(S)	
			NDOT BIG SMOKEY ROADSIDE PARK						
NYE	NC	NV0002147	RP807NY	25	GROUNDWATER		1	WELL(S)	
			NDOT BUTTON POINT ROADSIDE PARK						
HUMBOLDT	NC	NV0001054	RP808HU	600	GROUNDWATER		1	WELL(S)	
PERSHING	NC	NV0002160	NDOT COSGRAVE ROADSIDE PARK RP804PE	500	GROUNDWATER		1	WELL(S)	
			NDOT LATHROP WELLS ROADSIDE PARK						
NYE	NC	NV0002146	RP801NY	50	GROUNDWATER		1	WELL(S)	
ESMERALDA	NC	NV0002089	NDOT MILLERS NV ROADSIDE PARK RP801ES	200	GROUNDWATER		1	WELL(S)	
CLARK	NC	NV0001101	NDOT SEARCHLIGHT WELCOME CENTER	50	GROUNDWATER		1	WELL(S)	
NYE	NC	NV0000943	NDOT SUNNYSIDE ROADSIDE PARK RP810NY	25	GROUNDWATER		1	WELL(S)	
					PURCHASED			CONSECUTIVE	
CHURCHILL	NC	NV0002034	NDOT TRINITY ROADSIDE PARK RP806CH	100	GROUNDWATER		1	CONNECTION(S)	
HUMBOLDT	NC	NV0002102	NDOT VALMY ROADSIDE PARK RP809HU	367	GROUNDWATER		1	WELL(S)	
WASHOE	NC	NV0004022	NDOT WADSWORTH REST STOP	25	GROUNDWATER		1	WELL(S)	
					PURCHASED SURFACE			CONSECUTIVE	
CLARK	C	NV0003028	NELLIS AIR FORCE BASE	19081	WATER		8	WELL(S)	2
CONNECTION(S)									
CHURCHILL	NC	NV0002014	NEVADA LIVESTOCK MARKETING	25	GROUNDWATER		1	WELL(S)	
NYE	NTNC	NV0000360	NEVADA TEST SITE A23 AND 6	1700	GROUNDWATER		3	WELL(S)	
NYE	NC	NV0004099	NEVADA TEST SITE AREA 12	25	GROUNDWATER		1	WELL(S)	
NYE	NC	NV0004098	NEVADA TEST SITE AREA 25	120	GROUNDWATER		2	WELL(S)	
ELKO	C	NV0000037	NEVADA YOUTH TRAINING CENTER	100	GROUNDWATER		1	WELL(S)	
CHURCHILL	NTNC	NV0000903	NEW MILLENNIUM BUILDING SYSTEMS, LLC	50	GROUNDWATER		1	WELL(S)	
CLARK	NC	NV0004110	NEW PARADISE MB CHURCH	25	GROUNDWATER		1	WELL(S)	
					PURCHASED SURFACE			CONSECUTIVE	
CLARK	NTNC	NV0001112	NEW YORK NEW YORK HOTEL AND CASINO	2000	WATER		1	CONNECTION(S)	
EUREKA	NTNC	NV0002600	NEWMONT GOLD GOLD QUARRY	700	GROUNDWATER		3	WELL(S)	
EUREKA	NTNC	NV0002603	NEWMONT GOLD NORTH AREA LEACH	300	GROUNDWATER		1	WELL(S)	
ELKO	NTNC	NV0001138	NEWMONT LONG CANYON MINE	110	GROUNDWATER		1	WELL(S)	

Nevada Water Systems and Water Sources

County	Water System Type	Water System ID	Water System Name	Population Served	Primary Water Source	Primary Sources Type	Number of Sources	Additional Source Type	Number of Sources
DOUGLAS	NTNC	NV0000977	NORTH COUNTY WATER SYSTEM	200	GROUNDWATER		2 WELL(S)	CONSECUTIVE CONNECTION(S)	3
CLARK	C	NV0000175	NORTH LAS VEGAS UTILITIES	306570	PURCHASED SURFACE WATER		4 WELL(S)	CONSECUTIVE CONNECTION(S)	2
WASHOE	NTNC	NV0000870	NORTH VALLEY BUS FACILITY	60	GROUNDWATER		1 WELL(S)		
HUMBOLDT	NTNC	NV0002513	NORTH VALMY POWER PLANT	120	GROUNDWATER		1 WELL(S)		
NYE	NTNC	NV0004067	NORTHWEST ACADEMY	50	GROUNDWATER		1 WELL(S)		
CLARK	C	NV0003005	NPS BOULDER BEACH	722	PURCHASED SURFACE WATER		1 CONNECTION(S)	CONSECUTIVE	
CLARK	C	NV0002506	NPS CALLVILLE BAY	250	SURFACE WATER		1 INTAKE(S)		
CLARK	NTNC	NV0002501	NPS COTTONWOOD COVE	592	GROUNDWATER		2 WELL(S)		
CLARK	C	NV0002503	NPS ECHO BAY	274	SURFACE WATER		1 INTAKE(S)		
CLARK	NC	NV0003004	NPS LAS VEGAS BAY	25	PURCHASED SURFACE WATER		1 CONNECTION(S)	CONSECUTIVE	
STOREY	NTNC	NV0002596	NV POWER	87	GROUNDWATER		2 WELL(S)		
NYE	NTNC	NV0002152	NYE COUNTY COMPLEX	100	GROUNDWATER		2 WELL(S)		
ELKO	C	NV0004017	OASIS MHP	46	GROUNDWATER		1 WELL(S)		
CHURCHILL	NC	NV0000921	OASIS SPRINGS	25	GROUNDWATER		1 WELL(S)		
CHURCHILL	C	NV0000052	OK MOBILE HOME PARK	90	GROUNDWATER		1 WELL(S)		
CHURCHILL	NC	NV0004028	OLAM SVI	98	GROUNDWATER		1 WELL(S)		
WASHOE	C	NV0000797	OLD FORTY WEST MOTEL	40	GROUNDWATER		2 WELL(S)		
CHURCHILL	C	NV0000303	OLD RIVER WATER COMPANY	300	GROUNDWATER		2 WELL(S)		
WASHOE	C	NV0002526	OLD WASHOE ESTATES	135	GROUNDWATER		2 WELL(S)		
NYE	NC	NV0001105	ORCHARD VALLEY MARKET	25	GROUNDWATER		1 WELL(S)		
HUMBOLDT	C	NV0003032	OROVADA WATER DISTRICT	200	GROUNDWATER		2 WELL(S)		
NYE	NC	NV0004018	PAHRUMP FIRE STATION BLM	25	GROUNDWATER		1 WELL(S)		
NYE	NC	NV0005034	PAHRUMP RV PARK	120	GROUNDWATER		1 WELL(S)		
NYE	NTNC	NV0003036	PAHRUMP SENIOR CENTER INC	70	GROUNDWATER		1 WELL(S)		
NYE	C	NV0000926	PAHRUMP UTILITY COMPANY INC	985	GROUNDWATER		5 WELL(S)		
CLARK	C	NV0000819	PALM GARDENS WATER CO OP	42	GROUNDWATER		2 WELL(S)		
LINCOLN	C	NV0000185	PANACA FARMSTEAD WATER ASSOCIATION	900	GROUNDWATER		2 WELL(S)		
HUMBOLDT	NTNC	NV0002186	PARADISE VALLEY ELEMENTARY	35	GROUNDWATER		1 WELL(S)		
HUMBOLDT	NC	NV0002106	PARADISE VALLEY PARK	40	GROUNDWATER		1 WELL(S)		
NYE	NC	NV0001094	PATCH OF HEAVEN	50	GROUNDWATER		1 WELL(S)		
ELKO	NC	NV0002064	PETES TRAILER COURT	24	GROUNDWATER		1 WELL(S)		
LANDER	NTNC	NV0000902	PHOENIX MINE POTABLE WATER SYSTEM	400	GROUNDWATER		1 WELL(S)		
NYE	NC	NV0004063	PICK AND SHOVEL INVESTMENTS	25	GROUNDWATER		1 WELL(S)		
HUMBOLDT	NTNC	NV0002095	PILOT TRAVEL CENTER 485	1448	GROUNDWATER		1 WELL(S)		

Nevada Water Systems and Water Sources

County	Water System Type	Water System ID	Water System Name	Population Served	Primary Water Source	Primary Sources Type	Number of Sources	Additional Source Type	Number of Sources
DOUGLAS	C	NV0000030	SIERRA ESTATES GID	160	GROUNDWATER		1 WELL(S)	CONSECUTIVE CONNECTION(S)	1
CLARK	C	NV0001116	SIGNATURE TOWERS	516	PURCHASED SURFACE WATER		1 CONNECTION(S)	CONSECUTIVE CONNECTION(S)	
WASHOE	C	NV0004021	SILVER KNOLLS MUTUAL WATER COMPANY	120	GROUNDWATER		2 WELL(S)		
ESMERALDA	C	NV0000363	SILVER PEAK WATER SYSTEM	138	GROUNDWATER		2 WELL(S)		
LYON	NC	NV0004100	SILVER SPRINGS MEETINGHOUSE LDS	25	GROUNDWATER		1 WELL(S)		
LYON	C	NV0000223	SILVER SPRINGS MUTUAL WATER COMPANY	3070	GROUNDWATER		3 WELL(S)		
CLARK	NTNC	NV0000342	SILVERHAWK POWER PLANT	25	GROUNDWATER		1 WELL(S)		
CHURCHILL	NC	NV0002581	SKIPS MINI MARKET	25	GROUNDWATER		1 WELL(S)		
CLARK	C	NV0004031	SKY RANCH ESTATES	110	GROUNDWATER		2 WELL(S)		
WASHOE	NC	NV0000760	SKY TAVERN	50	GROUNDWATER		1 SPRING(S)		
WASHOE	NC	NV0000761	SLIDE MOUNTAIN SKI AREA	200	GROUNDWATER		3 SPRING(S)		
CLARK	NTNC	NV0001140	SLOAN ARMY RESERVE CENTER	348	GROUNDWATER		1 WELL(S)		
LYON	NC	NV0004107	SMITH VALLEY BAPTIST CHURCH	500	GROUNDWATER		1 WELL(S)		
LYON	NTNC	NV0002189	SMITH VALLEY SCHOOLS	500	GROUNDWATER		1 WELL(S)		
CLARK	C	NV0001102	SNWA COYOTE SPRING VALLEY-MOAPA PWS	25	GROUNDWATER		1 WELL(S)		
LYON	NTNC	NV0002515	SNYDER LIVESTOCK COMPANY INC	40	GROUNDWATER		1 WELL(S)		
CHURCHILL	NC	NV0000929	SONIC BURGER	265	GROUNDWATER		1 WELL(S)		
ELKO	C	NV0000351	SOUTH CRESTVIEW HOMEOWNERS	60	GROUNDWATER		3 WELL(S)		
ELKO	NC	NV0002209	SOUTH RUBY CAMPGROUND USFS	30	GROUNDWATER		1 WELL(S)		
CLARK	C	NV0005062	SOUTHERN DESERT CORRECTIONAL CTR NDOC	4842	GROUNDWATER		4 WELL(S)		
CLARK	NTNC	NV0000289	SOUTHERN NEVADA WATER SYSTEM	200	SURFACE WATER		1 INTAKE(S)		
ELKO	NC	NV0000873	SOUTHFORK STATE PARK AND RECREATION AREA	25	GROUNDWATER		1 WELL(S)		
CLARK	NC	NV0004108	SPEED VEGAS	200	PURCHASED GROUNDWATER		1 CONNECTION(S)	CONSECUTIVE CONNECTION(S)	
CLARK	NC	NV0004071	SPENCER W KIMBALL SCOUT RESERVATION	300	GROUNDWATER		2 WELL(S)		
CLARK	C	NV0000221	SPIRIT MOUNTAIN UTILITY	375	GROUNDWATER		2 WELL(S)		
DOUGLAS	NC	NV0004041	SPOONER LAKE STATE PARK	207	GROUNDWATER		1 WELL(S)		
NYE	NTNC	NV0001093	SPRING MOUNTAIN MOTOR SPORTS RANCH	450	GROUNDWATER		1 WELL(S)		
CLARK	NC	NV0001071	SPRING MOUNTAIN RANCH STATE PARK	225	GROUNDWATER		1 WELL(S)		

Nevada Water Systems and Water Sources

County	Water System Type	Water System ID	Water System Name	Population Served	Primary Water Source	Primary Sources Type	Number of Sources	Additional Source Type	Number of Sources
						PURCHASED			CONSECUTIVE
CLARK	C	NV0000292	SPRING MOUNTAIN YOUTH CAMP	120	GROUNDWATER				1 CONNECTION(S)
CLARK	NC	NV0003103	SPRING MOUNTAINS VISITOR GATEWAY	215	GROUNDWATER				1 WELL(S)
LINCOLN	NC	NV0002124	SPRING VALLEY STATE PARK	386	GROUNDWATER				1 WELL(S)
WASHOE	NTNC	NV0004061	SPRINGWOOD EQUESTRIAN CENTER	175	GROUNDWATER				1 WELL(S)
WHITE PINE	NC	NV0002178	STAGE STOP CAFE	50	GROUNDWATER				1 SPRING(S)
LYON	NC	NV0002608	STAGECOACH COUNTRY MARKET	25	GROUNDWATER				1 WELL(S)
LYON	C	NV0000224	STAGECOACH GID	1411	GROUNDWATER				4 WELL(S)
LYON	NC	NV0004040	STAGECOACH MARKET	25	GROUNDWATER				1 WELL(S)
NYE	NC	NV0002598	STAGESTOP RESTAURANT	25	GROUNDWATER				1 WELL(S)
WASHOE	C	NV0000801	STAMP MILL	118	GROUNDWATER				2 WELL(S)
HUMBOLDT	C	NV0000252	STAR CITY PROPERTIES	285	GROUNDWATER				2 WELL(S)
PERSHING	NC	NV0002517	STAR POINT MHP RV PARK	25	GROUNDWATER				1 WELL(S)
WASHOE	C	NV0000282	STEAMBOAT SPRINGS WATERWORKS INC	998	GROUNDWATER				2 WELL(S)
CARSON CITY	NTNC	NV0004084	STEWART COMPLEX	300	GROUNDWATER				1 WELL(S)
STOREY	C	NV0000240	STOREY COUNTY WATER DISTRICT	1420	SURFACE WATER				1 INTAKE(S)
NYE	NC	NV0000829	SULLIVANS PUB	25	GROUNDWATER				1 WELL(S)
						PURCHASED SURFACE			CONSECUTIVE
WASHOE	C	NV0000211	SUN VALLEY GID	17000	WATER				1 CONNECTION(S)
CLARK	C	NV0000124	SUNRISE ACRES WATER ASSOCIATION	231	GROUNDWATER				2 WELL(S)
WASHOE	C	NV0002525	SUNRISE ESTATES	90	GROUNDWATER				2 WELL(S)
CLARK	C	NV0000123	SUNRISE MOUNTAIN TP	100	GROUNDWATER				1 WELL(S)
NYE	C	NV0005066	SUNSET MHP	90	GROUNDWATER				2 WELL(S)
WASHOE	C	NV0000765	SUTCLIFFE MOBILE PARK	60	GROUNDWATER				2 WELL(S)
CLARK	NC	NV0000329	T AND J INVESTMENTS DBA THE GROVE	65	GROUNDWATER				1 WELL(S)
STOREY	NTNC	NV0000913	TAHOE RENO INDUSTRIAL CENTER	6000	GROUNDWATER				5 WELL(S)
NYE	NC	NV0002575	TATUADO WILD SIDE TAVERN	25	GROUNDWATER				1 WELL(S)
ELKO	NC	NV0002076	TAYLOR CANYON CLUB	70	GROUNDWATER				1 WELL(S)
CARSON CITY	C	NV0000028	TERRACE GARDEN APARTMENTS	60	GROUNDWATER				1 WELL(S)
ELKO	NC	NV0003044	TERRACES PICNIC GROUNDS USFS	25	GROUNDWATER				1 SPRING(S)
DOUGLAS	NTNC	NV0002227	THE CLUB AT CLEAR CREEK TAHOE	25	GROUNDWATER				1 WELL(S)
NYE	NC	NV0003035	THE HUBB	25	GROUNDWATER				1 WELL(S)
EUREKA	C	NV0000414	THE LODGE AT PINE VALLEY	320	GROUNDWATER				1 WELL(S)
NYE	NC	NV0000340	THE MAVERICK	25	GROUNDWATER				1 WELL(S)
WASHOE	NC	NV0000727	THE VINE	125	GROUNDWATER				1 WELL(S)
ELKO	NC	NV0003043	THOMAS CANYON CAMPGROUND USFS	25	GROUNDWATER				1 SPRING(S)
WHITE PINE	NC	NV0003049	TIMBER CREEK CAMPGROUND USFS	47	GROUNDWATER				1 SPRING(S)

Nevada Water Systems and Water Sources

County	Water System Type	Water System ID	Water System Name	Population Served	Primary Water Source	Primary Sources Type	Number of Sources	Additional Source Type	Number of Sources
HUMBOLDT	NC	NV0002112	VALMY STATION	25	GROUNDWATER		1		WELL(S)
HUMBOLDT	C	NV0003016	VALMY STATION MOBILE HOME PARK	96	GROUNDWATER		1		WELL(S)
CLARK	C	NV0000182	VANS TRAILER OASIS	75	GROUNDWATER		1		WELL(S)
WASHOE	C	NV0000196	VERDI MEADOWS UTILITY COMPANY INC	510	GROUNDWATER		2		WELL(S)
WASHOE	NTNC	NV0000773	VERDI MUTUAL WATER COMPANY	300	GROUNDWATER		1		SPRING(S)
WASHOE	NTNC	NV0003000	VERDI SCHOOL	250	GROUNDWATER		1		WELL(S)
NYE	NC	NV0002556	VFW PAHRUMP POST 10054	25	GROUNDWATER		1		WELL(S)
HUMBOLDT	NC	NV0002543	VIRGIN VALLEY CAMPGROUND	25	GROUNDWATER		1		WELL(S)
CLARK	C	NV0000167	VIRGIN VALLEY WATER DISTRICT	18000	GROUNDWATER		8		WELL(S)
WASHOE	C	NV0000281	WADSWORTH MOBILE HOME PARK	90	GROUNDWATER		2		WELL(S)
MINERAL	C	NV0000268	WALKER LAKE GID	300	GROUNDWATER		2		WELL(S)
LYON	NC	NV0004048	WALKER RIVER RESORT	25	GROUNDWATER		1		WELL(S)
WHITE PINE	NC	NV0000922	WARD CHARCOAL OVENS STATE PARK	25	GROUNDWATER		1		WELL(S)
WHITE PINE	NC	NV0003046	WARD MOUNTAIN CAMPGROUND USFS	600	GROUNDWATER		1		WELL(S)
WASHOE	NC	NV0000793	WASHOE LAKE STATE PARK	467	GROUNDWATER		1		WELL(S)
WASHOE	NC	NV0000318	WASHOE LAKE STATE PARK NORTH BOAT RAMP	25	GROUNDWATER		1		WELL(S)
WASHOE	NC	NV0003094	WASHOE REGIONAL SHOOTING RANGE	25	GROUNDWATER		1		WELL(S)
WASHOE	NC	NV0004113	WASHOE VALLEY CHRISTIAN CHURCH	840	GROUNDWATER		1		WELL(S)
WASHOE	NC	NV0004065	WASHOE VALLEY MEETINGHOUSE FACILITY LDS	108	GROUNDWATER		1		WELL(S)
WASHOE	C	NV0000280	WEBB MOBILE HOME PARK	30	GROUNDWATER		2		WELL(S)
LYON	C	NV0000242	WEED HEIGHTS DEVELOPMENT	340	GROUNDWATER		2		WELL(S)
ELKO	NC	NV0002078	WELCOME STATION RV PARK LLC	35	GROUNDWATER		1		WELL(S)
LYON	NC	NV0000243	WELLINGTON STATION RESORT	64	GROUNDWATER		1		WELL(S)
ELKO	NTNC	NV0005005	WELLS HONOR CAMP NDOC	150	GROUNDWATER		1		WELL(S)
ELKO	C	NV0000245	WELLS MUNICIPAL WATER DEPARTMENT	1300	GROUNDWATER		4		WELL(S)
ELKO	NTNC	NV0001126	WEST END WATER COOP ASSOC	25	GROUNDWATER		1		WELL(S)
DOUGLAS	C	NV0002054	WEST VALLEY WATER SYSTEM	663	GROUNDWATER		3	CONSECUTIVE CONNECTION(S)	WELL(S) 1
ELKO	C	NV0000246	WEST WENDOVER WATER SYSTEM	4200	GROUNDWATER		8		WELL(S)
WHITE PINE	NC	NV0003054	WHEELER PEAK CAMPGROUND NPS	60	GROUNDWATER		1		SPRING(S)
WHITE PINE	NC	NV0001135	WHIPPLES COUNTRY STORE	25	GROUNDWATER		1		WELL(S)
CLARK	C	NV0001073	WHISKEY PETES	7000	GROUNDWATER		2		WELL(S)
NYE	NC	NV0000946	WHOS DUNES	25	GROUNDWATER		1		WELL(S)
CHURCHILL	C	NV0000058	WILDES MANOR	70	GROUNDWATER		1		WELL(S)
ELKO	NC	NV0002080	WILDHORSE RESORT	25	GROUNDWATER		1		WELL(S)
ELKO	NC	NV0003059	WILDHORSE STATE PARK AND RECREATION AREA	25	GROUNDWATER		1		WELL(S)
MINERAL	NC	NV0001128	WILDKAT RANCH	25	GROUNDWATER		1		WELL(S)

Nevada Water Systems and Water Sources

County	Water System Type	Water System ID	Water System Name	Population Served	Primary Water Source	Primary Sources Type	Number of Sources	Additional Source Type	Number of Sources
CLARK	NTNC	NV0001139	TIMET CORPORATION	574	PURCHASED SURFACE WATER	CONSECUTIVE CONNECTION(S)	1		
CHURCHILL	C	NV0000055	TOLAS WATERWORKS CO OP	250	GROUNDWATER	1 WELL(S)	1		
NYE	NTNC	NV0000804	TOLICHA PEAK ELECTRONIC COMBAT RANGE	80	GROUNDWATER	1 WELL(S)	1		
NYE	NTNC	NV0000823	TONOPAH CONSERVATION CAMP NDOC	150	PURCHASED GROUNDWATER	CONSECUTIVE CONNECTION(S)	1		
NYE	NTNC	NV0005002	TONOPAH ELECTRONIC COMBAT RANGE O AND M	127	GROUNDWATER	1 WELL(S)	1		
NYE	C	NV0000237	TONOPAH PUBLIC UTILITIES	2853	GROUNDWATER	6 WELL(S)	6		
NYE	NTNC	NV0005001	TONOPAH TEST RANGE AREA 10 INDUSTRIAL	130	GROUNDWATER	3 WELL(S)	3		
NYE	NTNC	NV0004068	TONOPAH TEST RANGE MANCAMP	30	GROUNDWATER	2 WELL(S)	2		
NYE	NTNC	NV0003014	TONOPAH TEST RANGE SITE 6	150	GROUNDWATER	1 WELL(S)	1		
DOUGLAS	C	NV0000070	TOPAZ LAKE WATER CO INC	40	GROUNDWATER	4 WELL(S)	4		
DOUGLAS	C	NV0000239	TOPAZ RANCH ESTATES GID	2100	GROUNDWATER	2 WELL(S)	2		
DOUGLAS	NC	NV0002518	TOPAZ SUMMIT SPRING	25	GROUNDWATER	1 WELL(S)	1		
CLARK	C	NV0000314	TORREY PINES TINA LN WTR ASSOC	70	GROUNDWATER	1 WELL(S)	1		
NYE	NC	NV0000386	TOWER PIZZA	25	GROUNDWATER	1 WELL(S)	1		
DOUGLAS	C	NV0000168	TOWN OF MINDEN	3500	GROUNDWATER	9 WELL(S)	9	CONSECUTIVE CONNECTION(S)	2
CLARK	NC	NV0000331	TRAILS END GENERAL STORE	225	GROUNDWATER	1 WELL(S)	1		
PERSHING	NTNC	NV0002159	TRAVEL CENTERS OF AMERICA NO 181	1051	GROUNDWATER	3 WELL(S)	3		
CLARK	NTNC	NV0001059	TROPICANA RESORT AND CASINO	5950	PURCHASED SURFACE WATER	CONSECUTIVE CONNECTION(S)	1	WELL(S)	2
CLARK	NC	NV0004060	TROUT CANYON LAND AND WATER USERS ASSOC	60	GROUNDWATER	1 WELL(S)	1		
WASHOE	NTNC	NV0000978	TRUCKEE CANYON	25	GROUNDWATER	1 WELL(S)	1		
WASHOE	C	NV0000190	TRUCKEE MEADOWS WATER AUTHORITY	311932	SURFACE WATER	2 INTAKE(S)	2	WELL(S)	73
EUREKA	NTNC	NV0000403	TS POWER PLANT	62	GROUNDWATER	1 WELL(S)	1		
NYE	NC	NV0000827	TUMBLEWEED TAVERN	25	GROUNDWATER	1 WELL(S)	1		
PERSHING	NC	NV0003072	TURN 3 RV PARK AND STORE	25	GROUNDWATER	1 WELL(S)	1		
ELKO	C	NV0000189	TUSCARORA WATER SYSTEM	72	GROUNDWATER	1 WELL(S)	1		
HUMBOLDT	NTNC	NV0005070	TWIN CREEKS	600	GROUNDWATER	1 WELL(S)	1		
DOUGLAS	C	NV0000817	UPPAWAY WATER SYSTEM	85	GROUNDWATER	2 WELL(S)	2		
WASHOE	NC	NV0001147	URBAN ROOTS	43	GROUNDWATER	1 WELL(S)	1		
NYE	NTNC	NV0001145	US ECOLOGY	90	GROUNDWATER	1 WELL(S)	1		
CLARK	NC	NV0001075	VALLEY OF FIRE STATE PARK	1000	GROUNDWATER	1 WELL(S)	1		
ELKO	C	NV0000805	VALLEY VIEW RV PARK	250	GROUNDWATER	2 WELL(S)	2		

Nevada Water Systems and Water Sources

County	Water System Type	Water System ID	Water System Name	Population Served	Primary Water Source	Primary Sources Type	Number of Sources	Additional Source Type	Number of Sources
DOUGLAS	NTNC	NV0000816	WILLIAMS RIDGE TECH PARK	60	GROUNDWATER		1	WELL(S)	
ELKO	NC	NV0002211	WILSON RESERVOIR BLM CAMPGROUND	30	GROUNDWATER		1	WELL(S)	
LINCOLN	NC	NV0000399	WINDMILL RIDGE RESTAURANT AND LODGE	25	GROUNDWATER		1	WELL(S)	
HUMBOLDT	C	NV0000248	WINNEMUCCA CITY OF	8066	GROUNDWATER		5	WELL(S)	1 SPRING(S)

Nevada Water Systems and Water Sources

County	Water System Type	Water System ID	Water System Name	Population Served	Primary Water Source	Primary Sources Type	Number of Sources	Additional Source Type	Number of Sources
CLARK	NTNC	NV0001141	WYNN RESORTS	9416	PURCHASED SURFACE WATER		1	CONSECUTIVE CONNECTION(S)	
LYON	C	NV0000255	YERINGTON CITY OF	3300	GROUNDWATER		4	WELL(S)	
DOUGLAS	NTNC	NV0002059	ZEPHYR COVE LODGE AND RESORT	500	GROUNDWATER		3	WELL(S)	
DOUGLAS	C	NV0000258	ZEPHYR COVE WATER UTILITY DISTR	1209	SURFACE WATER		1	INTAKE(S)	

2016 Nevada Annual Compliance Report By Chemical

EPA Region	9	Primacy Agency Code	NV	Rule Family	IOC	Violation Category	Maximum Contaminant Level Violation
Contaminant Code		Contaminant	# of Violations		# of RTC Violations		# of PWS in Violation
1074		Antimony	1		0		1
1005		Arsenic	91		70		9
1040		Nitrate	14		11		1
		Total =	106		81		11

EPA Region	9	Primacy Agency Code	NV	Rule Family	IOC	Violation Category	Monitoring and Reporting
Contaminant Code		Contaminant	# of Violations		# of RTC Violations		# of PWS in Violation
1005		Arsenic	16		5		6
1010		Barium	1		1		0
1015		Cadmium	1		1		0
1020		Chromium	1		1		0
CIOC		Cyanide	1		0		1
1025		Fluoride	2		1		1
CIO2		IOC Phase 2	1		0		1
CIO5		IOC Phase 5	2		1		1
1040		Nitrate	61		43		18
1041		Nitrite	29		5		23
1045		Selenium	1		1		0
1052		Sodium	2		1		1
		Total =	118		61		53

EPA Region	9	Primacy Agency Code	NV	Rule Family	SOC	Violation Category	Monitoring and Reporting
Contaminant Code		Contaminant	# of Violations		# of RTC Violations		# of PWS in Violation
2105		2,4-D	1		0		1
2050		Atrazine	1		0		1
2039		DI(2-Ethylexyl) Phthalate	1		0		1
2033		Endothall	1		1		0
2034		Glyphosphate	1		0		1
2037		Simazine	1		0		1
2063		SOCS PH5 Dioxin	3		3		0
CSOC		SOCS PHASE 2 & 5	4		2		2
		Total =	13		6		7

2016 Nevada Annual Compliance Report By Chemical

EPA Region	9	Primacy Agency Code	NV	Rule Family	VOC	Violation Category	Monitoring and Reporting
Contaminant Code		Contaminant		# of Violations		# of RTC Violations	# of PWS in Violation
2992		Ethylbenzene		2		1	1
CVOC		VOCS PHASE 2 & 5		14		7	6
2955		Xylenes, Total		2		1	1
		Total =		18		9	8

EPA Region	9	Primacy Agency Code	NV	Rule Family	RADS	Violation Category	Maximum Contaminant Level Violation
Contaminant Code		Contaminant		# of Violations		# of RTC Violations	# of PWS in Violation
4006		Combined Uranium		4		4	0
		Total =		4		4	0

EPA Region	9	Primacy Agency Code	NV	Rule Family	RADS	Violation Category	Monitoring and Reporting
Contaminant Code		Contaminant		# of Violations		# of RTC Violations	# of PWS in Violation
CRAU		Radionuclides		2		2	0
CRGA		RADS Gross Alpha		1		0	1
CRUR		RADS Uranium		6		2	2
		Total =		9		4	3

EPA Region	9	Primacy Agency Code	NV	Rule Family	ST1 DBP	Violation Category	Monitoring and Reporting
Contaminant Code		Contaminant		# of Violations		# of RTC Violations	# of PWS in Violation
0999		Chlorine		46		32	9
		Total =		46		32	9

EPA Region	9	Primacy Agency Code	NV	Rule Family	ST1 DBP	Violation Category	Other Compliance
Contaminant Code		Contaminant		# of Violations		# of RTC Violations	# of PWS in Violation
0999		Chlorine		1		1	0
		Total =		1		1	0

EPA Region	9	Primacy Agency Code	NV	Rule Family	ST2 DBP	Violation Category	Maximum Contaminant Level Violation
Contaminant Code		Contaminant		# of Violations		# of RTC Violations	# of PWS in Violation
2950		DBPR Stage 2 TTHM		5		5	0
		Total =		5		5	0

2016 Nevada Annual Compliance Report By Chemical

EPA Region	9	Primacy Agency Code	NV	Rule Family	ST2 DBP	Violation Category	Monitoring and Reporting
Contaminant Code	Contaminant	# of Violations			# of RTC Violations		# of PWS in Violation
2456	DBPR Stage 2 TTHM	2			0		2
2950	DBPR Stage 2 HAA5	1			0		1
CDB2	Disinfection Byprod Stage 2	24			13		11
Total =		27			13		14

EPA Region	9	Primacy Agency Code	NV	Rule Family	ST2 DBP	Violation Category	Failure to Submit OEL
Contaminant Code	Contaminant	# of Violations			# of RTC Violations		# of PWS in Violation
2456	DBPR Stage 2 TTHM	1			1		0
Total =		1			1		0

EPA Region	9	Primacy Agency Code	NV	Rule Family	SWT Rule	Violation Category	Failure to Filter
Contaminant Code	Contaminant	# of Violations			# of RTC Violations		# of PWS in Violation
0200	SWTR	1					1
Total =		1			0		1

EPA Region	9	Primacy Agency Code	NV	Rule Family	TCR	Violation Category	Maximum Contaminant Level Violation
Contaminant Code	Contaminant	# of Violations			# of RTC Violations		# of PWS in Violation
3100	Coliform (TCR)	11			11		0
Total =		11			11		0

EPA Region	9	Primacy Agency Code	NV	Rule Family	TCR	Violation Category	Monitoring and Reporting
Contaminant Code	Contaminant	# of Violations			# of RTC Violations		# of PWS in Violation
3100	Coliform (TCR)	26			26		0
Total =		26			26		0

EPA Region	9	Primacy Agency Code	NV	Rule Family	rTCR	Violation Category	Monitoring and Reporting
Contaminant Code	Contaminant	# of Violations			# of RTC Violations		# of PWS in Violation
8000	Coliform (rTCR)	62			55		4
Total =		62			55		4

2016 Nevada Annual Compliance Report By Chemical

EPA Region	9	Primacy Agency Code	NV	Rule Family	rTCR	Violation Category	Treatment Technique
Contaminant Code		Contaminant		# of Violations		# of RTC Violations	# of PWS in Violation
8000		Coliform (rTCR)		2		1	1
		Total =		2		1	1

EPA Region	9	Primacy Agency Code	NV	Rule Family	GWR	Violation Category	Monitoring and Reporting
Contaminant Code		Contaminant		# of Violations		# of RTC Violations	# of PWS in Violation
3014		E.Coli (GWR Assesment)		5		5	0
3014		E.Coli (GWR Triggered/Additional)		9		7	2
		Total =		14		12	2

EPA Region	9	Primacy Agency Code	NV	Rule Family	GWR	Violation Category	Other Violation
Contaminant Code		Contaminant		# of Violations		# of RTC Violations	# of PWS in Violation
0700		Groundwater Rule		3		1	1
		Total =		3		1	1

EPA Region	9	Primacy Agency Code	NV	Rule Family	LCR	Violation Category	Monitoring and Reporting
Contaminant Code		Contaminant		# of Violations		# of RTC Violations	# of PWS in Violation
5000		Lead and Copper Rule		17		4	10
		Total =		17		4	10

EPA Region	9	Primacy Agency Code	NV	Rule Family	LCR	Violation Category	Treatment Technique
Contaminant Code		Contaminant		# of Violations		# of RTC Violations	# of PWS in Violation
5000		Lead and Copper Rule		3		0	2
		Total =		3		0	2

EPA Region	9	Primacy Agency Code	NV	Rule Family	N/A	Violation Category	Other Violation
Contaminant Code		Contaminant		# of Violations		# of RTC Violations	# of PWS in Violation
7000		Consumer Confidence Rule		12		2	9
7500		Public Notice		11		0	3
		Total =		23		2	12

2016 Nevada Annual Compliance Report By Chemical

EPA Region	9	Primacy Agency Code	NV	Rule Family	SECONDARIES	Violation Category
Contaminant Code		Contaminant	# of Violations	# of RTC Violations	# of PWS in Violation	
1002		Aluminum	1	1	0	
1025		Fluoride	2	0	2	
1028		Iron	13	1	6	
1032		Manganese	23	7	11	
1920		Odor	11	3	5	
1055		Sulfate	12	0	4	
1930		TDS	21	3	7	
Total =			83	15	35	

EPA Region	9	Primacy Agency Code	NV	Rule Family	SECONDARIES	Violation Category	Monitoring and Reporting
Contaminant Code		Contaminant	# of Violations	# of RTC Violations	# of PWS in Violation		
1002		Aluminum	2	0	2		
1017		Chloride	1	0	1		
3100		Coliform	1	0	1		
1905		Color	4	0	4		
1022		Copper	1	0	1		
1025		Fluoride	2	0	2		
1028		Iron	10	3	6		
1032		Manganese	13	7	6		
1031		Magnesium	2	1	1		
1089		MBAS	1	0	1		
1040		Nitrate	1	0	1		
1920		Odor	2	0	2		
1925		pH	1	0	1		
CSC2		SECONDARY IOCS	21	2	18		
1050		Silver	1	0	1		
1055		Sulfate	8	5	3		
1930		TDS	9	4	5		
		Zinc	2	0	2		
Total =			82	22	58		

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0000703	AIR BASE INN	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2015	12/31/2015		4/11/2016
Total Number of Violations for this Water System:										1
NV0000005	ALAMO SEWER AND WATER GID	02	1005	ARSENIC	IOC	MCL, AVERAGE	4/1/2015	6/30/2015	0.011 MG/L	3/31/2016
NV0000005	ALAMO SEWER AND WATER GID	02	1005	ARSENIC	IOC	MCL, AVERAGE	7/1/2015	9/30/2015	0.012 MG/L	3/31/2016
NV0000005	ALAMO SEWER AND WATER GID	02	1005	ARSENIC	IOC	MCL, AVERAGE	10/1/2015	12/31/2015	0.012 MG/L	3/31/2016
NV0000005	ALAMO SEWER AND WATER GID	03MJ	CIOC	IOC PH 5 CYANIDE	IOC	MONITORING, ROUTINE MAJOR	1/1/2014	12/31/2016		
NV0000005	ALAMO SEWER AND WATER GID	03MJ	CIO2	IOCS PHASE 2	IOC	MONITORING, ROUTINE MAJOR	1/1/2014	12/31/2016		
NV0000005	ALAMO SEWER AND WATER GID	03MJ	CIO5	IOCS PHASE 5	IOC	MONITORING, ROUTINE MAJOR	1/1/2014	12/31/2016		
NV0000005	ALAMO SEWER AND WATER GID	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2015	12/31/2015		7/13/2016
NV0000005	ALAMO SEWER AND WATER GID	03MJ	CNO2	NITRITE	IOC	MONITORING, ROUTINE MAJOR	1/1/2014	12/31/2016		
Total Number of Violations for this Water System:										8
NV0003061	AMARGOSA SENIOR CENTER	93	1055	SULFATE		STATE FAILURE TO MONITOR	1/1/2014	12/31/2016		5/18/2017
Total Number of Violations for this Water System:										1
NV0000811	AMARGOSA VALLEY VFW POST 6826	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2015	12/31/2015		1/4/2016
NV0000811	AMARGOSA VALLEY VFW POST 6826	23MJ	3100	COLIFORM (TCR)		MONITORING (TCR), ROUTINE MAJOR	10/1/2015	12/31/2015		1/4/2016
NV0000811	AMARGOSA VALLEY VFW POST 6826	3AMJ	3014	E. COLI		MONITORING, ROUTINE, MAJOR (RTCR)	7/1/2016	9/30/2016		11/21/2016
Total Number of Violations for this Water System:										3

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0005033	ANCHOR IN MHP	23MJ	3100	COLIFORM (TCR)		MONITORING (TCR), ROUTINE MAJOR	12/1/2015	12/31/2015		1/26/2016
Total Number of Violations for this Water System:										1
NV0004088	ANIMAL ARK	3AMJ	3014	E. COLI		MONITORING, ROUTINE, MAJOR (RTCR)	10/1/2016	10/31/2016		12/5/2016
NV0004088	ANIMAL ARK	3AMJ	3014	E. COLI		MONITORING, ROUTINE, MAJOR (RTCR)	11/1/2016	11/30/2016		12/5/2016
NV0004088	ANIMAL ARK	S1	1032	MANGANESE		STATE MCL EXCEDENCE	10/1/2016	12/31/2016	0.53 MG/L	
Total Number of Violations for this Water System:										3
NV0004105	ANTELOPE VALLEY MEETINGHOUSE LDS	S1	1028	IRON		STATE MCL EXCEDENCE	7/1/2014	9/30/2014	3.9 MG/L	4/19/2016
Total Number of Violations for this Water System:										1
NV0000191	ARROWHEAD MHP	27MJ	0999	CHLORINE	ST1 DBP	MONITORING, ROUTINE (DBP), MAJOR	10/1/2015	12/31/2015		12/31/2016
Total Number of Violations for this Water System:										1
NV0000879	ASIA UNION ELECTRONIC CHEMICAL	27MJ	CDB2	DBPR STAGE 2		MONITORING, ROUTINE (DBP), MAJOR	1/1/2014	9/30/2016		
Total Number of Violations for this Water System:										1
NV0000982	BALD MOUNTAIN MINE	S1	1920	ODOR		STATE MCL EXCEDENCE	10/1/2015	12/31/2015	17 TON	7/13/2016
Total Number of Violations for this Water System:										1
NV0000720	BAR M BAR	3AMJ	3014	E. COLI		MONITORING, ROUTINE, MAJOR (RTCR)	9/1/2016	9/30/2016		10/24/2016
Total Number of Violations for this Water System:										1
NV0005077	BARRICK GOLDSTRIKE FACILITY	27MJ	CDB2	DBPR STAGE 2		MONITORING, ROUTINE (DBP), MAJOR	10/1/2015	9/30/2016		
NV0005077	BARRICK GOLDSTRIKE FACILITY	S1	1920	ODOR		STATE MCL EXCEDENCE	1/1/2016	3/31/2016	4 TON	

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0005077	BARRICK GOLDSTRIKE FACILITY	S1	1920	ODOR		STATE MCL EXCEDENCE	7/1/2016	9/30/2016	24 TON	
Total Number of Violations for this Water System:										3
NV0000147	BERMUDA PALMS MANAGEMENT LLC	02	1005	ARSENIC	IOC	MCL, AVERAGE	7/1/2015	9/30/2015	0.011 MG/L	3/22/2016
NV0000147	BERMUDA PALMS MANAGEMENT LLC	02	1005	ARSENIC	IOC	MCL, AVERAGE	10/1/2015	12/31/2015	0.0118 MG/L	3/22/2016
Total Number of Violations for this Water System:										2
NV0002041	BEST WESTERN TOPAZ LAKE INN	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2015	12/31/2015		12/7/2016
Total Number of Violations for this Water System:										1
NV0004092	BIG BEND WATER DISTRICT	41	0999	CHLORINE	ST1 DBP	RES DISINFECT CONCENTRATION (SWTR)	7/1/2016	7/31/2016		8/31/2016
Total Number of Violations for this Water System:										1
NV0000736	BIGLIERI WATER SYSTEM	3AMN	3014	E. COLI		MONITORING, ROUTINE, MINOR (RTCR)	4/1/2016	6/30/2016		7/27/2016
Total Number of Violations for this Water System:										1
NV0003053	BIRD CREEK CAMPGROUND USFS	22	3100	COLIFORM (TCR)		MCL (TCR), MONTHLY	8/1/2015	8/31/2015		6/16/2016
Total Number of Violations for this Water System:										1
NV0000323	BLUE DIAMOND SALOON	93	1055	SULFATE		STATE FAILURE TO MONITOR	10/1/2015	12/31/2015		4/20/2016
NV0000323	BLUE DIAMOND SALOON	93	1055	SULFATE		STATE FAILURE TO MONITOR	1/1/2016	3/31/2016		4/20/2016
NV0000323	BLUE DIAMOND SALOON	93	1930	TDS		STATE FAILURE TO MONITOR	10/1/2015	12/31/2015		4/20/2016
NV0000323	BLUE DIAMOND SALOON	93	1930	TDS		STATE FAILURE TO MONITOR	1/1/2016	3/31/2016		4/20/2016
NV0000323	BLUE DIAMOND SALOON	S1	1055	SULFATE		STATE MCL EXCEDENCE	4/1/2016	6/30/2016	530 MG/L	

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0000323	BLUE DIAMOND SALOON	S1	1055	SULFATE		STATE MCL EXCEEDENCE	10/1/2016	12/31/2016	570 MG/L	
NV0000323	BLUE DIAMOND SALOON	S1	1930	TDS		STATE MCL EXCEEDENCE	4/1/2016	6/30/2016	1100 MG/L	
NV0000323	BLUE DIAMOND SALOON	S1	1930	TDS		STATE MCL EXCEEDENCE	7/1/2016	9/30/2016	1100 MG/L	
Total Number of Violations for this Water System:										8
NV0000955	BLUE DIAMOND TRAVEL CENTER	93	1905	COLOR		STATE FAILURE TO MONITOR	1/1/2014	12/31/2016		
NV0000955	BLUE DIAMOND TRAVEL CENTER	93	1089	MBAS - FOAMING AGENTS		STATE FAILURE TO MONITOR	1/1/2014	12/31/2016		
NV0000955	BLUE DIAMOND TRAVEL CENTER	93	1920	ODOR		STATE FAILURE TO MONITOR	1/1/2014	12/31/2016		
Total Number of Violations for this Water System:										3
NV0003066	BOB SCOTT CAMPGROUND USFS	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2016	12/31/2016		5/21/2017
Total Number of Violations for this Water System:										1
NV0000709	BOOMTOWN HOTEL AND CASINO INC	27MJ	CDB2	DBPR STAGE 2		MONITORING, ROUTINE (DBP), MAJOR	9/1/2014	12/31/2016		
NV0000709	BOOMTOWN HOTEL AND CASINO INC	S1	1002	ALUMINUM		STATE MCL EXCEEDENCE	4/1/2016	6/30/2016	1.1 MG/L	10/27/2016
NV0000709	BOOMTOWN HOTEL AND CASINO INC	S1	1032	MANGANESE		STATE MCL EXCEEDENCE	4/1/2016	6/30/2016	0.74 MG/L	10/27/2016
Total Number of Violations for this Water System:										3
NV0002090	BOONIES	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2015	12/31/2015		8/22/2016
NV0002090	BOONIES	23MJ	3100	COLIFORM (TCR)		MONITORING (TCR), ROUTINE MAJOR	1/1/2016	3/31/2016		3/30/2016
NV0002090	BOONIES	93	CSC2	SECONDARY IOCS		STATE FAILURE TO MONITOR	1/1/2014	12/31/2016		
Total Number of Violations for this Water System:										3

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0000321	BRANDOS SPORTS BAR	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2016	12/31/2016		
NV0000321	BRANDOS SPORTS BAR	03MJ	CNO2	NITRITE	IOC	MONITORING, ROUTINE MAJOR	1/1/2014	12/31/2016		
Total Number of Violations for this Water System:										2
NV0000389	BUCKBOARD GENERAL STORE	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2014	12/31/2014		6/7/2016
NV0000389	BUCKBOARD GENERAL STORE	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2015	12/31/2015		6/7/2016
NV0000389	BUCKBOARD GENERAL STORE	23MJ	3100	COLIFORM (TCR)		MONITORING (TCR), ROUTINE MAJOR	7/1/2015	9/30/2015		6/7/2016
NV0000389	BUCKBOARD GENERAL STORE	23MJ	3100	COLIFORM (TCR)		MONITORING (TCR), ROUTINE MAJOR	10/1/2015	12/31/2015		6/7/2016
NV0000389	BUCKBOARD GENERAL STORE	23MJ	3100	COLIFORM (TCR)		MONITORING (TCR), ROUTINE MAJOR	1/1/2016	3/31/2016		6/7/2016
Total Number of Violations for this Water System:										5
NV0000341	CARMENS MEXICAN RESTAURANT	23MJ	3100	COLIFORM (TCR)		MONITORING (TCR), ROUTINE MAJOR	10/1/2015	12/31/2015		3/29/2016
NV0000341	CARMENS MEXICAN RESTAURANT	93	1032	MANGANESE		STATE FAILURE TO MONITOR	10/1/2015	12/31/2015		3/29/2016
NV0000341	CARMENS MEXICAN RESTAURANT	S1	1032	MANGANESE		STATE MCL EXCEEDENCE	7/1/2015	9/30/2015	0.17 MG/L	5/17/2016
Total Number of Violations for this Water System:										3
NV0000958	CARSON CAR CENTER	3AMJ	3014	E. COLI		MONITORING, ROUTINE, MAJOR (RTCR)	7/1/2016	9/30/2016		11/17/2016
Total Number of Violations for this Water System:										1
NV0003068	CARSON RIVER ESTATES	27MJ	0999	CHLORINE	ST1 DBP	MONITORING, ROUTINE (DBP), MAJOR	10/1/2016	12/31/2016		
NV0003068	CARSON RIVER ESTATES	3AMJ	3014	E. COLI		MONITORING, ROUTINE, MAJOR (RTCR)	11/1/2016	11/30/2016		12/11/2016
Total Number of Violations for this Water System:										2

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0002140	CARVERS CAFE	3BMJ	3014	E. COLI		MONITORING, ADD. ROUTINE, MAJOR (RTCR)	8/1/2016	8/31/2016		9/26/2016
Total Number of Violations for this Water System:										1
NV0000218	CARVERS SMOKEY VALLEY RV AND MHP	02	1005	ARSENIC	IOC	MCL, AVERAGE	1/1/2016	3/31/2016	0.012 MG/L	2/15/2017
NV0000218	CARVERS SMOKEY VALLEY RV AND MHP	02	1005	ARSENIC	IOC	MCL, AVERAGE	4/1/2016	6/30/2016	0.011 MG/L	2/15/2017
NV0000218	CARVERS SMOKEY VALLEY RV AND MHP	02	1005	ARSENIC	IOC	MCL, AVERAGE	7/1/2016	9/30/2016	0.012 MG/L	2/15/2017
NV0000218	CARVERS SMOKEY VALLEY RV AND MHP	02	1005	ARSENIC	IOC	MCL, AVERAGE	10/1/2016	12/31/2016	0.011 MG/L	2/15/2017
Total Number of Violations for this Water System:										4
NV0000059	CASEY ROAD MHP	02	1005	ARSENIC	IOC	MCL, AVERAGE	10/1/2016	12/31/2016	0.040 MG/L	
NV0000059	CASEY ROAD MHP	51	5000	LEAD & COPPER RULE		INITIAL TAP SAMPLING (LCR)	4/1/2001			
NV0000059	CASEY ROAD MHP	51	5000	LEAD & COPPER RULE		INITIAL TAP SAMPLING (LCR)	4/1/2001			
NV0000059	CASEY ROAD MHP	71	7000	CONSUMER CONFIDENCE RULE		CCR REPORT	7/1/2016			
NV0000059	CASEY ROAD MHP	S1	1032	MANGANESE		STATE MCL EXCEDENCE	10/1/2016	12/31/2016	0.28 MG/L	
Total Number of Violations for this Water System:										5
NV0002533	CHUCK LENZIE GENERATING STATION	03MJ	CIOF	IOC FLUORIDE		MONITORING, ROUTINE MAJOR	4/1/2016	6/30/2016		
NV0002533	CHUCK LENZIE GENERATING STATION	93	1002	ALUMINUM		STATE FAILURE TO MONITOR	4/1/2016	6/30/2016		
Total Number of Violations for this Water System:										2
NV0000277	CONESTOGA MHP	71	7000	CONSUMER CONFIDENCE RULE		CCR REPORT	7/1/2014			
Total Number of Violations for this Water System:										1

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0000385	COYOTE CORNER III	3BMJ	3014	E. COLI		MONITORING, ADD. ROUTINE, MAJOR (RTCR)	7/1/2016	7/31/2016		8/18/2016
NV0000385	COYOTE CORNER III	93	1055	SULFATE		STATE FAILURE TO MONITOR	10/1/2015	12/31/2015		3/28/2016
NV0000385	COYOTE CORNER III	93	1055	SULFATE		STATE FAILURE TO MONITOR	7/1/2016	9/30/2016		
NV0000385	COYOTE CORNER III	93	1930	TDS		STATE FAILURE TO MONITOR	10/1/2015	12/31/2015		3/28/2016
NV0000385	COYOTE CORNER III	93	1930	TDS		STATE FAILURE TO MONITOR	7/1/2016	9/30/2016		
Total Number of Violations for this Water System:										5
NV0002565	COYOTE CORNER MARKET	93	CSC2	SECONDARY IOCS		STATE FAILURE TO MONITOR	1/1/2014	12/31/2016		
Total Number of Violations for this Water System:										1
NV0001081	CREECH AIR FORCE BASE	03MJ	2039	DI(2-ETHYLHEXYL) PHTHALATE		MONITORING, ROUTINE MAJOR	1/1/2016	3/31/2016		2/8/2016
NV0001081	CREECH AIR FORCE BASE	S1	1028	IRON		STATE MCL EXCEDENCE	10/1/2016	12/31/2016	1.6 MG/L	
Total Number of Violations for this Water System:										2
NV0000193	CRYSTAL TP	03MJ	CDAS	ARSENIC (AS)		MONITORING, ROUTINE MAJOR	1/1/2011	12/31/2013		9/15/2016
NV0000193	CRYSTAL TP	03MJ	CDAS	ARSENIC (AS)		MONITORING, ROUTINE MAJOR	1/1/2014	12/31/2016		
NV0000193	CRYSTAL TP	03MJ	CDAS	ARSENIC (AS)		MONITORING, ROUTINE MAJOR	1/1/2014	12/31/2016		
NV0000193	CRYSTAL TP	03MJ	CDAS	ARSENIC (AS)		MONITORING, ROUTINE MAJOR	1/1/2014	12/31/2016		
Total Number of Violations for this Water System:										4
NV0002068	CURRIE STORE	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2015	12/31/2015		8/18/2016
NV0002068	CURRIE STORE	03MJ	CNO2	NITRITE	IOC	MONITORING, ROUTINE MAJOR	1/1/2014	12/31/2016		

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
Total Number of Violations for this Water System:										2
NV0000149	DESERT PARADISE MHP	02	1005	ARSENIC	IOC	MCL, AVERAGE	1/1/2016	3/31/2016	0.0155 MG/L	
NV0000149	DESERT PARADISE MHP	02	1005	ARSENIC	IOC	MCL, AVERAGE	4/1/2016	6/30/2016	0.015 MG/L	
NV0000149	DESERT PARADISE MHP	02	1005	ARSENIC	IOC	MCL, AVERAGE	7/1/2016	9/30/2016	0.014 MG/L	
NV0000149	DESERT PARADISE MHP	02	1005	ARSENIC	IOC	MCL, AVERAGE	10/1/2016	12/31/2016	0.014 MG/L	
NV0000149	DESERT PARADISE MHP	34MJ	3014	E. COLI		MONITOR GWR TRIGGERED/ADDITONAL, MAJOR	10/14/2016	12/5/2016		12/5/2016
NV0000149	DESERT PARADISE MHP	75	7500	PUBLIC NOTICE		PUBLIC NOTICE RULE LINKED TO VIOLATION	10/1/2010			
Total Number of Violations for this Water System:										6
NV0001008	DESERT SOUTHWEST CONFERENCE	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2016	12/31/2016		
Total Number of Violations for this Water System:										1
NV0001148	DIAMOND PLASTICS	02	1074	ANTIMONY, TOTAL	IOC	MCL, AVERAGE	10/1/2016	12/31/2016	0.0063 MG/L	
NV0001148	DIAMOND PLASTICS	02	1005	ARSENIC	IOC	MCL, AVERAGE	10/1/2016	12/31/2016	0.012 MG/L	
NV0001148	DIAMOND PLASTICS	S1	1025	FLUORIDE		STATE MCL EXCEDENCE	10/1/2016	12/31/2016	2.4 MG/L	
NV0001148	DIAMOND PLASTICS	S1	1032	MANGANESE		STATE MCL EXCEDENCE	10/1/2016	12/31/2016	0.4 MG/L	
Total Number of Violations for this Water System:										4
NV0004096	DOUBLE D BAR & GRILL	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2015	12/31/2015		9/29/2016
NV0004096	DOUBLE D BAR & GRILL	03MJ	CNO2	NITRITE	IOC	MONITORING, ROUTINE MAJOR	1/1/2014	12/31/2016		
NV0004096	DOUBLE D BAR & GRILL	23MJ	3100	COLIFORM (TCR)		MONITORING (TCR), ROUTINE MAJOR	7/1/2015	9/30/2015		8/22/2016

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0004096	DOUBLE D BAR & GRILL	23MJ	3100	COLIFORM (TCR)		MONITORING (TCR), ROUTINE MAJOR	10/1/2015	12/31/2015		8/22/2016
NV0004096	DOUBLE D BAR & GRILL	23MJ	3100	COLIFORM (TCR)		MONITORING (TCR), ROUTINE MAJOR	1/1/2016	3/31/2016		8/22/2016
NV0004096	DOUBLE D BAR & GRILL	34MJ	3014	E. COLI		MONITOR GWR TRIGGERED/ADDITONAL, MAJOR	8/25/2016	9/8/2016		9/8/2016
NV0004096	DOUBLE D BAR & GRILL	3AMJ	3014	E. COLI		MONITORING, ROUTINE, MAJOR (RTCR)	4/1/2016	6/30/2016		8/22/2016
NV0004096	DOUBLE D BAR & GRILL	3AMJ	3014	E. COLI		MONITORING, ROUTINE, MAJOR (RTCR)	11/1/2016	11/30/2016		12/27/2016
NV0004096	DOUBLE D BAR & GRILL	93	CSC2	SECONDARY IOCS		STATE FAILURE TO MONITOR	1/1/2014	12/31/2016		

Total Number of Violations for this Water System: 9

NV0000949	DOVETAIL RANCH	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2016	12/31/2016		1/5/2017
NV0000949	DOVETAIL RANCH	93	1028	IRON		STATE FAILURE TO MONITOR	1/1/2016	12/31/2016		
NV0000949	DOVETAIL RANCH	93	1032	MANGANESE		STATE FAILURE TO MONITOR	1/1/2016	12/31/2016		

Total Number of Violations for this Water System: 3

NV0000809	DUTCHMAN ACRES	52	5000	LEAD & COPPER RULE		FOLLOW-UP OR ROUTINE TAP M/R (LCR)	10/1/2016			
NV0000809	DUTCHMAN ACRES	71	7000	CONSUMER CONFIDENCE RULE		CCR REPORT	7/1/2016	11/8/2016		11/8/2016

Total Number of Violations for this Water System: 2

NV0000188	EAGLE VALLEY RESORT	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2016	12/31/2016		4/25/2017
NV0000188	EAGLE VALLEY RESORT	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2016	12/31/2016		4/25/2017
NV0000188	EAGLE VALLEY RESORT	03MJ	CNO2	NITRITE	IOC	MONITORING, ROUTINE MAJOR	1/1/2014	12/31/2016		

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0000188	EAGLE VALLEY RESORT	03MJ	CNO2	NITRITE	IOC	MONITORING, ROUTINE MAJOR	1/1/2014	12/31/2016		
NV0000188	EAGLE VALLEY RESORT	3AMJ	3014	E. COLI		MONITORING, ROUTINE, MAJOR (RTCR)	10/1/2016	12/31/2016		12/20/2016
NV0000188	EAGLE VALLEY RESORT	93	CSC2	SECONDARY IOCS		STATE FAILURE TO MONITOR	1/1/2014	12/31/2016		
NV0000188	EAGLE VALLEY RESORT	93	CSC2	SECONDARY IOCS		STATE FAILURE TO MONITOR	1/1/2014	12/31/2016		
Total Number of Violations for this Water System:										7
NV0003098	EAST 50 BAR	23MJ	3100	COLIFORM (TCR)		MONITORING (TCR), ROUTINE MAJOR	1/1/2016	3/31/2016		5/4/2016
NV0003098	EAST 50 BAR	3AMJ	3014	E. COLI		MONITORING, ROUTINE, MAJOR (RTCR)	10/1/2016	12/31/2016		2/7/2017
Total Number of Violations for this Water System:										2
NV0000038	ELY MUNICIPAL WATER DEPARTMENT	24MN	3100	COLIFORM (TCR)		MONITORING (TCR), ROUTINE MINOR	12/1/2015	12/31/2015		1/27/2016
NV0000038	ELY MUNICIPAL WATER DEPARTMENT	27MJ	0999	CHLORINE	ST1 DBP	MONITORING, ROUTINE (DBP), MAJOR	10/1/2015	12/31/2015		12/27/2016
NV0000038	ELY MUNICIPAL WATER DEPARTMENT	27MJ	CHA2	DBPR STAGE 2 HAAS		MONITORING, ROUTINE (DBP), MAJOR	1/1/2016	12/31/2016		
NV0000038	ELY MUNICIPAL WATER DEPARTMENT	27MJ	CTT2	DBPR STAGE 2 TTHM		MONITORING, ROUTINE (DBP), MAJOR	1/1/2016	12/31/2016		
Total Number of Violations for this Water System:										4
NV0000042	EMPIRE MINING COMPANY	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2016	12/31/2016		2/1/2017
NV0000042	EMPIRE MINING COMPANY	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2016	12/31/2016		2/1/2017
NV0000042	EMPIRE MINING COMPANY	03MJ	CSOC	SOCS PHASE 2 & 5		MONITORING, ROUTINE MAJOR	1/1/2014	12/31/2016		
NV0000042	EMPIRE MINING COMPANY	03MJ	CVOC	VOCS PHASE 2 & 5		MONITORING, ROUTINE MAJOR	1/1/2016	12/31/2016		

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0000042	EMPIRE MINING COMPANY	27MJ	0999	CHLORINE	ST1 DBP	MONITORING, ROUTINE (DBP), MAJOR	4/1/2016	6/30/2016		9/22/2016
NV0000042	EMPIRE MINING COMPANY	27MJ	0999	CHLORINE	ST1 DBP	MONITORING, ROUTINE (DBP), MAJOR	4/1/2016	6/30/2016		9/22/2016
NV0000042	EMPIRE MINING COMPANY	71	7000	CONSUMER CONFIDENCE RULE		CCR REPORT	7/1/2014			
Total Number of Violations for this Water System:										7
NV0002594	FALLON LIVESTOCK EXCHANGE	S1	1032	MANGANESE		STATE MCL EXCEEDENCE	4/1/2016	6/30/2016	0.26 MG/L	
Total Number of Violations for this Water System:										1
NV0000350	FALLON NAVAL AIR STATION	27MJ	CDB2	DBPR STAGE 2		MONITORING, ROUTINE (DBP), MAJOR	1/1/2015	12/31/2015		9/13/2016
Total Number of Violations for this Water System:										1
NV0000916	FISH LAKE VALLEY SALOON	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2015	12/31/2015		9/7/2016
NV0000916	FISH LAKE VALLEY SALOON	03MJ	CNO2	NITRITE	IOC	MONITORING, ROUTINE MAJOR	1/1/2014	12/31/2016		
NV0000916	FISH LAKE VALLEY SALOON	23MJ	3100	COLIFORM (TCR)		MONITORING (TCR), ROUTINE MAJOR	1/1/2016	3/31/2016		4/27/2016
NV0000916	FISH LAKE VALLEY SALOON	93	CSC2	SECONDARY IOCS		STATE FAILURE TO MONITOR	1/1/2014	12/31/2016		
Total Number of Violations for this Water System:										4
NV0000884	FLORIDA CANYON MINING INC	27MJ	0999	CHLORINE	ST1 DBP	MONITORING, ROUTINE (DBP), MAJOR	10/1/2015	12/31/2015		12/31/2016
Total Number of Violations for this Water System:										1
NV0000155	FORT AMARGOSA RV PARK	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2015	12/31/2015		6/15/2016
Total Number of Violations for this Water System:										1
NV0000806	FORT CHURCHILL POWER PLANT	02	1005	ARSENIC	IOC	MCL, AVERAGE	10/1/2015	12/31/2015	0.016 MG/L	12/22/2016

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0000806	FORT CHURCHILL POWER PLANT	02	1005	ARSENIC	IOC	MCL, AVERAGE	1/1/2016	3/31/2016	0.017 MG/L	12/22/2016
NV0000806	FORT CHURCHILL POWER PLANT	02	1005	ARSENIC	IOC	MCL, AVERAGE	4/1/2016	6/30/2016	0.019 MG/L	12/22/2016
NV0000806	FORT CHURCHILL POWER PLANT	02	1005	ARSENIC	IOC	MCL, AVERAGE	7/1/2016	9/30/2016	0.018 MG/L	12/22/2016
NV0000806	FORT CHURCHILL POWER PLANT	03MJ	2992	ETHYLBENZENE		MONITORING, ROUTINE MAJOR	1/1/2016	12/31/2016		
NV0000806	FORT CHURCHILL POWER PLANT	03MJ	2955	XYLENES, TOTAL		MONITORING, ROUTINE MAJOR	1/1/2016	12/31/2016		

Total Number of Violations for this Water System: 6

NV0000063	GABBS WATER SYSTEM	03MJ	CSOD	SODIUM (NA)		MONITORING, ROUTINE MAJOR	1/1/2014	12/31/2016		5/18/2017
NV0000063	GABBS WATER SYSTEM	03MJ	CVOC	VOCS PHASE 2 & 5		MONITORING, ROUTINE MAJOR	1/1/2016	12/31/2016		5/18/2017
NV0000063	GABBS WATER SYSTEM	03MJ	CVOC	VOCS PHASE 2 & 5		MONITORING, ROUTINE MAJOR	1/1/2014	12/31/2016		5/18/2017

Total Number of Violations for this Water System: 3

NV0000066	GARDNERVILLE RANCHOS GID	03MJ	CRUR	RADS URANIUM		MONITORING, ROUTINE MAJOR	1/1/2008	12/31/2013		4/11/2016
NV0000066	GARDNERVILLE RANCHOS GID	03MJ	CRUR	RADS URANIUM		MONITORING, ROUTINE MAJOR	1/1/2008	12/31/2013		3/2/2016
NV0000066	GARDNERVILLE RANCHOS GID	03MJ	CSOC	SOCS PHASE 2 & 5		MONITORING, ROUTINE MAJOR	1/1/2014	12/31/2016		

Total Number of Violations for this Water System: 3

NV0000065	GARDNERVILLE TOWN WATER	S1	1920	ODOR		STATE MCL EXCEDENCE	4/1/2016	6/30/2016	70 TON	10/11/2016
-----------	-------------------------	----	------	------	--	---------------------	----------	-----------	--------	------------

Total Number of Violations for this Water System: 1

NV0000372	GEORGIA PACIFIC GYPSUM LLC	02	1005	ARSENIC	IOC	MCL, AVERAGE	4/1/2016	6/30/2016	0.011 MG/L	3/27/2017
NV0000372	GEORGIA PACIFIC GYPSUM LLC	02	1005	ARSENIC	IOC	MCL, AVERAGE	7/1/2016	9/30/2016	0.012 MG/L	3/27/2017

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0000372	GEORGIA PACIFIC GYPSUM LLC	02	1005	ARSENIC	IOC	MCL, AVERAGE	10/1/2016	12/31/2016	0.013 MG/L	3/27/2017
NV0000372	GEORGIA PACIFIC GYPSUM LLC	03MJ	CDAS	ARSENIC (AS)		MONITORING, ROUTINE MAJOR	4/1/2016	4/30/2016		
Total Number of Violations for this Water System:										4
NV0000071	GERLACH GID	03MJ	CRGA	RADS GROSS ALPHA		MONITORING, ROUTINE MAJOR	1/1/2016	12/31/2016		
NV0000071	GERLACH GID	03MJ	CRUR	RADS URANIUM		MONITORING, ROUTINE MAJOR	1/1/2016	12/31/2016		
NV0000071	GERLACH GID	27MJ	CDB2	DBPR STAGE 2		MONITORING, ROUTINE (DBP), MAJOR	1/1/2016	12/31/2016		
Total Number of Violations for this Water System:										3
NV0003029	GIRL SCOUTS NV CAMP FOXTAIL	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2015	12/31/2015		5/25/2016
NV0003029	GIRL SCOUTS NV CAMP FOXTAIL	23MJ	3100	COLIFORM (TCR)		MONITORING (TCR), ROUTINE MAJOR	7/1/2015	9/30/2015		6/30/2016
NV0003029	GIRL SCOUTS NV CAMP FOXTAIL	93	1028	IRON		STATE FAILURE TO MONITOR	7/1/2015	7/31/2015		5/25/2016
Total Number of Violations for this Water System:										3
NV0000881	GOLD CANYON CAFE	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2015	12/31/2015		1/27/2016
NV0000881	GOLD CANYON CAFE	23MJ	3100	COLIFORM (TCR)		MONITORING (TCR), ROUTINE MAJOR	7/1/2015	9/30/2015		1/26/2016
NV0000881	GOLD CANYON CAFE	23MJ	3100	COLIFORM (TCR)		MONITORING (TCR), ROUTINE MAJOR	10/1/2015	12/31/2015		1/26/2016
NV0000881	GOLD CANYON CAFE	3AMJ	3014	E. COLI		MONITORING, ROUTINE, MAJOR (RTCR)	10/1/2016	12/31/2016		1/26/2017
Total Number of Violations for this Water System:										4
NV0001124	GOLD DIGGERS SALOON & GRUBB	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2016	12/31/2016		1/17/2017
NV0001124	GOLD DIGGERS SALOON & GRUBB	3AMJ	3014	E. COLI		MONITORING, ROUTINE, MAJOR (RTCR)	7/1/2016	9/30/2016		10/31/2016

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
Total Number of Violations for this Water System:										2
NV0000751	GOLD RANCH CASINO	S1	1032	MANGANESE		STATE MCL EXCEDENCE	1/1/2016	3/31/2016	0.16 MG/L	12/1/2016
NV0000751	GOLD RANCH CASINO	S1	1032	MANGANESE		STATE MCL EXCEDENCE	4/1/2016	6/30/2016	0.18 MG/L	12/1/2016
Total Number of Violations for this Water System:										2
NV0001045	GOODSPRINGS SCHOOL CCSD	27MJ	CDB2	DBPR STAGE 2		MONITORING, ROUTINE (DBP), MAJOR	1/1/2014	9/30/2016		
Total Number of Violations for this Water System:										1
NV0004109	GRANITE HILLS BAPTIST CHURCH	3AMJ	3014	E. COLI		MONITORING, ROUTINE, MAJOR (RTCR)	7/1/2016	9/30/2016		1/31/2017
Total Number of Violations for this Water System:										1
NV0005027	GREAT BASIN WATER CO SPRING CREEK MHP	S1	1920	ODOR		STATE MCL EXCEDENCE	10/1/2016	12/31/2016	35 TON	
Total Number of Violations for this Water System:										1
NV0001131	HALLIBURTON DUNPHY MILL	S1	1032	MANGANESE		STATE MCL EXCEDENCE	4/1/2016	6/30/2016	0.22 MG/L	
NV0001131	HALLIBURTON DUNPHY MILL	S1	1032	MANGANESE		STATE MCL EXCEDENCE	7/1/2016	9/30/2016	0.21 MG/L	
NV0001131	HALLIBURTON DUNPHY MILL	S1	1032	MANGANESE		STATE MCL EXCEDENCE	10/1/2016	12/31/2016	0.22 MG/L	
NV0001131	HALLIBURTON DUNPHY MILL	S1	1920	ODOR		STATE MCL EXCEDENCE	4/1/2016	6/30/2016	24.0 TON	
NV0001131	HALLIBURTON DUNPHY MILL	S1	1920	ODOR		STATE MCL EXCEDENCE	7/1/2016	9/30/2016	6.0 TON	
NV0001131	HALLIBURTON DUNPHY MILL	S1	1920	ODOR		STATE MCL EXCEDENCE	10/1/2016	12/31/2016	17.0 TON	4/19/2017
Total Number of Violations for this Water System:										6
NV0002580	HARMON JUNCTION	3AMJ	3014	E. COLI		MONITORING, ROUTINE, MAJOR (RTCR)	5/1/2016	5/31/2016		6/16/2016

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0002580	HARMON JUNCTION	S1	1055	SULFATE		STATE MCL EXCEEDENCE	4/1/2016	6/30/2016	763 MG/L	
NV0002580	HARMON JUNCTION	S1	1055	SULFATE		STATE MCL EXCEEDENCE	10/1/2016	12/31/2016	950 MG/L	
NV0002580	HARMON JUNCTION	S1	1930	TDS		STATE MCL EXCEEDENCE	4/1/2016	6/30/2016	1800 MG/L	
NV0002580	HARMON JUNCTION	S1	1930	TDS		STATE MCL EXCEEDENCE	10/1/2016	12/31/2016	2200 MG/L	

Total Number of Violations for this Water System: 5

NV0000357	HAWTHORNE ARMY DEPOT	02	2950	TTHM	IOC	MCL, AVERAGE	4/1/2015	6/30/2015	0.084 MG/L	8/11/2016
NV0000357	HAWTHORNE ARMY DEPOT	02	2950	TTHM	IOC	MCL, AVERAGE	7/1/2015	9/30/2015	0.139 MG/L	8/11/2016
NV0000357	HAWTHORNE ARMY DEPOT	02	2950	TTHM	IOC	MCL, AVERAGE	10/1/2015	12/31/2015	0.158 MG/L	8/11/2016
NV0000357	HAWTHORNE ARMY DEPOT	02	2950	TTHM	IOC	MCL, LRAA	1/1/2016	3/31/2016	0.127 MG/L	8/11/2016
NV0000357	HAWTHORNE ARMY DEPOT	02	2950	TTHM	IOC	MCL, AVERAGE	4/1/2016	6/30/2016	0.106 MG/L	8/11/2016

Total Number of Violations for this Water System: 5

NV0000073	HAWTHORNE UTILITIES	27MJ	0999	CHLORINE	ST1 DBP	MONITORING, ROUTINE (DBP), MAJOR	7/1/2015	9/30/2015		9/30/2016
-----------	---------------------	------	------	----------	---------	----------------------------------	----------	-----------	--	-----------

Total Number of Violations for this Water System: 1

NV0004053	HODGES TRANSPORTATION CO	03MJ	CDAS	ARSENIC (AS)		MONITORING, ROUTINE MAJOR	1/1/2016	3/31/2016		
NV0004053	HODGES TRANSPORTATION CO	03MJ	CDAS	ARSENIC (AS)		MONITORING, ROUTINE MAJOR	1/1/2016	3/31/2016		
NV0004053	HODGES TRANSPORTATION CO	03MJ	CDAS	ARSENIC (AS)		MONITORING, ROUTINE MAJOR	1/1/2016	3/31/2016		
NV0004053	HODGES TRANSPORTATION CO	03MJ	CDAS	ARSENIC (AS)		MONITORING, ROUTINE MAJOR	1/1/2016	3/31/2016		

Total Number of Violations for this Water System: 4

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0002586	HOLLYWOOD SKATE	3AMJ	3014	E. COLI		MONITORING, ROUTINE, MAJOR (RTCR)	4/1/2016	6/30/2016		9/30/2016
NV0002586	HOLLYWOOD SKATE	3AMJ	3014	E. COLI		MONITORING, ROUTINE, MAJOR (RTCR)	10/1/2016	12/31/2016		2/16/2017
NV0002586	HOLLYWOOD SKATE	93	1032	MANGANESE		STATE FAILURE TO MONITOR	4/1/2016	6/30/2016		9/30/2016
NV0002586	HOLLYWOOD SKATE	93	CSC2	SECONDARY IOCS		STATE FAILURE TO MONITOR	1/1/2014	12/31/2016		2/16/2017
NV0002586	HOLLYWOOD SKATE	S1	1032	MANGANESE		STATE MCL EXCEEDENCE	1/1/2016	3/31/2016	1.3 MG/L	
Total Number of Violations for this Water System:										5
NV0001083	HOOVER DAM LODGE DBA HACIENDA	51	5000	LEAD & COPPER RULE		INITIAL TAP SAMPLING (LCR)	7/1/2016			
Total Number of Violations for this Water System:										1
NV0000833	HORIZON C-STORES LLC	93	CSC2	SECONDARY IOCS		STATE FAILURE TO MONITOR	1/1/2014	12/31/2016		
Total Number of Violations for this Water System:										1
NV0000918	HORIZON MARKET III	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2016	12/31/2016		4/28/2017
Total Number of Violations for this Water System:										1
NV0000082	INDIAN SPRINGS WATER CO INC	03MJ	CVOC	VOCS PHASE 2 & 5		MONITORING, ROUTINE MAJOR	1/1/2014	12/31/2016		
NV0000082	INDIAN SPRINGS WATER CO INC	03MJ	CVOC	VOCS PHASE 2 & 5		MONITORING, ROUTINE MAJOR	1/1/2014	12/31/2016		
NV0000082	INDIAN SPRINGS WATER CO INC	27MJ	0999	CHLORINE	ST1 DBP	MONITORING, ROUTINE (DBP), MAJOR	7/1/2016	9/30/2016		2/2/2017
Total Number of Violations for this Water System:										3
NV0000088	JACKPOT WATER SYSTEM	03MJ	2992	ETHYLBENZENE		MONITORING, ROUTINE MAJOR	1/1/2015	12/31/2015		8/10/2016
NV0000088	JACKPOT WATER SYSTEM	03MJ	2955	XYLENES, TOTAL		MONITORING, ROUTINE MAJOR	1/1/2015	12/31/2015		8/10/2016

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0000088	JACKPOT WATER SYSTEM	27MJ	CDB2	DBPR STAGE 2		MONITORING, ROUTINE (DBP), MAJOR	1/1/2014	12/31/2014		12/19/2016
NV0000088	JACKPOT WATER SYSTEM	27MJ	CDB2	DBPR STAGE 2		MONITORING, ROUTINE (DBP), MAJOR	1/1/2015	12/31/2015		12/19/2016
NV0000088	JACKPOT WATER SYSTEM	71	7000	CONSUMER CONFIDENCE RULE		CCR REPORT	7/1/2015	6/30/2016		6/30/2016
NV0000088	JACKPOT WATER SYSTEM	S1	1920	ODOR		STATE MCL EXCEEDENCE	4/1/2016	6/30/2016	17 TON	
NV0000088	JACKPOT WATER SYSTEM	S1	1920	ODOR		STATE MCL EXCEEDENCE	7/1/2016	9/30/2016	4 TON	

Total Number of Violations for this Water System: 7

NV0003013	JERRITT CANYON GOLD JERRITT CANYON MINE	03MJ	CVOC	VOCS PHASE 2 & 5		MONITORING, ROUTINE MAJOR	1/1/2014	12/31/2014		6/1/2016
NV0003013	JERRITT CANYON GOLD JERRITT CANYON MINE	03MJ	CVOC	VOCS PHASE 2 & 5		MONITORING, ROUTINE MAJOR	1/1/2015	12/31/2015		6/1/2016
NV0003013	JERRITT CANYON GOLD JERRITT CANYON MINE	52	5000	LEAD & COPPER RULE		FOLLOW-UP OR ROUTINE TAP M/R (LCR)	10/1/2016			

Total Number of Violations for this Water System: 3

NV0000313	JERRITT CANYON GOLD SSX MINE	27MJ	0999	CHLORINE	ST1 DBP	MONITORING, ROUTINE (DBP), MAJOR	10/1/2016	12/31/2016		
NV0000313	JERRITT CANYON GOLD SSX MINE	27MJ	0999	CHLORINE	ST1 DBP	MONITORING, ROUTINE (DBP), MAJOR	10/1/2016	12/31/2016		
NV0000313	JERRITT CANYON GOLD SSX MINE	27MJ	0999	CHLORINE	ST1 DBP	MONITORING, ROUTINE (DBP), MAJOR	10/1/2016	12/31/2016		
NV0000313	JERRITT CANYON GOLD SSX MINE	3AMJ	3014	E. COLI		MONITORING, ROUTINE, MAJOR (RTCR)	10/1/2016	12/31/2016		1/12/2017
NV0000313	JERRITT CANYON GOLD SSX MINE	52	5000	LEAD & COPPER RULE		FOLLOW-UP OR ROUTINE TAP M/R (LCR)	10/1/2016			

Total Number of Violations for this Water System: 5

NV0002071	JIGGS BAR	93	1032	MANGANESE		STATE FAILURE TO MONITOR	1/1/2016	12/31/2016		
-----------	-----------	----	------	-----------	--	--------------------------	----------	------------	--	--

Total Number of Violations for this Water System: 1

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0000731	JOHNNY CASSINARIS RESTAURANT	3AMJ	3014	E. COLI		MONITORING, ROUTINE, MAJOR (RTCR)	10/1/2016	10/31/2016		11/21/2016
Total Number of Violations for this Water System:										1
NV0001107	KAPEX WATER SYSTEM CITY OF NLV	52	5000	LEAD & COPPER RULE		FOLLOW-UP OR ROUTINE TAP M/R (LCR)	10/1/2015			6/29/2016
Total Number of Violations for this Water System:										1
NV0000932	KEYSTONE CENTER	03MJ	CNO2	NITRITE	IOC	MONITORING, ROUTINE MAJOR	1/1/2014	12/31/2016		
NV0000932	KEYSTONE CENTER	34MJ	3014	E. COLI		MONITOR GWR TRIGGERED/ADDITONAL, MAJOR	7/6/2016	7/18/2016		7/18/2016
NV0000932	KEYSTONE CENTER	93	CSC2	SECONDARY IOCS		STATE FAILURE TO MONITOR	1/1/2014	12/31/2016		
Total Number of Violations for this Water System:										3
NV0002198	KINGS RIVER ELEMENTARY SCHOOL	22	3100	COLIFORM (TCR)		MCL (TCR), MONTHLY	10/1/2015	10/31/2015		2/22/2016
NV0002198	KINGS RIVER ELEMENTARY SCHOOL	22	3100	COLIFORM (TCR)		MCL (TCR), MONTHLY	11/1/2015	11/30/2015		2/22/2016
NV0002198	KINGS RIVER ELEMENTARY SCHOOL	22	3100	COLIFORM (TCR)		MCL (TCR), MONTHLY	12/1/2015	12/31/2015		2/22/2016
NV0002198	KINGS RIVER ELEMENTARY SCHOOL	51	5000	LEAD & COPPER RULE		INITIAL TAP SAMPLING (LCR)	1/1/2017			
Total Number of Violations for this Water System:										4
NV0002174	KOA OF ELY CAMPGROUND	03MJ	CVOC	VOCS PHASE 2 & 5		MONITORING, ROUTINE MAJOR	1/1/2016	12/31/2016		
Total Number of Violations for this Water System:										1
NV0002028	LAHONTAN DAM STATE PARK	42	0200	SWTR		FAILURE TO FILTER (SWTR)	5/1/1998			
Total Number of Violations for this Water System:										1
NV0000942	LAKER PLAZA INC	S1	1032	MANGANESE		STATE MCL EXCEDENCE	1/1/2016	3/31/2016	0.15 MG/L	

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0000942	LAKER PLAZA INC	S1	1055	SULFATE		STATE MCL EXCEEDENCE	1/1/2016	3/31/2016	1400 MG/L	
NV0000942	LAKER PLAZA INC	S1	1055	SULFATE		STATE MCL EXCEEDENCE	4/1/2016	6/30/2016	1700 MG/L	
NV0000942	LAKER PLAZA INC	S1	1055	SULFATE		STATE MCL EXCEEDENCE	7/1/2016	9/30/2016	1700 MG/L	
NV0000942	LAKER PLAZA INC	S1	1055	SULFATE		STATE MCL EXCEEDENCE	10/1/2016	12/31/2016	1800 MG/L	
NV0000942	LAKER PLAZA INC	S1	1930	TDS		STATE MCL EXCEEDENCE	1/1/2016	3/31/2016	2400 MG/L	
NV0000942	LAKER PLAZA INC	S1	1930	TDS		STATE MCL EXCEEDENCE	4/1/2016	6/30/2016	2700 MG/L	
NV0000942	LAKER PLAZA INC	S1	1930	TDS		STATE MCL EXCEEDENCE	7/1/2016	9/30/2016	2900 MG/L	
NV0000942	LAKER PLAZA INC	S1	1930	TDS		STATE MCL EXCEEDENCE	10/1/2016	12/31/2016	2700 MG/L	

Total Number of Violations for this Water System: 9

NV0000928	LAMOILLE VALLEY PLAZA	02	1005	ARSENIC	IOC	MCL, AVERAGE	1/1/2016	3/31/2016	0.023 MG/L	
NV0000928	LAMOILLE VALLEY PLAZA	02	1005	ARSENIC	IOC	MCL, AVERAGE	4/1/2016	6/30/2016	0.024 MG/L	
NV0000928	LAMOILLE VALLEY PLAZA	02	1005	ARSENIC	IOC	MCL, AVERAGE	7/1/2016	9/30/2016	0.024 MG/L	
NV0000928	LAMOILLE VALLEY PLAZA	02	1005	ARSENIC	IOC	MCL, AVERAGE	10/1/2016	12/31/2016	0.024 MG/L	
NV0000928	LAMOILLE VALLEY PLAZA	03MJ	CDAS	ARSENIC (AS)		MONITORING, ROUTINE MAJOR	4/1/2016	6/30/2016		10/24/2016

Total Number of Violations for this Water System: 5

NV0000273	LAMOILLE WATER USERS ASSOC	27MJ	CDB2	DBPR STAGE 2		MONITORING, ROUTINE (DBP), MAJOR	1/1/2014	12/31/2016		
NV0000273	LAMOILLE WATER USERS ASSOC	52	5000	LEAD & COPPER RULE		FOLLOW-UP OR ROUTINE TAP M/R (LCR)	10/1/2015	8/23/2016		8/23/2016

Total Number of Violations for this Water System: 2

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0000008	LANDER CO SEWER AND WATER DIST 1 BM	27MJ	CDB2	DBPR STAGE 2		MONITORING, ROUTINE (DBP), MAJOR	8/1/2014	7/31/2015		7/12/2016
Total Number of Violations for this Water System:										1
NV0000006	LANDER CO SEWER AND WATER DIST 2	03MJ	2033	ENDOTHALL		MONITORING, ROUTINE MAJOR	1/1/2016	3/31/2016		4/13/2016
NV0000006	LANDER CO SEWER AND WATER DIST 2	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2015	12/31/2015		3/22/2016
NV0000006	LANDER CO SEWER AND WATER DIST 2	03MJ	CVOC	VOCS PHASE 2 & 5		MONITORING, ROUTINE MAJOR	1/1/2016	3/31/2016		11/10/2016
NV0000006	LANDER CO SEWER AND WATER DIST 2	27MJ	0999	CHLORINE	ST1 DBP	MONITORING, ROUTINE (DBP), MAJOR	7/1/2016	9/30/2016		12/6/2016
Total Number of Violations for this Water System:										4
NV0000307	LAS VEGAS SKI AND SNOWBOARD RESORT	34MJ	3014	E. COLI		MONITOR GWR TRIGGERED/ADDITONAL, MAJOR	11/2/2016			
NV0000307	LAS VEGAS SKI AND SNOWBOARD RESORT	3AMN	3014	E. COLI		MONITORING, ROUTINE, MINOR (RTCR)	10/1/2016	10/31/2016		
Total Number of Violations for this Water System:										2
NV0004005	LDS LEE RECREATION CAMP	S1	1930	TDS		STATE MCL EXCEDENCE	7/1/2016	9/30/2016	1100 MG/L	
Total Number of Violations for this Water System:										1
NV0000865	LIGHTNING W	71	7000	CONSUMER CONFIDENCE RULE		CCR REPORT	7/1/2016			
Total Number of Violations for this Water System:										1
NV0000392	LOVELL CANYON RESIDENTIAL LLC	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2016	12/31/2016		
NV0000392	LOVELL CANYON RESIDENTIAL LLC	03MJ	CNO2	NITRITE	IOC	MONITORING, ROUTINE MAJOR	1/1/2014	12/31/2016		
NV0000392	LOVELL CANYON RESIDENTIAL LLC	3AMJ	3014	E. COLI		MONITORING, ROUTINE, MAJOR (RTCR)	8/1/2016	8/31/2016		9/7/2016
Total Number of Violations for this Water System:										3

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0000861	LOVELOCK CORRECTIONAL	27MJ	CDB2	DBPR STAGE 2		MONITORING, ROUTINE (DBP), MAJOR	1/1/2015	8/31/2015		8/3/2016
NV0000861	LOVELOCK CORRECTIONAL	27MJ	CDB2	DBPR STAGE 2		MONITORING, ROUTINE (DBP), MAJOR	1/1/2016	12/31/2016		
Total Number of Violations for this Water System:										2
NV0000161	LOVELOCK MEADOWS WATER DISTRICT	27MJ	CDB2	DBPR STAGE 2		MONITORING, ROUTINE (DBP), MAJOR	9/1/2014	8/31/2015		8/1/2016
Total Number of Violations for this Water System:										1
NV0000917	LOW LOW LIQUOR CIGARETTES AND	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2016	12/31/2016		4/12/2017
NV0000917	LOW LOW LIQUOR CIGARETTES AND	03MJ	CNO2	NITRITE	IOC	MONITORING, ROUTINE MAJOR	1/1/2014	12/31/2016		4/12/2017
NV0000917	LOW LOW LIQUOR CIGARETTES AND	22	3100	COLIFORM (TCR)		MCL (TCR), MONTHLY	12/1/2015	12/31/2015		1/13/2016
Total Number of Violations for this Water System:										3
NV0001130	M RESORT SPA AND CASINO	27MJ	0999	CHLORINE	ST1 DBP	MONITORING, ROUTINE (DBP), MAJOR	10/1/2016	12/31/2016		
NV0001130	M RESORT SPA AND CASINO	3AMN	3014	E. COLI		MONITORING, ROUTINE, MINOR (RTRC)	11/1/2016	11/30/2016		12/19/2016
Total Number of Violations for this Water System:										2
NV0000165	MANHATTAN TOWN WATER	03MJ	CDAS	ARSENIC (AS)		MONITORING, ROUTINE MAJOR	1/1/2014	12/31/2016		5/18/2017
NV0000165	MANHATTAN TOWN WATER	03MJ	1010	BARIUM		MONITORING, ROUTINE MAJOR	1/1/2014	12/31/2016		5/18/2017
NV0000165	MANHATTAN TOWN WATER	03MJ	1015	CADMIUM	IOC	MONITORING, ROUTINE MAJOR	1/1/2014	12/31/2016		5/18/2017
NV0000165	MANHATTAN TOWN WATER	03MJ	1020	CHROMIUM		MONITORING, ROUTINE MAJOR	1/1/2014	12/31/2016		5/18/2017
NV0000165	MANHATTAN TOWN WATER	03MJ	CIOF	IOC FLUORIDE		MONITORING, ROUTINE MAJOR	1/1/2014	12/31/2016		5/18/2017
NV0000165	MANHATTAN TOWN WATER	03MJ	CIO5	IOCS PHASE 5		MONITORING, ROUTINE MAJOR	1/1/2014	12/31/2016		5/18/2017

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0000165	MANHATTAN TOWN WATER	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2016	12/31/2016		5/18/2017
NV0000165	MANHATTAN TOWN WATER	03MJ	CNO2	NITRITE	IOC	MONITORING, ROUTINE MAJOR	1/1/2014	12/31/2016		5/18/2017
NV0000165	MANHATTAN TOWN WATER	03MJ	1045	SELENIUM		MONITORING, ROUTINE MAJOR	1/1/2014	12/31/2016		5/18/2017
NV0000165	MANHATTAN TOWN WATER	93	1055	SULFATE		STATE FAILURE TO MONITOR	1/1/2014	12/31/2016		5/18/2017
Total Number of Violations for this Water System:										10
NV0001103	MARIGOLD MINE POTABLE WATER	53	5000	LEAD & COPPER RULE		WATER QUALITY PARAMETER M/R (LCR)	1/1/2016	6/30/2016		
NV0001103	MARIGOLD MINE POTABLE WATER	53	5000	LEAD & COPPER RULE		WATER QUALITY PARAMETER M/R (LCR)	1/1/2016	6/30/2016		
NV0001103	MARIGOLD MINE POTABLE WATER	53	5000	LEAD & COPPER RULE		WATER QUALITY PARAMETER M/R (LCR)	7/1/2016	12/31/2016		
Total Number of Violations for this Water System:										3
NV0000162	MCDERMITT WATER SYSTEM	02	1005	ARSENIC	IOC	MCL, AVERAGE	10/1/2016	12/31/2016	0.012 MG/L	
NV0000162	MCDERMITT WATER SYSTEM	03MJ	CSO8	SOCS PH5 DIOXIN		MONITORING, ROUTINE MAJOR	10/1/2015	12/31/2015		4/19/2016
Total Number of Violations for this Water System:										2
NV0002508	MCWILLIAMS WATER SYSTEM	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2015	12/31/2015		7/22/2016
NV0002508	MCWILLIAMS WATER SYSTEM	03MJ	CNO2	NITRITE	IOC	MONITORING, ROUTINE MAJOR	1/1/2014	12/31/2016		
Total Number of Violations for this Water System:										2
NV0000757	MELS DINER	3AMJ	3014	E. COLI		MONITORING, ROUTINE, MAJOR (RTCR)	4/1/2016	4/30/2016		5/26/2016
Total Number of Violations for this Water System:										1
NV0000074	MINA LUNING WATER SYSTEM	27MJ	0999	CHLORINE	ST1 DBP	MONITORING, ROUTINE (DBP), MAJOR	7/1/2015	9/30/2015		9/30/2016

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
Total Number of Violations for this Water System:										1
NV0001151	MINERAL RIDGE MINE	S1	1028	IRON		STATE MCL EXCEDENCE	1/1/2016	3/31/2016	2.1 MG/L	
NV0001151	MINERAL RIDGE MINE	S1	1028	IRON		STATE MCL EXCEDENCE	4/1/2016	6/30/2016	4.5 MG/L	
NV0001151	MINERAL RIDGE MINE	S1	1028	IRON		STATE MCL EXCEDENCE	7/1/2016	9/30/2016	2.1 MG/L	
NV0001151	MINERAL RIDGE MINE	S1	1028	IRON		STATE MCL EXCEDENCE	10/1/2016	12/31/2016	8 MG/L	
NV0001151	MINERAL RIDGE MINE	S1	1032	MANGANESE		STATE MCL EXCEDENCE	1/1/2016	3/31/2016	0.28 MG/L	
NV0001151	MINERAL RIDGE MINE	S1	1055	SULFATE		STATE MCL EXCEDENCE	1/1/2016	3/31/2016	740 MG/L	
NV0001151	MINERAL RIDGE MINE	S1	1055	SULFATE		STATE MCL EXCEDENCE	4/1/2016	6/30/2016	710 MG/L	
NV0001151	MINERAL RIDGE MINE	S1	1055	SULFATE		STATE MCL EXCEDENCE	7/1/2016	9/30/2016	640 MG/L	
NV0001151	MINERAL RIDGE MINE	S1	1055	SULFATE		STATE MCL EXCEDENCE	10/1/2016	12/31/2016	650 MG/L	
NV0001151	MINERAL RIDGE MINE	S1	1930	TDS		STATE MCL EXCEDENCE	1/1/2016	3/31/2016	1300 MG/L	
NV0001151	MINERAL RIDGE MINE	S1	1930	TDS		STATE MCL EXCEDENCE	4/1/2016	6/30/2016	1300 MG/L	
NV0001151	MINERAL RIDGE MINE	S1	1930	TDS		STATE MCL EXCEDENCE	7/1/2016	9/30/2016	1400 MG/L	
NV0001151	MINERAL RIDGE MINE	S1	1930	TDS		STATE MCL EXCEDENCE	10/1/2016	12/31/2016	1300 MG/L	
Total Number of Violations for this Water System:										13
NV0000160	MOAPA VALLEY WATER DISTRICT	03MJ	CDAS	ARSENIC (AS)		MONITORING, ROUTINE MAJOR	1/1/2016	3/31/2016		4/28/2016
NV0000160	MOAPA VALLEY WATER DISTRICT	27MJ	CTT2	DBPR STAGE 2 TTHM		MONITORING, ROUTINE (DBP), MAJOR	3/1/2015	2/28/2016		
Total Number of Violations for this Water System:										2

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0000169	MONTELLO WATER SYSTEM	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2015	12/31/2015		5/17/2016
Total Number of Violations for this Water System:										1
NV0002142	MOOSE LODGE 808	3AMJ	3014	E. COLI		MONITORING, ROUTINE, MAJOR (RTCR)	4/1/2016	6/30/2016		8/24/2016
Total Number of Violations for this Water System:										1
NV0000732	MOUNT ROSE BOWL PROPERTY OWNERS	27MJ	CDB2	DBPR STAGE 2		MONITORING, ROUTINE (DBP), MAJOR	1/1/2016	12/31/2016		
NV0000732	MOUNT ROSE BOWL PROPERTY OWNERS	53	5000	LEAD & COPPER RULE		WATER QUALITY PARAMETER M/R (LCR)	1/1/2015	6/30/2015		5/25/2016
NV0000732	MOUNT ROSE BOWL PROPERTY OWNERS	53	5000	LEAD & COPPER RULE		WATER QUALITY PARAMETER M/R (LCR)	1/1/2015	6/30/2015		5/25/2016
NV0000732	MOUNT ROSE BOWL PROPERTY OWNERS	57	5000	LEAD & COPPER RULE		OCCT/SOWT RECOMMENDATION/STUDY	7/22/2016			
NV0000732	MOUNT ROSE BOWL PROPERTY OWNERS	58	5000	LEAD & COPPER RULE		OCCT/SOWT INSTALL DEMONSTRATION (LCR)	7/22/2016			
Total Number of Violations for this Water System:										5
NV0001082	MOUNTAIN SPRINGS BAR INC	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2016	12/31/2016		
NV0001082	MOUNTAIN SPRINGS BAR INC	03MJ	CNO2	NITRITE	IOC	MONITORING, ROUTINE MAJOR	1/1/2014	12/31/2016		
NV0001082	MOUNTAIN SPRINGS BAR INC	23MJ	3100	COLIFORM (TCR)		MONITORING (TCR), ROUTINE MAJOR	10/1/2015	12/31/2015		2/12/2016
Total Number of Violations for this Water System:										3
NV0000743	MT ROSE CAMPGROUND USFS	3AMJ	3014	E. COLI		MONITORING, ROUTINE, MAJOR (RTCR)	8/1/2016	8/31/2016		9/9/2016
NV0000743	MT ROSE CAMPGROUND USFS	93	CSC2	SECONDARY IOCS		STATE FAILURE TO MONITOR	1/1/2014	12/31/2016		
Total Number of Violations for this Water System:										2

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0000876	NARCONON NEVADA RAINBOW CANYON	03MJ	CNO2	NITRITE	IOC	MONITORING, ROUTINE MAJOR	1/1/2014	12/31/2016		
Total Number of Violations for this Water System:										1
NV0000869	NATCHEZ GYM	27MJ	0999	CHLORINE	ST1 DBP	MONITORING, ROUTINE (DBP), MAJOR	4/1/2016	6/30/2016		
NV0000869	NATCHEZ GYM	3AMJ	3014	E. COLI		MONITORING, ROUTINE, MAJOR (RTCR)	5/1/2016	5/31/2016		6/3/2016
Total Number of Violations for this Water System:										2
NV0000774	NATCHEZ SCHOOL	3AMJ	3014	E. COLI		MONITORING, ROUTINE, MAJOR (RTCR)	5/1/2016	5/31/2016		6/3/2016
Total Number of Violations for this Water System:										1
NV0002214	NDOT BEOWAWE ROADSIDE PARK RP802	3AMJ	3014	E. COLI		MONITORING, ROUTINE, MAJOR (RTCR)	4/1/2016	4/30/2016		5/10/2016
NV0002214	NDOT BEOWAWE ROADSIDE PARK RP802	3AMJ	3014	E. COLI		MONITORING, ROUTINE, MAJOR (RTCR)	7/1/2016	7/31/2016		8/16/2016
Total Number of Violations for this Water System:										2
NV0001101	NDOT SEARCHLIGHT WELCOME CENTER	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2016	12/31/2016		
NV0001101	NDOT SEARCHLIGHT WELCOME CENTER	03MJ	CNO2	NITRITE	IOC	MONITORING, ROUTINE MAJOR	1/1/2014	12/31/2016		
Total Number of Violations for this Water System:										2
NV0002102	NDOT VALMY ROADSIDE PARK	S1	1028	IRON		STATE MCL EXCEDENCE	7/1/2016	9/30/2016	0.68 MG/L	
Total Number of Violations for this Water System:										1
NV0004022	NDOT WADSWORTH REST STOP	34MJ	3014	E. COLI		MONITOR GWR TRIGGERED/ADDITIONAL, MAJOR	9/5/2015			
NV0004022	NDOT WADSWORTH REST STOP	3AMJ	3014	E. COLI		MONITORING, ROUTINE, MAJOR (RTCR)	7/1/2016	7/31/2016		8/10/2016
Total Number of Violations for this Water System:										2

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0002014	NEVADA LIVESTOCK MARKETING	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2016	12/31/2016		3/6/2017
NV0002014	NEVADA LIVESTOCK MARKETING	03MJ	CNO2	NITRITE	IOC	MONITORING, ROUTINE MAJOR	1/1/2014	12/31/2016		
NV0002014	NEVADA LIVESTOCK MARKETING	3BMJ	3014	E. COLI		MONITORING, ADD. ROUTINE, MAJOR (RTCR)	7/1/2016	7/31/2016		8/19/2016
NV0002014	NEVADA LIVESTOCK MARKETING	93	CSC2	SECONDARY IOCS		STATE FAILURE TO MONITOR	1/1/2014	12/31/2016		
Total Number of Violations for this Water System:										4
NV0000903	NEW MILLENNIUM BUILDING SYSTEMS,	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2016	12/31/2016		4/4/2017
NV0000903	NEW MILLENNIUM BUILDING SYSTEMS,	03MJ	CNO2	NITRITE	IOC	MONITORING, ROUTINE MAJOR	1/1/2014	12/31/2016		4/4/2017
Total Number of Violations for this Water System:										2
NV0000870	NORTH VALLEY BUS FACILITY	3AMJ	3014	E. COLI		MONITORING, ROUTINE, MAJOR (RTCR)	5/1/2016	5/31/2016		6/3/2016
Total Number of Violations for this Water System:										1
NV0004067	NORTHWEST ACADEMY	27MJ	0999	CHLORINE	ST1 DBP	MONITORING, ROUTINE (DBP), MAJOR	10/1/2016	12/31/2016		
Total Number of Violations for this Water System:										1
NV0003005	NPS BOULDER BEACH	35	2950	TTHM		FAILURE SUBMIT OEL REPORT FOR TTHM	1/8/2016	5/23/2016		5/23/2016
Total Number of Violations for this Water System:										1
NV0002503	NPS ECHO BAY	52	5000	LEAD & COPPER RULE		FOLLOW-UP OR ROUTINE TAP M/R (LCR)	10/1/2016			
Total Number of Violations for this Water System:										1
NV0000921	OASIS SPRINGS	S1	1032	MANGANESE		STATE MCL EXCEDENCE	1/1/2016	3/31/2016	0.18 MG/L	
NV0000921	OASIS SPRINGS	S1	1032	MANGANESE		STATE MCL EXCEDENCE	4/1/2016	6/30/2016	0.4 MG/L	

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
-----------------	-------------------	----------	--------------	--------------	------------	-----------------	------------------------------	----------------------------	------------	----------

Total Number of Violations for this Water System: 2

NV0000797	OLD FORTY WEST MOTEL	02	1005	ARSENIC	IOC	MCL, AVERAGE	10/1/2016	12/31/2016	0.075 MG/L	
NV0000797	OLD FORTY WEST MOTEL	03MJ	CRAU	RADIONUCLIDES		MONITORING, ROUTINE MAJOR	1/1/2016	12/31/2016		12/20/2016
NV0000797	OLD FORTY WEST MOTEL	03MJ	CRAU	RADIONUCLIDES		MONITORING, ROUTINE MAJOR	1/1/2016	12/31/2016		12/20/2016
NV0000797	OLD FORTY WEST MOTEL	03MJ	CSO8	SOCS PH5 DIOXIN		MONITORING, ROUTINE MAJOR	1/1/2016	3/31/2016		12/20/2016
NV0000797	OLD FORTY WEST MOTEL	03MJ	CSO8	SOCS PH5 DIOXIN		MONITORING, ROUTINE MAJOR	1/1/2016	3/31/2016		12/20/2016
NV0000797	OLD FORTY WEST MOTEL	03MJ	CSOC	SOCS PHASE 2 & 5		MONITORING, ROUTINE MAJOR	1/1/2016	12/31/2016		12/20/2016
NV0000797	OLD FORTY WEST MOTEL	03MJ	CSOC	SOCS PHASE 2 & 5		MONITORING, ROUTINE MAJOR	1/1/2016	12/31/2016		12/20/2016
NV0000797	OLD FORTY WEST MOTEL	03MJ	CVOC	VOCS PHASE 2 & 5		MONITORING, ROUTINE MAJOR	7/1/2016	9/30/2016		12/20/2016
NV0000797	OLD FORTY WEST MOTEL	03MJ	CVOC	VOCS PHASE 2 & 5		MONITORING, ROUTINE MAJOR	7/1/2016	9/30/2016		12/20/2016
NV0000797	OLD FORTY WEST MOTEL	3AMJ	3014	E. COLI		MONITORING, ROUTINE, MAJOR (RTCR)	4/1/2016	4/30/2016		
NV0000797	OLD FORTY WEST MOTEL	3AMJ	3014	E. COLI		MONITORING, ROUTINE, MAJOR (RTCR)	5/1/2016	5/31/2016		
NV0000797	OLD FORTY WEST MOTEL	3AMJ	3014	E. COLI		MONITORING, ROUTINE, MAJOR (RTCR)	6/1/2016	6/30/2016		

Total Number of Violations for this Water System: 12

NV0000303	OLD RIVER WATER COMPANY	02	1005	ARSENIC	IOC	MCL, AVERAGE	1/1/2009	3/31/2009	0.026 MG/L	5/27/2016
NV0000303	OLD RIVER WATER COMPANY	02	1005	ARSENIC	IOC	MCL, AVERAGE	4/1/2009	6/30/2009	0.027 MG/L	5/27/2016
NV0000303	OLD RIVER WATER COMPANY	02	1005	ARSENIC	IOC	MCL, AVERAGE	7/1/2009	9/30/2009	0.027 MG/L	5/27/2016

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0000303	OLD RIVER WATER COMPANY	02	1005	ARSENIC	IOC	MCL, AVERAGE	10/1/2009	12/31/2009	0.026 MG/L	5/27/2016
NV0000303	OLD RIVER WATER COMPANY	02	1005	ARSENIC	IOC	MCL, AVERAGE	1/1/2010	3/31/2010	0.025 MG/L	5/27/2016
NV0000303	OLD RIVER WATER COMPANY	02	1005	ARSENIC	IOC	MCL, AVERAGE	4/1/2010	6/30/2010	0.025 MG/L	5/27/2016
NV0000303	OLD RIVER WATER COMPANY	02	1005	ARSENIC	IOC	MCL, AVERAGE	7/1/2010	9/30/2010	0.025 MG/L	5/27/2016
NV0000303	OLD RIVER WATER COMPANY	02	1005	ARSENIC	IOC	MCL, AVERAGE	10/1/2010	12/31/2010	0.026 MG/L	5/27/2016
NV0000303	OLD RIVER WATER COMPANY	02	1005	ARSENIC	IOC	MCL, AVERAGE	1/1/2011	3/31/2011	0.026 MG/L	5/27/2016
NV0000303	OLD RIVER WATER COMPANY	02	1005	ARSENIC	IOC	MCL, AVERAGE	4/1/2011	6/30/2011	0.027 MG/L	5/27/2016
NV0000303	OLD RIVER WATER COMPANY	02	1005	ARSENIC	IOC	MCL, AVERAGE	7/1/2011	9/30/2011	0.026 MG/L	5/27/2016
NV0000303	OLD RIVER WATER COMPANY	02	1005	ARSENIC	IOC	MCL, AVERAGE	10/1/2011	12/31/2011	0.027 MG/L	5/27/2016
NV0000303	OLD RIVER WATER COMPANY	02	1005	ARSENIC	IOC	MCL, AVERAGE	1/1/2012	3/31/2012	0.027 MG/L	5/27/2016
NV0000303	OLD RIVER WATER COMPANY	02	1005	ARSENIC	IOC	MCL, AVERAGE	4/1/2012	6/30/2012	0.028 MG/L	5/27/2016
NV0000303	OLD RIVER WATER COMPANY	02	1005	ARSENIC	IOC	MCL, AVERAGE	7/1/2012	9/30/2012	0.028 MG/L	5/27/2016
NV0000303	OLD RIVER WATER COMPANY	02	1005	ARSENIC	IOC	MCL, AVERAGE	10/1/2012	12/31/2012	0.028 MG/L	5/27/2016
NV0000303	OLD RIVER WATER COMPANY	02	1005	ARSENIC	IOC	MCL, AVERAGE	1/1/2013	3/31/2013	0.029 MG/L	5/27/2016
NV0000303	OLD RIVER WATER COMPANY	02	1005	ARSENIC	IOC	MCL, AVERAGE	4/1/2013	6/30/2013	0.029 MG/L	5/27/2016
NV0000303	OLD RIVER WATER COMPANY	02	1005	ARSENIC	IOC	MCL, AVERAGE	7/1/2013	9/30/2013	0.029 MG/L	5/27/2016
NV0000303	OLD RIVER WATER COMPANY	02	1005	ARSENIC	IOC	MCL, AVERAGE	10/1/2013	12/31/2013	0.030 MG/L	5/27/2016

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0000303	OLD RIVER WATER COMPANY	02	1005	ARSENIC	IOC	MCL, AVERAGE	1/1/2014	3/31/2014	0.030 MG/L	5/27/2016
NV0000303	OLD RIVER WATER COMPANY	02	1005	ARSENIC	IOC	MCL, AVERAGE	4/1/2014	6/30/2014	0.027 MG/L	5/27/2016
NV0000303	OLD RIVER WATER COMPANY	02	1005	ARSENIC	IOC	MCL, AVERAGE	7/1/2014	9/30/2014	0.031 MG/L	5/27/2016
NV0000303	OLD RIVER WATER COMPANY	02	1005	ARSENIC	IOC	MCL, AVERAGE	10/1/2014	12/31/2014	0.030 MG/L	5/27/2016
NV0000303	OLD RIVER WATER COMPANY	02	1005	ARSENIC	IOC	MCL, AVERAGE	1/1/2015	3/31/2015	0.031 MG/L	5/27/2016
NV0000303	OLD RIVER WATER COMPANY	02	1005	ARSENIC	IOC	MCL, AVERAGE	4/1/2015	6/30/2015	0.034 MG/L	5/27/2016
NV0000303	OLD RIVER WATER COMPANY	02	1005	ARSENIC	IOC	MCL, AVERAGE	7/1/2015	9/30/2015	0.030 MG/L	5/27/2016
NV0000303	OLD RIVER WATER COMPANY	02	1005	ARSENIC	IOC	MCL, AVERAGE	10/1/2015	12/31/2015	0.034 MG/L	5/27/2016
NV0000303	OLD RIVER WATER COMPANY	02	1005	ARSENIC	IOC	MCL, AVERAGE	1/1/2016	3/31/2016	0.035 MG/L	5/27/2016

Total Number of Violations for this Water System: 29

NV0002526	OLD WASHOE ESTATES	71	7000	CONSUMER CONFIDENCE RULE		CCR REPORT	7/1/2016			
-----------	--------------------	----	------	--------------------------	--	------------	----------	--	--	--

Total Number of Violations for this Water System: 1

NV0001105	ORCHARD VALLEY MARKET	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2016	12/31/2016		
NV0001105	ORCHARD VALLEY MARKET	93	CSC2	SECONDARY IOCS		STATE FAILURE TO MONITOR	1/1/2014	12/31/2016		

Total Number of Violations for this Water System: 2

NV0003032	OROVADA WATER DISTRICT	71	7000	CONSUMER CONFIDENCE RULE		CCR REPORT	7/1/2015			
-----------	------------------------	----	------	--------------------------	--	------------	----------	--	--	--

Total Number of Violations for this Water System: 1

NV0004018	PAHRUMP FIRE STATION BLM	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2015	12/31/2015		6/28/2016
-----------	--------------------------	------	------	---------	-----	---------------------------	----------	------------	--	-----------

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
Total Number of Violations for this Water System:										1
NV0005034	PAHRUMP RV PARK	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2016	12/31/2016		
NV0005034	PAHRUMP RV PARK	03MJ	CNO2	NITRITE	IOC	MONITORING, ROUTINE MAJOR	1/1/2014	12/31/2016		
Total Number of Violations for this Water System:										2
NV0003036	PAHRUMP SENIOR CENTER INC	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2015	12/31/2015		8/12/2016
Total Number of Violations for this Water System:										1
NV0000819	PALM GARDENS WATER CO OP	27MJ	0999	CHLORINE	ST1 DBP	MONITORING, ROUTINE (DBP), MAJOR	1/1/2016	3/31/2016		8/30/2016
NV0000819	PALM GARDENS WATER CO OP	27MJ	0999	CHLORINE	ST1 DBP	MONITORING, ROUTINE (DBP), MAJOR	1/1/2016	3/31/2016		8/30/2016
NV0000819	PALM GARDENS WATER CO OP	27MJ	0999	CHLORINE	ST1 DBP	MONITORING, ROUTINE (DBP), MAJOR	1/1/2016	3/31/2016		8/30/2016
Total Number of Violations for this Water System:										3
NV0002186	PARADISE VALLEY ELEMENTARY	03MJ	CDAS	ARSENIC (AS)		MONITORING, ROUTINE MAJOR	1/1/2014	12/31/2016		
NV0002186	PARADISE VALLEY ELEMENTARY	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2015	12/31/2015		5/24/2016
NV0002186	PARADISE VALLEY ELEMENTARY	03MJ	CNO2	NITRITE	IOC	MONITORING, ROUTINE MAJOR	1/1/2014	12/31/2016		
NV0002186	PARADISE VALLEY ELEMENTARY	03MJ	CVOC	VOCS PHASE 2 & 5		MONITORING, ROUTINE MAJOR	1/1/2014	12/31/2016		
NV0002186	PARADISE VALLEY ELEMENTARY	52	5000	LEAD & COPPER RULE		FOLLOW-UP OR ROUTINE TAP M/R (LCR)	10/1/2016			
NV0002186	PARADISE VALLEY ELEMENTARY	93	CSEF	SEC IOC FLUORIDE		STATE FAILURE TO MONITOR	1/1/2014	12/31/2016		
NV0002186	PARADISE VALLEY ELEMENTARY	93	CSC2	SECONDARY IOCS		STATE FAILURE TO MONITOR	1/1/2014	12/31/2016		
Total Number of Violations for this Water System:										7

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0002106	PARADISE VALLEY PARK	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2015	12/31/2015		7/16/2016
NV0002106	PARADISE VALLEY PARK	3AMJ	3014	E. COLI		MONITORING, ROUTINE, MAJOR (RTCR)	9/1/2016	9/30/2016		
NV0002106	PARADISE VALLEY PARK	3AMJ	3014	E. COLI		MONITORING, ROUTINE, MAJOR (RTCR)	10/1/2016	10/31/2016		
Total Number of Violations for this Water System:										3
NV0002064	PETES TRAILER COURT	3AMJ	3014	E. COLI		MONITORING, ROUTINE, MAJOR (RTCR)	10/1/2016	12/31/2016		2/6/2017
Total Number of Violations for this Water System:										1
NV0004063	PICK AND SHOVEL INVESTMENTS	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2016	12/31/2016		
NV0004063	PICK AND SHOVEL INVESTMENTS	3AMJ	3014	E. COLI		MONITORING, ROUTINE, MAJOR (RTCR)	7/1/2016	9/30/2016		11/29/2016
Total Number of Violations for this Water System:										2
NV0000067	PINION PINES MHP	24MN	3100	COLIFORM (TCR)		MONITORING (TCR), ROUTINE MINOR	12/1/2015	12/31/2015		1/25/2016
Total Number of Violations for this Water System:										1
NV0000186	PIOCHE PUBLIC UTILITIES	03MJ	CDAS	ARSENIC (AS)		MONITORING, ROUTINE MAJOR	1/1/2014	12/31/2016		
NV0000186	PIOCHE PUBLIC UTILITIES	3AMN	3014	E. COLI		MONITORING, ROUTINE, MINOR (RTCR)	6/1/2016	6/30/2016		7/6/2016
Total Number of Violations for this Water System:										2
NV0001012	PIONEER SALOON	3AMJ	3014	E. COLI		MONITORING, ROUTINE, MAJOR (RTCR)	8/1/2016	8/31/2016		
Total Number of Violations for this Water System:										1
NV0000750	PLEASANT VALLEY SCHOOL	3AMJ	3014	E. COLI		MONITORING, ROUTINE, MAJOR (RTCR)	5/1/2016	5/31/2016		6/3/2016
Total Number of Violations for this Water System:										1

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0002571	RANCHO VISTA 4	52	5000	LEAD & COPPER RULE		FOLLOW-UP OR ROUTINE TAP M/R (LCR)	10/1/2016			
Total Number of Violations for this Water System:										1
NV0000898	RAPPORT EXECUTIVE RETREAT	S1	1032	MANGANESE		STATE MCL EXCEDENCE	7/1/2014	9/30/2014	1.1 MG/L	7/12/2016
Total Number of Violations for this Water System:										1
NV0000754	RIVER BEND MHP	93	1028	IRON		STATE FAILURE TO MONITOR	1/1/2016	12/31/2016		
NV0000754	RIVER BEND MHP	93	1032	MANGANESE		STATE FAILURE TO MONITOR	1/1/2016	12/31/2016		
Total Number of Violations for this Water System:										2
NV0000319	ROARK ESTATES WATER ASSOC	02	1005	ARSENIC	IOC	MCL, AVERAGE	10/1/2011	12/31/2011	0.012 MG/L	12/29/2016
NV0000319	ROARK ESTATES WATER ASSOC	02	1005	ARSENIC	IOC	MCL, AVERAGE	1/1/2012	3/31/2012	0.022 MG/L	12/29/2016
NV0000319	ROARK ESTATES WATER ASSOC	02	1005	ARSENIC	IOC	MCL, AVERAGE	4/1/2012	6/30/2012	0.027 MG/L	12/29/2016
NV0000319	ROARK ESTATES WATER ASSOC	02	1005	ARSENIC	IOC	MCL, AVERAGE	7/1/2012	9/30/2012	0.030 MG/L	12/29/2016
NV0000319	ROARK ESTATES WATER ASSOC	02	1005	ARSENIC	IOC	MCL, AVERAGE	10/1/2012	12/31/2012	0.026 MG/L	12/29/2016
NV0000319	ROARK ESTATES WATER ASSOC	02	1005	ARSENIC	IOC	MCL, AVERAGE	1/1/2013	3/31/2013	0.020 MG/L	12/29/2016
NV0000319	ROARK ESTATES WATER ASSOC	02	1005	ARSENIC	IOC	MCL, AVERAGE	4/1/2013	6/30/2013	0.020 MG/L	12/29/2016
NV0000319	ROARK ESTATES WATER ASSOC	02	1005	ARSENIC	IOC	MCL, AVERAGE	7/1/2013	9/30/2013	0.021 MG/L	12/29/2016
NV0000319	ROARK ESTATES WATER ASSOC	02	1005	ARSENIC	IOC	MCL, AVERAGE	10/1/2013	12/31/2013	0.021 MG/L	12/29/2016
NV0000319	ROARK ESTATES WATER ASSOC	02	1005	ARSENIC	IOC	MCL, AVERAGE	1/1/2014	3/31/2014	21 UG/L	12/29/2016

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0000319	ROARK ESTATES WATER ASSOC	02	1005	ARSENIC	IOC	MCL, AVERAGE	4/1/2014	6/30/2014	0.025 MG/L	12/29/2016
NV0000319	ROARK ESTATES WATER ASSOC	02	1005	ARSENIC	IOC	MCL, AVERAGE	7/1/2014	9/30/2014	0.024 MG/L	12/29/2016
NV0000319	ROARK ESTATES WATER ASSOC	02	1005	ARSENIC	IOC	MCL, AVERAGE	10/1/2014	12/31/2014	0.025 MG/L	12/29/2016
NV0000319	ROARK ESTATES WATER ASSOC	02	1005	ARSENIC	IOC	MCL, AVERAGE	1/1/2015	3/31/2015	0.024 MG/L	12/29/2016
NV0000319	ROARK ESTATES WATER ASSOC	02	1005	ARSENIC	IOC	MCL, AVERAGE	4/1/2015	6/30/2015	0.0204 MG/L	12/29/2016
NV0000319	ROARK ESTATES WATER ASSOC	02	1005	ARSENIC	IOC	MCL, AVERAGE	7/1/2015	9/30/2015	0.0205 MG/L	12/29/2016
NV0000319	ROARK ESTATES WATER ASSOC	02	1005	ARSENIC	IOC	MCL, AVERAGE	10/1/2015	12/31/2015	0.023 MG/L	12/29/2016
NV0000319	ROARK ESTATES WATER ASSOC	02	1005	ARSENIC	IOC	MCL, AVERAGE	1/1/2016	3/31/2016	0.026 MG/L	12/29/2016
NV0000319	ROARK ESTATES WATER ASSOC	02	1005	ARSENIC	IOC	MCL, AVERAGE	4/1/2016	6/30/2016	0.02725 MG/L	12/29/2016
NV0000319	ROARK ESTATES WATER ASSOC	02	1005	ARSENIC	IOC	MCL, AVERAGE	7/1/2016	9/30/2016	0.027 MG/L	12/29/2016
NV0000319	ROARK ESTATES WATER ASSOC	02	1005	ARSENIC	IOC	MCL, AVERAGE	10/1/2016	12/31/2016	0.027 MG/L	12/29/2016
NV0000319	ROARK ESTATES WATER ASSOC	03MJ	CDAS	ARSENIC (AS)		MONITORING, ROUTINE MAJOR	1/1/2016	12/31/2016		

Total Number of Violations for this Water System: 22

NV0000858	ROGELIO M GARCIA	03MJ	CNO2	NITRITE	IOC	MONITORING, ROUTINE MAJOR	1/1/2014	12/31/2016		4/14/2017
NV0000858	ROGELIO M GARCIA	93	CSC2	SECONDARY IOCS		STATE FAILURE TO MONITOR	1/1/2014	12/31/2016		3/31/2017

Total Number of Violations for this Water System: 2

NV0000767	ROSEMOUNT WATER CO	02	4006	COMBINED URANIUM	IOC	MCL, AVERAGE	1/1/2016	3/31/2016	70 UG/L	4/19/2017
-----------	--------------------	----	------	------------------	-----	--------------	----------	-----------	---------	-----------

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0000767	ROSEMOUNT WATER CO	02	4006	COMBINED URANIUM	IOC	MCL, AVERAGE	4/1/2016	6/30/2016	71 UG/L	4/19/2017
NV0000767	ROSEMOUNT WATER CO	02	4006	COMBINED URANIUM	IOC	MCL, AVERAGE	7/1/2016	9/30/2016	72 UG/L	4/19/2017
NV0000767	ROSEMOUNT WATER CO	02	4006	COMBINED URANIUM	IOC	MCL, AVERAGE	10/1/2016	12/31/2016	0.073 MG/L	4/19/2017
NV0000767	ROSEMOUNT WATER CO	03MJ	CRUR	RADS URANIUM		MONITORING, ROUTINE MAJOR	1/1/2016	12/31/2016		
NV0000767	ROSEMOUNT WATER CO	03MJ	CRUR	RADS URANIUM		MONITORING, ROUTINE MAJOR	1/1/2016	12/31/2016		
NV0000767	ROSEMOUNT WATER CO	03MJ	CRUR	RADS URANIUM		MONITORING, ROUTINE MAJOR	1/1/2016	12/31/2016		
NV0000767	ROSEMOUNT WATER CO	27MJ	0999	CHLORINE	ST1 DBP	MONITORING, ROUTINE (DBP), MAJOR	4/1/2016	6/30/2016		
NV0000767	ROSEMOUNT WATER CO	27MJ	CDB2	DBPR STAGE 2		MONITORING, ROUTINE (DBP), MAJOR	7/1/2015	6/30/2016		
NV0000767	ROSEMOUNT WATER CO	75	7500	PUBLIC NOTICE		PUBLIC NOTICE RULE LINKED TO VIOLATION	10/1/2015			
NV0000767	ROSEMOUNT WATER CO	75	7500	PUBLIC NOTICE		PUBLIC NOTICE RULE LINKED TO VIOLATION	4/1/2015			
NV0000767	ROSEMOUNT WATER CO	75	7500	PUBLIC NOTICE		PUBLIC NOTICE RULE LINKED TO VIOLATION	7/1/2015			
NV0000767	ROSEMOUNT WATER CO	75	7500	PUBLIC NOTICE		PUBLIC NOTICE RULE LINKED TO VIOLATION	1/1/2015			

Total Number of Violations for this Water System: 13

NV0000951	ROSIES PLACE	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2015	12/31/2015		5/17/2016
NV0000951	ROSIES PLACE	22	3100	COLIFORM (TCR)		MCL (TCR), MONTHLY	9/1/2015	9/30/2015		1/19/2016

Total Number of Violations for this Water System: 2

NV0004074	ROUND MOUNTAIN PUC	27MJ	CDB2	DBPR STAGE 2		MONITORING, ROUTINE (DBP), MAJOR	1/1/2016	12/31/2016		
-----------	--------------------	------	------	--------------	--	----------------------------------	----------	------------	--	--

Total Number of Violations for this Water System: 1

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0000885	RUBY HILL MINE	01	1040	NITRATE	IOC	MCL, SINGLE SAMPLE	7/1/2016	9/30/2016	18 MG/L	3/7/2017
NV0000885	RUBY HILL MINE	22	3100	COLIFORM (TCR)		MCL (TCR), MONTHLY	1/1/2016	1/31/2016		2/22/2016
Total Number of Violations for this Water System:										2
NV0002222	RYE PATCH TRAVEL CENTER INC	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2016	12/31/2016		4/21/2017
NV0002222	RYE PATCH TRAVEL CENTER INC	23MJ	3100	COLIFORM (TCR)		MONITORING (TCR), ROUTINE MAJOR	3/1/2016	3/31/2016		4/29/2016
NV0002222	RYE PATCH TRAVEL CENTER INC	2C	8000	REVISED TOTAL COLIFORM RULE (RTCR)		CORRECTIVE/EXPEDITED ACTIONS (RTCR)	8/23/2016			
NV0002222	RYE PATCH TRAVEL CENTER INC	3AMJ	3014	E. COLI		MONITORING, ROUTINE, MAJOR (RTCR)	5/1/2016	5/31/2016		6/7/2016
NV0002222	RYE PATCH TRAVEL CENTER INC	3AMJ	3014	E. COLI		MONITORING, ROUTINE, MAJOR (RTCR)	10/1/2016	10/31/2016		3/24/2017
NV0002222	RYE PATCH TRAVEL CENTER INC	3AMJ	3014	E. COLI		MONITORING, ROUTINE, MAJOR (RTCR)	11/1/2016	11/30/2016		3/24/2017
Total Number of Violations for this Water System:										6
NV0001092	RYNDON GAS & FOOD LLC	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2016	12/31/2016		3/7/2017
NV0001092	RYNDON GAS & FOOD LLC	03MJ	CNO2	NITRITE	IOC	MONITORING, ROUTINE MAJOR	1/1/2014	12/31/2016		
NV0001092	RYNDON GAS & FOOD LLC	3AMJ	3014	E. COLI		MONITORING, ROUTINE, MAJOR (RTCR)	10/1/2016	12/31/2016		2/28/2017
NV0001092	RYNDON GAS & FOOD LLC	93	CSC2	SECONDARY IOCS		STATE FAILURE TO MONITOR	1/1/2014	12/31/2016		
Total Number of Violations for this Water System:										4
NV0002566	SAGE SCHOOLS	3AMN	3014	E. COLI		MONITORING, ROUTINE, MINOR (RTCR)	10/1/2016	10/31/2016		11/9/2016
Total Number of Violations for this Water System:										1

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0002023	SAGE VALLEY MHP	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2016	12/31/2016		
NV0002023	SAGE VALLEY MHP	03MJ	CNO2	NITRITE	IOC	MONITORING, ROUTINE MAJOR	1/1/2014	12/31/2016		
NV0002023	SAGE VALLEY MHP	03MJ	CVOC	VOCS PHASE 2 & 5		MONITORING, ROUTINE MAJOR	1/1/2014	12/31/2016		
NV0002023	SAGE VALLEY MHP	27MJ	0999	CHLORINE	ST1 DBP	MONITORING, ROUTINE (DBP), MAJOR	7/1/2014	9/30/2014		2/3/2016
NV0002023	SAGE VALLEY MHP	27MJ	0999	CHLORINE	ST1 DBP	MONITORING, ROUTINE (DBP), MAJOR	7/1/2014	9/30/2014		2/3/2016
NV0002023	SAGE VALLEY MHP	27MJ	0999	CHLORINE	ST1 DBP	MONITORING, ROUTINE (DBP), MAJOR	7/1/2014	9/30/2014		2/3/2016
NV0002023	SAGE VALLEY MHP	27MJ	0999	CHLORINE	ST1 DBP	MONITORING, ROUTINE (DBP), MAJOR	10/1/2014	12/31/2014		2/3/2016
NV0002023	SAGE VALLEY MHP	27MJ	0999	CHLORINE	ST1 DBP	MONITORING, ROUTINE (DBP), MAJOR	10/1/2014	12/31/2014		2/3/2016
NV0002023	SAGE VALLEY MHP	27MJ	0999	CHLORINE	ST1 DBP	MONITORING, ROUTINE (DBP), MAJOR	10/1/2014	12/31/2014		2/3/2016
NV0002023	SAGE VALLEY MHP	27MJ	0999	CHLORINE	ST1 DBP	MONITORING, ROUTINE (DBP), MAJOR	1/1/2015	3/31/2015		2/3/2016
NV0002023	SAGE VALLEY MHP	27MJ	0999	CHLORINE	ST1 DBP	MONITORING, ROUTINE (DBP), MAJOR	1/1/2015	3/31/2015		2/3/2016
NV0002023	SAGE VALLEY MHP	27MJ	0999	CHLORINE	ST1 DBP	MONITORING, ROUTINE (DBP), MAJOR	1/1/2015	3/31/2015		2/3/2016
NV0002023	SAGE VALLEY MHP	27MJ	0999	CHLORINE	ST1 DBP	MONITORING, ROUTINE (DBP), MAJOR	4/1/2015	6/30/2015		2/3/2016
NV0002023	SAGE VALLEY MHP	27MJ	0999	CHLORINE	ST1 DBP	MONITORING, ROUTINE (DBP), MAJOR	4/1/2015	6/30/2015		2/3/2016
NV0002023	SAGE VALLEY MHP	27MJ	0999	CHLORINE	ST1 DBP	MONITORING, ROUTINE (DBP), MAJOR	4/1/2015	6/30/2015		2/3/2016
NV0002023	SAGE VALLEY MHP	27MJ	0999	CHLORINE	ST1 DBP	MONITORING, ROUTINE (DBP), MAJOR	7/1/2015	9/30/2015		2/3/2016
NV0002023	SAGE VALLEY MHP	27MJ	0999	CHLORINE	ST1 DBP	MONITORING, ROUTINE (DBP), MAJOR	7/1/2015	9/30/2015		2/3/2016

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0002023	SAGE VALLEY MHP	27MJ	0999	CHLORINE	ST1 DBP	MONITORING, ROUTINE (DBP), MAJOR	7/1/2015	9/30/2015		2/3/2016
NV0002023	SAGE VALLEY MHP	27MJ	0999	CHLORINE	ST1 DBP	MONITORING, ROUTINE (DBP), MAJOR	4/1/2016	6/30/2016		6/30/2016
NV0002023	SAGE VALLEY MHP	27MJ	0999	CHLORINE	ST1 DBP	MONITORING, ROUTINE (DBP), MAJOR	7/1/2016	9/30/2016		6/30/2016
NV0002023	SAGE VALLEY MHP	27MJ	0999	CHLORINE	ST1 DBP	MONITORING, ROUTINE (DBP), MAJOR	7/1/2016	9/30/2016		12/6/2016
NV0002023	SAGE VALLEY MHP	27MJ	0999	CHLORINE	ST1 DBP	MONITORING, ROUTINE (DBP), MAJOR	10/1/2016	12/31/2016		
NV0002023	SAGE VALLEY MHP	27MJ	CDB2	DBPR STAGE 2		MONITORING, ROUTINE (DBP), MAJOR	1/1/2014	8/31/2014		8/26/2016
NV0002023	SAGE VALLEY MHP	27MJ	CDB2	DBPR STAGE 2		MONITORING, ROUTINE (DBP), MAJOR	1/1/2015	8/31/2015		8/26/2016
NV0002023	SAGE VALLEY MHP	27MJ	CDBP	DISINFECTION BYPROD		MONITORING, ROUTINE (DBP), MAJOR	1/1/2013	12/31/2013		8/26/2016
NV0002023	SAGE VALLEY MHP	3AMJ	3014	E. COLI		MONITORING, ROUTINE, MAJOR (RTCR)	5/1/2016	5/31/2016		6/30/2016
NV0002023	SAGE VALLEY MHP	3AMJ	3014	E. COLI		MONITORING, ROUTINE, MAJOR (RTCR)	12/1/2016	12/31/2016		1/25/2017
NV0002023	SAGE VALLEY MHP	45	0700	GROUNDWATER RULE		FAILURE ADDRESS DEFICIENCY (GWR)	10/7/2014			
NV0002023	SAGE VALLEY MHP	71	7000	CONSUMER CONFIDENCE RULE		CCR REPORT	7/1/2016			
NV0002023	SAGE VALLEY MHP	71	7000	CONSUMER CONFIDENCE RULE		CCR REPORT	7/1/2015			
NV0002023	SAGE VALLEY MHP	S1	1032	MANGANESE		STATE MCL EXCEDENCE	7/1/2015	9/30/2015	0.16 MG/L	4/24/2016
NV0002023	SAGE VALLEY MHP	S1	1032	MANGANESE		STATE MCL EXCEDENCE	10/1/2015	12/31/2015	0.25 MG/L	4/24/2016
Total Number of Violations for this Water System:										32

NV0000872	SAGE VALLEY RV PARK	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2016	12/31/2016		
-----------	---------------------	------	------	---------	-----	---------------------------	----------	------------	--	--

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0000872	SAGE VALLEY RV PARK	03MJ	CNO2	NITRITE	IOC	MONITORING, ROUTINE MAJOR	1/1/2014	12/31/2016		
NV0000872	SAGE VALLEY RV PARK	19MJ	3014	E. COLI		MONITOR GWR ASSESSMENT, MAJOR	10/1/2015	10/31/2015		11/23/2016
NV0000872	SAGE VALLEY RV PARK	19MJ	3014	E. COLI		MONITOR GWR ASSESSMENT, MAJOR	10/1/2015	10/31/2015		11/23/2016
NV0000872	SAGE VALLEY RV PARK	19MJ	3014	E. COLI		MONITOR GWR ASSESSMENT, MAJOR	5/1/2016	5/31/2016		6/30/2016
NV0000872	SAGE VALLEY RV PARK	19MJ	3014	E. COLI		MONITOR GWR ASSESSMENT, MAJOR	5/1/2016	5/31/2016		6/3/2016
NV0000872	SAGE VALLEY RV PARK	19MJ	3014	E. COLI		MONITOR GWR ASSESSMENT, MAJOR	12/1/2016	12/31/2016		1/25/2017
NV0000872	SAGE VALLEY RV PARK	45	0700	GROUNDWATER RULE		FAILURE ADDRESS DEFICIENCY (GWR)	10/17/2014			
NV0000872	SAGE VALLEY RV PARK	93	1032	MANGANESE		STATE FAILURE TO MONITOR	4/1/2016	6/30/2016		2/28/2017
NV0000872	SAGE VALLEY RV PARK	93	1032	MANGANESE		STATE FAILURE TO MONITOR	7/1/2016	9/30/2016		2/28/2017
NV0000872	SAGE VALLEY RV PARK	93	1032	MANGANESE		STATE FAILURE TO MONITOR	10/1/2016	12/31/2016		2/28/2017
Total Number of Violations for this Water System:										11
NV0002191	SAND DUNE SALOON AND RV PARK	01	1040	NITRATE	IOC	MCL, SINGLE SAMPLE	10/1/2015	12/31/2015	11.7 MG/L	5/10/2016
NV0002191	SAND DUNE SALOON AND RV PARK	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	10/1/2016	12/31/2016		
Total Number of Violations for this Water System:										2
NV0004001	SANDY VALLEY ELEMENTARY SCHOOL	34MJ	3014	E. COLI		MONITOR GWR TRIGGERED/ADDITIONAL, MAJOR	7/20/2016	10/19/2016		10/19/2016
Total Number of Violations for this Water System:										1
NV0000915	SANTA ROSA STATION NFC	22	3100	COLIFORM (TCR)		MCL (TCR), MONTHLY	2/1/2016	2/29/2016		4/28/2016

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0000915	SANTA ROSA STATION NFC	22	3100	COLIFORM (TCR)		MCL (TCR), MONTHLY	3/1/2016	3/31/2016		4/28/2016
Total Number of Violations for this Water System:										2
NV0002557	SHARONS	23MJ	3100	COLIFORM (TCR)		MONITORING (TCR), ROUTINE MAJOR	10/1/2015	12/31/2015		3/31/2016
NV0002557	SHARONS	3AMJ	3014	E. COLI		MONITORING, ROUTINE, MAJOR (RTCR)	4/1/2016	6/30/2016		9/29/2016
NV0002557	SHARONS	93	1028	IRON		STATE FAILURE TO MONITOR	1/1/2016	12/31/2016		
Total Number of Violations for this Water System:										3
NV0003074	SHORT BRANCH	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2016	12/31/2016		1/3/2017
NV0003074	SHORT BRANCH	3BMJ	3014	E. COLI		MONITORING, ADD. ROUTINE, MAJOR (RTCR)	7/1/2016	7/31/2016		8/1/2016
NV0003074	SHORT BRANCH	93	1905	COLOR		STATE FAILURE TO MONITOR	1/1/2014	12/31/2016		
Total Number of Violations for this Water System:										3
NV0005028	SHOSHONE ESTATES WATER CO INC	02	1005	ARSENIC	IOC	MCL, AVERAGE	1/1/2016	3/31/2016	0.030 MG/L	
NV0005028	SHOSHONE ESTATES WATER CO INC	02	1005	ARSENIC	IOC	MCL, AVERAGE	4/1/2016	6/30/2016	0.030 MG/L	
NV0005028	SHOSHONE ESTATES WATER CO INC	02	1005	ARSENIC	IOC	MCL, AVERAGE	7/1/2016	9/30/2016	0.029 MG/L	
NV0005028	SHOSHONE ESTATES WATER CO INC	02	1005	ARSENIC	IOC	MCL, AVERAGE	10/1/2016	12/31/2016	0.030 MG/L	
NV0005028	SHOSHONE ESTATES WATER CO INC	34MJ	3014	E. COLI		MONITOR GWR TRIGGERED/ADDITONAL, MAJOR	8/2/2016	8/19/2016		8/19/2016
NV0005028	SHOSHONE ESTATES WATER CO INC	71	7000	CONSUMER CONFIDENCE RULE		CCR REPORT	7/1/2015			
NV0005028	SHOSHONE ESTATES WATER CO INC	71	7000	CONSUMER CONFIDENCE RULE		CCR REPORT	7/1/2014			
Total Number of Violations for this Water System:										7

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0000931	SIERRA COUNTRY ESTATES	58	5000	LEAD & COPPER RULE		OCCT/SOWT INSTALL DEMONSTRATION (LCR)	7/1/2010			
Total Number of Violations for this Water System:										1
NV0004021	SILVER KNOLLS MUTUAL WATER	02	1005	ARSENIC	IOC	MCL, AVERAGE	1/1/2015	3/31/2015	0.011 MG/L	6/30/2016
NV0004021	SILVER KNOLLS MUTUAL WATER	02	1005	ARSENIC	IOC	MCL, AVERAGE	4/1/2015	6/30/2015	0.011 MG/L	6/30/2016
NV0004021	SILVER KNOLLS MUTUAL WATER	02	1005	ARSENIC	IOC	MCL, AVERAGE	7/1/2015	9/30/2015	0.011 MG/L	6/30/2016
NV0004021	SILVER KNOLLS MUTUAL WATER	02	1005	ARSENIC	IOC	MCL, AVERAGE	10/1/2015	12/31/2015	.011 MG/L	6/30/2016
NV0004021	SILVER KNOLLS MUTUAL WATER	02	1005	ARSENIC	IOC	MCL, AVERAGE	1/1/2016	3/31/2016	0.011 MG/L	6/30/2016
Total Number of Violations for this Water System:										5
NV0000363	SILVER PEAK WATER SYSTEM	93	1930	TDS		STATE FAILURE TO MONITOR	12/1/2016	12/31/2016		
Total Number of Violations for this Water System:										1
NV0000760	SKY TAVERN	34MJ	3014	E. COLI		MONITOR GWR TRIGGERED/ADDITONAL, MAJOR	10/2/2016	10/6/2016		10/6/2016
NV0000760	SKY TAVERN	3AMJ	3014	E. COLI		MONITORING, ROUTINE, MAJOR (RTCR)	10/1/2016	10/31/2016		11/3/2016
Total Number of Violations for this Water System:										2
NV0001140	SLOAN ARMY RESERVE CENTER	S1	1930	TDS		STATE MCL EXCEDENCE	4/1/2015	6/30/2015	1018 MG/L	4/27/2016
NV0001140	SLOAN ARMY RESERVE CENTER	S1	1930	TDS		STATE MCL EXCEDENCE	7/1/2015	9/30/2015	1030 MG/L	4/27/2016
NV0001140	SLOAN ARMY RESERVE CENTER	S1	1930	TDS		STATE MCL EXCEDENCE	10/1/2015	12/31/2015	1020 MG/L	4/27/2016
Total Number of Violations for this Water System:										3
NV0000929	SONIC BURGER	23MJ	3100	COLIFORM (TCR)		MONITORING (TCR), ROUTINE MAJOR	1/1/2016	3/31/2016		6/1/2016

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0000929	SONIC BURGER	45	0700	GROUNDWATER RULE		FAILURE ADDRESS DEFICIENCY (GWR)	6/4/2015	8/17/2016		8/17/2016
Total Number of Violations for this Water System:										2
NV0000351	SOUTH CRESTVIEW HOMEOWNERS	03MJ	CNO2	NITRITE	IOC	MONITORING, ROUTINE MAJOR	1/1/2016	3/31/2016		1/25/2017
Total Number of Violations for this Water System:										1
NV0000562	SOUTHERN DESERT CORRECTIONAL CTR	22	3100	COLIFORM (TCR)		MCL (TCR), MONTHLY	12/1/2015	12/31/2015		1/25/2016
Total Number of Violations for this Water System:										1
NV00004071	SPENCER W KIMBALL SCOUT RESERVATION	03MJ	CNO2	NITRITE	IOC	MONITORING, ROUTINE MAJOR	1/1/2014	12/31/2016		
NV00004071	SPENCER W KIMBALL SCOUT RESERVATION	93	CSC2	SECONDARY IOCS		STATE FAILURE TO MONITOR	1/1/2014	12/31/2016		
Total Number of Violations for this Water System:										2
NV0000221	SPIRIT MOUNTAIN UTILITY	S1	1920	ODOR		STATE MCL EXCEEDENCE	10/1/2016	12/31/2016	70 TON	
Total Number of Violations for this Water System:										1
NV00003103	SPRING MOUNTAINS VISITOR GATEWAY	3AMJ	3014	E. COLI		MONITORING, ROUTINE, MAJOR (RTCR)	11/1/2016	11/30/2016		12/29/2016
NV00003103	SPRING MOUNTAINS VISITOR GATEWAY	3AMN	3014	E. COLI		MONITORING, ROUTINE, MINOR (RTCR)	10/1/2016	10/31/2016		12/29/2016
Total Number of Violations for this Water System:										2
NV00002598	STAGESTOP RESTAURANT	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2014	12/31/2014		2/25/2016
NV00002598	STAGESTOP RESTAURANT	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2015	12/31/2015		2/25/2016
Total Number of Violations for this Water System:										2
NV0000240	STOREY COUNTY WATER DISTRICT	24MN	3100	COLIFORM (TCR)		MONITORING (TCR), ROUTINE MINOR	3/1/2016	3/31/2016		4/19/2016

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0000240	STOREY COUNTY WATER DISTRICT	27MJ	0999	CHLORINE	ST1 DBP	MONITORING, ROUTINE (DBP), MAJOR	1/1/2016	3/31/2016		
Total Number of Violations for this Water System:										2
NV0000829	SULLIVANS PUB	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2016	12/31/2016		
NV0000829	SULLIVANS PUB	03MJ	CNO2	NITRITE	IOC	MONITORING, ROUTINE MAJOR	1/1/2014	12/31/2016		
NV0000829	SULLIVANS PUB	93	CSC2	SECONDARY IOCS		STATE FAILURE TO MONITOR	1/1/2014	12/31/2016		
Total Number of Violations for this Water System:										3
NV0000124	SUNRISE ACRES WATER ASSOCIATION	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2015	12/31/2015		10/3/2016
NV0000124	SUNRISE ACRES WATER ASSOCIATION	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2015	12/31/2015		10/3/2016
Total Number of Violations for this Water System:										2
NV0000123	SUNRISE MOUNTAIN TP	01	1040	NITRATE	IOC	MCL, SINGLE SAMPLE	4/1/2016	6/30/2016	11 MG/L	
NV0000123	SUNRISE MOUNTAIN TP	01	1040	NITRATE	IOC	MCL, SINGLE SAMPLE	7/1/2016	9/30/2016	12 MG/L	
NV0000123	SUNRISE MOUNTAIN TP	01	1040	NITRATE	IOC	MCL, SINGLE SAMPLE	10/1/2016	12/31/2016	12 MG/L	
NV0000123	SUNRISE MOUNTAIN TP	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	8/1/2016	8/31/2016		9/14/2016
NV0000123	SUNRISE MOUNTAIN TP	93	1031	MAGNESIUM		STATE FAILURE TO MONITOR	8/1/2016	8/31/2016		9/14/2016
NV0000123	SUNRISE MOUNTAIN TP	93	1930	TDS		STATE FAILURE TO MONITOR	8/1/2016	8/31/2016		9/14/2016
NV0000123	SUNRISE MOUNTAIN TP	S1	1930	TDS		STATE MCL EXCEDENCE	10/1/2016	12/31/2016	1091 MG/L	
Total Number of Violations for this Water System:										7
NV0005066	SUNSET MHP	93	1930	TDS		STATE FAILURE TO MONITOR	1/1/2014	12/31/2016		

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0005066	SUNSET MHP	93	1095	ZINC		STATE FAILURE TO MONITOR	1/1/2014	12/31/2016		
Total Number of Violations for this Water System:										2
NV0000765	SUTCLIFFE MOBILE PARK	03MJ	CSOD	SODIUM (NA)		MONITORING, ROUTINE MAJOR	1/1/2014	12/31/2016		
Total Number of Violations for this Water System:										1
NV0000329	T AND J INVESTMENTS DBA THE GROVE	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2015	12/31/2015		4/20/2016
Total Number of Violations for this Water System:										1
NV0000913	TAHOE RENO INDUSTRIAL CENTER	27MJ	0999	CHLORINE	ST1 DBP	MONITORING, ROUTINE (DBP), MAJOR	1/1/2015	3/31/2015		3/17/2016
Total Number of Violations for this Water System:										1
NV0002575	TATUADO WILD SIDE TAVERN	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2016	12/31/2016		
NV0002575	TATUADO WILD SIDE TAVERN	03MJ	CNO2	NITRITE	IOC	MONITORING, ROUTINE MAJOR	1/1/2014	12/31/2016		
NV0002575	TATUADO WILD SIDE TAVERN	3AMJ	3014	E. COLI		MONITORING, ROUTINE, MAJOR (RTCR)	7/1/2016	9/30/2016		3/8/2017
NV0002575	TATUADO WILD SIDE TAVERN	3AMJ	3014	E. COLI		MONITORING, ROUTINE, MAJOR (RTCR)	10/1/2016	12/31/2016		3/8/2017
NV0002575	TATUADO WILD SIDE TAVERN	93	CSC2	SECONDARY IOCS		STATE FAILURE TO MONITOR	1/1/2014	12/31/2016		
Total Number of Violations for this Water System:										5
NV0000340	THE MAVERICK	23MJ	3100	COLIFORM (TCR)		MONITORING (TCR), ROUTINE MAJOR	1/1/2016	3/31/2016		3/22/2016
Total Number of Violations for this Water System:										1
NV0005002	TONOPAH ELECTRONIC COMBAT RANGE O	27MJ	0999	CHLORINE	ST1 DBP	MONITORING, ROUTINE (DBP), MAJOR	7/1/2016	9/30/2016		12/6/2016
Total Number of Violations for this Water System:										1

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0002518	TOPAZ SUMMIT SPRING	03MJ	CNO2	NITRITE	IOC	MONITORING, ROUTINE MAJOR	1/1/2014	12/31/2016		
NV0002518	TOPAZ SUMMIT SPRING	23MJ	3100	COLIFORM (TCR)		MONITORING (TCR), ROUTINE MAJOR	1/1/2016	3/31/2016		6/7/2016
NV0002518	TOPAZ SUMMIT SPRING	3AMJ	3014	E. COLI		MONITORING, ROUTINE, MAJOR (RTCR)	7/1/2016	9/30/2016		12/13/2016
NV0002518	TOPAZ SUMMIT SPRING	93	CSC2	SECONDARY IOCS		STATE FAILURE TO MONITOR	1/1/2014	12/31/2016		

Total Number of Violations for this Water System: 4

NV0002159	TRAVEL CENTERS OF AMERICA NO 181	S1	1930	TDS		STATE MCL EXCEDENCE	1/1/2016	3/31/2016	1400 MG/L	
NV0002159	TRAVEL CENTERS OF AMERICA NO 181	S1	1930	TDS		STATE MCL EXCEDENCE	4/1/2016	6/30/2016	1300 MG/L	
NV0002159	TRAVEL CENTERS OF AMERICA NO 181	S1	1930	TDS		STATE MCL EXCEDENCE	7/1/2016	9/30/2016	1200 MG/L	
NV0002159	TRAVEL CENTERS OF AMERICA NO 181	S1	1930	TDS		STATE MCL EXCEDENCE	10/1/2016	12/31/2016	1300 MG/L	

Total Number of Violations for this Water System: 4

NV0003072	TURN 3 RV PARK AND STORE	3AMJ	3014	E. COLI		MONITORING, ROUTINE, MAJOR (RTCR)	4/1/2016	6/30/2016		9/22/2016
-----------	--------------------------	------	------	---------	--	-----------------------------------	----------	-----------	--	-----------

Total Number of Violations for this Water System: 1

NV0001145	US ECOLOGY	3AMJ	3014	E. COLI		MONITORING, ROUTINE, MAJOR (RTCR)	7/1/2016	9/30/2016		8/30/2016
NV0001145	US ECOLOGY	S1	1025	FLUORIDE		STATE MCL EXCEDENCE	10/1/2016	12/31/2016	3.0 MG/L	

Total Number of Violations for this Water System: 2

NV0000805	VALLEY VIEW RV PARK	93	3100	COLIFORM (TCR)		STATE FAILURE TO MONITOR	1/1/2016	12/31/2016		
NV0000805	VALLEY VIEW RV PARK	93	CNO3	NITRATE	IOC	STATE FAILURE TO MONITOR	1/1/2016	12/31/2016		

Total Number of Violations for this Water System: 2

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0003000	VERDI SCHOOL	03MJ	CDAS	ARSENIC (AS)		MONITORING, ROUTINE MAJOR	1/1/2016	3/31/2016		6/20/2016
NV0003000	VERDI SCHOOL	27MJ	0999	CHLORINE	ST1 DBP	MONITORING, ROUTINE (DBP), MAJOR	4/1/2016	6/30/2016		
NV0003000	VERDI SCHOOL	27MJ	0999	CHLORINE	ST1 DBP	MONITORING, ROUTINE (DBP), MAJOR	4/1/2016	6/30/2016		
NV0003000	VERDI SCHOOL	27MJ	0999	CHLORINE	ST1 DBP	MONITORING, ROUTINE (DBP), MAJOR	7/1/2016	9/30/2016		
NV0003000	VERDI SCHOOL	27MJ	0999	CHLORINE	ST1 DBP	MONITORING, ROUTINE (DBP), MAJOR	7/1/2016	9/30/2016		
NV0003000	VERDI SCHOOL	3AMJ	3014	E. COLI		MONITORING, ROUTINE, MAJOR (RTCR)	5/1/2016	5/31/2016		6/3/2016
Total Number of Violations for this Water System:										6
NV0002556	VFW PAHRUMP POST 10054	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2016	12/31/2016		
NV0002556	VFW PAHRUMP POST 10054	93	1055	SULFATE		STATE FAILURE TO MONITOR	1/1/2016	12/31/2016		
NV0002556	VFW PAHRUMP POST 10054	93	1930	TDS		STATE FAILURE TO MONITOR	1/1/2016	12/31/2016		
Total Number of Violations for this Water System:										3
NV0000167	VIRGIN VALLEY WATER DISTRICT	27MJ	CDB2	DBPR STAGE 2		MONITORING, ROUTINE (DBP), MAJOR	9/1/2014	8/31/2015		8/3/2016
Total Number of Violations for this Water System:										1
NV0000922	WARD CHARCOAL OVENS STATE PARK	S1	1028	IRON		STATE MCL EXCEEDENCE	4/1/2016	6/30/2016	0.74 MG/L	
NV0000922	WARD CHARCOAL OVENS STATE PARK	S1	1028	IRON		STATE MCL EXCEEDENCE	7/1/2016	9/30/2016	0.74 MG/L	
NV0000922	WARD CHARCOAL OVENS STATE PARK	S1	1028	IRON		STATE MCL EXCEEDENCE	10/1/2016	12/31/2016	0.82 MG/L	
Total Number of Violations for this Water System:										3
NV0000793	WASHOE LAKE STATE PARK	93	1028	IRON		STATE FAILURE TO MONITOR	10/1/2016	12/31/2016		

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0000793	WASHOE LAKE STATE PARK	93	1028	IRON		STATE FAILURE TO MONITOR	1/1/2016	12/31/2016		
NV0000793	WASHOE LAKE STATE PARK	93	1032	MANGANESE		STATE FAILURE TO MONITOR	10/1/2016	12/31/2016		
NV0000793	WASHOE LAKE STATE PARK	S1	1028	IRON		STATE MCL EXCEDENCE	7/1/2016	9/30/2016	1.3 MG/L	
NV0000793	WASHOE LAKE STATE PARK	S1	1032	MANGANESE		STATE MCL EXCEDENCE	4/1/2016	6/30/2016	0.19 MG/L	
NV0000793	WASHOE LAKE STATE PARK	S1	1032	MANGANESE		STATE MCL EXCEDENCE	7/1/2016	9/30/2016	0.27 MG/L	
Total Number of Violations for this Water System:										6

NV0000318	WASHOE LAKE STATE PARK NORTH BOAT	93	1028	IRON		STATE FAILURE TO MONITOR	10/1/2015	12/31/2015		5/26/2016
NV0000318	WASHOE LAKE STATE PARK NORTH BOAT	93	1028	IRON		STATE FAILURE TO MONITOR	1/1/2016	3/31/2016		5/26/2016
NV0000318	WASHOE LAKE STATE PARK NORTH BOAT	93	1028	IRON		STATE FAILURE TO MONITOR	10/1/2016	12/31/2016		
NV0000318	WASHOE LAKE STATE PARK NORTH BOAT	93	1032	MANGANESE		STATE FAILURE TO MONITOR	10/1/2015	12/31/2015		5/26/2016
NV0000318	WASHOE LAKE STATE PARK NORTH BOAT	93	1032	MANGANESE		STATE FAILURE TO MONITOR	1/1/2016	3/31/2016		5/26/2016
NV0000318	WASHOE LAKE STATE PARK NORTH BOAT	93	1032	MANGANESE		STATE FAILURE TO MONITOR	10/1/2016	12/31/2016		
NV0000318	WASHOE LAKE STATE PARK NORTH BOAT	S1	1028	IRON		STATE MCL EXCEDENCE	4/1/2016	6/30/2016	1.5 MG/L	
NV0000318	WASHOE LAKE STATE PARK NORTH BOAT	S1	1028	IRON		STATE MCL EXCEDENCE	7/1/2016	9/30/2016	7.4 MG/L	
NV0000318	WASHOE LAKE STATE PARK NORTH BOAT	S1	1032	MANGANESE		STATE MCL EXCEDENCE	4/1/2016	6/30/2016	0.17 MG/L	
NV0000318	WASHOE LAKE STATE PARK NORTH BOAT	S1	1032	MANGANESE		STATE MCL EXCEDENCE	7/1/2016	9/30/2016	0.32 MG/L	
Total Number of Violations for this Water System:										10

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0004065	WASHOE VALLEY MEETINGHOUSE	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	3/1/2016	3/31/2016		4/4/2016
NV0004065	WASHOE VALLEY MEETINGHOUSE	93	CSC2	SECONDARY IOCS		STATE FAILURE TO MONITOR	1/1/2014	12/31/2016		4/5/2017
Total Number of Violations for this Water System:										2
NV0000246	WEST WENDOVER WATER SYSTEM	93	1905	COLOR		STATE FAILURE TO MONITOR	1/1/2014	12/31/2016		
Total Number of Violations for this Water System:										1
NV0003054	WHEELER PEAK CAMPGROUND NPS	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2016	12/31/2016		
Total Number of Violations for this Water System:										1
NV0001135	WHIPPLES COUNTRY STORE	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2016	12/31/2016		
Total Number of Violations for this Water System:										1
NV0001073	WHISKEY PETES	27MJ	CDB2	DBPR STAGE 2		MONITORING, ROUTINE (DBP), MAJOR	10/1/2015	9/30/2016		
Total Number of Violations for this Water System:										1
NV0000946	WHOS DUNES	93	CSC2	SECONDARY IOCS		STATE FAILURE TO MONITOR	1/1/2014	12/31/2016		
Total Number of Violations for this Water System:										1
NV0000058	WILDES MANOR	02	1005	ARSENIC	IOC	MCL, AVERAGE	1/1/2016	3/31/2016	0.017 MG/L	
NV0000058	WILDES MANOR	02	1005	ARSENIC	IOC	MCL, AVERAGE	4/1/2016	6/30/2016	0.017 MG/L	
NV0000058	WILDES MANOR	02	1005	ARSENIC	IOC	MCL, AVERAGE	7/1/2016	9/30/2016	0.017 MG/L	
NV0000058	WILDES MANOR	02	1005	ARSENIC	IOC	MCL, AVERAGE	10/1/2016	12/31/2016	0.017 MG/L	
NV0000058	WILDES MANOR	03MJ	2105	2,4-D		MONITORING, ROUTINE MAJOR	1/1/2014	12/31/2016		

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0000058	WILDES MANOR	03MJ	2050	ATRAZINE		MONITORING, ROUTINE MAJOR	1/1/2014	12/31/2016		
NV0000058	WILDES MANOR	03MJ	2034	GLYPHOSATE		MONITORING, ROUTINE MAJOR	1/1/2014	12/31/2016		
NV0000058	WILDES MANOR	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2016	12/31/2016		
NV0000058	WILDES MANOR	03MJ	CNO2	NITRITE	IOC	MONITORING, ROUTINE MAJOR	1/1/2014	12/31/2016		
NV0000058	WILDES MANOR	03MJ	2037	SIMAZINE		MONITORING, ROUTINE MAJOR	1/1/2014	12/31/2016		
NV0000058	WILDES MANOR	03MJ	CVOC	VOCS PHASE 2 & 5		MONITORING, ROUTINE MAJOR	1/1/2014	12/31/2016		
NV0000058	WILDES MANOR	2ANC	8000	REVISED TOTAL COLIFORM RULE (RTCR)		LEVEL 1 ASSESS, MULTIPLE TC POS (RTCR)	7/11/2016	7/22/2016		7/22/2016
NV0000058	WILDES MANOR	75	7500	PUBLIC NOTICE		PUBLIC NOTICE RULE LINKED TO VIOLATION	1/1/2012			
NV0000058	WILDES MANOR	75	7500	PUBLIC NOTICE		PUBLIC NOTICE RULE LINKED TO VIOLATION	4/1/2015			
NV0000058	WILDES MANOR	75	7500	PUBLIC NOTICE		PUBLIC NOTICE RULE LINKED TO VIOLATION	1/1/2015			
NV0000058	WILDES MANOR	75	7500	PUBLIC NOTICE		PUBLIC NOTICE RULE LINKED TO VIOLATION	7/1/2012			
NV0000058	WILDES MANOR	75	7500	PUBLIC NOTICE		PUBLIC NOTICE RULE LINKED TO VIOLATION	4/1/2012			
NV0000058	WILDES MANOR	75	7500	PUBLIC NOTICE		PUBLIC NOTICE RULE LINKED TO VIOLATION	1/1/2015			
NV0000058	WILDES MANOR	93	1002	ALUMINUM		STATE FAILURE TO MONITOR	1/1/2014	12/31/2016		
NV0000058	WILDES MANOR	93	1017	CHLORIDE		STATE FAILURE TO MONITOR	1/1/2014	12/31/2016		
NV0000058	WILDES MANOR	93	1905	COLOR		STATE FAILURE TO MONITOR	1/1/2014	12/31/2016		
NV0000058	WILDES MANOR	93	1022	COPPER, FREE		STATE FAILURE TO MONITOR	1/1/2014	12/31/2016		

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0000058	WILDES MANOR	93	1028	IRON		STATE FAILURE TO MONITOR	1/1/2014	12/31/2016		
NV0000058	WILDES MANOR	93	1031	MAGNESIUM		STATE FAILURE TO MONITOR	1/1/2014	12/31/2016		
NV0000058	WILDES MANOR	93	1032	MANGANESE		STATE FAILURE TO MONITOR	1/1/2014	12/31/2016		
NV0000058	WILDES MANOR	93	1920	ODOR		STATE FAILURE TO MONITOR	1/1/2014	12/31/2016		
NV0000058	WILDES MANOR	93	1925	PH		STATE FAILURE TO MONITOR	1/1/2014	12/31/2016		
NV0000058	WILDES MANOR	93	CSEF	SEC IOC FLUORIDE		STATE FAILURE TO MONITOR	1/1/2014	12/31/2016		
NV0000058	WILDES MANOR	93	1050	SILVER		STATE FAILURE TO MONITOR	1/1/2014	12/31/2016		
NV0000058	WILDES MANOR	93	1055	SULFATE		STATE FAILURE TO MONITOR	1/1/2014	12/31/2016		
NV0000058	WILDES MANOR	93	1930	TDS		STATE FAILURE TO MONITOR	1/1/2014	12/31/2016		
NV0000058	WILDES MANOR	93	1095	ZINC		STATE FAILURE TO MONITOR	1/1/2014	12/31/2016		

Total Number of Violations for this Water System: 32

NV0002080	WILDHORSE RESORT	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2016	12/31/2016		
NV0002080	WILDHORSE RESORT	23MJ	3100	COLIFORM (TCR)		MONITORING (TCR), ROUTINE MAJOR	10/1/2015	12/31/2015		2/7/2016
NV0002080	WILDHORSE RESORT	34MJ	3014	E. COLI		MONITOR GWR TRIGGERED/ADDITIONAL, MAJOR	7/14/2016	7/19/2016		7/19/2016

Total Number of Violations for this Water System: 3

NV0001128	WILDKAT RANCH	23MJ	3100	COLIFORM (TCR)		MONITORING (TCR), ROUTINE MAJOR	10/1/2015	12/31/2015		3/24/2016
-----------	---------------	------	------	----------------	--	---------------------------------	-----------	------------	--	-----------

Total Number of Violations for this Water System: 1

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0002211	WILSON RESERVOIR BLM CAMPGROUND	22	3100	COLIFORM (TCR)		MCL (TCR), MONTHLY	10/1/2015	10/31/2015		4/1/2016
Total Number of Violations for this Water System:										1
NV0000399	WINDMILL RIDGE RESTAURANT AND	01	1040	NITRATE	IOC	MCL, SINGLE SAMPLE	10/1/2013	12/31/2013	11.4 MG/L	7/28/2016
NV0000399	WINDMILL RIDGE RESTAURANT AND	01	1040	NITRATE	IOC	MCL, SINGLE SAMPLE	1/1/2014	3/31/2014	11.9 MG/L	7/28/2016
NV0000399	WINDMILL RIDGE RESTAURANT AND	01	1040	NITRATE	IOC	MCL, SINGLE SAMPLE	4/1/2014	6/30/2014	12.7 MG/L	7/28/2016
NV0000399	WINDMILL RIDGE RESTAURANT AND	01	1040	NITRATE	IOC	MCL, SINGLE SAMPLE	10/1/2014	12/31/2014	10.8 MG/L	7/28/2016
NV0000399	WINDMILL RIDGE RESTAURANT AND	01	1040	NITRATE	IOC	MCL, SINGLE SAMPLE	1/1/2015	3/31/2015	13.3 MG/L	7/28/2016
NV0000399	WINDMILL RIDGE RESTAURANT AND	01	1040	NITRATE	IOC	MCL, SINGLE SAMPLE	4/1/2015	6/30/2015	11.2 MG/L	7/28/2016
NV0000399	WINDMILL RIDGE RESTAURANT AND	01	1040	NITRATE	IOC	MCL, SINGLE SAMPLE	7/1/2015	9/30/2015	11.3 MG/L	7/28/2016
NV0000399	WINDMILL RIDGE RESTAURANT AND	01	1040	NITRATE	IOC	MCL, SINGLE SAMPLE	10/1/2015	12/31/2015	10.6 MG/L	7/28/2016
NV0000399	WINDMILL RIDGE RESTAURANT AND	01	1040	NITRATE	IOC	MCL, SINGLE SAMPLE	1/1/2016	3/31/2016	13.7 MG/L	7/28/2016
Total Number of Violations for this Water System:										9
NV0000258	ZEPHYR COVE WATER UTILITY DISTR	27MJ	CDB2	DBPR STAGE 2		MONITORING, ROUTINE (DBP), MAJOR	1/1/2015	2/28/2015		9/7/2016
NV0000258	ZEPHYR COVE WATER UTILITY DISTR	27MJ	CDB2	DBPR STAGE 2		MONITORING, ROUTINE (DBP), MAJOR	3/1/2015	5/31/2015		9/7/2016
NV0000258	ZEPHYR COVE WATER UTILITY DISTR	27MJ	CDB2	DBPR STAGE 2		MONITORING, ROUTINE (DBP), MAJOR	6/1/2015	8/31/2015		9/7/2016
Total Number of Violations for this Water System:										3

Attachment A

RULE-SPECIFIC VIOLATION CRITERIA FOR THE ANNUAL PUBLIC WATER SYSTEMS COMPLIANCE REPORT¹

Chemical Contaminant Group Maximum Contaminant Level (MCL)

MCL - Single Sample or MCL Average (Violation Types 01 and 02).

Only Community Water Systems can have a MCL for the following contaminant codes: 1025, 4000, 4006, 4010, and 4100.

Both Community and Non-transient Non-community (NTNC) water systems can have an MCL for the following contaminant codes: 2051, 2050, 2046, 2959, 2946, 2931, 2065, 2067, 2010, 2015, 2020, 2383, 2105, 2110, 2306, 2031, 2035, 2039, 2041, 2032, 2033, 2005, 2034, 2274, 2042, 2036, 2040, 2037, 2063, 2990, 2982, 2984, 2976, 2981, 2977, 2980, 2380, 2992, 2989, 2968, 2996, 2987, 2991, 2979, 2955, 2983, 2326, 2964, 2985, 2378, 2969, 1005, 1094, 1010, 1015, 1020, 1035, 1036, 1045, 1074, 1075, 1024, 1085.

All systems can have an MCL for Nitrate (contaminant codes 1038, 1040, and 1041).

Chemical Contaminant Group Monitoring and Reporting (M/R)

M/R - Monitoring, Regular (Violation Types 03 and 04 and Major Indicator Flag = Y).

Only Community Water Systems can have an M/R for the following contaminant codes: 1025, 4000, 4006, 4010, and 4100.

Both Community and NTNC water systems can have an M/R for the following contaminant codes: 2051, 2050, 2046, 2959, 2946, 2931, 2065, 2067, 2010, 2015, 2020, 2383, 2105, 2110, 2306, 2031, 2035, 2039, 2041, 2032, 2033, 2005, 2034, 2274, 2042, 2036, 2040, 2037, 2063, 2990, 2982, 2984, 2976, 2981, 2977, 2980, 2380, 2992, 2989, 2968, 2996, 2987, 2991, 2979, 2955, 2983, 2326, 2964, 2985, 2378, 2969, 2950, 2456, 0999, 1005, 1094, 1010, 1015, 1020, 1035, 1045, 1074, 1075, 1024, 1085.

¹ For violations that extend beyond the calendar year, the violation is counted in each of the calendar years in which it occurred, unless it has returned to compliance prior to the beginning of the calendar year.

All systems can have an M/R for Nitrate (contaminant codes 1038, 1040, and 1041).

Chemical Contaminant Group Treatment Technique (TT)

Both Community and NTNC water systems can have a TT violation for Acrylamide and Epichlorohydrine (Violation type 07, contaminant codes 2265 and 2257).

Total Coliform Rule (TCR) MCLs

Any violation that is either Acute or Monthly (Violation types 21 and 22). The contaminant code for TCR is 3100.

TCR Significant M/R

Any major Routine or Repeat M/R violation (Violation types 23 and 25). The contaminant code for TCR is 3100.

Revised Total Coliform Rule (RTCR) MCLs

Any violation that is either Acute or Monthly (Violation type 1A). The contaminant code for RTCR is 8000.

RTCR Significant M/R

Any major Routine or Repeat M/R violation (Violation types 3A, 3B, 3C, 3D, 4D, 4E, 4F, 5A, and 5B). The contaminant code for RTCR is 8000.

RTCR TT

Violation types (2A, 2B, 2C, and 2D). The contaminant code for RTCR is 8000.

Surface Water Treatment Rule (SWTR) TT

Any TT violation for a filtered system (Violation type 41) and all unfiltered systems who are required to install filtration if at some point during the calendar year they were unfiltered. (Violation type 42 violations - these may not be in your state data systems). The contaminant code for SWTR is 0200.

SWTR Significant M/R

Any Significant surface water M/R violation by a filtered or unfiltered system (Violation Types 36 and 31 and Major Indicator Flag = Y, respectively). The contaminant code for SWTR is 0200.

Turbidity MCL

Any MCL Average violation for an unfiltered system (Violation type 02). The contaminant code for turbidity is 0100.

Turbidity Significant M/R

Any major regular M/R violation for an unfiltered system (Violation type 03 and Major Indicator Flag = Y). The contaminant code for turbidity is 0100.

Lead and Copper Rule (LCR) TT

Any Community or NTNC water system with a TT violation at any time during the calendar year (Violation Types 58, 62 and 65). Note: Violation type 62 has been combined under Violation type 58 in SDWIS.

LCR Significant M/R

Any Community or NTNC water system with a follow-up or routine tap sampling violation (Violation type 52) or any Community or NTNC water system who incurred an initial tap monitoring violation (Violation type 51) during the calendar year, or who incurred the initial tap violation prior to the calendar year, but failed to return to compliance prior to January 1 of the calendar year. Note: a system cannot have more than one initial tap monitoring violation counted in a calendar year.

In general: Count all violations above where any date in the violation compliance period begin and end date range falls within the calendar year **except** those that returned to compliance prior to the first day of the calendar year regardless of current system status.

Note: EPA has changed the state submitted compliance period end date of Violation types 51, 58, 62 and 65 to reflect either the date the violation returned to compliance or the date of 12/31/2015.

Consumer Confidence Report Rule (CCR) Significant Consumer Notification Violations and Public Notification Violations

Any Community water system that completely failed to provide a required consumer confidence report is in violation (Violation type 71). Because the violation continues until the system provides the report, the violation must also be reported in each subsequent year until the system returns to compliance. Public Notification violations are Violation type codes 75 for NPDWR and 76 for other potential health risk situations PN Violation (Non-NPDWR). For the Public Notice Violations the violation must be linked to a specific rule. The contaminant code for IESWTR is 0300. The contaminant codes for Stage 1 DBPR are 1009, 1011, 2456, 2950, 1006, 1008 and 0999.

Interim Enhanced Surface Water Treatment Rule (IESWTR) TT

Any public water system that uses surface water or ground water under the direct influence of surface water (GWUDI) and serving at least 10,000 people with a TT violation (Violations 37, 43, 44, and 47). The contaminant code for IESWTR is 0300. See Section II of the Implementation Guidance for Interim Enhanced Surface Water Treatment Rule (EPA 816-R-01-11, June 2001)

<http://www.epa.gov/safewater/mdbp/ieswtrimplguid.pdf> for additional information

IESWTR Significant Recordkeeping and M/R Violations

Any public water system that uses surface water or GWUDI and serving at least 10,000 people with an M/R violation (Violation 29 and Violation 38 and Major Indicator Flag = Y). The contaminant code for IESWTR is 0300. Any recordkeeping violation where system fails to maintain the results of individual filter monitoring for 3 years. Violation type is 09. The contaminant code is for IESWTR is 0300. See Section II of the Implementation Guidance for Interim Enhanced Surface Water Treatment Rule (EPA 816-R-01-11, June 2001) <http://www.epa.gov/safewater/mdbp/ieswtrimplguid.pdf> for additional information.

Filter Backwash Recycle Rule (FBRR) TT

Public water systems that use surface water or GWUDI, practice conventional or direct filtration, and recycle spent filter backwash, thickener supernatant, or liquids from dewatering processes. The violation code is 40. The contaminant code is 0500. See the Implementation Guide for the Filter Backwash Recycle Rule www.epa.gov/safewater/mdbp/guide_fbrr_ig_fnl_06-16-04.pdf [EPA 816-R-04-006, June 2004] for additional information.

Filter Backwash Recycle Rule (FBRR) M/R and Recordkeeping

Public water systems that use surface water or GWUDI, practice conventional or direct filtration, and recycle spent filter backwash, thickener supernatant, or liquids from dewatering processes. The violation code for M/R is 39 and for recordkeeping is 09. The contaminant code is 0500. See the Implementation Guide for the Filter Backwash Recycle Rule (EPA 816-R-04-006, June 2004) www.epa.gov/safewater/mdbp/guide_fbrr_ig_fnl_06-16-04.pdf for additional information.

Ground Water Rule (GWR)

All systems can have Ground Water Rule violations. The violation code for failure to collect triggered source water samples for E. coli after a TCR positive sample is 34.

Long Term 1 Enhanced Surface Water Treatment Rule (LT1ESWTR) TT

Public water systems that use surface water or GWUDI and serve fewer than 10,000 people. The violation codes are 37 and 47. Like the IESWTR The contaminant code for LT1ESTR the contaminant code is 0300. See Section V of the Long Term Enhanced Surface Water Treatment Rule (LT1ESWTR) Implementation Guide for additional information at the website: www.epa.gov/safewater/mdbp/pdfs/lt1eswtr/guidance_lt1_ig.pdf

Stage 1 and 2 Disinfectants and Disinfection Byproducts Rule (Stage 1 DBPR) TT

All CWS and NTNCWS that add a chemical disinfectant in any part of the drinking water treatment process and transient NCWS

using chlorine dioxide with TT violations (Violations 12, 37 and 46). The contaminant codes for Stage 1 DBPR are 0400 and 2920. See Section II of the Implementation Guidance for Stage 1 Disinfectants and Disinfection Byproducts Rule (EPA 816-R-01-12, June 2001) <http://www.epa.gov/safewater/mdbp/s1dbprimplguid.pdf> for additional information.

Stage 1 and 2 DBPR MCL and Maximum Residual Disinfectant Levels (MRDL)

All CWS and NTNCWS that add a chemical disinfectant in any part of the drinking water treatment process and transient NCWS using chlorine dioxide with MCL/MRDL violations (Violations 02 and 11). The contaminant codes for Stage 1 DBPR are 1009, 1011, 2456, 2950, 1006, 1008 and 0999. See Section II of the Implementation Guidance for Stage 1 Disinfectants and Disinfection Byproducts Rule (EPA 816-R-01-12, June 2001) <http://www.epa.gov/safewater/mdbp/s1dbprimplguid.pdf> for additional information.

Stage 1 and 2 DBPR M/R Violations

All CWS and NTNCWS that add a chemical disinfectant in any part of the drinking water treatment process and transient NCWS using chlorine dioxide with M/R violations (Violation 27 and Major Indicator Flag = Y). The contaminant codes for Stage 1 DBPR are 0400, 2920, 1009, 1011, 2456, 2950, 1006, 1008 and 0999. See Section II of the Implementation Guidance for Stage 1 Disinfectants and Disinfection Byproducts Rule (EPA 816-R-01-12, June 2001) at: <http://www.epa.gov/safewater/mdbp/s1dbprimplguid.pdf> for additional information.

Public Notification

The violation code for failure to notify the public after a violation is 06 for IESWTR, LT1ESWTR, and Stage 1 DBPR. The contaminant code for Stage 1 DBPR corresponds with the appropriate MCL/MRDL/TOC (1009, 1011, 2456, 2950, 1006, 1008 and 0999). The contaminant code for IESWTR and LT1ESWTR is 0300. For FBRR the violation code is 75 and the contaminant code is 0500.

Secondary Drinking Water Standard M/R Violations

All Nevada public water systems can have M/R (Violation type 93) for Secondary Drinking Water Standards, which consists of the following contaminant codes: 1002, 1017, 1022, 1028, 1031, 1032, 1050, 1055, 1089, 1095, 1905, 1920, 1925, and 1930.

Secondary Drinking Water Standard MCL Violations

All Nevada public water systems can have MCL average (Violation type S1) for Secondary Drinking Water Standards, which consists of the following contaminant codes: 1002, 1017, 1022, 1028, 1031, 1032, 1050, 1055, 1089, 1095, 1905, 1920, 1925, and 1930.

VIOLATION TYPES

State or EPA HQ	Type Code	VIOLATION NAME	ALTERNATE DESCRIPTION
HQ	01	MAXIMUM CONTAMINANT LEVEL (MCL), SINGLE SAMPLE	Excedence of MAXIMUM CONTAMINANT LEVEL (MCL) per 5-1.52
HQ	02	MAXIMUM CONTAMINANT LEVEL (MCL), AVERAGE, WITHOUT NUMBER OF EXCEDENCE	Excedence of MAXIMUM CONTAMINANT LEVEL (MCL) per 5-1.52
HQ	02	MAXIMUM CONTAMINANT LEVEL (MCL), AVERAGE, WITH NUMBER OF EXCEDENCE	Public Water Supply (PWS) Using Chlorine Dioxide - Chlorite - Average of any 3 sample set exceeds the MAXIMUM CONTAMINANT LEVEL (MCL) of 1.0 mg/L
HQ	03	MONITORING, ROUTINE MAJOR	Failure to monitor in accordance with section 5-1.51(b) and 5-1.52 Tables or perform analysis with approved methods
HQ	04	MONITORING, CONFIRMATION/CHECK MAJOR	No repeat samples were taken in response to a positive monitoring sample result.
HQ	05	NOTIFICATION, STATE	Failure to notify state
HQ	07	TREATMENT TECHNIQUES NON-SURFACE WATER TREATMENT RULE (Non-SWTR)	Failure to maintain free chlorine residual in distribution system.
HQ	08	VARIANCE / EXEMPTION / OTHER COMPLIANCE	Failure to abide by the authorized terms and conditions of a valid variance, waiver, or any other exemption.
HQ	09	RECORD KEEPING	Failure to retain proper records.
HQ	09	RECORD KEEPING FOR INDIVIDUAL FILTER /Filter Backwash Rule (FBR)	Failure to maintain filter monitoring records for 3 years (filter results every 15 minutes)
HQ	1A	E. COLI MCL	E. coli positive routine with insufficient repeat samples, or a combination of E. coli positive and Total Coliform positive results between routine and repeat samples, or Total Coliform positive routine with Total Coliform positive repeat sample not tested for E.coli.
HQ	2A	LEVEL 1 ASSESSMENT TREATMENT TECHNIQUE	Failure to conduct Level 1 assessment.
HQ	2B	LEVEL 2 ASSESSMENT TREATMENT TECHNIQUE	Failure to conduct Level 2 assessment.
HQ	2C	CORRECTIVE ACTIONS/EXPEDITED ACTIONS TREATMENT TECHNIQUE	Failure to complete corrective actions withn the required timeframe when a Level 1 or Level 2 assessment is triggered.
HQ	2D	STARTUP PROCEDURES TREATMENT TECHNIQUE	Failure to complete seasonal startup procedures
HQ	3A	ROUTINE MONITORING	Failure to collect routine samples at appropriate site/frequency.
HQ	3B	ADDITIONAL ROUTINE MONITORING	Failure to collect additional routine samples required the next month after any Total Coliform positive happens in water systems not on a baseline monthly monitoring
HQ	3C	TC SAMPLES (TRIGGERED BY TURBIDITY EXCEEDANCE) MONITORING	Failure to collect required extra total coliform samples due to turbidity exceedance.
HQ	3D	MONITORING VIOLATION DUE TO LAB AND/OR ANALYTICAL ERRORS	Failure to use the required/approved analytical methods, or follow holding times, or sample preparation, or collection methods, or failure to use certified and/or State-approved Laboratory.

VIOLATION TYPES

State or EPA HQ	Type Code	VIOLATION NAME	ALTERNATE DESCRIPTION
HQ	4D	E. COLI POSITIVE NOTIFICATION REPORTING	Failure to notify the State by the end of the day or the end of the next business day (based on State office closure communication procedures) about an E. coli positive compliance sample result.
HQ	4E	E. COLI MCL REPORTING	Failure to provide notification to the State that an E. coli MCL violation happened.
HQ	4F	NOTIFICATION OF VIOLATIONS - ASSESSMENTS, ASSESSMENT FORMS, CORRECTIVE/EXPEDITED ACTIONS REPORTING	Failure to provide notification to the State that violations related to Level 1 and 2 assessments, assessment forms, and corrective actions have happened.
HQ	5A	ERRORS WITH SAMPLE SITING PLAN	Failure to develop Sampling Site Plan or to revise Smapling Site Plan to include a sample collection schedule.
HQ	5B	RTCR RECORD KEEPING VIOLATIONS	Failure to keep records for Level 1 and Level2 assessments and corrective/expedited actions for 5 years, or failure to keep recoreds for 5 years on repest sample results that the State approved and extended the timeframe for sample collection, or failure to keep records on Samplinq Site Plan
HQ	11	MAXIMUM RESIDUAL DISINFECTANT LEVEL (MRDL) - Public Water Supply (PWS) Using Chlorine	Excedence of Maximum Residual Disinfectant Level (MRDL) of 4.0 mg/L (exception if microbial contamination problems in distribution system)
HQ	11	MAXIMUM RESIDUAL DISINFECTANT LEVEL (MRDL) MONITORING	Failure to perform minimum monitoring requirements.
HQ	12	QUALIFIED OPERATOR FAILURE	No certified operator in charge of operation of a water treatment plant.
HQ	13	MAXIMUM RESIDUAL DISINFECTANT LEVEL (MRDL) ACUTE - Public Water Supply (PWS) Using Chlorine Dioxide	ACUTE: If any of 3 required distribution samples taken on day after a daily entry point sample Maximum Residual Disinfectant Level (MRDL) exceeds 0.8 mg/L
HQ	19	MONITOR GWR ASSESSMENT	A system that fails to conduct assessment source water monitoring required by the state according to State-determined requirements for such monitoring [141.130(c)]
HQ	20	FAILURE TO CONSULT/RESPOND	A system that fails to consult with the State within 30 days regarding notice from the State of a significant deficiency, or written notice from a laboratory of a ground water source sample being fecal indicator-positive, or that corrective action is required after a fecal indicator-positive sample result. [141.403(a)(4)]
HQ	21	MAXIMUM CONTAMINANT LEVEL (MCL) - TOTAL COLIFORM RULE (TCR) ACUTE	Excedence of MAXIMUM CONTAMINANT LEVEL (MCL) per 5-1.52 Table 6--Microbiological Contaminants
HQ	22	MAXIMUM CONTAMINANT LEVEL (MCL) - TOTAL COLIFORM RULE (TCR), MONTHLY	Excedence of MAXIMUM CONTAMINANT LEVEL (MCL) per 5-1.52 Table 6--Microbiological Contaminants

VIOLATION TYPES

State or EPA HQ	Type Code	VIOLATION NAME	ALTERNATE DESCRIPTION
HQ	23	MONITORING TOTAL COLIFORM RULE (TCR), ROUTINE MAJOR	Failure to perform Table 11 Microbiological Minimum Monitoring Requirements
HQ	24	MONITORING (TCR), ROUTINE MINOR	A system collects some but not all of the scheduled routine total coliform samples at sites approved in the written sample siting plan according to the determined monitoring frequency. [141.21(a)(1)-(2)]
HQ	25	MONITORING TOTAL COLIFORM RULE (TCR), REPEAT MAJOR	Failure to perform Table 11 Microbiological Minimum Monitoring Requirements
HQ	26	MONITORING (TCR), REPEAT MINOR	A system notified of total coliform positive repeat sample and analyzes some but not all of the total coliform positive samples for fecal coliform/E. coli. [141.32(e)(1)]
HQ	27	MONITORING, ROUTINE DISINFECTION BYPRODUCT RULE (DBP), MAJOR - Bromate Monitoring / Reporting (M/R) - Public Water Supply (PWS) Using Ozone	Failure to collect 100% of required bromate samples
HQ	27	MONITORING, ROUTINE DISINFECTION BYPRODUCT RULE (DBP), MAJOR - Chlorine Monitoring / Reporting (M/R)	Collecting <90% of chlorine samples
HQ	27	MONITORING, ROUTINE DISINFECTION BYPRODUCT RULE (DBP), MAJOR - Total Organic Carbon (TOC) Monitoring / Reporting (M/R) - Surface / Groundwater Under Direct Influence of Surface Water (GUDI) Using Conventional Filtration	Failure to collect source & finished water TOC samples and alkalinity sample
HQ	27	HALOACETIC ACID / TOTAL TRIHALOMETHANE (HAA5/TTHM)- MAJOR Monitoring / Reporting (M/R) - SURFACE WATER / Groundwater Under Direct Influence of Surface Water (GUDI) Greater Than or Equal to 10,000 Population	Collecting <90% of (HAA5/TTHM) samples
HQ	27	HALOACETIC ACID / TOTAL TRIHALOMETHANE (HAA5/TTHM) - MAJOR Monitoring / Reporting (M/R) Surface / Groundwater Under Direct Influence of Surface Water (GUDI) Population between 500 and 9999	Collecting <90% of (HAA5/TTHM) samples
HQ	27	HALOACETIC ACID / TOTAL TRIHALOMETHANE (HAA5/TTHM) - MAJOR Monitoring / Reporting (M/R) - Surface / Groundwater Under Direct Influence of Surface Water (GUDI) < 500	Failure to collect/report at least 1 sample per plant per year during month of warmest water temperature
HQ	27	HALOACETIC ACID / TOTAL TRIHALOMETHANE (HAA5/TTHM) - MAJOR Monitoring / Reporting (M/R) - Groundwater Systems Greater Than or Equal to 10,000 Population	Collecting <90% of (HAA5/TTHM) samples
HQ	27	HALOACETIC ACID / TOTAL TRIHALOMETHANE (HAA5/TTHM) - MAJOR Monitoring / Reporting (M/R) - Groundwater Systems < 10,000 Population	Failure to collect/report all required samples

VIOLATION TYPES

State or EPA HQ	Type Code	VIOLATION NAME	ALTERNATE DESCRIPTION
HQ	27	FAILURE TO HAVE MONITORING PLAN DISINFECTION BYPRODUCT RULE (DBP)	Failure to develop, implement or submit monitoring plan
HQ	28	SANITARY SURVEY COOPERATION FAILURE	A system that does not collect 5 or more routine samples per month and fails to undergo an initial sanitary survey by June 29, 1994, for community water systems, and June 29, 1999 for non-community water systems; or fails to undergo another sanitary survey every five years for community water systems and every 10 years for non-community water systems. [141.21(d)(1)(i)]
HQ	29	FAILURE TO PRODUCE COMPREHENSIVE PERFORMANCE EVALUATION (CPE) - Interim Enhanced Surface Water Treatment Rule (IESWTR)	Failure to produce CPE evaluation documentation
HQ	30	FAILURE TO HAVE MONITORING PLAN (IDSE)	A system that fails to monitor for each quarter that a monitoring result would be used in calculating an LRAA. [141.621(e)]
HQ	30	MONITORING, ROUTINE (IDSE), MAJOR	A system that fails to conduct standard monitoring according to 141.601 or a system specific study that meets the requirements in 141.602. [141.600]
HQ	30	MONITORING, ROUTINE (IDSE), MINOR	Failure to submit an IDSE standard monitoring plan, System Specific Study plan, 40/30 waiver, or submitted plan found to be deficient. [141.600(c);141.601(a); 141.602(a)]
HQ	31	MONITORING, ROUTINE/REPEAT - MAJOR - Surface Water Treatment Rule - UNFILTERED (SWTR - Unfiltered)	Failure to collect < 90% of require samples per monitoring period
HQ	32	FAILURE TO HAVE MONITORING PLAN (LT2)	A system that fails to submit a complete source water monitoring plan, including a sampling schedule and description of sampling location. [141.702(a) & 141.703(f)]
HQ	32	MONITORING, SOURCE (LT2)	A system that fails to collect any source water sample required in accordance with the sampling schedule, sampling location, analytical method, approved laboratory, and reporting requirements of the rule. [141.701 - 141.706]
HQ	34	MONITORING, SOURCE (GWR), MAJOR	Failure to collect triggered source water sample after a Total Coliform Rule positive sample.
HQ	35	FAILURE SUBMIT IDSE/SUBPT V PLAN (DBPR2)	A system that fails to submit an IDSE report or Subpart V monitoring plan, or submitted plan found to be missing required elements. [141.601(c)(1-4); 141.602(b)(1-6); 141.605; and 141.622]
HQ	36	MONITORING, Routine/Repeat MAJOR Surface Water Treatment Rule -FILTER	Failure to collect < 90% of require samples per monitoring period

VIOLATION TYPES

State or EPA HQ	Type Code	VIOLATION NAME	ALTERNATE DESCRIPTION
HQ	37	FAILURE TO PROFILE / CONSULT - Interim Enhanced Surface Water Treatment Rule (IESWTR)	Failure to collect applicability data Treatment Technique (TT) violation
HQ	38	MONITORING, ROUTINE Interim Enhanced Surface Water Treatment Rule (IESWTR), MAJOR - Filtration/Combined Filter Effluent Surface/Groundwater Under Direct Influence of Surface Water (GUDI) >= 10,000 Population with Conventional/Direct Filtration	Collecting <90% of filter effluent samples for turbidity and reporting within 10 days after end of month
HQ	38	MONITORING, ROUTINE Interim Enhanced Surface Water Treatment Rule (IESWTR), MAJOR - Filtration/Combined Filter Effluent - Surface/Groundwater Under Direct Influence of Surface Water (GUDI) Serving >= 10,000 Population with Conventional/Direct Filtration	Failure to report that Public Water Supply (PWS) has conducted all filter monitoring to state within 10 days after end of each month
HQ	39	FAILURE TO SUBMIT PLANT SCHEMATIC (FBR)	A system that fails to notify the State in writing by December 8, 2003 if the system recycles spent filter backwash water, thickener supernatant, or liquids from dewatering processes and/or include a plant schematic and typical recycle flow in the notification. [141.76(b)]
HQ	40	FAILURE TO PROPERLY RECYCLE (FBR)	Failure to meet treatment technique requirements. [141.76(c)]
HQ	41	RESIDUAL DISINFECT CONCENTRATION - Surface Water Treatment Rule (SWTR) Surface or Groundwater Under Direct Influence (Groundwater Under Direct Influence of Surface Water (GUDI)) Serving Less Than 10,000 Population.	Cl ₂ Residual fell below 0.2 mg/l for more than 4 hours.
HQ	41	SINGLE COMBINED FILTER EFFLUENT (SWTR) - Surface or Groundwater Under Direct Influence (Groundwater Under Direct Influence of Surface Water (GUDI) Serving Less Than 10,000 Population.	Failure to maintain turbidity readings below 0.5 NTU in 95% of all measurements performed every 4 hours
HQ	41	MONTHLY COMBINED FILTER EFFLUENT (SWTR) - Surface or Groundwater Under Direct Influence (Groundwater Under Direct Influence of Surface Water (GUDI) Serving Less Than 10,000 Population.	Failure to meet performance standard of 0.5 NTU at the 95th percentile monthly.
HQ	42	FAILURE TO FILTER (SWTR)	Failure to provide filtration on a surface source after 6/29/93, unless avoidance criteria is met.
HQ	42	FAILURE TO PROVIDE GWR TREATMENT	Failure to meet GWR treatment requirements
HQ	42	FAILURE TO PROVIDE LT2 TREATMENT	Failure to meet Long Term 2 treatment requirements

VIOLATION TYPES

State or EPA HQ	Type Code	VIOLATION NAME	ALTERNATE DESCRIPTION
HQ	43	SINGLE COMB. FILTER EFFLUENT Interim Enhanced Surface Water Treatment Rule (IESWTR) Surface/Groundwater Under Direct Influence of Surface Water (GUDI) Greater Than or Equal to 10,000 Population with conventional / direct filtration.	Failure to achieve turbidity <1.0 NTU, in 100% of samples
HQ	43	SINGLE COMB. FILTER EFFLUENT Interim Enhanced Surface Water Treatment Rule (IESWTR) Surface/Groundwater Under Direct Influence of Surface Water (GUDI) Greater Than or Equal to 10,000 Population with alternative filtration.	Failure to achieve turbidity <State set limit, in 100% of samples
HQ	44	MONTHLY COMB. FILTER EFFLUENT Interim Enhanced Surface Water Treatment Rule (IESWTR) - Surface/Groundwater Under Direct Influence of Surface Water (GUDI) Greater Than or Equal to 10,000 Population with conventional or direct filtration	Failure to achieve turbidity <0.3 NTU in 95% of samples
HQ	44	MONTHLY COMB. FILTER EFFLUENT Interim Enhanced Surface Water Treatment Rule (IESWTR) - Surface / Groundwater Under Direct Influence of Surface Water (GUDI) Greater Than or Equal to 10,000 Population with alternative filtration.	Failure to achieve turbidity <State set limit in 95% of samples
HQ	45	FAILURE ADDRESS DEFICIENCY	A system with a significant deficiency that after 120 days of receiving written notification of the significant deficiency from the State fails to: 1) complete corrective action in accordance with any applicable State plan review processes or other State guidance and direction. [141.404(a)(1)]
HQ	46	INADEQUATE DBP PRECURSOR REMOVAL - Surface / Groundwater Under Direct Influence of Surface Water (GUDI) using conventional filtration	Failure to meet DBP precursor removal (TOC)
HQ	47	UNCOVERED STORAGE FACILITY - Interim Enhanced Surface Water Treatment Rule (IESWTR)	Uncovered reservoir without adequate post disinfection.
HQ	48	FAILURE TO ADDRESS CONTAMINATION (GWR)	A system with a fecal indicator positive sample (that has not been invalidated by the State) and after 120 days of receiving notice of the fecal indicator positive sample has failed to: 1) complete corrective action in accordance with any applicable State plan review processes or other State guidance and direction. [141.404(b)(1)]
HQ	51	INITIAL TAP SAMPLING (PB/CU)	Failure to monitor for lead and copper in accordance with 5-1.42
HQ	52	FOLLOW-UP OR ROUTINE TAP Monitoring / Reporting (M/R) (PB/CU)	Failure to monitor for lead and copper in accordance with 5-1.42

VIOLATION TYPES

State or EPA HQ	Type Code	VIOLATION NAME	ALTERNATE DESCRIPTION
HQ	53	WATER QUALITY PARAMETER M/R (LCR)	Failure to collect the required number of WQP samples using correct sampling procedures and conduct analyses using the correct procedures. [141.87(a) - (e)]
HQ	56	INITIAL/FOLLOW-UP/ROUTINE SOWT M/R (LCR)	Failure to collect the required number of source water samples using correct sampling procedures and conduct analyses using the correct procedures in accordance with 141.88(a)(1) - (e)(1). [141.88(a)(1) - (e)(1)]
	57	OCCT/SOWT RECOMMENDATION/STUDY (LCR)	For an SOWT Recommendation violation, failure to submit a SOWT recommendation no later than 180 days after the end of the monitoring period during which the lead or copper action level was exceeded. [141.83(a)(1) & 141.90(d)(1)]
HQ	58	OPTIMAL CORROSION CONTROL TREATMENT / SOURCE WATER TREATMENT (OCCT/SOWT) INSTALLATION DEMONSTRATION	Failure to install and operate Optimal Corrosion Control Treatment (OCCT) or fail to demonstrate that OCCT already is in place.
HQ	59	WQP LEVEL NON-COMPLIANCE (LCR)	Failure to: Maintain OWQP minimum or ranges in accordance with 141.82(g). Also, If you adopted the OWQP compliance method from the LCRMR, the violation definition also includes failure to: Meet daily values for more than 9 days in a 6-month monitoring period. [141.82(g)]
HQ	63	MPL LEVEL NON-COMPLIANCE (LCR)	Failure to meet either State-designated or approved MPL in accordance with 141.83(b)(5).
HQ	64	LEAD SERVICE LINE REPLACEMENT (LCR)	A system which exceeds the lead action level after implementation of applicable corrosion control and/or source water treatment requirements (whichever sampling occurs later) and fails to complete the lead service line replacement requirements. [141.84(a)]
HQ	65	PUBLIC EDUCATION LEAD / COPPER (PB/CU)	Failure to deliver public education materials where lead action level is exceeded.
HQ	71	CONSUMER CONFIDENCE REPORT (CCR)	Failure to provide Consumer Confidence Report
HQ	72	CCR ADEQUACY/AVAILABILITY/CONTENT	Delivery of a CCR that is significantly deficient in content to the extent that the CCR does not meet the requirements of the SDWA and the Federal regulations. [141.205]
HQ	75	PUBLIC NOTICE RULE LINKED TO VIOLATION	Failure to Public Notice Violation of National Primary Drinking Water Regulations (NPDWR)
ST	93	MONITORING, ROUTINE MAJOR	Failure to monitor in accordance with section NAC 445.1.456 or perform analysis with approved methods

VIOLATION TYPES

State or EPA HQ	Type Code	VIOLATION NAME	ALTERNATE DESCRIPTION
ST	S1	MAXIMUM CONTAMINANT LEVEL (MCL), AVERAGE, WITH NUMBER OF EXCEDENCE	Excedence of MAXIMUM CONTAMINANT LEVEL (MCL) per NAC 445A.455