

**STATE OF NEVADA
PUBLIC WATER SYSTEMS
ANNUAL COMPLIANCE REPORT
FOR
THE YEAR 2019**



NEVADA DIVISION OF

**ENVIRONMENTAL
PROTECTION**

**NEVADA DIVISION OF ENVIRONMENTAL PROTECTION
BUREAU OF SAFE DRINKING WATER**

**901 S. STEWART ST., Ste. 4001
CARSON CITY, NV 89701**

TABLE OF CONTENTS

The Drinking Water Program: An Overview	page 1
Nevada Public Water Systems General Information	page 5
2019 Violation Statistics	page 6
2019 Violations Summary Report	page 7
Nevada Public Water Systems And Water Sources	Section 2
Annual Compliance Report by Chemical.....	Appendix A
Annual Compliance Detail Report by Water System	Appendix B
Attachment A: Rule-Specific Violation Criteria	A-1
Attachment V: Violation Type Codes.	V-1

The Drinking Water Program: An Overview

The EPA established the Public Water System Supervision (PWSS) Program under the authority of the 1974 Safe Drinking Water Act (SDWA). Under the SDWA and the 1986 Amendments, EPA sets national limits on contaminant levels in drinking water to ensure that the water is safe for human consumption. These limits are known as Maximum Contaminant Levels (MCLs) and the Maximum Residual Disinfectant Levels (MRDLs). For some regulations, EPA establishes treatment techniques in lieu of an MCL to control unacceptable levels of contaminants in water. The Agency also regulates how often public water systems (PWSs) monitor their water for contaminants and report the monitoring results to the states or EPA. Generally, the larger the population served by a water system, the more frequent the monitoring and reporting (M/R) requirements. In addition, EPA requires PWSs to monitor for unregulated contaminants to provide data for future regulatory development. Finally, EPA requires PWSs to notify their consumers when they have violated these regulations. The 1996 Amendments to the SDWA require consumer notification to include a clear and understandable explanation of the nature of the violation, its potential adverse health effects, steps that the PWS is undertaking to correct the violation and the possibility of alternative water supplies during the violation.

The SDWA applies to the 50 states, the District of Columbia, Indian Lands, Puerto Rico, the Virgin Islands, American Samoa, Guam, and the Commonwealth of the Northern Mariana Islands.

The SDWA allows states and territories to seek EPA approval to administer their own PWSS Programs. The authority to run a PWSS Program is called primacy. For a state to receive primacy, EPA must determine that the state meets certain requirements laid out in the SDWA and the regulations, including the adoption of drinking water regulations that are at least as stringent as the Federal regulations and a demonstration that they can enforce the program requirements. Of the 56 states and territories, all but Wyoming and the District of Columbia have primacy. The EPA Regional Offices administer the PWSS Programs within these two jurisdictions.

The 1986 SDWA Amendments gave Indian Tribes the right to apply for and receive primacy. EPA currently administers PWSS Programs on all Indian lands except the Navaho Nation, which was granted primacy in late 2000.

Annual State PWS Report

Each quarter, primacy states submit data to the Safe Drinking Water Information System (SDWIS/FED), an automated database maintained by EPA. The data submitted include, but are not limited to, PWS inventory information, the incidence of Maximum Contaminant Level, Maximum Residual Disinfectant Level, monitoring, and treatment technique violations; and information on enforcement activity related to these violations. Section 1414(c)(3) of the Safe Drinking Water Act requires states to provide EPA with an annual report of violations of the primary drinking water standards. This report provides the numbers of violations in each of six categories: MCLs, MRDLs treatment techniques, variances and exemptions, significant monitoring violations, and significant consumer notification violations. The EPA Regional Offices report the information for Wyoming, the District of Columbia, and all Indian Lands but the Navaho Nation. EPA Regional offices also report Federal enforcement actions taken. Data retrieved from SDWIS/FED form the basis of this report.

Public Water System

A Public Water System (PWS) is defined as a system that provides water via piping or other constructed conveyances for human consumption to at least 15 service connections or serves an average of at least 25 people for at least 60 days each year. There are three types of PWSs. PWSs can be community (such as towns), non-transient non-community (such as schools or factories), or transient non-community systems (such as rest stops or parks). For this report when the acronym "PWS" is used, it means systems of all types unless specified in greater detail.

Maximum Contaminant Level

Under the Safe Drinking Water Act (SDWA), the EPA sets national limits on contaminant levels in drinking water to ensure that the water is safe for human consumption. These limits are known as Maximum Contaminant Levels (MCLs).

Maximum Residual Disinfectant Level

The EPA sets national limits on residual disinfectant levels in drinking water to reduce the risk of exposure to disinfectant byproducts formed, when public water systems add chemical disinfectant for either primary or residual treatment. These limits are known as Maximum Residual Disinfectant Levels (MRDLs).

Treatment Techniques

For some regulations, the EPA establishes treatment techniques (TTs) in lieu of an MCL to control unacceptable levels of certain contaminants. For example, treatment techniques have been established for viruses, some bacteria, and turbidity.

Variations and Exemptions

A primacy state can grant a PWS a variance from a primary drinking water regulation if the characteristics of the raw water sources reasonably available to the PWS do not allow the system to meet the MCL. To obtain a variance, the system must agree to install the best available technology, treatment techniques, or other means of limiting drinking water contamination that the Administrator finds are available (taking costs into account), and the state must find that the variance will not result in an unreasonable risk to public health. The variance shall be reviewed not less than every 5 years to determine if the system remains eligible for the variance.

A primacy state can grant an exemption temporarily relieving a PWS of its obligation to comply with an MCL, treatment technique, or both if the system's noncompliance results from compelling factors (which may include economic factors) and the system was in operation on the effective date of the MCL or treatment technique requirement. The state will require the PWS to comply with the MCL or treatment technique as expeditiously as practicable, but not later than 3 years after the otherwise applicable compliance date.

Monitoring

A PWS is required to monitor and verify that the levels of contaminants present in the water do not exceed the MCL. If a PWS fails to have its water tested as required or fails to report test results correctly to the primacy agent, a monitoring violation occurs.

Significant Monitoring Violations

For this report, significant monitoring violations are generally defined as any significant monitoring violation that occurred during the calendar year of the report. A Significant monitoring violation, with rare exceptions, occurs when no samples were taken or no results were reported during a compliance period.

Consumer Notification

Every Community Water System is required to deliver to its customers a brief annual water quality report. This report is to include some educational material, and will provide information on the source water, the levels of any detected contaminants, and compliance with drinking water regulations.

Significant Consumer Notification Violations

For this report, a significant public notification violation occurred if a community water system completely failed to provide its customers the required annual water quality report.

Public Notice Violations

The Public Notification Rule requires all PWS to notify their consumers any time a PWS violated a national primary drinking water regulation or has a situation posing a risk to public health. Notices must be provided to persons served (not just billing consumers).

NEVADA PUBLIC WATER SYSTEMS
GENERAL INFORMATION

There are **606 Active Public Water Systems in Nevada:**

198 Community Systems serving **2,837,424** people.

164 systems serve between 25 and 3,300 people.
22 systems serve between 3,301 and 10,000 people.
7 systems serve between 10,001 and 50,000 people.
5 systems serve more than 50,001 people.

24 of the Community Water Systems use surface water and serve **2,581,186** of the **2,837,424** people that are served by Community water systems.

156 Non-Transient Non-Community Systems (NTNC) serving **231,546** people.

135 systems serve between 25 and 3,300 people.
16 systems serve between 3,301 and 10,000 people.
5 systems serve more than 10,001 people.

36 of the Non-Transient Non-Community Systems use surface water and serve **183,865** of the **231,546** people served by NTNC systems.

252 Transient Non-Community Systems (NC) serving **35,183** people.

All of the Transient Non-Community Systems serve between 25 and 3,300 people.

3 of the Transient Non-Community Systems use surface water and serve **142** of the **35,183** people served by NC systems.

Where to Obtain the 2019 Annual State Public Water Systems Report

NEVADA publishes their Annual Compliance Report and distributes them to the county libraries in the state. It is also available on the Bureau of Safe Drinking Water web site at: <https://ndep.nv.gov/water/drinking-water>

2019 VIOLATION STATISTICS FOR NEVADA WATER SYSTEMS

Total number of regulated systems	606
Total number of violations	938
Total number of systems that had one or more violations	264
Total number of systems that returned to compliance	138
Total number of systems still in violation	126

State of Nevada 2019 PWS Compliance Report
Violations for Compliance Year 2019

Violations Category	Systems in Violation	Violations
Maximum Contaminant Level Exceedance Violations	29	125
Chemical Contaminant Group Monitoring Violations	82	209
Maximum Containment Level Violations, E.coli (RTCR)	2	3
Revised Total Coliform Rule Monitoring Violations	100	153
Revised Total Coliform Rule Treatment Technique Violations	7	10
Surface Water Treatment Rule, Interim Enhanced Surface Water Lead and Copper Rule	1	16
Consumer Confidence Report	17	29
Disinfection Byproducts Rule – Stage 1	28	28
Disinfection Byproducts Rule – Stage 2	16	25
Ground Water Rule	27	31
Public Notice Violations	49	60
State Certified Operator Failure	3	3
State Secondary Maximum Contaminant Level Exceedance Violations	3	3
State Secondary Chemical Contaminant Group Monitoring Violations	44	157
	53	86

2019 Nevada Annual Compliance Summary Report

Maximum Contaminant Violations							
Epa Region	Primacy Agency Code	Violation Category	Rule Group	Rule Name	# of Viols	# of RTC Viols	# of PWS in Viols
9	NV	Maximum Contaminant Level Violation	Chems	Arsenic	93	51	19
9	NV	Maximum Contaminant Level Violation	Chems	IOC	11	11	1
9	NV	Maximum Contaminant Level Violation	Chems	Nitrates	11	8	8
9	NV	Maximum Contaminant Level Violation	Chems	Rads	10	10	2
9	NV	Maximum Contaminant Level Violation	Chems	Organics	0	0	0
9	NV	Maximum Contaminant Level Violation	DBPs	St2 DBP	3	0	2
9	NV	Maximum Contaminant Level Violation	Microbial	RTCR	3	3	2
	NV	State Maximum Contaminant Level Violation	Secondaries	Secondaries	157	114	44
Total =					288	197	78

Monitoring and Reporting Violations							
Epa Region	Primacy Agency Code	Violation Category	Rule Group	Rule Name	# of Viols	# of RTC Viols	# of PWS in Viols
9	NV	Monitoring and Reporting	Chems	IOC	69	22	52
9	NV	Monitoring and Reporting	Chems	LCR	26	10	16
9	NV	Monitoring and Reporting	Chems	Nitrates	63	38	55
9	NV	Monitoring and Reporting	Chems	Rads	29	22	8
9	NV	Monitoring and Reporting	Chems	Organics	49	11	22
9	NV	Monitoring and Reporting	DBPs	St1 DBP	25	21	16
9	NV	Monitoring and Reporting	DBPs	St2 DBP	28	19	25
9	NV	Monitoring and Reporting	Microbial	GWR	10	10	9
9	NV	Monitoring and Reporting	Microbial	TCR	0	0	0
9	NV	Monitoring and Reporting	Microbial	RTCR	153	142	101
9	NV	Monitoring and Reporting	SWTR	SWTR	16	16	1
	NV	State Monitoring and Reporting	Secondaries	Secondaries	86	41	53
Total =					554	352	358

2019 Nevada Annual Compliance Summary Report

Other Violations							
Epa Region	Primacy Agency Code	Violation Category	Rule Group	Rule Name	# of Viols	# of RTC Viols	# of PWS in Viols
9	NV	Other Violation	Other	Other	3	0	3
9	NV	Other Violation	Chems	LCR	1	0	1
9	NV	Other Violation	Other	CCR	28	19	28
9	NV	Other Violation	Other	PN rule	3	3	3
Total =					35	22	35

Treatment Technique Violations							
Epa Region	Primacy Agency Code	Violation Category	Rule Group	Rule Name	# of Viols	# of RTC Viols	# of PWS in Viols
9	NV	Treatment Technique Violation	Microbial	RTCR	9	8	7
9	NV	Treatment Technique Violation	Microbial	GWR	50	26	41
9	NV	Treatment Technique Violation	Chems	LCR	2	1	1
Total =					61	35	49

Acronym	Description
CCR	Consumer Compliance Rule
GWR	Ground Water Rule
LCR	Lead and Copper Rule
IOC	Inorganic Chemicals
PN Rule	Public Notice Rule
Rads	Radionuclides
St1 DBP	Stage 1 Disinfection By-Products
St2 DBP	Stage 2 Disinfection By-Products
TCR	Total Coliform Rule
RTCR	Revised Total Coliform Rule
SWTR	Surface Water Treatment Rule

Nevada Water Systems and Water Sources

County	Water System Type	Water System ID	Water System Name	Population Served	Primary Water Source	Primary Sources Type	Number of Sources	Additional Source Type	Number of Sources
WASHOE	NC	NV0000735	4TH STREET BISTRO	30	GROUNDWATER		1		
LINCOLN	NC	NV0002563	A COWBOYS DREAM	26	GROUNDWATER		1		
HUMBOLDT	NC	NV0000915	A1 FUEL STOP	25	GROUNDWATER		1		
LYON	NTNC	NV0001195	ACG MATERIALS	63	GROUNDWATER		1		
NYE	NTNC	NV0001181	ACRES CULTIVATION	248	GROUNDWATER		1		
WASHOE	NC	NV0000703	AIR BASE INN	25	GROUNDWATER		1		
WASHOE	NC	NV0000866	AIR SAILING INC GLIDERPORT	25	GROUNDWATER		1		
LINCOLN	C	NV0000005	ALAMO SEWER AND WATER GID	900	GROUNDWATER		2		
NYE	NTNC	NV0002190	AMARGOSA ELEMENTARY SCHOOL	200	GROUNDWATER		1	CONSECUTIVE CONNECTION(S)	1
NYE	NC	NV0000828	AMARGOSA PARK	25	GROUNDWATER		1		
NYE	NTNC	NV0003061	AMARGOSA SENIOR CENTER	25	GROUNDWATER		1		
NYE	NTNC	NV0005037	AMARGOSA TOWN COMPLEX	25	GROUNDWATER		1		
NYE	NC	NV0000155	AMARGOSA VALLEY RV PARK	25	GROUNDWATER		1		
NYE	NC	NV0000811	AMARGOSA VALLEY VFW POST 6826	25	GROUNDWATER		1		
NYE	C	NV0002558	AMARGOSA WATER COMPANY	54	GROUNDWATER		2		
NYE	C	NV0005033	ANCHOR IN MHP	36	GROUNDWATER		1		
ELKO	NC	NV0002088	ANGEL CREEK CAMPGROUND USFS	75	GROUNDWATER		1		
ELKO	NC	NV0003037	ANGEL LAKE CAMPGROUND USFS	100	GROUNDWATER		1		
WASHOE	NC	NV0004088	ANIMAL ARK	100	GROUNDWATER		1		
LANDER	NC	NV0004105	ANTELOPE VALLEY MEETINGHOUSE LDS	25	GROUNDWATER		1		
CLARK	NTNC	NV0000379	APEX REGIONAL WASTE MGMT CENTER	107	GROUNDWATER		1		
NYE	NC	NV0004027	ASH MEADOWS NATIONAL WILDLIFE REFUGE FWS	25	GROUNDWATER		1		
STOREY	NTNC	NV0000879	ASIA UNION ELECTRONIC CHEMICALS RENO	25	GROUNDWATER		1		
NYE	NC	NV0003010	BAILEYS HOT SPRINGS	25	GROUNDWATER		1		
WHITE PINE	NC	NV0003052	BAKER CREEK CAMPGROUND NPS	45	GROUNDWATER		1		
WHITE PINE	C	NV0000863	BAKER WATER AND SEWER GID	85	GROUNDWATER		1		
WHITE PINE	NTNC	NV0000982	BALD MOUNTAIN MINE	110	GROUNDWATER		1		
CLARK	NTNC	NV0001162	BALLY'S	7850	PURCHASED SURFACE WATER		1	CONSECUTIVE CONNECTION(S)	
WASHOE	NC	NV0000720	BAR M BAR	25	GROUNDWATER		1		
LANDER	NTNC	NV0000892	BARRICK CORTEZ GOLD MINES PIPELINE	555	GROUNDWATER		1		
LANDER	NTNC	NV0001097	BARRICK CORTEZ HILLS	611	GROUNDWATER		1		
EUREKA	NTNC	NV0005077	BARRICK GOLDSTRIKE FACILITY	2100	GROUNDWATER		1		
HUMBOLDT	NTNC	NV0002528	BARRICK TURQUOISE RIDGE INC	480	GROUNDWATER		1		
NYE	NC	NV0004026	BASE CAMP US AIR FORCE	25	GROUNDWATER		2		
LANDER	NC	NV0004126	BATTLE MOUNTAIN AIRPORT AND RACEWAY	200	GROUNDWATER		1		
NYE	NC	NV0005038	BEATTY RV PARK	25	GROUNDWATER		1		

Nevada Water Systems and Water Sources

County	Water System Type	Water System ID	Water System Name	Population Served	Primary Water Source	Primary Sources Type	Number of Sources	Additional Source Type	Number of Sources
NYE	C	NV0000009	BEATTY WATER AND SANITATION DISTRICT	1024	GROUNDWATER		6	WELL(S)	
LINCOLN	NC	NV0002120	BEAVER DAM STATE PARK	25	GROUNDWATER		1	WELL(S)	
CLARK	NTNC	NV0001117	BELLAGIO RESORT AND CASINO	17171	PURCHASED SURFACE WATER		1	CONSECUTIVE CONNECTION(S)	
CLARK	NTNC	NV0001155	BERKLEY	672	PURCHASED SURFACE WATER		1	CONSECUTIVE CONNECTION(S)	
NYE	NC	NV0002151	BERLIN ICHTHYOSAUR STATE PARK	50	GROUNDWATER		1	WELL(S)	
CLARK	C	NV0000147	BERMUDA PALMS MANAGEMENT LLC	60	GROUNDWATER		1	WELL(S)	
DOUGLAS	NC	NV0002041	BEST WESTERN TOPAZ LAKE INN	300	GROUNDWATER		1	WELL(S)	
CLARK	C	NV0004092	BIG BEND WATER DISTRICT	8800	SURFACE WATER		1	INTAKE(S)	
NYE	C	NV0000362	BIG FIVE PARK	65	GROUNDWATER		1	WELL(S)	
NYE	C	NV0000369	BIG VALLEY MHP	50	GROUNDWATER		2	WELL(S)	
WHITE PINE	NC	NV0003053	BIRD CREEK CAMPGROUND USFS	30	GROUNDWATER		1	WELL(S)	
WASHOE	NC	NV0000381	BLACK ROCK STATION	25	GROUNDWATER		1	WELL(S)	
CLARK	NC	NV0000323	BLUE DIAMOND RAINBOW SW PLAZA WATER	100	GROUNDWATER		1	WELL(S)	
CLARK	NC	NV0000955	BLUE DIAMOND TRAVEL CENTER H-325	33	GROUNDWATER		1	WELL(S)	
CLARK	C	NV0000092	BLUE DIAMOND WATER CO OP INC	85	GROUNDWATER		1	SPRING(S)	
CLARK	C	NV0000010	BLUE DIAMOND WATER COMPANY	527	PURCHASED GROUNDWATER		1	CONSECUTIVE CONNECTION(S)	
LANDER	NC	NV0003066	BOB SCOTT CAMPGROUND USFS	25	GROUNDWATER		1	WELL(S)	
ESMERALDA	NC	NV0002090	BOONIES	50	GROUNDWATER		1	WELL(S)	
WHITE PINE	NC	NV0005059	BORDER INN	25	GROUNDWATER		1	WELL(S)	
CLARK	C	NV0000011	BOULDER CITY	15000	PURCHASED SURFACE WATER		1	CONSECUTIVE CONNECTION(S)	
WASHOE	NC	NV0000710	BOWERS MANSION	100	GROUNDWATER		1	WELL(S)	
CLARK	NC	NV0000321	BRANDOS SPORTS BAR	105	GROUNDWATER		1	WELL(S)	
LYON	NC	NV0000389	BUCKBOARD GENERAL STORE	25	GROUNDWATER		1	WELL(S)	
NYE	C	NV0002538	C VALLEY MHP	54	GROUNDWATER		2	WELL(S)	
LINCOLN	C	NV0000013	CALIENTE PUBLIC UTILITIES	1100	GROUNDWATER		3	WELL(S)	
ELKO	NC	NV0001091	CALIFORNIA NATIONAL HISTORIC TRAILS CTR	178	GROUNDWATER		1	WELL(S)	
NYE	C	NV0000408	CALVADA MEADOWS GBWC	77	GROUNDWATER		1	WELL(S)	
DOUGLAS	NC	NV0004033	CAMP GALILEE	30	GROUNDWATER		1	WELL(S)	
CLARK	NC	NV0002509	CAMP LADY OF THE SNOWS	60	GROUNDWATER		1	WELL(S)	
ELKO	NC	NV0004050	CAMP LAMOILLE LIONS CLUB	50	GROUNDWATER		1	WELL(S)	
CLARK	NC	NV0005009	CAMP LEE CANYON CCPR	30	GROUNDWATER		1	WELL(S)	

Nevada Water Systems and Water Sources

County	Water System Type	Water System ID	Water System Name	Population Served	Primary Water Source	Primary Sources Type	Number of Sources	Additional Source Type	Number of Sources
CLARK	NC	NV0002502	CAMP POTOSI CCPR	26	GROUNDWATER		1	WELL(S)	
STOREY	C	NV0005056	CANYON GID	1310	GROUNDWATER		2	WELL(S)	
NYE	NC	NV0000405	CARBERRY SQUARE	50	GROUNDWATER		1	WELL(S)	
ELKO	NTNC	NV0002524	CARLIN HONOR CAMP NDOC	147	GROUNDWATER		1	WELL(S)	
ELKO	C	NV0000014	CARLIN UTILITIES	2500	GROUNDWATER		1	WELL(S)	SPRING(S)
LYON	NC	NV0000341	CARMENS MEXICAN RESTAURANT	25	GROUNDWATER		1	WELL(S)	
CARSON CITY	C	NV0000015	CARSON CITY PUBLIC WORKS	56000	SURFACE WATER		30	WELL(S)	SPRING(S)
CHURCHILL	C	NV0003068	CARSON RIVER ESTATES	90	GROUNDWATER		3	WELL(S)	
NYE	NC	NV0002140	CARVERS CAFE	50	GROUNDWATER		1	WELL(S)	
NYE	C	NV0000218	CARVERS SMOKEY VALLEY RV AND MHP	250	GROUNDWATER		1	WELL(S)	
WHITE PINE	NC	NV0004035	CAVE LAKE STATE PARK	2000	GROUNDWATER		1	SPRING(S)	
DOUGLAS	C	NV0000259	CAVE ROCK SKYLAND	1267	SURFACE WATER		1	INTAKE(S)	
WHITE PINE	NC	NV0000301	CAVE SPRINGS WATER SYSTEM NPS	1000	GROUNDWATER		3	SPRING(S)	
NYE	NTNC	NV0001095	CEDAR PASS WATER SYSTEM	250	GROUNDWATER		1	WELL(S)	
CLARK	NTNC	NV0000364	CERTAIN TEED GYPSUM	85	GROUNDWATER		2	WELL(S)	
LYON	NC	NV0002128	CG BAR	25	GROUNDWATER		1	WELL(S)	
NYE	NC	NV0002555	CHAMPIONS	25	GROUNDWATER		1	WELL(S)	
WHITE PINE	NC	NV0002165	CHERRY CREEK WATER DISTRICT	25	GROUNDWATER		1	WELL(S)	
NYE	NC	NV0003060	CHERRY PATCH LOVE RANCH	25	GROUNDWATER		1	WELL(S)	
NYE	NC	NV0004085	CHICKEN RANCH	25	GROUNDWATER		2	WELL(S)	
DOUGLAS	NTNC	NV0005078	CHINA SPRINGS YOUTH CAMP	92	GROUNDWATER		1	WELL(S)	
NYE	C	NV0002554	CHIPMUNK RETREAT	44	GROUNDWATER		1	WELL(S)	
CLARK	NTNC	NV0002533	CHUCK LENZIE GENERATING STATION	54	GROUNDWATER		3	WELL(S)	
WASHOE	NC	NV0004079	CHUCKS CIRCLE C MARKET	25	GROUNDWATER		1	WELL(S)	
LYON	NC	NV0005020	CHURCHILL BUTTE COMPLEX	25	GROUNDWATER		1	WELL(S)	
CLARK	NTNC	NV0001113	CIRCUS CIRCUS CASINO	2668	PURCHASED SURFACE WATER		1	CONSECUTIVE CONNECTION(S)	
CLARK	NTNC	NV0001106	CITY CENTER HOTELS	8900	PURCHASED SURFACE WATER		1	CONSECUTIVE CONNECTION(S)	
PERSHING	NTNC	NV0003076	COEUR ROCHESTER INC	32	GROUNDWATER		1	WELL(S)	
CLARK	C	NV0004000	COLD CREEK CANYON HOMEOWNERS	180	GROUNDWATER		2	WELL(S)	
WHITE PINE	C	NV0005057	COLD CREEK MHP	35	GROUNDWATER		1	WELL(S)	
WASHOE	NC	NV0004103	COLD SPRINGS MEETINGHOUSE LDS	25	GROUNDWATER		1	WELL(S)	
CHURCHILL	NC	NV0002017	COLD SPRINGS STATION RESORT	25	GROUNDWATER		1	WELL(S)	
HUMBOLDT	NC	NV0002113	COMMUNITY HALL PARADISE VALLEY	72	GROUNDWATER		1	WELL(S)	
WASHOE	C	NV0000277	CONESTOGA MHP	120	GROUNDWATER		1	WELL(S)	
CLARK	NC	NV0001024	CORN CREEK FIELD STATION FWS	25	GROUNDWATER		1	WELL(S)	
LANDER	NTNC	NV0002570	CORTEZ MILL 1 POTABLE WATER SYSTEM	83	GROUNDWATER		1	WELL(S)	

Nevada Water Systems and Water Sources

County	Water System Type	Water System ID	Water System Name	Population Served	Primary Water Source	Primary Sources Type	Number of Sources	Additional Source Type	Number of Sources
CLARK	NTNC	NV0001137	COSMOPOLITAN HOTEL	5534	PURCHASED SURFACE WATER		1	CONSECUTIVE CONNECTION(S)	
CARSON CITY	C	NV0000017	COTTONWOOD MHP	250	GROUNDWATER		3	WELL(S)	
NYE	C	NV0005032	COUNTRY VIEW ESTATES GBWC	1292	GROUNDWATER		3	WELL(S)	
NYE	NC	NV0000385	COYOTE CORNER III	25	GROUNDWATER		1	WELL(S)	
NYE	NC	NV0002565	COYOTE CORNER MARKET	25	GROUNDWATER		1	WELL(S)	
CLARK	NTNC	NV0001081	CREECH AIR FORCE BASE	4200	GROUNDWATER		3	WELL(S)	
NYE	NTNC	NV0000418	CRESCENT DUNES SOLAR ENERGY	40	GROUNDWATER		2	WELL(S)	
EUREKA	C	NV0000043	CRESCENT VALLEY WATER SYSTEM	340	GROUNDWATER		2	WELL(S)	
CLARK	NTNC	NV0001164	CROMWELL HOTEL AND CASINO	1500	PURCHASED SURFACE WATER		1	CONSECUTIVE CONNECTION(S)	
WASHOE	NC	NV0000717	CROSBYS LODGE	25	GROUNDWATER		1	WELL(S)	
WASHOE	NC	NV0000718	CRYSTAL PEAK PARK	30	GROUNDWATER		1	WELL(S)	
WASHOE	C	NV0000193	CRYSTAL TP	80	GROUNDWATER		2	WELL(S)	
HUMBOLDT	NTNC	NV0001191	CSS FARMS LLC	30	GROUNDWATER		1	WELL(S)	
WASHOE	NC	NV0000719	DAVIS CREEK PARK	100	GROUNDWATER		1	WELL(S)	
LYON	NC	NV0000881	DAYTON TAP HOUSE LLC	25	GROUNDWATER		1	WELL(S)	
LYON	C	NV0000032	DAYTON VALLEY WATER SYSTEM	15830	GROUNDWATER		9	WELL(S)	CONSECUTIVE CONNECTION(S)
HUMBOLDT	NC	NV0000001	DENIO JUNCTION	25	GROUNDWATER		1	WELL(S)	
MINERAL	NTNC	NV0001156	DENTON RAWHIDE MINE	75	GROUNDWATER		2	WELL(S)	
NYE	NC	NV0002196	DESERT CENTER PLAZA	300	GROUNDWATER		1	WELL(S)	
WASHOE	NC	NV0000736	DESERT INVESTMENT GROUP LTD	250	GROUNDWATER		2	WELL(S)	
NYE	C	NV0000831	DESERT MIRAGE HOMEOWNERS ASSOCIATION	230	GROUNDWATER		2	WELL(S)	
CLARK	C	NV0000149	DESERT PARADISE MHP	70	GROUNDWATER		1	WELL(S)	
CLARK	NC	NV0001008	DESERT SOUTHWEST CONFERENCE	30	GROUNDWATER		1	WELL(S)	
NYE	C	NV0000300	DESERT UTILITIES	1086	GROUNDWATER		3	WELL(S)	
EUREKA	C	NV0002574	DEVILS GATE GID DISTRICT 1	65	GROUNDWATER		1	WELL(S)	
EUREKA	C	NV0002573	DEVILS GATE WATER SYSTEM GID 2	70	PURCHASED GROUNDWATER		1	CONSECUTIVE CONNECTION(S)	
HUMBOLDT	NC	NV0002094	DIAMOND INN BAR	25	GROUNDWATER		1	WELL(S)	
HUMBOLDT	NTNC	NV0001148	DIAMOND PLASTICS	38	GROUNDWATER		1	WELL(S)	
WASHOE	NC	NV0002609	DOLLAR GENERAL	123	GROUNDWATER		1	WELL(S)	
ELKO	NC	NV0004096	DOUBLE D BAR & GRILL	25	GROUNDWATER		1	WELL(S)	
DOUGLAS	NC	NV0002043	DOUGLAS COUNTY LAMPE PARK	200	GROUNDWATER		1	WELL(S)	
DOUGLAS	NC	NV0002044	DOUGLAS COUNTY TOPAZ PARK	100	GROUNDWATER		1	WELL(S)	
ELKO	NC	NV0000949	DOVETAIL RANCH	25	GROUNDWATER		1	WELL(S)	

Nevada Water Systems and Water Sources

County	Water System Type	Water System ID	Water System Name	Population Served	Primary Water Source	Primary Sources Type	Number of Sources	Additional Source Type	Number of Sources
LYON	NC	NV0002593	DRESSLER PARK	25	GROUNDWATER		1	WELL(S)	
PERSHING	C	NV0000809	DUTCHMAN ACRES	260	GROUNDWATER		2	WELL(S)	
ESMERALDA	NTNC	NV0002184	DYER ELEMENTARY SCHOOL	70	GROUNDWATER		1	WELL(S)	
LINCOLN	NC	NV0000188	EAGLE VALLEY RESORT	25	GROUNDWATER		2	WELL(S)	
LYON	NC	NV0003098	EAST 50 BAR	25	GROUNDWATER		1	WELL(S)	
DOUGLAS	NC	NV0002218	EAST PEAK LODGE	2000	GROUNDWATER		1	WELL(S)	
DOUGLAS	C	NV0002216	EAST VALLEY WATER SYSTEM	4030	PURCHASED GROUNDWATER		1	WELL(S)	CONSECUTIVE CONNECTION(S)
CLARK	C	NV0000106	EASTLAND HEIGHTS WATER ASSOCIATION	400	GROUNDWATER		2	WELL(S)	
LINCOLN	NC	NV0002123	ECHO CANYON STATE PARK	196	GROUNDWATER		1	WELL(S)	
WASHOE	NC	NV0004135	ECOLOGICA CORPORATION	25	GROUNDWATER		1	WELL(S)	
DOUGLAS	NTNC	NV0000235	EDGEWOOD WATER COMPANY	3800	SURFACE WATER		1	INTAKE(S)	CONSECUTIVE CONNECTION(S)
CLARK	NC	NV0004111	EL DORADO CANYON MINE TOURS	25	GROUNDWATER		1	WELL(S)	
NYE	NC	NV0001105	EL VALLE RESTAURANT	25	GROUNDWATER		1	WELL(S)	
DOUGLAS	C	NV0000271	ELK POINT COUNTRY CLUB	325	GROUNDWATER		2	WELL(S)	
ELKO	C	NV0000272	ELKO CITY OF	20451	GROUNDWATER		17	WELL(S)	
ELKO	C	NV0002075	ELKO RV PARK AT RYNDON	357	GROUNDWATER		2	WELL(S)	
NYE	NC	NV0000923	ELKS LODGE PAHRUMP	25	GROUNDWATER		1	WELL(S)	
WHITE PINE	NTNC	NV0004083	ELY CONSERVATION CAMP NDOC	150	GROUNDWATER		1	WELL(S)	
WHITE PINE	C	NV0005071	ELY MAXIMUM SECURITY PRISON NDOC	1099	GROUNDWATER		2	WELL(S)	
WHITE PINE	C	NV0000038	ELY MUNICIPAL WATER DEPARTMENT	5000	GROUNDWATER		6	WELL(S)	
WASHOE	C	NV0000042	EMPIRE MINING COMPANY	350	GROUNDWATER		2	WELL(S)	
STOREY	NTNC	NV0003075	EP MINERALS LLC CLARK	50	GROUNDWATER		1	WELL(S)	
CHURCHILL	NTNC	NV0004120	EP MINERALS LLC FERNLEY	41	GROUNDWATER		1	WELL(S)	
CLARK	C	NV0000109	EQUESTRIAN ESTATES CO OP WATER ASSOC	108	GROUNDWATER		2	WELL(S)	
NYE	C	NV0002552	ESCAPEE CO OP OF NEVADA	200	GROUNDWATER		2	WELL(S)	
ESMERALDA	NC	NV0000890	ESMERALDA MARKET AND GAS LLC	25	GROUNDWATER		2	WELL(S)	
EUREKA	NC	NV0004104	EUREKA MEETINGHOUSE LDS	70	GROUNDWATER		1	WELL(S)	
EUREKA	C	NV0000044	EUREKA WATER ASSOCIATION	450	GROUNDWATER		2	WELL(S)	SPRING(S)
CLARK	NTNC	NV0001114	EXCALIBUR RESORT AND CASINO	2607	PURCHASED SURFACE WATER		1	CONSECUTIVE CONNECTION(S)	
DOUGLAS	C	NV0002540	FAIRGROUNDS/SUNRISE ESTATES	911	GROUNDWATER		3	WELL(S)	
CHURCHILL	C	NV0000045	FALLON CITY OF	8500	GROUNDWATER		4	WELL(S)	CONSECUTIVE CONNECTION(S)
CHURCHILL	NC	NV0002594	FALLON LIVESTOCK LLC	25	GROUNDWATER		1	WELL(S)	
CHURCHILL	C	NV0000350	FALLON NAVAL AIR STATION	3000	GROUNDWATER		3	WELL(S)	CONSECUTIVE CONNECTION(S)
CHURCHILL	NC	NV0002534	FALLON RV PARK	25	GROUNDWATER		1	WELL(S)	

Nevada Water Systems and Water Sources

County	Water System Type	Water System ID	Water System Name	Population Served	Primary Water Source	Primary Sources Type	Number of Sources	Additional Source Type	Number of Sources
LYON	C	NV0000062	FERNLEY PUBLIC WORKS	18000	GROUNDWATER		6	WELL(S)	
WHITE PINE	NTNC	NV0001142	FIORÉ GOLD PAN MINE	100	GROUNDWATER		1	WELL(S)	
LANDER	NTNC	NV0001100	FIRE CREEK MINE	60	GROUNDWATER		1	WELL(S)	
WHITE PINE	NC	NV0002170	FIRESIDE INN	50	GROUNDWATER		1	WELL(S)	
ESMERALDA	NC	NV0000916	FISH LAKE VALLEY SALOON	25	GROUNDWATER		1	WELL(S)	
CLARK	NTNC	NV0001175	FLAMINGO LAS VEGAS HOTEL AND CASINO	9421	PURCHASED SURFACE WATER		1	CONSECUTIVE CONNECTION(S)	
PERSHING	NTNC	NV0000884	FLORIDA CANYON MINING INC	150	GROUNDWATER		1	WELL(S)	
CLARK	NC	NV0001053	FLOYD LAMB PARK	100	GROUNDWATER		2	WELL(S)	
WASHOE	C	NV0000200	FOOTHILL TRAILER PARK	35	GROUNDWATER		1	WELL(S)	
DOUGLAS	C	NV0000959	FOOTHILL WATER SYSTEM	346	GROUNDWATER		3	WELL(S)	
LYON	NC	NV0002132	FORT CHURCHILL HISTORIC STATE PARK	207	GROUNDWATER		1	WELL(S)	
WASHOE	NC	NV0000893	FRANKTOWN MEADOWS	25	GROUNDWATER		2	WELL(S)	
NYE	NTNC	NV0001174	FRONT SIGHT FIREARMS TRAINING INSTITUTE	224	GROUNDWATER		1	WELL(S)	
NYE	C	NV0000063	GABBS WATER SYSTEM	411	GROUNDWATER		2	WELL(S)	
NYE	NC	NV0000917	GAMEBIRD PLAZA LLC	25	GROUNDWATER		1	WELL(S)	
DOUGLAS	C	NV0000066	GARDNERVILLE RANCHOS GID	9500	GROUNDWATER		7	WELL(S)	
DOUGLAS	C	NV0000065	GARDNERVILLE WATER COMPANY	4500	GROUNDWATER		7	WELL(S)	CONSECUTIVE CONNECTION(S)
CHURCHILL	NC	NV0002587	GAS STORE WEST	25	GROUNDWATER		1	WELL(S)	
CLARK	NTNC	NV0000372	GEORGIA PACIFIC GYPSUM LLC	100	GROUNDWATER		1	WELL(S)	
WASHOE	C	NV0000071	GERLACH GID	180	GROUNDWATER		2	SPRING(S)	
CLARK	NC	NV0003029	GIRL SCOUTS NV CAMP FOXTAIL	250	GROUNDWATER		1	WELL(S)	
DOUGLAS	C	NV0000356	GLENBROOK WATER COOPERATIVE INC	1000	SURFACE WATER		1	INTAKE(S)	
HUMBOLDT	C	NV0005029	GOLCONDA GID	60	GROUNDWATER		2	WELL(S)	SPRING(S)
EUREKA	NTNC	NV0001159	GOLD BAR MINE	70	GROUNDWATER		2	WELL(S)	
HUMBOLDT	C	NV0003079	GOLD COUNTRY ESTATES	1695	GROUNDWATER		4	WELL(S)	CONSECUTIVE CONNECTION(S)
PERSHING	NC	NV0001124	GOLD DIGGERS SALOON & GRUBB HOUSE	25	GROUNDWATER		1	WELL(S)	
WASHOE	NTNC	NV0000751	GOLD RANCH CASINO	1000	GROUNDWATER		1	WELL(S)	
WASHOE	NC	NV0004064	GOLDEN VALLEY PARK	25	GROUNDWATER		1	WELL(S)	
ESMERALDA	C	NV0000072	GOLDFIELD TOWN WATER	350	GROUNDWATER		2	WELL(S)	
CLARK	NTNC	NV0001045	GOODSPRINGS SCHOOL CCSD	25	GROUNDWATER		1	WELL(S)	
CLARK	NTNC	NV0001144	GRANDVIEW AT LAS VEGAS	5750	PURCHASED SURFACE WATER		1	CONSECUTIVE CONNECTION(S)	
WASHOE	C	NV0000035	GRANDVIEW TERRACE WATER DISTRICT	328	GROUNDWATER		3	WELL(S)	
WASHOE	NTNC	NV0002202	GRANITE CONSTRUCTION	50	GROUNDWATER		1	WELL(S)	
WASHOE	NC	NV0004109	GRANITE HILLS BAPTIST CHURCH	94	GROUNDWATER		1	WELL(S)	

Nevada Water Systems and Water Sources

County	Water System Type	Water System ID	Water System Name	Population Served	Primary Water Source	Primary Sources Type	Number of Sources	Additional Source Type	Number of Sources
WASHOE	C	NV0000207	GREAT BASIN WATER CO COLD SPRINGS	7962	GROUNDWATER		5 WELL(S)		
WASHOE	C	NV0001086	GREAT BASIN WATER CO SPANISH SPRINGS	2030	GROUNDWATER		2 WELL(S)	CONSECUTIVE CONNECTION(S)	1
ELKO	C	NV0000036	GREAT BASIN WATER CO SPRING CREEK	6708	GROUNDWATER		9 WELL(S)		
ELKO	C	NV0005027	GREAT BASIN WATER CO SPRING CREEK MHP	7545	GROUNDWATER		3 WELL(S)		
NYE	C	NV0000270	GREAT BASIN WATER COMPANY	8538	GROUNDWATER		5 WELL(S)		
LINCOLN	NC	NV0002119	GREEN VALLEY GROCERY	25	GROUNDWATER		1 SPRING(S)		
LANDER	NTNC	NV0004117	GREYSTONE MINE	36	PURCHASED GROUNDWATER		1 CONSECUTIVE CONNECTION(S)		
CHURCHILL	NC	NV0002580	HARMON JUNCTION	150	GROUNDWATER		1 WELL(S)		
CLARK	NTNC	NV0001171	HARRAHS LAS VEGAS	8031	PURCHASED SURFACE WATER		1 CONSECUTIVE CONNECTION(S)		
CLARK	C	NV0001080	HARRIS SPRINGS RANCH	40	GROUNDWATER		1 WELL(S)		
MINERAL	C	NV0000357	HAWTHORNE ARMY DEPOT	300	SURFACE WATER		2 WELL(S)	INTAKE(S)	1
MINERAL	C	NV0000073	HAWTHORNE UTILITIES	2900	GROUNDWATER		5 WELL(S)		
CLARK	C	NV0000076	HENDERSON CITY OF	321781	SURFACE WATER		2 CONSECUTIVE CONNECTION(S)	INTAKE(S)	1
LYON	NC	NV0004037	HEYDAY INN	25	GROUNDWATER		1 WELL(S)		
WHITE PINE	NC	NV0000961	HIDDEN CANYON RANCH	140	GROUNDWATER		1 WELL(S)		
NYE	NC	NV0002141	HIGHWAY 95 FUEL & FOOD	25	GROUNDWATER		1 WELL(S)		
CLARK	C	NV0000145	HILLCREST MANOR WATER USERS ASSOCIATION	450	GROUNDWATER		2 WELL(S)		
CLARK	NTNC	NV0001160	HILTON GRAND VACATIONS CONVENTION	982	PURCHASED SURFACE WATER		1 CONSECUTIVE CONNECTION(S)		
CLARK	NTNC	NV0001143	HILTON GRAND VACATIONS ELARA	2544	PURCHASED SURFACE WATER		1 CONSECUTIVE CONNECTION(S)		
CLARK	NTNC	NV0001136	HILTON GRAND VACATIONS FLAMINGO	712	PURCHASED SURFACE WATER		1 CONSECUTIVE CONNECTION(S)		
CLARK	NTNC	NV0001150	HILTON GRAND VACATIONS LAS VEGAS BLVD	2488	PURCHASED SURFACE WATER		1 CONSECUTIVE CONNECTION(S)		
LYON	NTNC	NV0004053	HODGES TRANSPORTATION CO	160	GROUNDWATER		3 WELL(S)		
DOUGLAS	C	NV0002046	HOLBROOK STATION RV AND MHP	180	GROUNDWATER		2 WELL(S)		
CLARK	NTNC	NV0003006	HOOVER DAM	3000	SURFACE WATER		2 INTAKE(S)		

Nevada Water Systems and Water Sources

County	Water System Type	Water System ID	Water System Name	Population Served	Primary Water Source	Primary Sources Type	Number of Sources	Additional Source Type	Number of Sources
CLARK	NTNC	NV0001083	HOOVER DAM LODGE DBA HACIENDA	141	PURCHASED SURFACE WATER		1	CONSECUTIVE CONNECTION(S)	
NYE	NC	NV0000833	HORIZON C STORES 1 PAHRUMP VALLEY BLVD	25	GROUNDWATER		1	WELL(S)	
NYE	NC	NV0000827	HORIZON C STORES 2 TUMBLEWEED TAVERN	357	GROUNDWATER		1	WELL(S)	
NYE	NC	NV0000918	HORIZON C STORES 3 LINDA STREET	25	GROUNDWATER		1	WELL(S)	
HUMBOLDT	NTNC	NV0005069	HUMBOLDT CONSERVATION CAMP NDOC	140	GROUNDWATER		1	WELL(S)	
PERSHING	NC	NV0001125	HUMBOLDT RIVER RANCH ASSOCIATION	150	GROUNDWATER		1	WELL(S)	
HUMBOLDT	NTNC	NV0000864	HYCROFT RESOURCES & DEVELOPMENT	921	GROUNDWATER		1	WELL(S)	
CLARK	NC	NV0004073	IDLE SPURS LOUNGE AND RESTAURANT	58	GROUNDWATER		1	WELL(S)	
PERSHING	C	NV0000226	IMLAY WATER SYSTEM	200	GROUNDWATER		2	WELL(S)	
WASHOE	C	NV0000158	INCLINE VILLAGE GID	9313	SURFACE WATER		1	INTAKE(S)	
DOUGLAS	C	NV0000355	INDIAN HILLS GID	5700	GROUNDWATER		3	WELL(S)	CONSECUTIVE CONNECTION(S)
CLARK	C	NV0000082	INDIAN SPRINGS WATER CO INC	900	GROUNDWATER		2	WELL(S)	
MINERAL	NTNC	NV0001178	ISABELLA PEARL MINE	25	GROUNDWATER		2	WELL(S)	
CLARK	NC	NV0000331	J AND J GENERAL STORE	225	GROUNDWATER		1	WELL(S)	
ELKO	NC	NV0002069	JACK CREEK LODGE	25	GROUNDWATER		1	WELL(S)	
ELKO	C	NV0000088	JACKPOT WATER SYSTEM	1240	GROUNDWATER		5	WELL(S)	
ELKO	C	NV0002070	JARBIDGE WATER SYSTEM	200	SURFACE WATER		2	INTAKE(S)	
CLARK	C	NV0000089	JEAN UTILITY SERVICES INC	560	GROUNDWATER		3	WELL(S)	
ELKO	NTNC	NV0003013	JERRITT CANYON GOLD JERRITT CANYON MINE	125	GROUNDWATER		2	WELL(S)	
ELKO	NTNC	NV0000313	JERRITT CANYON GOLD SSX MINE	125	GROUNDWATER		1	WELL(S)	
ELKO	NC	NV0002071	JIGGS BAR	25	GROUNDWATER		1	WELL(S)	
WASHOE	NC	NV0000731	JOHNNY CASSINARIS RESTAURANT	150	GROUNDWATER		1	WELL(S)	
ELKO	NTNC	NV0001126	JOYGLOBAL SURFACE MINING INC	25	GROUNDWATER		1	WELL(S)	
CLARK	NTNC	NV0001107	KAPEX WATER SYSTEM CITY OF NLV	25	GROUNDWATER		1	WELL(S)	
WASHOE	C	NV0000199	KE TA MOBILE HOME PARK	60	GROUNDWATER		2	WELL(S)	
CHURCHILL	NTNC	NV0002024	KENNAMETAL INC	75	GROUNDWATER		1	WELL(S)	
LINCOLN	NC	NV0002121	KERSHAW RYAN STATE PARK	25	GROUNDWATER		1	WELL(S)	
CLARK	NC	NV0000932	KEYSTONE CENTER	30	GROUNDWATER		1	WELL(S)	
HUMBOLDT	NTNC	NV0002198	KINGS RIVER ELEMENTARY SCHOOL	27	GROUNDWATER		1	WELL(S)	
CLARK	C	NV0000287	KINGS ROW TP	860	GROUNDWATER		1	WELL(S)	CONSECUTIVE CONNECTION(S)
DOUGLAS	C	NV0000004	KINGSBURY GID	3839	SURFACE WATER		1	INTAKE(S)	
LANDER	C	NV0000265	KINGSTON TOWN WATER UTILITIES	350	GROUNDWATER		2	WELL(S)	
ELKO	NTNC	NV0000908	KLONDEX MIDAS OPERATIONS INC	80	GROUNDWATER		2	WELL(S)	
WHITE PINE	C	NV0002174	KOA OF ELY CAMPGROUND	80	GROUNDWATER		2	WELL(S)	

Nevada Water Systems and Water Sources

County	Water System Type	Water System ID	Water System Name	Population Served	Primary Water Source	Primary Sources Type	Number of Sources	Additonal Source Type	Number of Sources
WASHOE	NC	NV0000700	KRUSE FEED AND HARDWARE	1000	GROUNDWATER		1 WELL(S)		
CLARK	C	NV0000142	KYLE CANYON WATER DISTRICT	1040	GROUNDWATER		4 WELL(S)		
CHURCHILL	NC	NV0002028	LAHONTAN DAM STATE PARK	26	GROUNDWATER UNDER INFLUENCE OF SURFACE WATER		2 SPRING(S)		
LYON	NC	NV0002133	LAHONTAN DAM STATE PARK BEACH 3	25	GROUNDWATER		1 WELL(S)		
LYON	NC	NV0005021	LAHONTAN DAM STATE PARK BEACH 7	50	GROUNDWATER		1 WELL(S)		
CLARK	NC	NV0000942	LAKER PLAZA INC	27	PURCHASED SURFACE WATER		1 WELL(S)	CONSECUTIVE CONNECTION(S)	1
NYE	NTNC	NV0000834	LAKESIDE CASINO AND RV PARK	175	GROUNDWATER		1 WELL(S)		
ELKO	NTNC	NV0000928	LAMOILLE VALLEY PLAZA	351	GROUNDWATER		1 WELL(S)		
ELKO	C	NV0000273	LAMOILLE WATER USERS ASSOC	200	GROUNDWATER		2 WELL(S)		
LANDER	C	NV0000008	LANDER CO SEWER AND WATER DIST 1 BM	3635	GROUNDWATER		4 WELL(S)		
LANDER	C	NV0000006	LANDER CO SEWER AND WATER DIST 2 AUSTIN	350	GROUNDWATER		2 WELL(S)	SPRING(S)	1
WHITE PINE	NC	NV0004055	LANES TRAVEL CENTER	50	GROUNDWATER		1 WELL(S)		
CLARK	C	NV0000090	LAS VEGAS VALLEY WATER DISTRICT	1502604	SURFACE WATER		58 WELL(S)	CONSECUTIVE CONNECTION(S)	2
CHURCHILL	NC	NV0000938	LATTIN FARMS	25	GROUNDWATER		1 WELL(S)		
NYE	NC	NV0005068	LDS CHURCH PAHRUMP WARD	175	GROUNDWATER		1 WELL(S)		
ELKO	NC	NV0004005	LDS LEE RECREATION CAMP	100	GROUNDWATER		1 WELL(S)		
CLARK	NTNC	NV0000307	LEE CANYON SKI AREA	352	GROUNDWATER		2 WELL(S)		
EUREKA	NTNC	NV0000338	LEEVILLE POTABLE WATER SYSTEM	147	GROUNDWATER		2 WELL(S)		
WHITE PINE	NC	NV0003051	LEHMAN CREEK CAMPGROUND NPS	60	GROUNDWATER		1 SPRING(S)		
WASHOE	NC	NV0004077	LEMMON VALLEY HORSEMANS PARK	100	GROUNDWATER		1 WELL(S)		
CLARK	NTNC	NV0001000	LHOIST NORTH AMERICA	136	GROUNDWATER		2 WELL(S)		
WASHOE	C	NV0000865	LIGHTNING W	163	GROUNDWATER		3 WELL(S)		
CLARK	NTNC	NV0001163	LINQ HOTEL AND CASINO	5172	PURCHASED SURFACE WATER		1 CONNECTION(S)	CONSECUTIVE CONNECTION(S)	
LINCOLN	NC	NV0002192	LITTLE A LE INN	60	GROUNDWATER		1 WELL(S)		
DOUGLAS	C	NV0002050	LOGAN CREEK ESTATES GID	60	GROUNDWATER		1 WELL(S)		
CHURCHILL	NTNC	NV0001185	LOGOS CHRISTIAN ACADEMY	25	GROUNDWATER		1 WELL(S)		
HUMBOLDT	NTNC	NV0000907	LONE TREE MINE	150	GROUNDWATER		1 WELL(S)		
NYE	NTNC	NV0000871	LONGSTREET INN AND CASINO	185	GROUNDWATER		1 WELL(S)		
CLARK	NC	NV0000392	LOVELL CANYON RESIDENTIAL LLC	35	GROUNDWATER		1 WELL(S)		
PERSHING	C	NV0000861	LOVELOCK CORRECTIONAL CENTER NDOC	1630	PURCHASED GROUNDWATER		1 CONNECTION(S)	CONSECUTIVE CONNECTION(S)	
PERSHING	C	NV0000161	LOVELOCK MEADOWS WATER DISTRICT	3562	GROUNDWATER		3 WELL(S)		

Nevada Water Systems and Water Sources

County	Water System Type	Water System ID	Water System Name	Population Served	Primary Water Source	Primary Sources Type	Number of Sources	Additional Source Type	Number of Sources
CLARK	NTNC	NV0002602	LOVES TRAVEL STOP AND COUNTRY STORE	3025	GROUNDWATER		1 WELL(S)		
CLARK	C	NV0000140	LUNA VISTA	66	GROUNDWATER		1 WELL(S)		
WHITE PINE	NC	NV0004101	LUND MEETINGHOUSE LDS	25	GROUNDWATER		1 WELL(S)		
WHITE PINE	NTNC	NV0000979	LUND SCHOOL	140	GROUNDWATER		1 WELL(S)		
CLARK	NTNC	NV0001111	LUXOR RESORT AND CASINO	3196	PURCHASED SURFACE WATER		1 CONNECTION(S)	CONSECUTIVE	
HUMBOLDT	NC	NV0002220	LYE CREEK CAMPGROUND USFS	25	GROUNDWATER		1 SPRING(S)		
CLARK	NTNC	NV0001130	M RESORT SPA AND CASINO	3550	PURCHASED SURFACE WATER		1 CONNECTION(S)	CONSECUTIVE	
NYE	NC	NV0005019	MABELS BAR	25	GROUNDWATER		1 WELL(S)		
WASHOE	NC	NV0000738	MAGIC CARPET GOLF	25	GROUNDWATER		1 WELL(S)		
WHITE PINE	NC	NV0002175	MAJORS STATION	25	GROUNDWATER		1 WELL(S)		
CLARK	NTNC	NV0001119	MANDALAY BAY RESORT AND CASINO	10549	PURCHASED SURFACE WATER		1 CONNECTION(S)	CONSECUTIVE	
NYE	C	NV0000165	MANHATTAN TOWN WATER	40	GROUNDWATER		1 WELL(S)		
HUMBOLDT	NTNC	NV0001103	MARIGOLD MINE POTABLE WATER SYSTEM	300	GROUNDWATER		1 WELL(S)		
STOREY	NTNC	NV0000878	MARS PETCARE US INC	140	GROUNDWATER		1 WELL(S)		
HUMBOLDT	C	NV0000162	MCDERMITT WATER SYSTEM	200	GROUNDWATER		2 WELL(S)		
WHITE PINE	C	NV0000163	MCGILL WATER AND SEWER DIST	1200	GROUNDWATER		2 WELL(S)		
CLARK	NC	NV0002508	MCWILLIAMS WATER SYSTEM	2505	GROUNDWATER		1 WELL(S)	CONSECUTIVE CONNECTION(S)	1
WASHOE	NC	NV0000757	MELS DINER	1000	GROUNDWATER		1 WELL(S)		
WASHOE	NC	NV0000950	MEMORIAL POINT STATE PARK	25	GROUNDWATER		1 WELL(S)		
CLARK	NTNC	NV0001121	MGM GRAND HOTEL AND CASINO	15500	PURCHASED SURFACE WATER		1 CONNECTION(S)	CONSECUTIVE	
ELKO	NC	NV0003071	MIDAS WATER COOPERATIVE	25	GROUNDWATER		2 WELL(S)		
CHURCHILL	NC	NV0002027	MIDLEGATE STATION	25	GROUNDWATER		1 WELL(S)		
CARSON CITY	NC	NV0002006	MILL HOUSE INN MOTEL	50	GROUNDWATER		1 WELL(S)		
MINERAL	C	NV0000074	MINA LUNING WATER SYSTEM	300	GROUNDWATER		3 WELL(S)		
CLARK	NTNC	NV0001120	MIRAGE RESORT AND CASINO	4400	PURCHASED SURFACE WATER		1 CONNECTION(S)	CONSECUTIVE	
CLARK	C	NV0000160	MOAPA VALLEY WATER DISTRICT	8500	GROUNDWATER		4 WELL(S)	SPRING(S)	2
DOUGLAS	C	NV0002564	MONTANA	330	GROUNDWATER		2 WELL(S)	CONSECUTIVE CONNECTION(S)	1

Nevada Water Systems and Water Sources

County	Water System Type	Water System ID	Water System Name	Population Served	Primary Water Source	Primary Sources Type	Number of Sources	Additional Source Type	Number of Sources
ELKO	C	NV0000169	MONTELLO WATER SYSTEM	287	GROUNDWATER		2	SPRING(S)	
NYE	NC	NV0002142	MOOSE LODGE 808	25	GROUNDWATER		1	WELL(S)	
WASHOE	C	NV0000732	MOUNT ROSE BOWL PROPERTY OWNERS WATER CO	40	GROUNDWATER		1	WELL(S)	SPRING(S)
ELKO	C	NV0000170	MOUNTAIN CITY WATER AND SEWER	30	GROUNDWATER		1	SPRING(S)	
NYE	C	NV0000920	MOUNTAIN FALLS WATER SYSTEM GBWC	1718	GROUNDWATER		2	WELL(S)	
CLARK	NC	NV0001082	MOUNTAIN SPRINGS BAR INC	75	GROUNDWATER		1	WELL(S)	
DOUGLAS	C	NV0003081	MOUNTAIN VIEW MHP	45	GROUNDWATER		1	WELL(S)	
NYE	C	NV0005067	MOUNTAIN VIEW MHP GBWC	65	GROUNDWATER		1	WELL(S)	
WASHOE	NC	NV0000789	MSJK PROPERTIES LLC	50	GROUNDWATER		1	WELL(S)	
CLARK	NC	NV0001010	MT CHARLESTON PUB LLC	450	GROUNDWATER		1	WELL(S)	
CLARK	C	NV0001015	MT CHARLESTON WATER COMPANY	335	GROUNDWATER		1	WELL(S)	
WASHOE	NC	NV0000743	MT ROSE CAMPGROUND USFS	25	GROUNDWATER		1	WELL(S)	
WASHOE	NC	NV0000744	MT ROSE SKI TAHOE	800	GROUNDWATER		1	SPRING(S)	
ELKO	NC	NV0001088	MUSTANG MONUMENT	25	GROUNDWATER		1	WELL(S)	
LINCOLN	NC	NV0000876	NARCONON NEVADA RAINBOW CANYON	44	GROUNDWATER		1	WELL(S)	
CHURCHILL	NTNC	NV0002541	NAS CENTROID EW RANGE	80	GROUNDWATER		1	WELL(S)	
WASHOE	NTNC	NV0000869	NATCHEZ GYM	175	GROUNDWATER		1	WELL(S)	
WASHOE	NTNC	NV0000774	NATCHEZ SCHOOL	200	GROUNDWATER		1	WELL(S)	
EUREKA	NC	NV0002214	NDOT BEOWAWE ROADSIDE PARK RP802 EU	100	GROUNDWATER		1	WELL(S)	
NYE	NC	NV0002147	NDOT BIG SMOKEY ROADSIDE PARK RP807NY	25	GROUNDWATER		1	WELL(S)	
HUMBOLDT	NC	NV0001054	NDOT BUTTON POINT ROADSIDE PARK RP808HU	600	GROUNDWATER		1	WELL(S)	
PERSHING	NC	NV0002160	NDOT COSGRAVE ROADSIDE PARK RP804PE	600	GROUNDWATER		1	WELL(S)	
NYE	NC	NV0002146	NDOT LATHROP WELLS ROADSIDE PARK RP801NY	200	GROUNDWATER		1	WELL(S)	
ESMERALDA	NC	NV0002089	NDOT MILLERS NV ROADSIDE PARK RP801ES	900	GROUNDWATER		1	WELL(S)	
CLARK	NC	NV0001101	NDOT SEARCHLIGHT WELCOME CENTER	50	GROUNDWATER		1	WELL(S)	
NYE	NC	NV0000943	NDOT SUNNYSIDE ROADSIDE PARK RP810NY	25	GROUNDWATER		1	WELL(S)	
CHURCHILL	NC	NV0002034	NDOT TRINITY ROADSIDE PARK RP806CH	100	GROUNDWATER		1	CONSECUTIVE CONNECTION(S)	
HUMBOLDT	NC	NV0002102	NDOT VALMY ROADSIDE PARK RP809HU	367	GROUNDWATER		1	WELL(S)	
WASHOE	NC	NV0004022	NDOT WADSWORTH REST STOP	25	GROUNDWATER		1	WELL(S)	

Nevada Water Systems and Water Sources

County	Water System Type	Water System ID	Water System Name	Population Served	Primary Water Source	Primary Sources Type	Number of Sources	Additional Source Type	Number of Sources
CLARK	C	NV0003028	NELLIS AIR FORCE BASE	19081	PURCHASED SURFACE WATER		7 WELL(S)	CONSECUTIVE CONNECTION(S)	2
CHURCHILL	NC	NV0002014	NEVADA LIVESTOCK MARKETING	25	GROUNDWATER		1 WELL(S)		
CLARK	C	NV0000699	NEVADA STATE VETERANS HOME BOULDER CITY	708	PURCHASED SURFACE WATER		1 CONNECTION(S)	CONSECUTIVE CONNECTION(S)	
CLARK	NTNC	NV0005006	NEVADA TEST AND TRAINING RANGE PT BRAVO	50	GROUNDWATER		1 WELL(S)		
CLARK	NC	NV0000378	NEVADA TEST AND TRAINING RANGE SILVER FL	35	GROUNDWATER		1 WELL(S)		
ELKO	C	NV0000037	NEVADA YOUTH TRAINING CENTER	100	GROUNDWATER		1 WELL(S)		
CHURCHILL	NTNC	NV0000903	NEW MILLENNIUM BUILDING SYSTEMS, LLC	50	GROUNDWATER		1 WELL(S)		
CLARK	NTNC	NV0001112	NEW YORK NEW YORK HOTEL AND CASINO	7000	PURCHASED SURFACE WATER		1 CONNECTION(S)	CONSECUTIVE CONNECTION(S)	
EUREKA	NTNC	NV0002600	NEWMONT GOLD GOLD QUARRY	700	GROUNDWATER		3 WELL(S)		
EUREKA	NTNC	NV0002603	NEWMONT GOLD NORTH AREA LEACH	300	GROUNDWATER		1 WELL(S)		
ELKO	NTNC	NV0001138	NEWMONT LONG CANYON MINE	110	GROUNDWATER		1 WELL(S)		
NYE	NC	NV0004099	NNSS AREA 12	25	GROUNDWATER		1 WELL(S)		
NYE	NC	NV0004098	NNSS AREA 25	120	GROUNDWATER		2 WELL(S)		
NYE	NTNC	NV0000360	NNSS SITE AREA A23 AND 6	1700	GROUNDWATER		3 WELL(S)		
DOUGLAS	NTNC	NV0000977	NORTH COUNTY WATER SYSTEM	200	GROUNDWATER		2 WELL(S)	CONSECUTIVE CONNECTION(S)	3
CLARK	C	NV0000175	NORTH LAS VEGAS UTILITIES	306570	PURCHASED SURFACE WATER		2 WELL(S)	CONSECUTIVE CONNECTION(S)	2
WASHOE	NTNC	NV0000870	NORTH VALLEY BUS FACILITY	60	GROUNDWATER		1 WELL(S)		
HUMBOLDT	NTNC	NV0002513	NORTH VALMY POWER PLANT	120	GROUNDWATER		2 WELL(S)		
CLARK	C	NV0003005	NPS BOULDER BEACH	722	PURCHASED SURFACE WATER		1 CONNECTION(S)	CONSECUTIVE CONNECTION(S)	
CLARK	C	NV0002506	NPS CALLVILLE BAY	250	SURFACE WATER		1 INTAKE(S)		
CLARK	NTNC	NV0002501	NPS COTTONWOOD COVE	592	GROUNDWATER		2 WELL(S)		
CLARK	C	NV0002503	NPS ECHO BAY	274	SURFACE WATER		1 INTAKE(S)		
CLARK	NC	NV0003004	NPS LAS VEGAS BAY	25	PURCHASED SURFACE WATER		1 CONNECTION(S)	CONSECUTIVE CONNECTION(S)	
NYE	NTNC	NV0002152	NYE COUNTY COMPLEX	100	GROUNDWATER		2 WELL(S)		
ELKO	C	NV0004017	OASIS MHP	46	GROUNDWATER		1 WELL(S)		
CHURCHILL	NC	NV0000921	OASIS SPRINGS	25	GROUNDWATER		1 WELL(S)		
CHURCHILL	C	NV0000052	OK MOBILE HOME PARK	90	GROUNDWATER		1 WELL(S)		
CHURCHILL	NC	NV0004028	OLAM SVI	98	GROUNDWATER		1 WELL(S)		

Nevada Water Systems and Water Sources

County	Water System Type	Water System ID	Water System Name	Population Served	Primary Water Source	Primary Sources Type	Number of Sources	Additional Source Type	Number of Sources
WASHOE	C	NV0000797	OLD FORTY WEST MOTEL	40	GROUNDWATER		2	WELL(S)	
CHURCHILL	C	NV0000303	OLD RIVER WATER COMPANY	300	GROUNDWATER		2	WELL(S)	
WASHOE	C	NV0002526	OLD WASHOE ESTATES	135	GROUNDWATER		2	WELL(S)	
HUMBOLDT	C	NV0003032	OROVADA WATER DISTRICT	200	GROUNDWATER		2	WELL(S)	
LINCOLN	NC	NV0004106	PAHRANAGAT NATIONAL WILDLIFE REFUGE FWS	25	GROUNDWATER		1	WELL(S)	
NYE	NC	NV0004018	PAHRUMP FIRE STATION BLM	25	GROUNDWATER		1	WELL(S)	
NYE	NC	NV0005034	PAHRUMP RV PARK	120	GROUNDWATER		1	WELL(S)	
NYE	NTNC	NV0003036	PAHRUMP SENIOR CENTER INC	70	GROUNDWATER		1	WELL(S)	
NYE	C	NV0000926	PAHRUMP UTILITY COMPANY INC	985	GROUNDWATER		5	WELL(S)	
CLARK	C	NV0000819	PALM GARDENS WATER CO OP	42	GROUNDWATER		2	WELL(S)	
LINCOLN	C	NV0000185	PANACA FARMSTEAD WATER ASSOCIATION	900	GROUNDWATER		2	WELL(S)	
HUMBOLDT	NTNC	NV0002186	PARADISE VALLEY ELEMENTARY	35	GROUNDWATER		1	WELL(S)	
HUMBOLDT	NC	NV0002106	PARADISE VALLEY PARK	40	GROUNDWATER		1	WELL(S)	
CLARK	NTNC	NV0001166	PARIS LAS VEGAS HOTEL AND CASINO	30	PURCHASED SURFACE WATER		1	CONSECUTIVE CONNECTION(S)	
CLARK	NTNC	NV0001118	PARK MGM	1980	PURCHASED SURFACE WATER		1	CONSECUTIVE CONNECTION(S)	
NYE	NC	NV0001094	PATCH OF HEAVEN	50	GROUNDWATER		1	WELL(S)	
NYE	NTNC	NV0004067	PEACOX CHARITABLE REMAINDER UNITRUST	50	GROUNDWATER		1	WELL(S)	
ELKO	NC	NV0002064	PETES TRAILER COURT	24	GROUNDWATER		1	WELL(S)	
LANDER	NTNC	NV0000902	PHOENIX MINE POTABLE WATER SYSTEM	400	GROUNDWATER		1	WELL(S)	
NYE	NC	NV0004063	PICK AND SHOVEL INVESTMENTS	25	GROUNDWATER		1	WELL(S)	
HUMBOLDT	NTNC	NV0002095	PILOT TRAVEL CENTER 485	1448	GROUNDWATER		1	WELL(S)	
DOUGLAS	C	NV0000172	PINEVIEW ESTATES	450	GROUNDWATER		1	WELL(S)	
DOUGLAS	C	NV0000067	PINION PINES MHP	30	GROUNDWATER		1	WELL(S)	
LINCOLN	C	NV0000186	PIOCHE PUBLIC UTILITIES	700	GROUNDWATER		3	WELL(S)	
LINCOLN	C	NV0000187	PIOCHE PUBLIC UTILITIES CASTLETON	60	GROUNDWATER		1	SPRING(S)	
CLARK	NC	NV0001012	PIONEER SALOON	25	GROUNDWATER		1	WELL(S)	
CLARK	NTNC	NV0001180	PLANET HOLLYWOOD HOTEL AND CASINO	6509	PURCHASED SURFACE WATER		1	CONSECUTIVE CONNECTION(S)	
NYE	C	NV0000402	PLEASANT VALLEY	110	GROUNDWATER		2	WELL(S)	
WASHOE	NTNC	NV0000750	PLEASANT VALLEY SCHOOL	300	GROUNDWATER		1	WELL(S)	
CLARK	NTNC	NV0001127	POLO TOWERS	1512	PURCHASED SURFACE WATER		1	CONSECUTIVE CONNECTION(S)	

Nevada Water Systems and Water Sources

County	Water System Type	Water System ID	Water System Name	Population Served	Primary Water Source	Primary Sources Type	Number of Sources	Additional Source Type	Number of Sources
NYE	NTNC	NV0001170	PREMIER MAGNESIA	114	GROUNDWATER		1 WELL(S)		
CLARK	C	NV0001073	PRIMM VALLEY CASINO RESORTS	7000	GROUNDWATER		2 WELL(S)		
LYON	NTNC	NV0001133	PUMPKIN HOLLOW SHAFT SITE	200	GROUNDWATER	PURCHASED	1 CONSECUTIVE CONNECTION(S)		
CHURCHILL	C	NV0000054	R AND M MOBILE HOME PARK	130	GROUNDWATER		2 WELL(S)		
CLARK	C	NV0000370	RAINBOW GARDENS WATER USERS	45	GROUNDWATER		1 WELL(S)		
CLARK	NC	NV0001069	RANCH HOUSE	25	GROUNDWATER		1 WELL(S)		
CLARK	C	NV0000129	RANCHO COOPERATIVE WATER COMPANY	112	GROUNDWATER		2 WELL(S)		
NYE	C	NV0002571	RANCHO VISTA 4	50	GROUNDWATER		2 WELL(S)		
LINCOLN	NC	NV0000898	RAPPORT EXECUTIVE RETREAT	25	GROUNDWATER		2 WELL(S)		
CLARK	NC	NV0003100	RED ROCK CAMPGROUND BLM	25	GROUNDWATER		1 WELL(S)	CONSECUTIVE CONNECTION(S)	1
CLARK	NC	NV0005011	RED ROCK CANYON VISITOR CENTER BLM	844	GROUNDWATER		1 WELL(S)	CONSECUTIVE CONNECTION(S)	1
CLARK	NC	NV0003101	RED ROCK FIRE STN AND LAW ENF BLM	25	GROUNDWATER		1 WELL(S)		
PERSHING	NTNC	NV0001205	RELIEF CANYON MINE	36	GROUNDWATER		2 WELL(S)		
WASHOE	C	NV0000701	RENO SAHARA TRAILER PARK	60	GROUNDWATER		2 WELL(S)		
WASHOE	NTNC	NV0001132	RENO TECHNOLOGY PARK WATER COMPANY	30	GROUNDWATER		2 WELL(S)		
CLARK	NTNC	NV0001167	RIO RESORT AND CASINO	7132	PURCHASED SURFACE WATER		1 CONSECUTIVE CONNECTION(S)		
WASHOE	C	NV0000191	RIO VISTA MHC LLC	65	GROUNDWATER		2 WELL(S)		
CLARK	NC	NV0004029	RITCHIE BROTHERS	1013	GROUNDWATER		1 WELL(S)		
WASHOE	C	NV0000754	RIVER BEND MHP	45	GROUNDWATER		1 WELL(S)		
WASHOE	NC	NV0003001	RIVERBELLE PROPERTIES LLC SASQUATCH INN	1000	GROUNDWATER		1 WELL(S)		
CLARK	NTNC	NV0001042	RIVERSIDE RESORT	1772	GROUNDWATER		3 WELL(S)		
DOUGLAS	C	NV0000068	RIVERVIEW MOBILE HOME PARK	59	GROUNDWATER		1 WELL(S)		
CLARK	C	NV0000319	ROARK ESTATES WATER ASSOC	62	GROUNDWATER		1 WELL(S)		
WHITE PINE	NTNC	NV0000855	ROBINSON NEVADA MINING COMPANY	437	GROUNDWATER		1 WELL(S)		
LYON	NC	NV0000858	ROGELIO M GARCIA	25	GROUNDWATER		1 WELL(S)		
WASHOE	C	NV0000767	ROSEMOUNT WATER CO	54	GROUNDWATER		1 SPRING(S)		
LYON	NC	NV0000951	ROSIES PLACE	25	GROUNDWATER		1 WELL(S)		
DOUGLAS	C	NV0000260	ROUND HILL GID	1200	SURFACE WATER		1 INTAKE(S)		
NYE	NTNC	NV0001122	ROUND MOUNTAIN GOLD HILL WATER SYSTEM	250	GROUNDWATER		2 WELL(S)		
NYE	C	NV0004074	ROUND MOUNTAIN PUC	1200	GROUNDWATER		2 WELL(S)		
NYE	NTNC	NV0002535	ROUND MOUNTAIN SMOKY VALLEY MINE	380	GROUNDWATER		3 WELL(S)		

Nevada Water Systems and Water Sources

County	Water System Type	Water System ID	Water System Name	Population Served	Primary Water Source	Primary Sources Type	Number of Sources	Additional Source Type	Number of Sources
HUMBOLDT	NC	NV0002542	ROYAL PEACOCK RV PARK	53	GROUNDWATER		1	WELL(S)	
ELKO	NC	NV0004112	RUBY 360 LODGE	25	GROUNDWATER		1	WELL(S)	
EUREKA	NTNC	NV0000885	RUBY HILL MINE	125	GROUNDWATER		1	WELL(S)	
ELKO	NC	NV0003070	RUBY VALLEY LDS CHAPEL	90	GROUNDWATER		1	WELL(S)	
ELKO	NTNC	NV0002084	RUBY VALLEY SCHOOL	30	GROUNDWATER		1	WELL(S)	
WHITE PINE	C	NV0000164	RUTH WATER DISTRICT	470	GROUNDWATER	PURCHASED	1	CONSECUTIVE CONNECTION(S)	
PERSHING	NC	NV0002222	RYE PATCH PETROLEUM	40	GROUNDWATER		1	WELL(S)	
PERSHING	NC	NV0002223	RYE PATCH STATE PARK	25	GROUNDWATER		1	WELL(S)	
PERSHING	NC	NV0005023	RYE PATCH STATE PARK PICNIC AREA	27	GROUNDWATER		1	WELL(S)	
ELKO	NC	NV0001092	RYNDON GAS & FOOD LLC	277	GROUNDWATER		1	WELL(S)	
DOUGLAS	NC	NV0002047	S AND J VENTURES DBA JUNCTION BAR	35	GROUNDWATER		1	WELL(S)	
ELKO	NTNC	NV0002566	SAGE SCHOOLS	2200	GROUNDWATER		2	WELL(S)	
CHURCHILL	C	NV0002023	SAGE VALLEY PARK LLC	188	GROUNDWATER		1	WELL(S)	
CHURCHILL	NC	NV0000872	SAGE VALLEY RV PARK LLC	25	GROUNDWATER		1	WELL(S)	
CHURCHILL	C	NV0000406	SAND CREEK	953	GROUNDWATER		1	WELL(S)	
WASHOE	NC	NV0000746	SAND HARBOR STATE PARK	1000	GROUNDWATER		1	WELL(S)	
NYE	NC	NV0001096	SANDERS WINERY	25	GROUNDWATER		1	WELL(S)	
CLARK	NC	NV0000380	SANDY VALLEY CENTER	25	GROUNDWATER		1	WELL(S)	
CLARK	NTNC	NV0004001	SANDY VALLEY ELEMENTARY SCHOOL CCSD	230	GROUNDWATER		1	WELL(S)	
CLARK	NTNC	NV0004001	SANDY VALLEY ELEMENTARY SCHOOL CCSD	230	GROUNDWATER		1	WELL(S)	
CLARK	NC	NV0000317	SANDY VALLEY LIBRARY COMM CTR	50	GROUNDWATER		2	WELL(S)	
CLARK	NC	NV0004102	SANDY VALLEY MEETINGHOUSE LDS	25	GROUNDWATER		1	WELL(S)	
MINERAL	NTNC	NV0000897	SCHURZ ELEMENTARY SCHOOL	70	GROUNDWATER		1	WELL(S)	
HUMBOLDT	NC	NV0000352	SCOTT SHADY COURT	90	GROUNDWATER		3	WELL(S)	
CLARK	NTNC	NV0002577	SCPPA APEX GENERATING STATION	25	GROUNDWATER		1	WELL(S)	
CLARK	C	NV0000219	SEARCHLIGHT WATER COMPANY	760	GROUNDWATER		3	WELL(S)	
DOUGLAS	NC	NV0000844	SEVEN ELEVEN NO 23074	734	GROUNDWATER		1	WELL(S)	
NYE	NTNC	NV0005036	SHERIS RANCH	33	GROUNDWATER		2	WELL(S)	
CLARK	C	NV0000126	SHETLAND WATER DISTRICT	38	GROUNDWATER		1	WELL(S)	
NYE	NC	NV0003074	SHORT BRANCH	25	GROUNDWATER		1	WELL(S)	
NYE	C	NV0005028	SHOSHONE ESTATES WATER CO INC	240	GROUNDWATER		2	WELL(S)	
DOUGLAS	C	NV0000931	SIERRA COUNTRY ESTATES	47	GROUNDWATER		2	WELL(S)	
DOUGLAS	C	NV0000030	SIERRA ESTATES GID	160	GROUNDWATER		1	WELL(S)	CONSECUTIVE CONNECTION(S)
WASHOE	NC	NV0004125	SIERRA SAFARI ZOO	35	GROUNDWATER		1	WELL(S)	
CLARK	C	NV0001116	SIGNATURE TOWERS	516	PURCHASED SURFACE WATER		1	CONSECUTIVE CONNECTION(S)	

Nevada Water Systems and Water Sources

County	Water System Type	Water System ID	Water System Name	Population Served	Primary Water Source	Primary Sources Type	Number of Sources	Additional Source Type	Number of Sources
WASHOE	C	NV0004021	SILVER KNOLLS MUTUAL WATER COMPANY	120	GROUNDWATER		2 WELL(S)		
ESMERALDA	C	NV0000363	SILVER PEAK WATER SYSTEM	138	GROUNDWATER		2 WELL(S)		
LYON	NC	NV0004100	SILVER SPRINGS MEETINGHOUSE LDS	25	GROUNDWATER		1 WELL(S)		
LYON	C	NV0000223	SILVER SPRINGS MUTUAL WATER COMPANY	3070	GROUNDWATER		3 WELL(S)		
CLARK	NTNC	NV0000342	SILVERHAWK POWER PLANT	25	GROUNDWATER		1 WELL(S)		
CHURCHILL	NC	NV0002581	SKIPS MINI MARKET	25	GROUNDWATER		1 WELL(S)		
CLARK	C	NV0004031	SKY RANCH ESTATES	110	GROUNDWATER		2 WELL(S)		
WASHOE	NC	NV0000760	SKY TAVERN	50	GROUNDWATER		1 SPRING(S)		
WASHOE	NC	NV0000761	SLIDE MOUNTAIN SKI AREA	200	GROUNDWATER		3 SPRING(S)		
CLARK	NTNC	NV0001140	SLOAN ARMY RESERVE CENTER	348	GROUNDWATER		1 WELL(S)		
LYON	NC	NV0004107	SMITH VALLEY BAPTIST CHURCH	500	GROUNDWATER		1 WELL(S)		
LYON	NTNC	NV0002189	SMITH VALLEY SCHOOLS	500	GROUNDWATER		1 WELL(S)		
NYE	NC	NV0004127	SMOKY JOES	25	GROUNDWATER		1 WELL(S)		
CLARK	C	NV0001102	SNWA COYOTE SPRING VALLEY-MOAPA PWS	25	GROUNDWATER		1 WELL(S)		
LYON	NTNC	NV0002515	SNYDER LIVESTOCK COMPANY INC	40	GROUNDWATER		1 WELL(S)		
CHURCHILL	NC	NV0000929	SONIC BURGER	265	GROUNDWATER		1 WELL(S)		
ELKO	C	NV0000351	SOUTH CRESTVIEW HOMEOWNERS	60	GROUNDWATER		3 WELL(S)		
ELKO	NC	NV0002209	SOUTH RUBY CAMPGROUND USFS	30	GROUNDWATER		1 WELL(S)		
CLARK	C	NV0005062	SOUTHERN DESERT CORRECTIONAL CTR	4842	GROUNDWATER		4 WELL(S)		
CLARK	C	NV0000289	NDOC	200	SURFACE WATER		1 INTAKE(S)		
ELKO	NC	NV0000873	SOUTHFORK STATE PARK AND RECREATION AREA	25	GROUNDWATER		1 WELL(S)		
CLARK	NC	NV0004108	SPEED VEGAS	200	PURCHASED GROUNDWATER		1 CONSECUTIVE CONNECTION(S)		
CLARK	NC	NV0004071	SPENCER W KIMBALL SCOUT RESERVATION	208	GROUNDWATER		2 WELL(S)		
CLARK	C	NV0000221	SPIRIT MOUNTAIN UTILITY	375	GROUNDWATER		2 WELL(S)		
DOUGLAS	NC	NV0004041	SPOONER LAKE STATE PARK	207	GROUNDWATER		1 WELL(S)		
NYE	C	NV0001093	SPRING MOUNTAIN MOTOR SPORTS RANCH	200	GROUNDWATER		2 WELL(S)		
CLARK	NC	NV0001071	SPRING MOUNTAIN RANCH STATE PARK	235	GROUNDWATER		1 WELL(S)		
CLARK	C	NV0000292	SPRING MOUNTAIN YOUTH CAMP	120	GROUNDWATER		1 SPRING(S)		
CLARK	NC	NV0003103	SPRING MOUNTAINS VISITOR GATEWAY	215	GROUNDWATER		1 WELL(S)		
LINCOLN	NC	NV0002124	SPRING VALLEY STATE PARK	386	GROUNDWATER		1 WELL(S)		
WASHOE	NTNC	NV0004061	SPRINGWOOD EQUESTRIAN CENTER	175	GROUNDWATER		1 WELL(S)		
LYON	NC	NV0002608	STAGECOACH COUNTRY MARKET	25	GROUNDWATER		1 WELL(S)		
LYON	C	NV0000224	STAGECOACH GID	1411	GROUNDWATER		4 WELL(S)		

Nevada Water Systems and Water Sources

County	Water System Type	Water System ID	Water System Name	Population Served	Primary Water Source	Primary Sources Type	Number of Sources	Additional Source Type	Number of Sources
LYON	NC	NV0004040	STAGECOACH MARKET	25	GROUNDWATER		1	WELL(S)	
NYE	NC	NV0002598	STAGESTOP RESTAURANT	25	GROUNDWATER		1	WELL(S)	
WASHOE	C	NV0000801	STAMPMILL	118	GROUNDWATER		2	WELL(S)	
HUMBOLDT	C	NV0000252	STAR CITY PROPERTIES	285	GROUNDWATER		2	WELL(S)	
PERSHING	NC	NV0002517	STAR POINT MHP RV PARK	25	GROUNDWATER		1	WELL(S)	
WASHOE	C	NV0000282	STEAMBOAT SPRINGS WATERWORKS INC	998	GROUNDWATER		2	WELL(S)	
STOREY	C	NV0000240	STOREY COUNTY WATER DISTRICT	1420	SURFACE WATER		1	INTAKE(S)	
NYE	NC	NV0000829	SULLIVANS PUB	25	GROUNDWATER		1	WELL(S)	
WASHOE	C	NV0000211	SUN VALLEY GID	17000	PURCHASED SURFACE WATER		2	CONSECUTIVE CONNECTION(S)	
CLARK	C	NV0000124	SUNRISE ACRES WATER ASSOCIATION	231	GROUNDWATER		2	WELL(S)	
WASHOE	C	NV0002525	SUNRISE ESTATES	90	GROUNDWATER		2	WELL(S)	
NYE	C	NV0005066	SUNSET MHP	90	GROUNDWATER		2	WELL(S)	
WASHOE	C	NV0000765	SUTCLIFFE MOBILE PARK	60	GROUNDWATER		2	WELL(S)	
CLARK	NC	NV0000329	T AND J INVESTMENTS DBA THE GROVE	65	GROUNDWATER		1	WELL(S)	
CLARK	NTNC	NV0001190	T MOBILE ARENA	473	PURCHASED SURFACE WATER		1	CONSECUTIVE CONNECTION(S)	
NYE	NC	NV0002575	TATUADO WILD SIDE TAVERN	25	GROUNDWATER		1	WELL(S)	
CARSON CITY	C	NV0000028	TERRACE GARDEN APARTMENTS	60	GROUNDWATER		1	WELL(S)	
ELKO	NC	NV0003044	TERRACES PICNIC GROUNDS USFS	25	GROUNDWATER		1	SPRING(S)	
DOUGLAS	NTNC	NV0002227	THE CLUB AT CLEAR CREEK TAHOE	25	PURCHASED GROUNDWATER		1	CONSECUTIVE CONNECTION(S)	
CHURCHILL	NC	NV0000306	THE GRID	70	GROUNDWATER		1	WELL(S)	
NYE	NC	NV0003035	THE HUBB	25	GROUNDWATER		1	WELL(S)	
WASHOE	NC	NV0004076	THE LODGE AT GALENA	142	GROUNDWATER		1	WELL(S)	
EUREKA	C	NV0000414	THE LODGE AT PINE VALLEY	320	GROUNDWATER		1	WELL(S)	
WASHOE	NC	NV0000727	THE VINE	125	GROUNDWATER		1	WELL(S)	
ELKO	NC	NV0003043	THOMAS CANYON CAMPGROUND USFS	25	GROUNDWATER		1	SPRING(S)	
WASHOE	NC	NV0004114	THUNDERBIRD LODGE	90	SURFACE WATER		1	INTAKE(S)	
WHITE PINE	NC	NV0003049	TIMBER CREEK CAMPGROUND USFS	47	GROUNDWATER		1	SPRING(S)	
CLARK	NTNC	NV0001139	TIMET CORPORATION	574	PURCHASED SURFACE WATER		1	CONSECUTIVE CONNECTION(S)	
CHURCHILL	C	NV0000055	TOLAS WATERWORKS CO OP	250	GROUNDWATER		1	WELL(S)	
NYE	NTNC	NV0000804	TOLICHA PEAK ELECTRONIC COMBAT RANGE	80	GROUNDWATER		1	WELL(S)	

Nevada Water Systems and Water Sources

County	Water System Type	Water System ID	Water System Name	Population Served	Primary Water Source	Primary Sources Type	Number of Sources	Additional Source Type	Number of Sources
NYE	NTNC	NV0000823	TONOPAH CONSERVATION CAMP NDOC	150	PURCHASED GROUNDWATER		1	CONSECUTIVE CONNECTION(S)	
NYE	NTNC	NV0005002	TONOPAH ELECTRONIC COMBAT RANGE O AND M	127	GROUNDWATER		1	WELL(S)	
NYE	C	NV0000237	TONOPAH PUBLIC UTILITIES	2853	GROUNDWATER		6	WELL(S)	
NYE	NTNC	NV0005001	TONOPAH TEST RANGE AREA 10 INDUSTRIAL	130	GROUNDWATER		1	WELL(S)	
NYE	NTNC	NV0004068	TONOPAH TEST RANGE MANCAMP	30	GROUNDWATER		2	WELL(S)	
NYE	NTNC	NV0003014	TONOPAH TEST RANGE SITE 6	150	GROUNDWATER		1	WELL(S)	
CHURCHILL	NC	NV0002586	TOP GUN SKATE	25	GROUNDWATER		1	WELL(S)	
DOUGLAS	C	NV0000070	TOPAZ LAKE WATER CO INC	40	GROUNDWATER		4	WELL(S)	
DOUGLAS	C	NV0000239	TOPAZ RANCH ESTATES GID AND WATER CO	2100	GROUNDWATER		2	WELL(S)	
DOUGLAS	NC	NV0002518	TOPAZ SUMMIT SPRING	25	GROUNDWATER		1	WELL(S)	
CLARK	C	NV0000314	TORREY PINES TINA LN WTR ASSOC	70	GROUNDWATER		1	WELL(S)	
NYE	NC	NV0000386	TOWER PIZZA	25	GROUNDWATER		1	WELL(S)	
DOUGLAS	C	NV0000168	TOWN OF MINDEN	3500	GROUNDWATER		9	WELL(S)	CONSECUTIVE CONNECTION(S)
PERSHING	NTNC	NV0002159	TRAVEL CENTERS OF AMERICA NO 181	1051	GROUNDWATER		2	WELL(S)	
STOREY	NTNC	NV0000913	TRI GENERAL IMPROVEMENT DISTRICT	10001	GROUNDWATER		7	WELL(S)	
CLARK	NTNC	NV0001059	TROPICANA RESORT AND CASINO TROUT CANYON LAND AND WATER USERS ASSOC	3689	PURCHASED SURFACE WATER		2	WELL(S)	CONSECUTIVE CONNECTION(S)
CLARK	NC	NV0004060	TROPICANA RESORT AND CASINO TROUT CANYON LAND AND WATER USERS ASSOC	60	GROUNDWATER		1	WELL(S)	
WASHOE	NTNC	NV0000978	TRUCKEE CANYON	25	GROUNDWATER		2	WELL(S)	
WASHOE	C	NV0000190	TRUCKEE MEADOWS WATER AUTHORITY	311932	SURFACE WATER		71	WELL(S)	INTAKE(S)
EUREKA	NTNC	NV0000403	TS POWER PLANT	62	GROUNDWATER		1	WELL(S)	
PERSHING	NC	NV0003072	TURN 3 RV PARK AND STORE	25	GROUNDWATER		1	WELL(S)	
ELKO	C	NV0000189	TUSCARORA WATER SYSTEM	72	GROUNDWATER		1	WELL(S)	
HUMBOLDT	NTNC	NV0005070	TWIN CREEKS	600	GROUNDWATER		1	WELL(S)	
DOUGLAS	C	NV0000817	UPPAWAY WATER SYSTEM	85	GROUNDWATER		2	WELL(S)	
NYE	NTNC	NV0001145	US ECOLOGY NEVADA	90	GROUNDWATER		1	WELL(S)	
CLARK	NC	NV0001075	VALLEY OF FIRE STATE PARK	1000	GROUNDWATER		1	WELL(S)	
ELKO	C	NV0000805	VALLEY VIEW RV PARK	250	GROUNDWATER		2	WELL(S)	
HUMBOLDT	NC	NV0002112	VALMY FUEL STOP INC	45	GROUNDWATER		1	WELL(S)	
HUMBOLDT	C	NV0003016	VALMY STATION MOBILE HOME PARK	96	GROUNDWATER		1	WELL(S)	
CLARK	NTNC	NV0001165	VENETIAN PALAZZO	19387	PURCHASED SURFACE WATER		1	CONSECUTIVE CONNECTION(S)	
WASHOE	C	NV0000196	VERDI MEADOWS UTILITY COMPANY INC	510	GROUNDWATER		2	WELL(S)	

Nevada Water Systems and Water Sources

County	Water System Type	Water System ID	Water System Name	Population Served	Primary Water Source	Primary Sources Type	Number of Sources	Additional Source Type	Number of Sources
WASHOE	NTNC	NV0000773	VERDI MUTUAL WATER COMPANY	300	GROUNDWATER		1	SPRING(S)	
WASHOE	NTNC	NV0003000	VERDI SCHOOL	250	GROUNDWATER		1	WELL(S)	
NYE	NC	NV0002556	VFW PAHRUMP POST 10054	75	GROUNDWATER		1	WELL(S)	
HUMBOLDT	NC	NV0002543	VIRGIN VALLEY CAMPGROUND FWS	25	GROUNDWATER		1	WELL(S)	
CLARK	C	NV0000167	VIRGIN VALLEY WATER DISTRICT	18000	GROUNDWATER		10	WELL(S)	
WASHOE	C	NV0000281	WADSWORTH MOBILE HOME PARK	90	GROUNDWATER		2	WELL(S)	
CLARK	NTNC	NV0001172	WALDORF ASTORIA HOTEL LAS VEGAS	25	PURCHASED SURFACE WATER		1	CONSECUTIVE CONNECTION(S)	
MINERAL	C	NV0000268	WALKER LAKE GID	300	GROUNDWATER		2	WELL(S)	
LYON	NC	NV0004048	WALKER RIVER RESORT	25	GROUNDWATER		2	WELL(S)	
LYON	NC	NV0004118	WALKER RIVER STATE REC AREA PITCHFORK	120	GROUNDWATER		1	WELL(S)	
WHITE PINE	NC	NV0000922	WARD CHARCOAL OVENS STATE PARK	25	GROUNDWATER		1	WELL(S)	
WHITE PINE	NC	NV0003046	WARD MOUNTAIN CAMPGROUND USFS	600	GROUNDWATER		1	WELL(S)	
WASHOE	NC	NV0000793	WASHOE LAKE STATE PARK	467	GROUNDWATER		1	WELL(S)	
WASHOE	NC	NV0000318	WASHOE LAKE STATE PARK NORTH BOAT RAMP	25	GROUNDWATER		1	WELL(S)	
WASHOE	NC	NV0003094	WASHOE REGIONAL SHOOTING RANGE	25	GROUNDWATER		1	WELL(S)	
WASHOE	NC	NV0004113	WASHOE VALLEY CHRISTIAN CHURCH	840	GROUNDWATER		1	WELL(S)	
WASHOE	NC	NV0004065	WASHOE VALLEY MEETINGHOUSE FACILITY LDS	108	GROUNDWATER		1	WELL(S)	
WASHOE	C	NV0000280	WEBB MOBILE HOME PARK	30	GROUNDWATER		2	WELL(S)	
LYON	C	NV0000242	WEED HEIGHTS DEVELOPMENT	340	GROUNDWATER		2	WELL(S)	
ELKO	NC	NV0002078	WELCOME STATION RV PARK LLC	35	GROUNDWATER		1	WELL(S)	
LYON	NC	NV0000243	WELLINGTON STATION RESORT	64	GROUNDWATER		1	WELL(S)	
ELKO	NTNC	NV0005005	WELLS HONOR CAMP NDOC	150	GROUNDWATER		1	WELL(S)	
ELKO	C	NV0000245	WELLS MUNICIPAL WATER DEPARTMENT	1300	GROUNDWATER		4	WELL(S)	
WASHOE	C	NV0000709	WEST RENO WATER SYSTEM	820	GROUNDWATER		4	WELL(S)	
DOUGLAS	C	NV0002054	WEST VALLEY WATER SYSTEM	663	GROUNDWATER		3	WELL(S)	CONSECUTIVE CONNECTION(S)
ELKO	C	NV0000246	WEST WENDOVER WATER SYSTEM	4200	GROUNDWATER		8	WELL(S)	1

Nevada Water Systems and Water Sources

County	Water System Type	Water System ID	Water System Name	Population Served	Primary Water Source	Primary Sources Type	Number of Sources	Additional Source Type	Number of Sources
WHITE PINE	NC	NV0003054	WHEELER PEAK CAMPGROUND NPS	60	GROUNDWATER		1	SPRING(S)	
NYE	NC	NV0000946	WHOS DUNES	25	GROUNDWATER		1	WELL(S)	
ELKO	NC	NV0002080	WILDHORSE RESORT	25	GROUNDWATER		1	WELL(S)	
ELKO	NC	NV0003059	WILDHORSE STATE PARK AND RECREATION AREA	45	GROUNDWATER		1	WELL(S)	
MINERAL	NC	NV0001128	WILDKAT RANCH	25	GROUNDWATER		1	WELL(S)	
DOUGLAS	NTNC	NV0000816	WILLIAMS RIDGE TECH PARK	60	GROUNDWATER		1	WELL(S)	
ELKO	NC	NV0002211	WILSON RESERVOIR BLM CAMPGROUND	30	GROUNDWATER		1	WELL(S)	
LINCOLN	NC	NV0000399	WINDMILL RIDGE RESTAURANT AND LODGE	25	GROUNDWATER		1	WELL(S)	
HUMBOLDT	C	NV0000248	WINNEMUCCA CITY OF	8066	GROUNDWATER		5	WELL(S)	SPRING(S)
CLARK	NTNC	NV0001141	WYNN RESORTS	9416	PURCHASED SURFACE WATER		1	CONSECUTIVE CONNECTION(S)	

2019 Nevada Annual Compliance Report By Chemical

EPA Region	9	Primacy Agency Code	NV	Rule Family	IOC	Violation Category	Maximum Contaminant Level Violation
Contaminant Code		Contaminant		# of Violations		# of RTC Violations	# of PWS in Violation
1074		Antimony		11		11	1
1005		Arsenic		93		51	19
1040		Nitrate		11		8	8
		Total =		115		70	

EPA Region	9	Primacy Agency Code	NV	Rule Family	IOC	Violation Category	Monitoring and Reporting
Contaminant Code		Contaminant		# of Violations		# of RTC Violations	# of PWS in Violation
1005		Arsenic		26		12	13
CIO2		IOC Phase 2		3		1	3
CIO5		IOC Phase 5		5		1	4
CIOC		Cyanide		3		1	3
CIOF		Fluoride		1		1	1
CSOD		Sodium		5		1	5
1036		Nickel		1		0	1
1040		Nitrate		63		38	55
1041		Nitrite		24		5	22
		Total =		131		60	

2019 Nevada Annual Compliance Report By Chemical

EPA Region	9	Primacy Agency Code	NV	Rule Family	SOC	Violation Category	Monitoring and Reporting
Contaminant Code	Contaminant	# of Violations			# of RTC Violations		# of PWS in Violation
2931	1,2-Dibromo-3-Chloropropane	1			0		1
2105	2,4-D	1			0		1
2046	Carbofuran	1			0		1
2039	DI(2-Ethylexyl) Phthalate	3			2		3
2032	Diquat	1			0		1
2033	Endothall	1			0		1
2946	Ethylene Dibromide	2			0		2
2034	Glyphosphate	1			0		1
2036	Oxamyl	1			0		1
CSO8	SOCS PH5 Dioxin	3			0		2
CSOC	SOCS PHASE 2 & 5	14			3		7
		Total =		29		5	

EPA Region	9	Primacy Agency Code	NV	Rule Family	VOC	Violation Category	Monitoring and Reporting
Contaminant Code	Contaminant	# of Violations			# of RTC Violations		# of PWS in Violation
2992	Ethylbenzene	1			1		1
CVOC	VOCS Phase 2 & 5	18			4		11
2955	Xylenes, Total	1			1		1
		Total =		20		6	

EPA Region	9	Primacy Agency Code	NV	Rule Family	RADS	Violation Category	Maximum Contaminant Level Violation
Contaminant Code	Contaminant	# of Violations			# of RTC Violations		# of PWS in Violation
4006	Combined Uranium	10			10		3
		Total =		10		10	

EPA Region	9	Primacy Agency Code	NV	Rule Family	RADS	Violation Category	Monitoring and Reporting
Contaminant Code	Contaminant	# of Violations			# of RTC Violations		# of PWS in Violation
CRAU	Radionuclides	4			4		3
CRGA	Gross Alpha	1			0		1
CRRA	Radium 226 & 228	2			1		2
CRUR	RADS Uranium	22			17		3
		Total =		29		22	

2019 Nevada Annual Compliance Report By Chemical

EPA Region	9	Primacy Agency Code	NV	Rule Family	ST1 DBP	Violation Category	Monitoring and Reporting
Contaminant Code		Contaminant			# of Violations	# of RTC Violations	# of PWS in Violation
0999		Chlorine			25	21	16
		Total =			25	21	

EPA Region	9	Primacy Agency Code	NV	Rule Family	ST2 DBP	Violation Category	Maximum Contaminant Level Violation
Contaminant Code		Contaminant			# of Violations	# of RTC Violations	# of PWS in Violation
2950		DBPR Stage 2 TTHM			3	0	2
		Total =			3	0	

2019 Nevada Annual Compliance Report By Chemical

EPA Region	9	Primacy Agency Code	NV	Rule Family	ST2 DBP	Violation Category	Monitoring and Reporting
Contaminant Code		Contaminant		# of Violations		# of RTC Violations	# of PWS in Violation
2456		DBPR Stage 2 TTHM		3		3	2
2950		DBPR Stage 2 HAA5		2		2	2
CDB2		Disinfection Byprod Stage 2		23		14	22
Total =				28		19	

EPA Region	9	Primacy Agency Code	NV	Rule Family	SWT Rule	Violation Category	Monitoring and Reporting
Contaminant Code		Contaminant		# of Violations		# of RTC Violations	# of PWS in Violation
0999		Chlorine		8		8	1
0100		Turbidity		8		8	1
Total =				16		16	

EPA Region	9	Primacy Agency Code	NV	Rule Family	rTCR	Violation Category	Maximum Contaminant Level Violation
Contaminant Code		Contaminant		# of Violations		# of RTC Violations	# of PWS in Violation
8000		Coliform (rTCR)		3		3	2
Total =				3		3	

2019 Nevada Annual Compliance Report By Chemical

EPA Region	9	Primacy Agency Code	NV	Rule Family	rTCR	Violation Category	Monitoring and Reporting
Contaminant Code		Contaminant		# of Violations		# of RTC Violations	# of PWS in Violation
3014		e. Coli		25		25	18
		Total =		25		25	

EPA Region	9	Primacy Agency Code	NV	Rule Family	rTCR	Violation Category	Monitoring and Reporting
Contaminant Code		Contaminant		# of Violations		# of RTC Violations	# of PWS in Violation
8000		Coliform (rTCR)		128		117	84
		Total =		128		117	

EPA Region	9	Primacy Agency Code	NV	Rule Family	rTCR	Violation Category	Treatment Technique
Contaminant Code		Contaminant		# of Violations		# of RTC Violations	# of PWS in Violation
8000		Coliform (rTCR)		10		9	7
		Total =		10		9	

EPA Region	9	Primacy Agency Code	NV	Rule Family	GWR	Violation Category	Monitoring and Reporting
Contaminant Code		Contaminant		# of Violations		# of RTC Violations	# of PWS in Violation
3014		E.Coli (GWR Assesment)		2		2	1
3014		E.Coli (GWR Triggered/Additional		8		8	8
		Total =		10		10	

EPA Region	9	Primacy Agency Code	NV	Rule Family	GWR	Violation Category	Treatment Technique
Contaminant Code		Contaminant		# of Violations		# of RTC Violations	# of PWS in Violation
0700		Groundwater Rule		50		26	41
		Total =		50		26	

EPA Region	9	Primacy Agency Code	NV	Rule Family	LCR	Violation Category	Monitoring and Reporting
Contaminant Code		Contaminant		# of Violations		# of RTC Violations	# of PWS in Violation
5000		Lead and Copper Rule		21		10	15
CWQP		Water Quality Parameters		5		0	2
		Total =		26		10	

2019 Nevada Annual Compliance Report By Chemical

EPA Region	9	Primacy Agency Code	NV	Rule Family	LCR	Violation Category	Treatment Technique
Contaminant Code		Contaminant		# of Violations		# of RTC Violations	# of PWS in Violation
5000		Lead and Copper Rule		2		1	1
		Total =		2		1	

EPA Region	9	Primacy Agency Code	NV	Rule Family	N/A	Violation Category	Other Violation
Contaminant Code		Contaminant		# of Violations		# of RTC Violations	# of PWS in Violation
7000		Consumer Confidence Rule		28		19	28
5000		Lead Consumer Notice		1		0	1
7500		Public Notice		3		3	3
S6		State Certified Operator Failure		3		0	3
		Total =		35		22	

EPA Region	9	Primacy Agency Code	NV	Rule Family	SECONDARIES	Violation Category	Maximum Contaminant Level Violation
Contaminant Code		Contaminant		# of Violations		# of RTC Violations	# of PWS in Violation
1002		Aluminum		1		1	1
1017		Chloride		4		4	2
1905		Color		2		1	2
1025		Fluoride		20		7	5
1028		Iron		31		23	13
1032		Manganese		44		32	15
1920		Odor		11		8	7
1055		Sulfate		16		16	2
1930		TDS		28		22	6
		Total =		157		114	

2019 Nevada Annual Compliance Report By Chemical

EPA Region	9	Primacy Agency Code	NV	Rule Family	SECONDARIES	Violation Category	Monitoring and Reporting
Contaminant Code		Contaminant		# of Violations	# of RTC Violations	# of PWS in Violation	
1002		Aluminum		1	0	1	
1005		Arsenic		1	1	1	
1905		Color		3	2	3	
CSEF		Fluoride		1	0	1	
1028		Iron		11	7	7	
1032		Manganese		11	8	7	
1040		Nitrate		3	3	3	
1920		Odor		4	3	4	
1925		pH		1	0	1	
CSC2		SECONDARY IOCS		35	10	32	
1055		Sulfate		7	4	2	
1930		TDS		8	3	4	
		Total =		86	41		

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0000915	A1 FUEL STOP	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	10/1/2018	12/31/2018		1/28/2019
Total Number of Violations for this Water System:										1
NV0001195	ACG MATERIALS	03MJ	CDAS	ARSENIC (AS)	IOC	MONITORING, ROUTINE MAJOR	1/1/2017	12/31/2019		
Total Number of Violations for this Water System:										1
NV0000005	ALAMO SEWER AND WATER GID	03MJ	CRRA	RADS RADIUM 226&228	RAD	MONITORING, ROUTINE MAJOR	1/1/2014	12/31/2019		5/21/2020
Total Number of Violations for this Water System:										1
NV0000155	AMARGOSA VALLEY RV PARK	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2018	12/31/2018		4/18/2019
NV0000155	AMARGOSA VALLEY RV PARK	1A	3014	E. COLI	RTCR	MCL, E. COLI, POS E COLI (RTCR)	4/1/2018	4/30/2018		6/12/2019
NV0000155	AMARGOSA VALLEY RV PARK	1A	3014	E. COLI	RTCR	MCL, E. COLI, POS E COLI (RTCR)	6/1/2018	6/30/2018		6/12/2019
NV0000155	AMARGOSA VALLEY RV PARK	2C	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	CORRECTIVE/EXPEDITED ACTIONS (RTCR)	8/1/2018	6/24/2019		6/24/2019
NV0000155	AMARGOSA VALLEY RV PARK	2C	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	CORRECTIVE/EXPEDITED ACTIONS (RTCR)	8/1/2018	9/5/2019		9/5/2019
NV0000155	AMARGOSA VALLEY RV PARK	34MJ	3014	E. COLI	GWR	MONITOR GWR TRIGGERED/ADDITONAL, MAJOR	6/4/2019	8/22/2019		8/22/2019
NV0000155	AMARGOSA VALLEY RV PARK	45	0700	GROUNDWATER RULE	GWR	FAILURE ADDRESS DEFICIENCY (GWR)	8/4/2018	6/24/2019		6/24/2019
Total Number of Violations for this Water System:										7
NV0005033	ANCHOR IN MHP	03MJ	CDAS	ARSENIC (AS)	IOC	MONITORING, ROUTINE MAJOR	1/1/2017	12/31/2019		
NV0005033	ANCHOR IN MHP	03MJ	CSOD	SODIUM (NA)	IOC	MONITORING, ROUTINE MAJOR	1/1/2017	12/31/2019		
NV0005033	ANCHOR IN MHP	52	5000	LEAD & COPPER RULE	LCR	FOLLOW-UP OR ROUTINE TAP M/R (LCR)	10/1/2018			
Total Number of Violations for this Water System:										3

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0003037	ANGEL LAKE CAMPGROUND USFS	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	9/1/2019	9/30/2019		
Total Number of Violations for this Water System:										1
NV0004088	ANIMAL ARK	S1	1032	MANGANESE	SECONDARIES	STATE MCL EXCEDENCE	10/1/2016	12/31/2016	0.53 MG/L	1/31/2019
NV0004088	ANIMAL ARK	S1	1032	MANGANESE	SECONDARIES	STATE MCL EXCEDENCE	1/1/2017	3/31/2017	4.6 MG/L	1/31/2019
NV0004088	ANIMAL ARK	S1	1032	MANGANESE	SECONDARIES	STATE MCL EXCEDENCE	4/1/2017	6/30/2017	1.5 MG/L	1/31/2019
NV0004088	ANIMAL ARK	S1	1032	MANGANESE	SECONDARIES	STATE MCL EXCEDENCE	7/1/2017	9/30/2017	0.52 MG/L	1/31/2019
NV0004088	ANIMAL ARK	S1	1032	MANGANESE	SECONDARIES	STATE MCL EXCEDENCE	1/1/2018	3/31/2018	0.36 MG/L	1/31/2019
NV0004088	ANIMAL ARK	S1	1032	MANGANESE	SECONDARIES	STATE MCL EXCEDENCE	4/1/2018	6/30/2018	0.2 MG/L	1/31/2019
Total Number of Violations for this Water System:										6
NV0000379	APEX REGIONAL WASTE MGMT CENTER	45	0700	GROUNDWATER RULE	GWR	FAILURE ADDRESS DEFICIENCY (GWR)	10/30/2018	10/16/2019		10/16/2019
NV0000379	APEX REGIONAL WASTE MGMT CENTER	45	0700	GROUNDWATER RULE	GWR	FAILURE ADDRESS DEFICIENCY (GWR)	10/31/2018	10/16/2019		10/16/2019
NV0000379	APEX REGIONAL WASTE MGMT CENTER	93	1920	ODOR	SECONDARIES	STATE FAILURE TO MONITOR	1/1/2017	12/31/2019		5/26/2020
Total Number of Violations for this Water System:										3
NV0004027	ASH MEADOWS NATIONAL WILDLIFE	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2018	12/31/2018		8/12/2019
Total Number of Violations for this Water System:										1
NV0001162	BALLYS	51	5000	LEAD & COPPER RULE	LCR	INITIAL TAP SAMPLING (LCR)	7/1/2019			
Total Number of Violations for this Water System:										1

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0000720	BAR M BAR	S1	1032	MANGANESE	SECONDARIES	STATE MCL EXCEDENCE	4/1/2019	6/30/2019	0.25 MG/L	
NV0000720	BAR M BAR	S1	1032	MANGANESE	SECONDARIES	STATE MCL EXCEDENCE	7/1/2019	9/30/2019	0.22 MG/L	
NV0000720	BAR M BAR	S1	1032	MANGANESE	SECONDARIES	STATE MCL EXCEDENCE	10/1/2019	12/31/2019	0.22 MG/L	
Total Number of Violations for this Water System:										3
NV0002120	BEAVER DAM STATE PARK	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	10/1/2019	12/31/2019		
Total Number of Violations for this Water System:										1
NV0000147	BERMUDA PALMS MANAGEMENT LLC	02	1005	ARSENIC	IOC	MCL, AVERAGE	4/1/2019	6/30/2019	0.02 MG/L	
NV0000147	BERMUDA PALMS MANAGEMENT LLC	02	1005	ARSENIC	IOC	MCL, AVERAGE	7/1/2019	9/30/2019	0.022 MG/L	
NV0000147	BERMUDA PALMS MANAGEMENT LLC	02	1005	ARSENIC	IOC	MCL, AVERAGE	10/1/2019	12/31/2019	0.019 MG/L	
NV0000147	BERMUDA PALMS MANAGEMENT LLC	45	0700	GROUNDWATER RULE	GWR	FAILURE ADDRESS DEFICIENCY (GWR)	11/16/2019			
NV0000147	BERMUDA PALMS MANAGEMENT LLC	45	0700	GROUNDWATER RULE	GWR	FAILURE ADDRESS DEFICIENCY (GWR)	10/19/2019			
NV0000147	BERMUDA PALMS MANAGEMENT LLC	71	7000	CONSUMER CONFIDENCE RULE		CCR REPORT	7/1/2019	7/3/2019		7/3/2019
Total Number of Violations for this Water System:										6
NV0002041	BEST WESTERN TOPAZ LAKE INN	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2017	12/31/2017		1/31/2019
NV0002041	BEST WESTERN TOPAZ LAKE INN	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2019	12/31/2019		
Total Number of Violations for this Water System:										2
NV0000369	BIG VALLEY MHP	S1	1930	TDS	SECONDARIES	STATE MCL EXCEDENCE	7/1/2018	9/30/2018	1080 MG/L	1/7/2019
NV0000369	BIG VALLEY MHP	S1	1930	TDS	SECONDARIES	STATE MCL EXCEDENCE	4/1/2019	6/30/2019	1080 MG/L	4/15/2020

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0000369	BIG VALLEY MHP	S1	1930	TDS	SECONDARIES	STATE MCL EXCEDENCE	10/1/2019	12/31/2019	1060 MG/L	4/15/2020
Total Number of Violations for this Water System:										3

NV0000323	BLUE DIAMOND RAINBOW SW PLAZA	45	0700	GROUNDWATER RULE	GWR	FAILURE ADDRESS DEFICIENCY (GWR)	10/1/2018	4/30/2019		4/30/2019
NV0000323	BLUE DIAMOND RAINBOW SW PLAZA	S1	1055	SULFATE	SECONDARIES	STATE MCL EXCEDENCE	7/1/2015	9/30/2015	533 MG/L	1/8/2019
NV0000323	BLUE DIAMOND RAINBOW SW PLAZA	S1	1055	SULFATE	SECONDARIES	STATE MCL EXCEDENCE	4/1/2016	6/30/2016	530 MG/L	1/8/2019
NV0000323	BLUE DIAMOND RAINBOW SW PLAZA	S1	1055	SULFATE	SECONDARIES	STATE MCL EXCEDENCE	10/1/2016	12/31/2016	570 MG/L	1/8/2019
NV0000323	BLUE DIAMOND RAINBOW SW PLAZA	S1	1055	SULFATE	SECONDARIES	STATE MCL EXCEDENCE	4/1/2017	6/30/2017	520 MG/L	1/8/2019
NV0000323	BLUE DIAMOND RAINBOW SW PLAZA	S1	1055	SULFATE	SECONDARIES	STATE MCL EXCEDENCE	7/1/2017	9/30/2017	515 MG/L	1/8/2019
NV0000323	BLUE DIAMOND RAINBOW SW PLAZA	S1	1055	SULFATE	SECONDARIES	STATE MCL EXCEDENCE	10/1/2017	12/31/2017	516 MG/L	1/8/2019
NV0000323	BLUE DIAMOND RAINBOW SW PLAZA	S1	1055	SULFATE	SECONDARIES	STATE MCL EXCEDENCE	1/1/2018	3/31/2018	530 MG/L	1/8/2019
NV0000323	BLUE DIAMOND RAINBOW SW PLAZA	S1	1055	SULFATE	SECONDARIES	STATE MCL EXCEDENCE	7/1/2018	9/30/2018	520 MG/L	1/8/2019
NV0000323	BLUE DIAMOND RAINBOW SW PLAZA	S1	1930	TDS	SECONDARIES	STATE MCL EXCEDENCE	7/1/2015	9/30/2015	1049 MG/L	6/27/2019
NV0000323	BLUE DIAMOND RAINBOW SW PLAZA	S1	1930	TDS	SECONDARIES	STATE MCL EXCEDENCE	4/1/2016	6/30/2016	1100 MG/L	6/27/2019
NV0000323	BLUE DIAMOND RAINBOW SW PLAZA	S1	1930	TDS	SECONDARIES	STATE MCL EXCEDENCE	7/1/2016	9/30/2016	1100 MG/L	6/27/2019
NV0000323	BLUE DIAMOND RAINBOW SW PLAZA	S1	1930	TDS	SECONDARIES	STATE MCL EXCEDENCE	1/1/2017	3/31/2017	1020 MG/L	6/27/2019
NV0000323	BLUE DIAMOND RAINBOW SW PLAZA	S1	1930	TDS	SECONDARIES	STATE MCL EXCEDENCE	4/1/2017	6/30/2017	1270 MG/L	6/27/2019
NV0000323	BLUE DIAMOND RAINBOW SW PLAZA	S1	1930	TDS	SECONDARIES	STATE MCL EXCEDENCE	10/1/2017	12/31/2017	1283 MG/L	6/27/2019

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0000323	BLUE DIAMOND RAINBOW SW PLAZA	S1	1930	TDS	SECONDARIES	STATE MCL EXCEDENCE	1/1/2018	3/31/2018	1125 MG/L	6/27/2019
NV0000323	BLUE DIAMOND RAINBOW SW PLAZA	S1	1930	TDS	SECONDARIES	STATE MCL EXCEDENCE	4/1/2018	6/30/2018	1020 MG/L	6/27/2019
NV0000323	BLUE DIAMOND RAINBOW SW PLAZA	S1	1930	TDS	SECONDARIES	STATE MCL EXCEDENCE	10/1/2019	12/31/2019	1100 MG/L	
Total Number of Violations for this Water System:										18
NV0000092	BLUE DIAMOND WATER CO OP INC	71	7000	CONSUMER CONFIDENCE RULE		CCR REPORT	7/1/2019	9/27/2019		9/27/2019
Total Number of Violations for this Water System:										1
NV0003066	BOB SCOTT CAMPGROUND USFS	1A	3014	E. COLI	RTCR	MCL, E. COLI, POS E COLI (RTCR)	9/1/2019	9/30/2019		9/19/2019
Total Number of Violations for this Water System:										1
NV0002090	BOONIES	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	1/1/2019	3/31/2019		4/4/2019
NV0002090	BOONIES	93	CSC2	SECONDARY IOCS	SECONDARIES	STATE FAILURE TO MONITOR	1/1/2011	12/31/2013		9/13/2019
NV0002090	BOONIES	93	CSC2	SECONDARY IOCS	SECONDARIES	STATE FAILURE TO MONITOR	1/1/2014	12/31/2016		9/13/2019
Total Number of Violations for this Water System:										3
NV0005059	BORDER INN	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	1/1/2019	3/31/2019		4/22/2019
Total Number of Violations for this Water System:										1
NV0000389	BUCKBOARD GENERAL STORE	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2019	12/31/2019		2/19/2020
NV0000389	BUCKBOARD GENERAL STORE	03MJ	CNO2	NITRITE	IOC	MONITORING, ROUTINE MAJOR	1/1/2017	12/31/2019		
NV0000389	BUCKBOARD GENERAL STORE	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	9/1/2018	9/30/2018		4/29/2019
NV0000389	BUCKBOARD GENERAL STORE	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	10/1/2018	10/31/2018		4/29/2019

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0000389	BUCKBOARD GENERAL STORE	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	11/1/2018	11/30/2018		4/29/2019
NV0000389	BUCKBOARD GENERAL STORE	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	12/1/2018	12/31/2018		4/29/2019
NV0000389	BUCKBOARD GENERAL STORE	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	1/1/2019	1/31/2019		4/29/2019
NV0000389	BUCKBOARD GENERAL STORE	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	2/1/2019	2/28/2019		4/29/2019
NV0000389	BUCKBOARD GENERAL STORE	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	3/1/2019	3/31/2019		4/29/2019
NV0000389	BUCKBOARD GENERAL STORE	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	5/1/2019	5/31/2019		11/21/2019
NV0000389	BUCKBOARD GENERAL STORE	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	6/1/2019	6/30/2019		11/21/2019
NV0000389	BUCKBOARD GENERAL STORE	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	7/1/2019	7/31/2019		11/21/2019
NV0000389	BUCKBOARD GENERAL STORE	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	8/1/2019	8/31/2019		11/21/2019
NV0000389	BUCKBOARD GENERAL STORE	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	9/1/2019	9/30/2019		11/21/2019
NV0000389	BUCKBOARD GENERAL STORE	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	10/1/2019	10/31/2019		11/21/2019
NV0000389	BUCKBOARD GENERAL STORE	93	CSC2	SECONDARY IOCS	SECONDARIES	STATE FAILURE TO MONITOR	1/1/2017	12/31/2019		

Total Number of Violations for this Water System: 16

NV0002538	C VALLEY MHP	45	0700	GROUNDWATER RULE	GWR	FAILURE ADDRESS DEFICIENCY (GWR)	3/16/2019			
-----------	--------------	----	------	------------------	-----	----------------------------------	-----------	--	--	--

Total Number of Violations for this Water System: 1

NV0004033	CAMP GALILEE	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	1/1/2019	3/31/2019		4/24/2019
-----------	--------------	------	------	------------------------------------	------	-----------------------------------	----------	-----------	--	-----------

Total Number of Violations for this Water System: 1

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0005056	CANYON GID	02	1005	ARSENIC	IOC	MCL, AVERAGE	4/1/2019	6/30/2019	0.012 MG/L	11/20/2019
NV0005056	CANYON GID	02	1005	ARSENIC	IOC	MCL, AVERAGE	7/1/2019	9/30/2019	0.011 MG/L	11/20/2019
Total Number of Violations for this Water System:										2
NV0000405	CARBERRY SQUARE	01	1040	NITRATE	IOC	MCL, SINGLE SAMPLE	1/1/2019	3/31/2019	13 MG/L	3/12/2020
NV0000405	CARBERRY SQUARE	01	1040	NITRATE	IOC	MCL, SINGLE SAMPLE	4/1/2019	6/30/2019	16 MG/L	3/12/2020
NV0000405	CARBERRY SQUARE	01	1040	NITRATE	IOC	MCL, SINGLE SAMPLE	7/1/2019	9/30/2019	13 MG/L	3/12/2020
Total Number of Violations for this Water System:										3
NV0000014	CARLIN UTILITIES	27MJ	2456	TOTAL HALOACETIC ACIDS (HAA5)	ST2 DBP	MONITORING, ROUTINE (DBP), MAJOR	1/1/2018	12/31/2018		11/14/2019
Total Number of Violations for this Water System:										1
NV0000341	CARMENS MEXICAN RESTAURANT	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	11/1/2019	11/30/2019		12/11/2019
Total Number of Violations for this Water System:										1
NV0003068	CARSON RIVER ESTATES	03MJ	2931	1,2-DIBROMO-3-CHLOROPROPANE	SOC	MONITORING, ROUTINE MAJOR	1/1/2014	12/31/2019		
NV0003068	CARSON RIVER ESTATES	03MJ	CDAS	ARSENIC (AS)	IOC	MONITORING, ROUTINE MAJOR	1/1/2017	12/31/2019		
NV0003068	CARSON RIVER ESTATES	03MJ	CDAS	ARSENIC (AS)	IOC	MONITORING, ROUTINE MAJOR	1/1/2017	12/31/2019		
NV0003068	CARSON RIVER ESTATES	03MJ	CDAS	ARSENIC (AS)	IOC	MONITORING, ROUTINE MAJOR	1/1/2017	12/31/2019		
NV0003068	CARSON RIVER ESTATES	03MJ	CDAS	ARSENIC (AS)	IOC	MONITORING, ROUTINE MAJOR	1/1/2017	12/31/2019		
NV0003068	CARSON RIVER ESTATES	03MJ	2039	DI(2-ETHYLHEXYL) PHTHALATE	SOC	MONITORING, ROUTINE MAJOR	10/1/2019	12/31/2019		
NV0003068	CARSON RIVER ESTATES	03MJ	2032	DIQUAT	SOC	MONITORING, ROUTINE MAJOR	1/1/2014	12/31/2019		

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0003068	CARSON RIVER ESTATES	03MJ	2033	ENDOTHALL	SOC	MONITORING, ROUTINE MAJOR	1/1/2014	12/31/2019		
NV0003068	CARSON RIVER ESTATES	03MJ	2946	ETHYLENE DIBROMIDE	SOC	MONITORING, ROUTINE MAJOR	1/1/2014	12/31/2019		
NV0003068	CARSON RIVER ESTATES	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2018	12/31/2018		12/16/2019
NV0003068	CARSON RIVER ESTATES	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2018	12/31/2018		8/28/2019
NV0003068	CARSON RIVER ESTATES	03MJ	CRGA	RADS GROSS ALPHA	RAD	MONITORING, ROUTINE MAJOR	1/1/2011	12/31/2019		
NV0003068	CARSON RIVER ESTATES	03MJ	CRRA	RADS RADIUM 226&228	RAD	MONITORING, ROUTINE MAJOR	1/1/2011	12/31/2019		
NV0003068	CARSON RIVER ESTATES	03MJ	CVOC	VOCS PHASE 2 & 5	VOC	MONITORING, ROUTINE MAJOR	1/1/2017	12/31/2019		
NV0003068	CARSON RIVER ESTATES	27MJ	0999	CHLORINE	ST1 DBP	MONITORING, ROUTINE (DBP), MAJOR	7/1/2019	9/30/2019		8/15/2019
NV0003068	CARSON RIVER ESTATES	27MJ	0999	CHLORINE	ST1 DBP	MONITORING, ROUTINE (DBP), MAJOR	10/1/2019	12/31/2019		
NV0003068	CARSON RIVER ESTATES	27MJ	CDB2	DBPR STAGE 2	ST2 DBP	MONITORING, ROUTINE (DBP), MAJOR	1/1/2018	12/31/2018		11/14/2019
NV0003068	CARSON RIVER ESTATES	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	11/1/2019	11/30/2019		12/5/2019
NV0003068	CARSON RIVER ESTATES	52	5000	LEAD & COPPER RULE	LCR	FOLLOW-UP OR ROUTINE TAP M/R (LCR)	10/1/2019			
NV0003068	CARSON RIVER ESTATES	52	5000	LEAD & COPPER RULE	LCR	FOLLOW-UP OR ROUTINE TAP M/R (LCR)	10/1/2018			
NV0003068	CARSON RIVER ESTATES	52	5000	LEAD & COPPER RULE	LCR	FOLLOW-UP OR ROUTINE TAP M/R (LCR)	10/1/2017			
NV0003068	CARSON RIVER ESTATES	93	1920	ODOR	SECONDARIES	STATE FAILURE TO MONITOR	1/1/2017	12/31/2019		
Total Number of Violations for this Water System:										22

NV0002140	CARVERS CAFE	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	4/1/2019	6/30/2019		8/6/2019
Total Number of Violations for this Water System:										1

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0000218	CARVERS SMOKEY VALLEY RV AND MHP	71	7000	CONSUMER CONFIDENCE RULE		CCR REPORT	7/1/2019	7/23/2019		7/23/2019
Total Number of Violations for this Water System:										1
NV0004035	CAVE LAKE STATE PARK	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2018	12/31/2018		1/8/2019
Total Number of Violations for this Water System:										1
NV0002128	CG BAR	45	0700	GROUNDWATER RULE	GWR	FAILURE ADDRESS DEFICIENCY (GWR)	1/11/2020			
Total Number of Violations for this Water System:										1
NV0002555	CHAMPIONS	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2019	12/31/2019		
NV0002555	CHAMPIONS	03MJ	CNO2	NITRITE	IOC	MONITORING, ROUTINE MAJOR	1/1/2017	12/31/2019		
NV0002555	CHAMPIONS	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	1/1/2019	3/31/2019		
NV0002555	CHAMPIONS	93	CSC2	SECONDARY IOCS	SECONDARIES	STATE FAILURE TO MONITOR	1/1/2017	12/31/2019		
Total Number of Violations for this Water System:										4
NV0003060	CHERRY PATCH LOVE RANCH	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2018	12/31/2018		5/3/2019
NV0003060	CHERRY PATCH LOVE RANCH	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	10/1/2019	12/31/2019		1/7/2020
Total Number of Violations for this Water System:										2
NV0004085	CHICKEN RANCH	45	0700	GROUNDWATER RULE	GWR	FAILURE ADDRESS DEFICIENCY (GWR)	9/30/2019			
Total Number of Violations for this Water System:										1
NV0002554	CHIPMUNK RETREAT	71	7000	CONSUMER CONFIDENCE RULE		CCR REPORT	7/1/2019	7/3/2019		7/3/2019
Total Number of Violations for this Water System:										1

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0005020	CHURCHILL BUTTE COMPLEX	01	1040	NITRATE	IOC	MCL, SINGLE SAMPLE	10/1/2019	12/31/2019	12.5 MG/L	
Total Number of Violations for this Water System:										1
NV0004000	COLD CREEK CANYON HOMEOWNERS	71	7000	CONSUMER CONFIDENCE RULE		CCR REPORT	7/1/2019	9/27/2019		9/27/2019
Total Number of Violations for this Water System:										1
NV0004103	COLD SPRINGS MEETINGHOUSE LDS	93	CSC2	SECONDARY IOCS	SECONDARIES	STATE FAILURE TO MONITOR	1/1/2017	12/31/2019		
Total Number of Violations for this Water System:										1
NV0002570	CORTEZ MILL 1 POTABLE WATER	02	1005	ARSENIC	IOC	MCL, AVERAGE	4/1/2018	6/30/2018	0.014 MG/L	3/4/2019
NV0002570	CORTEZ MILL 1 POTABLE WATER	02	1005	ARSENIC	IOC	MCL, AVERAGE	7/1/2018	9/30/2018	0.012 MG/L	3/4/2019
NV0002570	CORTEZ MILL 1 POTABLE WATER	02	1005	ARSENIC	IOC	MCL, AVERAGE	10/1/2018	12/31/2018	0.012 MG/L	3/4/2019
Total Number of Violations for this Water System:										3
NV0000017	COTTONWOOD MHP	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	6/1/2019	6/30/2019		7/26/2019
Total Number of Violations for this Water System:										1
NV0000385	COYOTE CORNER III	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	11/1/2019	11/30/2019		12/10/2019
NV0000385	COYOTE CORNER III	45	0700	GROUNDWATER RULE	GWR	FAILURE ADDRESS DEFICIENCY (GWR)	3/10/2019			
NV0000385	COYOTE CORNER III	93	1055	SULFATE	SECONDARIES	STATE FAILURE TO MONITOR	10/1/2018	12/31/2018		2/19/2019
NV0000385	COYOTE CORNER III	93	1055	SULFATE	SECONDARIES	STATE FAILURE TO MONITOR	4/1/2019	6/30/2019		
NV0000385	COYOTE CORNER III	93	1055	SULFATE	SECONDARIES	STATE FAILURE TO MONITOR	7/1/2019	9/30/2019		
NV0000385	COYOTE CORNER III	93	1055	SULFATE	SECONDARIES	STATE FAILURE TO MONITOR	10/1/2019	12/31/2019		

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0000385	COYOTE CORNER III	93	1930	TDS	SECONDARIES	STATE FAILURE TO MONITOR	10/1/2018	12/31/2018		2/19/2019
NV0000385	COYOTE CORNER III	93	1930	TDS	SECONDARIES	STATE FAILURE TO MONITOR	4/1/2019	6/30/2019		
NV0000385	COYOTE CORNER III	93	1930	TDS	SECONDARIES	STATE FAILURE TO MONITOR	7/1/2019	9/30/2019		
NV0000385	COYOTE CORNER III	93	1930	TDS	SECONDARIES	STATE FAILURE TO MONITOR	10/1/2019	12/31/2019		
Total Number of Violations for this Water System:										10
NV0002565	COYOTE CORNER MARKET	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	10/1/2018	12/31/2018		3/28/2019
NV0002565	COYOTE CORNER MARKET	3BMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ADD. ROUTINE, MAJOR (RTCR)	9/1/2019	9/30/2019		11/5/2019
NV0002565	COYOTE CORNER MARKET	93	CSC2	SECONDARY IOCS	SECONDARIES	STATE FAILURE TO MONITOR	1/1/2014	12/31/2016		12/10/2019
Total Number of Violations for this Water System:										3
NV0000418	CRESCENT DUNES SOLAR ENERGY	01	1040	NITRATE	IOC	MCL, SINGLE SAMPLE	7/1/2019	9/30/2019	12 MG/L	1/14/2020
Total Number of Violations for this Water System:										1
NV0000043	CRESCENT VALLEY WATER SYSTEM	27MJ	CDB2	DBPR STAGE 2	ST2 DBP	MONITORING, ROUTINE (DBP), MAJOR	1/1/2016	12/31/2018		11/14/2019
Total Number of Violations for this Water System:										1
NV0000717	CROSBYS LODGE	3AMJ	3014	E. COLI	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	9/1/2019	9/30/2019		10/16/2019
Total Number of Violations for this Water System:										1
NV0000718	CRYSTAL PEAK PARK	S1	1028	IRON	SECONDARIES	STATE MCL EXCEDENCE	7/1/2017	9/30/2017	1.3 MG/L	8/14/2019
NV0000718	CRYSTAL PEAK PARK	S1	1028	IRON	SECONDARIES	STATE MCL EXCEDENCE	4/1/2018	6/30/2018	0.7 MG/L	8/14/2019
NV0000718	CRYSTAL PEAK PARK	S1	1032	MANGANESE	SECONDARIES	STATE MCL EXCEDENCE	10/1/2018	12/31/2018	0.2 MG/L	10/9/2019

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0000718	CRYSTAL PEAK PARK	S1	1032	MANGANESE	SECONDARIES	STATE MCL EXCEDENCE	4/1/2019	6/30/2019	0.18 MG/L	10/9/2019
NV0000718	CRYSTAL PEAK PARK	S1	1920	ODOR	SECONDARIES	STATE MCL EXCEDENCE	7/1/2017	9/30/2017	17 TON	8/14/2019
NV0000718	CRYSTAL PEAK PARK	S1	1920	ODOR	SECONDARIES	STATE MCL EXCEDENCE	4/1/2018	6/30/2018	8 TON	8/14/2019
NV0000718	CRYSTAL PEAK PARK	S1	1920	ODOR	SECONDARIES	STATE MCL EXCEDENCE	7/1/2018	9/30/2018	50 TON	8/14/2019

Total Number of Violations for this Water System: 7

NV0000193	CRYSTAL TP	02	1005	ARSENIC	IOC	MCL, AVERAGE	1/1/2018	3/31/2018	0.051 MG/L	12/4/2019
NV0000193	CRYSTAL TP	02	1005	ARSENIC	IOC	MCL, AVERAGE	1/1/2018	3/31/2018	0.057 MG/L	6/3/2019
NV0000193	CRYSTAL TP	02	1005	ARSENIC	IOC	MCL, AVERAGE	4/1/2018	6/30/2018	0.057 MG/L	6/3/2019
NV0000193	CRYSTAL TP	02	1005	ARSENIC	IOC	MCL, AVERAGE	4/1/2018	6/30/2018	0.051 MG/L	12/4/2019
NV0000193	CRYSTAL TP	02	1005	ARSENIC	IOC	MCL, AVERAGE	4/1/2018	6/30/2018	0.050 MG/L	5/15/2019
NV0000193	CRYSTAL TP	02	1005	ARSENIC	IOC	MCL, AVERAGE	7/1/2018	9/30/2018	0.051 MG/L	12/4/2019
NV0000193	CRYSTAL TP	02	1005	ARSENIC	IOC	MCL, AVERAGE	7/1/2018	9/30/2018	0.025 MG/L	5/15/2019
NV0000193	CRYSTAL TP	02	1005	ARSENIC	IOC	MCL, AVERAGE	7/1/2018	9/30/2018	0.057 MG/L	6/3/2019
NV0000193	CRYSTAL TP	02	1005	ARSENIC	IOC	MCL, AVERAGE	10/1/2018	12/31/2018	0.017 MG/L	5/15/2019
NV0000193	CRYSTAL TP	02	1005	ARSENIC	IOC	MCL, AVERAGE	10/1/2018	12/31/2018	0.019 MG/L	5/1/2019
NV0000193	CRYSTAL TP	02	1005	ARSENIC	IOC	MCL, AVERAGE	10/1/2018	12/31/2018	0.051 MG/L	12/4/2019
NV0000193	CRYSTAL TP	02	1005	ARSENIC	IOC	MCL, AVERAGE	10/1/2018	12/31/2018	0.029 MG/L	6/3/2019

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0000193	CRYSTAL TP	02	1005	ARSENIC	IOC	MCL, AVERAGE	1/1/2019	3/31/2019	0.015 MG/L	6/3/2019
NV0000193	CRYSTAL TP	02	1005	ARSENIC	IOC	MCL, AVERAGE	1/1/2019	3/31/2019	0.025 MG/L	12/4/2019
NV0000193	CRYSTAL TP	02	1005	ARSENIC	IOC	MCL, AVERAGE	1/1/2019	3/31/2019	0.011 MG/L	5/15/2019
NV0000193	CRYSTAL TP	02	1005	ARSENIC	IOC	MCL, AVERAGE	4/1/2019	6/30/2019	.017 MG/L	12/4/2019
NV0000193	CRYSTAL TP	02	1005	ARSENIC	IOC	MCL, AVERAGE	7/1/2019	9/30/2019	0.013 MG/L	12/4/2019
NV0000193	CRYSTAL TP	03MJ	CDAS	ARSENIC (AS)	IOC	MONITORING, ROUTINE MAJOR	1/1/2017	12/31/2019		
NV0000193	CRYSTAL TP	03MJ	CDAS	ARSENIC (AS)	IOC	MONITORING, ROUTINE MAJOR	1/1/2017	12/31/2019		

Total Number of Violations for this Water System: 19

NV0000881	DAYTON TAP HOUSE LLC	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2019	12/31/2019		
NV0000881	DAYTON TAP HOUSE LLC	03MJ	CNO2	NITRITE	IOC	MONITORING, ROUTINE MAJOR	1/1/2017	12/31/2019		
NV0000881	DAYTON TAP HOUSE LLC	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	1/1/2019	3/31/2019		4/30/2019
NV0000881	DAYTON TAP HOUSE LLC	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	10/1/2019	10/31/2019		11/22/2019
NV0000881	DAYTON TAP HOUSE LLC	93	CSC2	SECONDARY IOCS	SECONDARIES	STATE FAILURE TO MONITOR	1/1/2017	12/31/2019		

Total Number of Violations for this Water System: 5

NV0000001	DENIO JUNCTION	34MJ	3014	E. COLI	GWR	MONITOR GWR TRIGGERED/ADDITONAL, MAJOR	6/28/2019	7/1/2019		7/1/2019
-----------	----------------	------	------	---------	-----	--	-----------	----------	--	----------

Total Number of Violations for this Water System: 1

NV0001156	DENTON RAWHIDE MINE	02	1005	ARSENIC	IOC	MCL, AVERAGE	1/1/2019	3/31/2019	0.066 MG/L	
-----------	---------------------	----	------	---------	-----	--------------	----------	-----------	------------	--

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0001156	DENTON RAWHIDE MINE	02	1005	ARSENIC	IOC	MCL, AVERAGE	4/1/2019	6/30/2019	0.061 MG/L	
NV0001156	DENTON RAWHIDE MINE	02	1005	ARSENIC	IOC	MCL, AVERAGE	7/1/2019	9/30/2019	0.061 MG/L	
NV0001156	DENTON RAWHIDE MINE	02	1005	ARSENIC	IOC	MCL, AVERAGE	10/1/2019	12/31/2019	0.060 MG/L	
NV0001156	DENTON RAWHIDE MINE	S1	1025	FLUORIDE	SECONDARIES	STATE MCL EXCEEDENCE	1/1/2019	3/31/2019	3.0 MG/L	
NV0001156	DENTON RAWHIDE MINE	S1	1025	FLUORIDE	SECONDARIES	STATE MCL EXCEEDENCE	4/1/2019	6/30/2019	2.9 MG/L	
NV0001156	DENTON RAWHIDE MINE	S1	1025	FLUORIDE	SECONDARIES	STATE MCL EXCEEDENCE	7/1/2019	9/30/2019	3.2 MG/L	
NV0001156	DENTON RAWHIDE MINE	S1	1025	FLUORIDE	SECONDARIES	STATE MCL EXCEEDENCE	10/1/2019	12/31/2019	3.1 MG/L	
Total Number of Violations for this Water System:										8

NV0000736	DESERT INVESTMENT GROUP LTD	01	1040	NITRATE	IOC	MCL, SINGLE SAMPLE	10/1/2018	12/31/2018	11 MG/L	5/17/2019
Total Number of Violations for this Water System:										1

NV0000149	DESERT PARADISE MHP	02	1005	ARSENIC	IOC	MCL, AVERAGE	1/1/2019	3/31/2019	0.016 MG/L	
NV0000149	DESERT PARADISE MHP	02	1005	ARSENIC	IOC	MCL, AVERAGE	4/1/2019	6/30/2019	0.015 MG/L	
NV0000149	DESERT PARADISE MHP	02	1005	ARSENIC	IOC	MCL, AVERAGE	7/1/2019	9/30/2019	0.015 MG/L	
NV0000149	DESERT PARADISE MHP	02	1005	ARSENIC	IOC	MCL, AVERAGE	10/1/2019	12/31/2019	0.016 MG/L	
NV0000149	DESERT PARADISE MHP	45	0700	GROUNDWATER RULE	GWR	FAILURE ADDRESS DEFICIENCY (GWR)	10/8/2018			
NV0000149	DESERT PARADISE MHP	45	0700	GROUNDWATER RULE	GWR	FAILURE ADDRESS DEFICIENCY (GWR)	10/8/2018			
NV0000149	DESERT PARADISE MHP	45	0700	GROUNDWATER RULE	GWR	FAILURE ADDRESS DEFICIENCY (GWR)	10/8/2018			

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0000149	DESERT PARADISE MHP	45	0700	GROUNDWATER RULE	GWR	FAILURE ADDRESS DEFICIENCY (GWR)	10/8/2018			
NV0000149	DESERT PARADISE MHP	45	0700	GROUNDWATER RULE	GWR	FAILURE ADDRESS DEFICIENCY (GWR)	10/8/2018			
NV0000149	DESERT PARADISE MHP	45	0700	GROUNDWATER RULE	GWR	FAILURE ADDRESS DEFICIENCY (GWR)	10/8/2018			
NV0000149	DESERT PARADISE MHP	71	7000	CONSUMER CONFIDENCE RULE		CCR REPORT	7/1/2019	7/3/2019		7/3/2019
Total Number of Violations for this Water System:										11
NV0002094	DIAMOND INN BAR	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2019	12/31/2019		
NV0002094	DIAMOND INN BAR	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	4/1/2019	6/30/2019		7/16/2019
Total Number of Violations for this Water System:										2
NV0001148	DIAMOND PLASTICS	02	1074	ANTIMONY, TOTAL	IOC	MCL, AVERAGE	10/1/2016	12/31/2016	0.0063 MG/L	8/12/2019
NV0001148	DIAMOND PLASTICS	02	1074	ANTIMONY, TOTAL	IOC	MCL, AVERAGE	1/1/2017	3/31/2017	0.0087 MG/L	8/12/2019
NV0001148	DIAMOND PLASTICS	02	1074	ANTIMONY, TOTAL	IOC	MCL, AVERAGE	4/1/2017	6/30/2017	.01 MG/L	8/12/2019
NV0001148	DIAMOND PLASTICS	02	1074	ANTIMONY, TOTAL	IOC	MCL, AVERAGE	7/1/2017	9/30/2017	0.011 MG/L	8/12/2019
NV0001148	DIAMOND PLASTICS	02	1074	ANTIMONY, TOTAL	IOC	MCL, AVERAGE	10/1/2017	12/31/2017	0.011 MG/L	8/12/2019
NV0001148	DIAMOND PLASTICS	02	1074	ANTIMONY, TOTAL	IOC	MCL, AVERAGE	1/1/2018	3/31/2018	0.010 MG/L	8/12/2019
NV0001148	DIAMOND PLASTICS	02	1074	ANTIMONY, TOTAL	IOC	MCL, AVERAGE	4/1/2018	6/30/2018	0.009 MG/L	8/12/2019
NV0001148	DIAMOND PLASTICS	02	1074	ANTIMONY, TOTAL	IOC	MCL, AVERAGE	7/1/2018	9/30/2018	0.008 MG/L	8/12/2019
NV0001148	DIAMOND PLASTICS	02	1074	ANTIMONY, TOTAL	IOC	MCL, AVERAGE	10/1/2018	12/31/2018	0.007 MG/L	8/12/2019

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0001148	DIAMOND PLASTICS	02	1074	ANTIMONY, TOTAL	IOC	MCL, AVERAGE	1/1/2019	3/31/2019	0.008 MG/L	8/12/2019
NV0001148	DIAMOND PLASTICS	02	1074	ANTIMONY, TOTAL	IOC	MCL, AVERAGE	4/1/2019	6/30/2019	0.007 MG/L	8/12/2019
NV0001148	DIAMOND PLASTICS	02	1005	ARSENIC	IOC	MCL, AVERAGE	10/1/2016	12/31/2016	0.012 MG/L	8/12/2019
NV0001148	DIAMOND PLASTICS	02	1005	ARSENIC	IOC	MCL, AVERAGE	1/1/2017	3/31/2017	0.027 MG/L	8/12/2019
NV0001148	DIAMOND PLASTICS	02	1005	ARSENIC	IOC	MCL, AVERAGE	4/1/2017	6/30/2017	0.028 MG/L	8/12/2019
NV0001148	DIAMOND PLASTICS	02	1005	ARSENIC	IOC	MCL, AVERAGE	7/1/2017	9/30/2017	0.027 MG/L	8/12/2019
NV0001148	DIAMOND PLASTICS	02	1005	ARSENIC	IOC	MCL, AVERAGE	10/1/2017	12/31/2017	0.027 MG/L	8/12/2019
NV0001148	DIAMOND PLASTICS	02	1005	ARSENIC	IOC	MCL, AVERAGE	1/1/2018	3/31/2018	0.025 MG/L	8/12/2019
NV0001148	DIAMOND PLASTICS	02	1005	ARSENIC	IOC	MCL, AVERAGE	4/1/2018	6/30/2018	0.024 MG/L	8/12/2019
NV0001148	DIAMOND PLASTICS	02	1005	ARSENIC	IOC	MCL, AVERAGE	7/1/2018	9/30/2018	0.023 MG/L	8/12/2019
NV0001148	DIAMOND PLASTICS	02	1005	ARSENIC	IOC	MCL, AVERAGE	10/1/2018	12/31/2018	0.020 MG/L	8/12/2019
NV0001148	DIAMOND PLASTICS	02	1005	ARSENIC	IOC	MCL, AVERAGE	1/1/2019	3/31/2019	0.020 MG/L	8/12/2019
NV0001148	DIAMOND PLASTICS	02	1005	ARSENIC	IOC	MCL, AVERAGE	4/1/2019	6/30/2019	0.013 MG/L	8/12/2019
NV0001148	DIAMOND PLASTICS	03MJ	CVOC	VOCS PHASE 2 & 5	VOC	MONITORING, ROUTINE MAJOR	1/1/2018	12/31/2018		3/7/2019
NV0001148	DIAMOND PLASTICS	S1	1025	FLUORIDE	SECONDARIES	STATE MCL EXCEDENCE	1/1/2019	3/31/2019	2.4 MG/L	
NV0001148	DIAMOND PLASTICS	S1	1032	MANGANESE	SECONDARIES	STATE MCL EXCEDENCE	4/1/2019	6/30/2019	0.6 MG/L	

Total Number of Violations for this Water System: 25

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0004096	DOUBLE D BAR & GRILL	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2019	12/31/2019		
NV0004096	DOUBLE D BAR & GRILL	03MJ	CNO2	NITRITE	IOC	MONITORING, ROUTINE MAJOR	1/1/2014	12/31/2016		3/25/2019
NV0004096	DOUBLE D BAR & GRILL	2A	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	LEVEL 1 ASSESS, TC POS RT NO RPT (RTCR)	10/28/2019	1/3/2020		1/3/2020
NV0004096	DOUBLE D BAR & GRILL	2C	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	CORRECTIVE/EXPEDITED ACTIONS (RTCR)	11/28/2019	1/3/2020		1/3/2020
NV0004096	DOUBLE D BAR & GRILL	34MJ	3014	E. COLI	GWR	MONITOR GWR TRIGGERED/ADDITONAL, MAJOR	10/26/2019	12/23/2019		12/23/2019
NV0004096	DOUBLE D BAR & GRILL	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	1/1/2019	3/31/2019		4/22/2019
NV0004096	DOUBLE D BAR & GRILL	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	5/1/2019	5/31/2019		7/23/2019
NV0004096	DOUBLE D BAR & GRILL	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	6/1/2019	6/30/2019		7/23/2019
NV0004096	DOUBLE D BAR & GRILL	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	8/1/2019	8/31/2019		9/25/2019
NV0004096	DOUBLE D BAR & GRILL	93	CSC2	SECONDARY IOCS	SECONDARIES	STATE FAILURE TO MONITOR	1/1/2017	12/31/2019		

Total Number of Violations for this Water System: 10

NV0000949	DOVETAIL RANCH	3BMN	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ADD. ROUTINE, MINOR (RTCR)	4/1/2019	4/30/2019		5/30/2019
NV0000949	DOVETAIL RANCH	93	1028	IRON	SECONDARIES	STATE FAILURE TO MONITOR	7/1/2019	9/30/2019		12/16/2019
NV0000949	DOVETAIL RANCH	93	1032	MANGANESE	SECONDARIES	STATE FAILURE TO MONITOR	1/1/2019	3/31/2019		4/29/2019
NV0000949	DOVETAIL RANCH	93	1032	MANGANESE	SECONDARIES	STATE FAILURE TO MONITOR	7/1/2019	9/30/2019		12/16/2019
NV0000949	DOVETAIL RANCH	S1	1028	IRON	SECONDARIES	STATE MCL EXCEDENCE	10/1/2017	12/31/2017	1.4 MG/L	2/1/2019
NV0000949	DOVETAIL RANCH	S1	1028	IRON	SECONDARIES	STATE MCL EXCEDENCE	4/1/2018	6/30/2018	0.73 MG/L	2/1/2019

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0000949	DOVETAIL RANCH	S1	1032	MANGANESE	SECONDARIES	STATE MCL EXCEEDENCE	4/1/2018	6/30/2018	0.39 MG/L	2/1/2019
Total Number of Violations for this Water System:										7

NV0000809	DUTCHMAN ACRES	03MJ	CSOC	SOCS PHASE 2 & 5	SOC	MONITORING, ROUTINE MAJOR	1/1/2011	12/31/2019		
NV0000809	DUTCHMAN ACRES	03MJ	CSOC	SOCS PHASE 2 & 5	SOC	MONITORING, ROUTINE MAJOR	1/1/2011	12/31/2019		
NV0000809	DUTCHMAN ACRES	03MJ	CVOC	VOCS PHASE 2 & 5	VOC	MONITORING, ROUTINE MAJOR	1/1/2017	12/31/2019		
NV0000809	DUTCHMAN ACRES	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	6/1/2019	6/30/2019		7/23/2019
NV0000809	DUTCHMAN ACRES	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	8/1/2019	8/31/2019		9/25/2019
NV0000809	DUTCHMAN ACRES	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	10/1/2019	10/31/2019		12/19/2019
NV0000809	DUTCHMAN ACRES	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	11/1/2019	11/30/2019		12/19/2019
NV0000809	DUTCHMAN ACRES	45	0700	GROUNDWATER RULE	GWR	FAILURE ADDRESS DEFICIENCY (GWR)	11/2/2018	3/21/2019		3/21/2019
NV0000809	DUTCHMAN ACRES	71	7000	CONSUMER CONFIDENCE RULE		CCR REPORT	7/1/2019	7/4/2019		7/4/2019
Total Number of Violations for this Water System:										9

NV0000188	EAGLE VALLEY RESORT	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2019	12/31/2019		
NV0000188	EAGLE VALLEY RESORT	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2019	12/31/2019		
NV0000188	EAGLE VALLEY RESORT	03MJ	CNO2	NITRITE	IOC	MONITORING, ROUTINE MAJOR	1/1/2017	12/31/2019		
NV0000188	EAGLE VALLEY RESORT	03MJ	CNO2	NITRITE	IOC	MONITORING, ROUTINE MAJOR	1/1/2017	12/31/2019		
NV0000188	EAGLE VALLEY RESORT	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	10/1/2018	12/31/2018		1/29/2019

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0000188	EAGLE VALLEY RESORT	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	7/1/2019	9/30/2019		10/8/2019
NV0000188	EAGLE VALLEY RESORT	93	CSC2	SECONDARY IOCS	SECONDARIES	STATE FAILURE TO MONITOR	1/1/2017	12/31/2019		
NV0000188	EAGLE VALLEY RESORT	93	CSC2	SECONDARY IOCS	SECONDARIES	STATE FAILURE TO MONITOR	1/1/2017	12/31/2019		
Total Number of Violations for this Water System:										8
NV0003098	EAST 50 BAR	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2018	12/31/2018		4/30/2019
NV0003098	EAST 50 BAR	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	10/1/2018	12/31/2018		2/11/2019
NV0003098	EAST 50 BAR	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	7/1/2019	9/30/2019		11/5/2019
NV0003098	EAST 50 BAR	93	CSC2	SECONDARY IOCS	SECONDARIES	STATE FAILURE TO MONITOR	1/1/2017	12/31/2019		
Total Number of Violations for this Water System:										4
NV0002123	ECHO CANYON STATE PARK	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	11/1/2019	11/30/2019		12/10/2019
Total Number of Violations for this Water System:										1
NV0000271	ELK POINT COUNTRY CLUB	27MJ	0999	CHLORINE	ST1 DBP	MONITORING, ROUTINE (DBP), MAJOR	4/1/2018	6/30/2018		6/17/2019
NV0000271	ELK POINT COUNTRY CLUB	27MJ	0999	CHLORINE	ST1 DBP	MONITORING, ROUTINE (DBP), MAJOR	4/1/2018	6/30/2018		6/17/2019
NV0000271	ELK POINT COUNTRY CLUB	27MJ	0999	CHLORINE	ST1 DBP	MONITORING, ROUTINE (DBP), MAJOR	4/1/2018	6/30/2018		6/17/2019
NV0000271	ELK POINT COUNTRY CLUB	27MJ	0999	CHLORINE	ST1 DBP	MONITORING, ROUTINE (DBP), MAJOR	7/1/2018	9/30/2018		6/17/2019
Total Number of Violations for this Water System:										4
NV0000272	ELKO CITY OF	93	CSC2	SECONDARY IOCS	SECONDARIES	STATE FAILURE TO MONITOR	1/1/2017	12/31/2019		
NV0000272	ELKO CITY OF	93	CSC2	SECONDARY IOCS	SECONDARIES	STATE FAILURE TO MONITOR	1/1/2017	12/31/2019		

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
Total Number of Violations for this Water System:										2
NV0002075	ELKO RV PARK AT RYNDON	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	7/1/2019	7/31/2019		8/5/2019
Total Number of Violations for this Water System:										1
NV0000923	ELKS LODGE PAHRUMP	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2019	12/31/2019		
NV0000923	ELKS LODGE PAHRUMP	93	CSC2	SECONDARY IOCS	SECONDARIES	STATE FAILURE TO MONITOR	1/1/2017	12/31/2019		
Total Number of Violations for this Water System:										2
NV0005071	ELY MAXIMUM SECURITY PRISON	34MJ	3014	E. COLI	GWR	MONITOR GWR TRIGGERED/ADDITONAL, MAJOR	6/16/2019	7/23/2019		7/23/2019
NV0005071	ELY MAXIMUM SECURITY PRISON	71	7000	CONSUMER CONFIDENCE RULE		CCR REPORT	7/1/2019			
NV0005071	ELY MAXIMUM SECURITY PRISON	S1	1028	IRON	SECONDARIES	STATE MCL EXCEDENCE	4/1/2018	6/30/2018	0.67 MG/L	1/14/2019
Total Number of Violations for this Water System:										3
NV0000038	ELY MUNICIPAL WATER DEPARTMENT	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2019	12/31/2019		
NV0000038	ELY MUNICIPAL WATER DEPARTMENT	03MJ	CSOD	SODIUM (NA)	IOC	MONITORING, ROUTINE MAJOR	1/1/2017	12/31/2019		
NV0000038	ELY MUNICIPAL WATER DEPARTMENT	03MJ	CVOC	VOCS PHASE 2 & 5	VOC	MONITORING, ROUTINE MAJOR	1/1/2017	12/31/2019		
NV0000038	ELY MUNICIPAL WATER DEPARTMENT	27MJ	CHA2	DBPR STAGE 2 HAA5	ST2 DBP	MONITORING, ROUTINE (DBP), MAJOR	1/1/2016	12/31/2016		11/13/2019
NV0000038	ELY MUNICIPAL WATER DEPARTMENT	27MJ	CTT2	DBPR STAGE 2 TTHM	ST2 DBP	MONITORING, ROUTINE (DBP), MAJOR	1/1/2016	12/31/2016		11/13/2019
NV0000038	ELY MUNICIPAL WATER DEPARTMENT	27MJ	CTT2	DBPR STAGE 2 TTHM	ST2 DBP	MONITORING, ROUTINE (DBP), MAJOR	1/1/2017	12/31/2017		11/13/2019
NV0000038	ELY MUNICIPAL WATER DEPARTMENT	93	1028	IRON	SECONDARIES	STATE FAILURE TO MONITOR	10/1/2019	12/31/2019		
Total Number of Violations for this Water System:										7

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0000042	EMPIRE MINING COMPANY	27MJ	0999	CHLORINE	ST1 DBP	MONITORING, ROUTINE (DBP), MAJOR	1/1/2019	3/31/2019		4/25/2019
NV0000042	EMPIRE MINING COMPANY	27MJ	0999	CHLORINE	ST1 DBP	MONITORING, ROUTINE (DBP), MAJOR	1/1/2019	3/31/2019		2/26/2019
NV0000042	EMPIRE MINING COMPANY	27MJ	0999	CHLORINE	ST1 DBP	MONITORING, ROUTINE (DBP), MAJOR	10/1/2019	12/31/2019		2/25/2020
NV0000042	EMPIRE MINING COMPANY	27MJ	0999	CHLORINE	ST1 DBP	MONITORING, ROUTINE (DBP), MAJOR	10/1/2019	12/31/2019		2/25/2020
NV0000042	EMPIRE MINING COMPANY	27MJ	CDB2	DBPR STAGE 2	ST2 DBP	MONITORING, ROUTINE (DBP), MAJOR	1/1/2015	9/30/2017		11/14/2019
NV0000042	EMPIRE MINING COMPANY	27MJ	CDB2	DBPR STAGE 2	ST2 DBP	MONITORING, ROUTINE (DBP), MAJOR	1/1/2018	9/30/2018		11/14/2019
NV0000042	EMPIRE MINING COMPANY	3AMJ	3014	E. COLI	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	1/1/2019	1/31/2019		2/26/2019
NV0000042	EMPIRE MINING COMPANY	3AMJ	3014	E. COLI	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	3/1/2019	3/31/2019		4/25/2019
NV0000042	EMPIRE MINING COMPANY	51	5000	LEAD & COPPER RULE	LCR	INITIAL TAP SAMPLING (LCR)	1/1/2020			
NV0000042	EMPIRE MINING COMPANY	53	5000	LEAD & COPPER RULE	LCR	WATER QUALITY PARAMETER M/R (LCR)	1/1/2019	6/30/2019		
NV0000042	EMPIRE MINING COMPANY	53	5000	LEAD & COPPER RULE	LCR	WATER QUALITY PARAMETER M/R (LCR)	7/1/2019	12/31/2019		

Total Number of Violations for this Water System: 11

NV0003075	EP MINERALS LLC CLARK	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2018	12/31/2018		7/29/2019
-----------	-----------------------	------	------	---------	-----	---------------------------	----------	------------	--	-----------

Total Number of Violations for this Water System: 1

NV0004120	EP MINERALS LLC FERNLEY	02	1005	ARSENIC	IOC	MCL, AVERAGE	4/1/2017	6/30/2017	0.04 MG/L	1/24/2019
NV0004120	EP MINERALS LLC FERNLEY	02	1005	ARSENIC	IOC	MCL, AVERAGE	7/1/2017	9/30/2017	0.040 MG/L	1/24/2019
NV0004120	EP MINERALS LLC FERNLEY	02	1005	ARSENIC	IOC	MCL, AVERAGE	10/1/2017	12/31/2017	0.040 MG/L	1/24/2019

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0004120	EP MINERALS LLC FERNLEY	02	1005	ARSENIC	IOC	MCL, AVERAGE	1/1/2018	3/31/2018	0.123 MG/L	1/24/2019
NV0004120	EP MINERALS LLC FERNLEY	02	1005	ARSENIC	IOC	MCL, AVERAGE	4/1/2018	6/30/2018	0.118 MG/L	8/14/2019
NV0004120	EP MINERALS LLC FERNLEY	02	1005	ARSENIC	IOC	MCL, AVERAGE	4/1/2018	6/30/2018	0.118 MG/L	1/24/2019
NV0004120	EP MINERALS LLC FERNLEY	02	1005	ARSENIC	IOC	MCL, AVERAGE	7/1/2018	9/30/2018	0.118 MG/L	8/14/2019
NV0004120	EP MINERALS LLC FERNLEY	02	1005	ARSENIC	IOC	MCL, AVERAGE	7/1/2018	9/30/2018	0.118 MG/L	1/24/2019
NV0004120	EP MINERALS LLC FERNLEY	02	1005	ARSENIC	IOC	MCL, AVERAGE	10/1/2018	12/31/2018	0.094 MG/L	8/14/2019
NV0004120	EP MINERALS LLC FERNLEY	02	1005	ARSENIC	IOC	MCL, AVERAGE	1/1/2019	3/31/2019	0.070 MG/L	8/14/2019
NV0004120	EP MINERALS LLC FERNLEY	02	1005	ARSENIC	IOC	MCL, AVERAGE	4/1/2019	6/30/2019	0.035 MG/L	8/14/2019
NV0004120	EP MINERALS LLC FERNLEY	S1	1017	CHLORIDE	SECONDARIES	STATE MCL EXCEDENCE	10/1/2017	12/31/2017	608 MG/L	1/24/2019
NV0004120	EP MINERALS LLC FERNLEY	S1	1017	CHLORIDE	SECONDARIES	STATE MCL EXCEDENCE	1/1/2018	3/31/2018	640 MG/L	1/24/2019
NV0004120	EP MINERALS LLC FERNLEY	S1	1017	CHLORIDE	SECONDARIES	STATE MCL EXCEDENCE	4/1/2018	6/30/2018	570 MG/L	1/24/2019
NV0004120	EP MINERALS LLC FERNLEY	S1	1930	TDS	SECONDARIES	STATE MCL EXCEDENCE	10/1/2017	12/31/2017	1650 MG/L	1/24/2019
NV0004120	EP MINERALS LLC FERNLEY	S1	1930	TDS	SECONDARIES	STATE MCL EXCEDENCE	1/1/2018	3/31/2018	1600 MG/L	1/24/2019
NV0004120	EP MINERALS LLC FERNLEY	S1	1930	TDS	SECONDARIES	STATE MCL EXCEDENCE	4/1/2018	6/30/2018	1700 MG/L	1/24/2019

Total Number of Violations for this Water System: 17

NV0000109	EQUESTRIAN ESTATES CO OP WATER ASSOC	02	1005	ARSENIC	IOC	MCL, AVERAGE	1/1/2019	3/31/2019	0.011 MG/L	8/21/2019
NV0000109	EQUESTRIAN ESTATES CO OP WATER ASSOC	02	1005	ARSENIC	IOC	MCL, AVERAGE	4/1/2019	6/30/2019	0.019 MG/L	8/21/2019

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0000109	EQUESTRIAN ESTATES CO OP WATER ASSOC	71	7000	CONSUMER CONFIDENCE RULE		CCR REPORT	7/1/2019	9/27/2019		9/27/2019
Total Number of Violations for this Water System:										3
NV0004104	EUREKA MEETINGHOUSE LDS	45	0700	GROUNDWATER RULE	GWR	FAILURE ADDRESS DEFICIENCY (GWR)	10/26/2019			
NV0004104	EUREKA MEETINGHOUSE LDS	93	CSC2	SECONDARY IOCS	SECONDARIES	STATE FAILURE TO MONITOR	1/1/2017	12/31/2019		
Total Number of Violations for this Water System:										2
NV0002594	FALLON LIVESTOCK LLC	93	1032	MANGANESE	SECONDARIES	STATE FAILURE TO MONITOR	9/1/2018	9/30/2018		2/8/2019
NV0002594	FALLON LIVESTOCK LLC	S1	1032	MANGANESE	SECONDARIES	STATE MCL EXCEDENCE	7/1/2018	9/30/2018	0.16 MG/L	9/22/2019
NV0002594	FALLON LIVESTOCK LLC	S1	1032	MANGANESE	SECONDARIES	STATE MCL EXCEDENCE	10/1/2018	12/31/2018	0.16 MG/L	9/22/2019
Total Number of Violations for this Water System:										3
NV0000350	FALLON NAVAL AIR STATION	27MJ	0999	CHLORINE	ST1 DBP	MONITORING, ROUTINE (DBP), MAJOR	10/1/2018	12/31/2018		1/23/2019
NV0000350	FALLON NAVAL AIR STATION	3AMN	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MINOR (RTCR)	12/1/2018	12/31/2018		1/23/2019
Total Number of Violations for this Water System:										2
NV0002534	FALLON RV PARK	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2019	12/31/2019		
NV0002534	FALLON RV PARK	03MJ	CNO2	NITRITE	IOC	MONITORING, ROUTINE MAJOR	1/1/2017	12/31/2019		
NV0002534	FALLON RV PARK	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	7/1/2019	9/30/2019		10/17/2019
NV0002534	FALLON RV PARK	93	1032	MANGANESE	SECONDARIES	STATE FAILURE TO MONITOR	10/1/2019	12/31/2019		
NV0002534	FALLON RV PARK	93	CSC2	SECONDARY IOCS	SECONDARIES	STATE FAILURE TO MONITOR	1/1/2017	12/31/2019		
Total Number of Violations for this Water System:										5

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0001100	FIRE CREEK MINE	27MJ	0999	CHLORINE	ST1 DBP	MONITORING, ROUTINE (DBP), MAJOR	4/1/2018	6/30/2018		6/19/2019
NV0001100	FIRE CREEK MINE	27MJ	CDB2	DBPR STAGE 2	ST2 DBP	MONITORING, ROUTINE (DBP), MAJOR	1/1/2019	12/31/2019		
NV0001100	FIRE CREEK MINE	S1	1920	ODOR	SECONDARIES	STATE MCL EXCEDENCE	4/1/2018	6/30/2018	17 TON	6/19/2019
NV0001100	FIRE CREEK MINE	S1	1920	ODOR	SECONDARIES	STATE MCL EXCEDENCE	10/1/2018	12/31/2018	6 TON	6/19/2019
Total Number of Violations for this Water System:										4
NV0002170	FIRESIDE INN	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	4/1/2019	6/30/2019		7/9/2019
Total Number of Violations for this Water System:										1
NV0001053	FLOYD LAMB PARK	3AMJ	3014	E. COLI	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	5/1/2018	5/31/2018		5/31/2019
Total Number of Violations for this Water System:										1
NV0000893	FRANKTOWN MEADOWS	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2018	12/31/2018		8/15/2019
NV0000893	FRANKTOWN MEADOWS	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2018	12/31/2018		8/15/2019
NV0000893	FRANKTOWN MEADOWS	45	0700	GROUNDWATER RULE	GWR	FAILURE ADDRESS DEFICIENCY (GWR)	5/2/2019	9/1/2019		9/1/2019
NV0000893	FRANKTOWN MEADOWS	93	1028	IRON	SECONDARIES	STATE FAILURE TO MONITOR	10/1/2018	12/31/2018		1/24/2019
NV0000893	FRANKTOWN MEADOWS	S1	1905	COLOR	SECONDARIES	STATE MCL EXCEDENCE	10/1/2019	12/31/2019	32.5 CU	
NV0000893	FRANKTOWN MEADOWS	S1	1028	IRON	SECONDARIES	STATE MCL EXCEDENCE	7/1/2019	9/30/2019	3.7 MG/L	
NV0000893	FRANKTOWN MEADOWS	S1	1028	IRON	SECONDARIES	STATE MCL EXCEDENCE	10/1/2019	12/31/2019	5.9 MG/L	
NV0000893	FRANKTOWN MEADOWS	S1	1028	IRON	SECONDARIES	STATE MCL EXCEDENCE	10/1/2019	12/31/2019	3.8 MG/L	
Total Number of Violations for this Water System:										8

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0001174	FRONT SIGHT FIREARMS TRAINING	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	11/1/2019	11/30/2019		12/17/2019
NV0001174	FRONT SIGHT FIREARMS TRAINING	51	5000	LEAD & COPPER RULE	LCR	INITIAL TAP SAMPLING (LCR)	1/1/2020			12/17/2019
Total Number of Violations for this Water System:										2
NV0000066	GARDNERVILLE RANCHOS GID	03MJ	2039	DI(2-ETHYLHEXYL) PHTHALATE	SOC	MONITORING, ROUTINE MAJOR	1/1/2018	12/31/2018		1/2/2019
Total Number of Violations for this Water System:										1
NV0002587	GAS STORE WEST	3BMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ADD. ROUTINE, MAJOR (RTCR)	6/1/2019	6/30/2019		7/9/2019
Total Number of Violations for this Water System:										1
NV0000071	GERLACH GID	27MJ	0999	CHLORINE	ST1 DBP	MONITORING, ROUTINE (DBP), MAJOR	10/1/2019	12/31/2019		
NV0000071	GERLACH GID	27MJ	CDB2	DBPR STAGE 2	ST2 DBP	MONITORING, ROUTINE (DBP), MAJOR	1/1/2018	12/31/2018		11/14/2019
NV0000071	GERLACH GID	3AMJ	3014	E. COLI	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	10/1/2019	10/31/2019		11/14/2019
NV0000071	GERLACH GID	45	0700	GROUNDWATER RULE	GWR	FAILURE ADDRESS DEFICIENCY (GWR)	4/29/2019			
Total Number of Violations for this Water System:										4
NV0003079	GOLD COUNTRY ESTATES	S1	1905	COLOR	SECONDARIES	STATE MCL EXCEDENCE	10/1/2019	12/31/2019	17.5 CU	4/22/2020
Total Number of Violations for this Water System:										1
NV0001124	GOLD DIGGERS SALOON & GRUBB	34MJ	3014	E. COLI	GWR	MONITOR GWR TRIGGERED/ADDITONAL, MAJOR	10/1/2019	10/8/2019		10/8/2019
NV0001124	GOLD DIGGERS SALOON & GRUBB	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	1/1/2019	3/31/2019		5/9/2019
NV0001124	GOLD DIGGERS SALOON & GRUBB	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	6/1/2019	6/30/2019		7/31/2019
NV0001124	GOLD DIGGERS SALOON & GRUBB	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	10/1/2019	10/31/2019		11/25/2019

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
Total Number of Violations for this Water System:										4
NV0000751	GOLD RANCH CASINO	S1	1032	MANGANESE	SECONDARIES	STATE MCL EXCEDENCE	4/1/2019	6/30/2019	0.3 MG/L	9/27/2019
Total Number of Violations for this Water System:										1
NV0004064	GOLDEN VALLEY PARK	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	7/1/2019	9/30/2019		
Total Number of Violations for this Water System:										1
NV0000072	GOLDFIELD TOWN WATER	02	1005	ARSENIC	IOC	MCL, AVERAGE	10/1/2018	12/31/2018	0.013 MG/L	12/9/2019
NV0000072	GOLDFIELD TOWN WATER	02	1005	ARSENIC	IOC	MCL, AVERAGE	1/1/2019	3/31/2019	0.016 MG/L	12/9/2019
NV0000072	GOLDFIELD TOWN WATER	02	1005	ARSENIC	IOC	MCL, AVERAGE	4/1/2019	6/30/2019	0.015 MG/L	12/9/2019
NV0000072	GOLDFIELD TOWN WATER	02	1005	ARSENIC	IOC	MCL, AVERAGE	7/1/2019	9/30/2019	0.015 MG/L	12/9/2019
NV0000072	GOLDFIELD TOWN WATER	71	7000	CONSUMER CONFIDENCE RULE		CCR REPORT	7/1/2019	8/1/2019		8/1/2019
Total Number of Violations for this Water System:										5
NV0002202	GRANITE CONSTRUCTION	3AMJ	3014	E. COLI	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	7/1/2019	9/30/2019		8/22/2019
NV0002202	GRANITE CONSTRUCTION	93	1925	PH	SECONDARIES	STATE FAILURE TO MONITOR	10/1/2019	12/31/2019		
Total Number of Violations for this Water System:										2
NV0004109	GRANITE HILLS BAPTIST CHURCH	03MJ	CNO2	NITRITE	IOC	MONITORING, ROUTINE MAJOR	1/1/2017	12/31/2019		
NV0004109	GRANITE HILLS BAPTIST CHURCH	93	CSC2	SECONDARY IOCS	SECONDARIES	STATE FAILURE TO MONITOR	1/1/2017	12/31/2019		
Total Number of Violations for this Water System:										2
NV0001086	GREAT BASIN WATER CO SPANISH SPRINGS	01	1040	NITRATE	IOC	MCL, SINGLE SAMPLE	10/1/2019	12/31/2019	12 MG/L	4/16/2020

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
Total Number of Violations for this Water System:										1
NV0004117	GREYSTONE MINE	51	5000	LEAD & COPPER RULE	LCR	INITIAL TAP SAMPLING (LCR)	7/1/2019			
Total Number of Violations for this Water System:										1
NV0001131	HALLIBURTON DUNPHY MILL	S1	1032	MANGANESE	SECONDARIES	STATE MCL EXCEDENCE	4/1/2019	6/30/2019	0.23 MG/L	
Total Number of Violations for this Water System:										1
NV0002580	HARMON JUNCTION	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	6/1/2019	6/30/2019		7/18/2019
NV0002580	HARMON JUNCTION	93	1055	SULFATE	SECONDARIES	STATE FAILURE TO MONITOR	4/1/2017	6/30/2017		5/20/2019
NV0002580	HARMON JUNCTION	93	1055	SULFATE	SECONDARIES	STATE FAILURE TO MONITOR	10/1/2017	12/31/2017		5/20/2019
NV0002580	HARMON JUNCTION	93	1055	SULFATE	SECONDARIES	STATE FAILURE TO MONITOR	10/1/2017	12/31/2017		5/20/2019
NV0002580	HARMON JUNCTION	93	1930	TDS	SECONDARIES	STATE FAILURE TO MONITOR	4/1/2017	6/30/2017		5/20/2019
NV0002580	HARMON JUNCTION	93	1930	TDS	SECONDARIES	STATE FAILURE TO MONITOR	10/1/2017	12/31/2017		5/20/2019
NV0002580	HARMON JUNCTION	S1	1055	SULFATE	SECONDARIES	STATE MCL EXCEDENCE	4/1/2016	6/30/2016	763 MG/L	5/20/2019
NV0002580	HARMON JUNCTION	S1	1055	SULFATE	SECONDARIES	STATE MCL EXCEDENCE	10/1/2016	12/31/2016	950 MG/L	5/20/2019
NV0002580	HARMON JUNCTION	S1	1055	SULFATE	SECONDARIES	STATE MCL EXCEDENCE	1/1/2017	3/31/2017	1100 MG/L	5/20/2019
NV0002580	HARMON JUNCTION	S1	1055	SULFATE	SECONDARIES	STATE MCL EXCEDENCE	7/1/2017	9/30/2017	1100 MG/L	5/20/2019
NV0002580	HARMON JUNCTION	S1	1055	SULFATE	SECONDARIES	STATE MCL EXCEDENCE	1/1/2018	3/31/2018	1200 MG/L	5/20/2019
NV0002580	HARMON JUNCTION	S1	1055	SULFATE	SECONDARIES	STATE MCL EXCEDENCE	4/1/2018	6/30/2018	1100 MG/L	5/20/2019

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0002580	HARMON JUNCTION	S1	1055	SULFATE	SECONDARIES	STATE MCL EXCEDENCE	7/1/2018	9/30/2018	1100 MG/L	5/20/2019
NV0002580	HARMON JUNCTION	S1	1055	SULFATE	SECONDARIES	STATE MCL EXCEDENCE	7/1/2018	9/30/2018	1100 MG/L	5/20/2019
NV0002580	HARMON JUNCTION	S1	1930	TDS	SECONDARIES	STATE MCL EXCEDENCE	4/1/2016	6/30/2016	1800 MG/L	5/20/2019
NV0002580	HARMON JUNCTION	S1	1930	TDS	SECONDARIES	STATE MCL EXCEDENCE	10/1/2016	12/31/2016	2200 MG/L	5/20/2019
NV0002580	HARMON JUNCTION	S1	1930	TDS	SECONDARIES	STATE MCL EXCEDENCE	1/1/2017	3/31/2017	2500 MG/L	5/20/2019
NV0002580	HARMON JUNCTION	S1	1930	TDS	SECONDARIES	STATE MCL EXCEDENCE	7/1/2017	9/30/2017	3600 MG/L	5/20/2019
NV0002580	HARMON JUNCTION	S1	1930	TDS	SECONDARIES	STATE MCL EXCEDENCE	1/1/2018	3/31/2018	3600 MG/L	5/20/2019
NV0002580	HARMON JUNCTION	S1	1930	TDS	SECONDARIES	STATE MCL EXCEDENCE	4/1/2018	6/30/2018	2200 MG/L	5/20/2019
NV0002580	HARMON JUNCTION	S1	1930	TDS	SECONDARIES	STATE MCL EXCEDENCE	7/1/2018	9/30/2018	2500 MG/L	5/20/2019
NV0002580	HARMON JUNCTION	S1	1930	TDS	SECONDARIES	STATE MCL EXCEDENCE	7/1/2018	9/30/2018	2500 MG/L	5/20/2019

Total Number of Violations for this Water System: 22

NV0000357	HAWTHORNE ARMY DEPOT	S1	1920	ODOR	SECONDARIES	STATE MCL EXCEDENCE	4/1/2017	6/30/2017	3.4 TON	7/11/2019
-----------	----------------------	----	------	------	-------------	---------------------	----------	-----------	---------	-----------

Total Number of Violations for this Water System: 1

NV0004037	HEYDAY INN	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2018	12/31/2018		5/20/2019
NV0004037	HEYDAY INN	03MJ	CNO2	NITRITE	IOC	MONITORING, ROUTINE MAJOR	1/1/2017	12/31/2019		
NV0004037	HEYDAY INN	2C	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	CORRECTIVE/EXPEDITED ACTIONS (RTCR)	9/5/2018	5/10/2019		5/10/2019
NV0004037	HEYDAY INN	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	9/1/2019	9/30/2019		10/9/2019

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0004037	HEYDAY INN	45	0700	GROUNDWATER RULE	GWR	FAILURE ADDRESS DEFICIENCY (GWR)	3/25/2018	1/25/2019		1/25/2019
NV0004037	HEYDAY INN	93	CSC2	SECONDARY IOCS	SECONDARIES	STATE FAILURE TO MONITOR	1/1/2017	12/31/2019		
Total Number of Violations for this Water System:										6
NV0000961	HIDDEN CANYON RANCH	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	10/1/2018	12/31/2018		2/12/2019
Total Number of Violations for this Water System:										1
NV0002141	HIGHWAY 95 FUEL & FOOD	45	0700	GROUNDWATER RULE	GWR	FAILURE ADDRESS DEFICIENCY (GWR)	10/4/2019			
Total Number of Violations for this Water System:										1
NV0000145	HILLCREST MANOR WATER USERS	71	7000	CONSUMER CONFIDENCE RULE		CCR REPORT	7/1/2019	8/16/2019		8/16/2019
Total Number of Violations for this Water System:										1
NV0004053	HODGES TRANSPORTATION CO	52	5000	LEAD & COPPER RULE	LCR	FOLLOW-UP OR ROUTINE TAP M/R (LCR)	10/1/2018	8/29/2019		8/29/2019
Total Number of Violations for this Water System:										1
NV0002046	HOLBROOK STATION RV AND MHP	03MJ	CIO2	IOCS PHASE 2	IOC	MONITORING, ROUTINE MAJOR	1/1/2017	12/31/2019		
NV0002046	HOLBROOK STATION RV AND MHP	03MJ	CIO5	IOCS PHASE 5	IOC	MONITORING, ROUTINE MAJOR	1/1/2017	12/31/2019		
NV0002046	HOLBROOK STATION RV AND MHP	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2019	12/31/2019		
NV0002046	HOLBROOK STATION RV AND MHP	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2019	12/31/2019		
NV0002046	HOLBROOK STATION RV AND MHP	03MJ	CVOC	VOCS PHASE 2 & 5	VOC	MONITORING, ROUTINE MAJOR	1/1/2017	12/31/2019		
NV0002046	HOLBROOK STATION RV AND MHP	03MJ	CVOC	VOCS PHASE 2 & 5	VOC	MONITORING, ROUTINE MAJOR	1/1/2017	12/31/2019		
NV0002046	HOLBROOK STATION RV AND MHP	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	1/1/2019	1/31/2019		2/11/2019

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
Total Number of Violations for this Water System:										7
NV0000833	HORIZON C STORES 1 PAHRUMP VALLEY	45	0700	GROUNDWATER RULE	GWR	FAILURE ADDRESS DEFICIENCY (GWR)	6/1/2018	9/24/2019		9/24/2019
NV0000833	HORIZON C STORES 1 PAHRUMP VALLEY	75	7500	PUBLIC NOTICE		PUBLIC NOTICE RULE LINKED TO VIOLATION	8/22/2018	9/2/2019		9/2/2019
Total Number of Violations for this Water System:										2
NV0000827	HORIZON C STORES 2 TUMBLEWEED TAVERN	S1	1028	IRON	SECONDARIES	STATE MCL EXCEDENCE	10/1/2019	12/31/2019	4.8 MG/L	
Total Number of Violations for this Water System:										1
NV0000918	HORIZON C STORES 3 LINDA STREET	45	0700	GROUNDWATER RULE	GWR	FAILURE ADDRESS DEFICIENCY (GWR)	7/21/2018	9/25/2019		9/25/2019
NV0000918	HORIZON C STORES 3 LINDA STREET	4B	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	REPORT SAMPLE RESULT/FAIL MONITOR RTCR	10/11/2019	10/18/2019		10/18/2019
NV0000918	HORIZON C STORES 3 LINDA STREET	75	7500	PUBLIC NOTICE		PUBLIC NOTICE RULE LINKED TO VIOLATION	4/30/2018	9/2/2019		9/2/2019
Total Number of Violations for this Water System:										3
NV0005069	HUMBOLDT CONSERVATION CAMP	01	1040	NITRATE	IOC	MCL, SINGLE SAMPLE	4/1/2019	6/30/2019	26 MG/L	8/26/2019
NV0005069	HUMBOLDT CONSERVATION CAMP	45	0700	GROUNDWATER RULE	GWR	FAILURE ADDRESS DEFICIENCY (GWR)	10/24/2016	5/23/2019		5/23/2019
Total Number of Violations for this Water System:										2
NV0004062	HUMBOLDT COUNTY LIBRARY DENIO	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2019	12/31/2019		1/23/2020
NV0004062	HUMBOLDT COUNTY LIBRARY DENIO	03MJ	CNO2	NITRITE	IOC	MONITORING, ROUTINE MAJOR	1/1/2017	12/31/2019		1/23/2020
NV0004062	HUMBOLDT COUNTY LIBRARY DENIO	93	1905	COLOR	SECONDARIES	STATE FAILURE TO MONITOR	7/1/2019	9/30/2019		
NV0004062	HUMBOLDT COUNTY LIBRARY DENIO	93	1028	IRON	SECONDARIES	STATE FAILURE TO MONITOR	7/1/2019	9/30/2019		
NV0004062	HUMBOLDT COUNTY LIBRARY DENIO	93	CSC2	SECONDARY IOCS	SECONDARIES	STATE FAILURE TO MONITOR	1/1/2017	12/31/2019		1/23/2020

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
Total Number of Violations for this Water System:										5
NV0000082	INDIAN SPRINGS WATER CO INC	27MJ	CDB2	DBPR STAGE 2	ST2 DBP	MONITORING, ROUTINE (DBP), MAJOR	10/1/2018	9/30/2019		
NV0000082	INDIAN SPRINGS WATER CO INC	71	7000	CONSUMER CONFIDENCE RULE		CCR REPORT	7/1/2019			
Total Number of Violations for this Water System:										2
NV0000088	JACKPOT WATER SYSTEM	03MJ	2992	ETHYLBENZENE	VOC	MONITORING, ROUTINE MAJOR	1/1/2018	12/31/2018		11/6/2019
NV0000088	JACKPOT WATER SYSTEM	03MJ	CRUR	RADS URANIUM	RAD	MONITORING, ROUTINE MAJOR	1/1/2014	12/31/2019		
NV0000088	JACKPOT WATER SYSTEM	03MJ	2955	XYLENES, TOTAL	VOC	MONITORING, ROUTINE MAJOR	1/1/2018	12/31/2018		11/6/2019
NV0000088	JACKPOT WATER SYSTEM	27MJ	CDB2	DBPR STAGE 2	ST2 DBP	MONITORING, ROUTINE (DBP), MAJOR	1/1/2019	12/31/2019		
NV0000088	JACKPOT WATER SYSTEM	93	1920	ODOR	SECONDARIES	STATE FAILURE TO MONITOR	4/1/2019	6/30/2019		7/15/2019
NV0000088	JACKPOT WATER SYSTEM	S1	1920	ODOR	SECONDARIES	STATE MCL EXCEDENCE	7/1/2018	9/30/2018	12 TON	3/20/2019
NV0000088	JACKPOT WATER SYSTEM	S1	1920	ODOR	SECONDARIES	STATE MCL EXCEDENCE	7/1/2019	9/30/2019	7 TON	
Total Number of Violations for this Water System:										7
NV0000313	JERRITT CANYON GOLD SSX MINE	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2018	12/31/2018		3/14/2019
NV0000313	JERRITT CANYON GOLD SSX MINE	27MJ	0999	CHLORINE	ST1 DBP	MONITORING, ROUTINE (DBP), MAJOR	7/1/2019	9/30/2019		12/10/2019
NV0000313	JERRITT CANYON GOLD SSX MINE	27MJ	CDB2	DBPR STAGE 2	ST2 DBP	MONITORING, ROUTINE (DBP), MAJOR	9/1/2018	8/31/2019		
NV0000313	JERRITT CANYON GOLD SSX MINE	3AMN	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MINOR (RTCR)	7/1/2019	9/30/2019		10/24/2019
Total Number of Violations for this Water System:										4
NV0002071	JIGGS BAR	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2018	12/31/2018		12/30/2019

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0002071	JIGGS BAR	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	7/1/2019	9/30/2019		12/30/2019
NV0002071	JIGGS BAR	S1	1032	MANGANESE	SECONDARIES	STATE MCL EXCEDENCE	4/1/2019	6/30/2019	0.2 MG/L	
NV0002071	JIGGS BAR	S1	1032	MANGANESE	SECONDARIES	STATE MCL EXCEDENCE	7/1/2019	9/30/2019	0.17 MG/L	
NV0002071	JIGGS BAR	S1	1032	MANGANESE	SECONDARIES	STATE MCL EXCEDENCE	10/1/2019	12/31/2019	0.16 MG/L	
Total Number of Violations for this Water System:										5
NV0001126	JOYGLOBAL SURFACE MINING INC	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	7/1/2019	9/30/2019		11/13/2019
Total Number of Violations for this Water System:										1
NV0002121	KERSHAW RYAN STATE PARK	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	11/1/2019	11/30/2019		12/10/2019
Total Number of Violations for this Water System:										1
NV0000932	KEYSTONE CENTER	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2019	12/31/2019		
NV0000932	KEYSTONE CENTER	2C	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	CORRECTIVE/EXPEDITED ACTIONS (RTCR)	12/24/2018	7/2/2019		7/2/2019
NV0000932	KEYSTONE CENTER	2C	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	CORRECTIVE/EXPEDITED ACTIONS (RTCR)	12/24/2018	9/9/2019		9/9/2019
NV0000932	KEYSTONE CENTER	3AMJ	3014	E. COLI	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	4/1/2019	4/30/2019		5/30/2019
NV0000932	KEYSTONE CENTER	3AMJ	3014	E. COLI	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	8/1/2019	8/31/2019		9/25/2019
NV0000932	KEYSTONE CENTER	93	CSC2	SECONDARY IOCS	SECONDARIES	STATE FAILURE TO MONITOR	1/1/2017	12/31/2019		
Total Number of Violations for this Water System:										6
NV0000349	KLONDEX HOLLISTER MINE INC	S1	1028	IRON	SECONDARIES	STATE MCL EXCEDENCE	7/1/2019	9/30/2019	1 MG/L	3/4/2020
Total Number of Violations for this Water System:										1

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0000908	KLONDEX MIDAS OPERATIONS INC	3AMN	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MINOR (RTCR)	1/1/2019	3/31/2019		5/1/2019
Total Number of Violations for this Water System:										1
NV0002174	KOA OF ELY CAMPGROUND	S1	1028	IRON	SECONDARIES	STATE MCL EXCEDENCE	7/1/2018	9/30/2018	2.7 MG/L	1/25/2019
Total Number of Violations for this Water System:										1
NV0000700	KRUSE FEED AND HARDWARE	01	1040	NITRATE	IOC	MCL, SINGLE SAMPLE	7/1/2018	9/30/2018	13 MG/L	1/2/2019
NV0000700	KRUSE FEED AND HARDWARE	01	1040	NITRATE	IOC	MCL, SINGLE SAMPLE	7/1/2019	9/30/2019	11 MG/L	
NV0000700	KRUSE FEED AND HARDWARE	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2017	12/31/2017		1/31/2019
NV0000700	KRUSE FEED AND HARDWARE	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	4/1/2019	6/30/2019		8/8/2019
NV0000700	KRUSE FEED AND HARDWARE	03MJ	CNO2	NITRITE	IOC	MONITORING, ROUTINE MAJOR	1/1/2017	12/31/2019		
NV0000700	KRUSE FEED AND HARDWARE	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	12/1/2018	12/31/2018		1/2/2019
NV0000700	KRUSE FEED AND HARDWARE	93	CSC2	SECONDARY IOCS	SECONDARIES	STATE FAILURE TO MONITOR	1/1/2017	12/31/2019		
Total Number of Violations for this Water System:										7
NV0002028	LAHONTAN DAM STATE PARK	36MJ	0999	CHLORINE	SWTR	MONITORING, RTN/RPT MAJOR (SWTR-FILTER)	3/1/2018	3/31/2018		2/14/2019
NV0002028	LAHONTAN DAM STATE PARK	36MJ	0999	CHLORINE	SWTR	MONITORING, RTN/RPT MAJOR (SWTR-FILTER)	4/1/2018	4/30/2018		2/14/2019
NV0002028	LAHONTAN DAM STATE PARK	36MJ	0999	CHLORINE	SWTR	MONITORING, RTN/RPT MAJOR (SWTR-FILTER)	5/1/2018	5/31/2018		2/14/2019
NV0002028	LAHONTAN DAM STATE PARK	36MJ	0999	CHLORINE	SWTR	MONITORING, RTN/RPT MAJOR (SWTR-FILTER)	6/1/2018	6/30/2018		2/14/2019
NV0002028	LAHONTAN DAM STATE PARK	36MJ	0999	CHLORINE	SWTR	MONITORING, RTN/RPT MAJOR (SWTR-FILTER)	7/1/2018	7/31/2018		2/14/2019

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0002028	LAHONTAN DAM STATE PARK	36MJ	0999	CHLORINE	SWTR	MONITORING, RTN/RPT MAJOR (SWTR-FILTER)	8/1/2018	8/31/2018		2/14/2019
NV0002028	LAHONTAN DAM STATE PARK	36MJ	0999	CHLORINE	SWTR	MONITORING, RTN/RPT MAJOR (SWTR-FILTER)	9/1/2018	9/30/2018		2/14/2019
NV0002028	LAHONTAN DAM STATE PARK	36MJ	0999	CHLORINE	SWTR	MONITORING, RTN/RPT MAJOR (SWTR-FILTER)	10/1/2018	10/31/2018		2/14/2019
NV0002028	LAHONTAN DAM STATE PARK	36MJ	0100	TURBIDITY	SWTR	MONITORING, RTN/RPT MAJOR (SWTR-FILTER)	3/1/2018	3/31/2018		2/14/2019
NV0002028	LAHONTAN DAM STATE PARK	36MJ	0100	TURBIDITY	SWTR	MONITORING, RTN/RPT MAJOR (SWTR-FILTER)	4/1/2018	4/30/2018		2/14/2019
NV0002028	LAHONTAN DAM STATE PARK	36MJ	0100	TURBIDITY	SWTR	MONITORING, RTN/RPT MAJOR (SWTR-FILTER)	5/1/2018	5/31/2018		2/14/2019
NV0002028	LAHONTAN DAM STATE PARK	36MJ	0100	TURBIDITY	SWTR	MONITORING, RTN/RPT MAJOR (SWTR-FILTER)	6/1/2018	6/30/2018		2/14/2019
NV0002028	LAHONTAN DAM STATE PARK	36MJ	0100	TURBIDITY	SWTR	MONITORING, RTN/RPT MAJOR (SWTR-FILTER)	7/1/2018	7/31/2018		2/14/2019
NV0002028	LAHONTAN DAM STATE PARK	36MJ	0100	TURBIDITY	SWTR	MONITORING, RTN/RPT MAJOR (SWTR-FILTER)	8/1/2018	8/31/2018		2/14/2019
NV0002028	LAHONTAN DAM STATE PARK	36MJ	0100	TURBIDITY	SWTR	MONITORING, RTN/RPT MAJOR (SWTR-FILTER)	9/1/2018	9/30/2018		2/14/2019
NV0002028	LAHONTAN DAM STATE PARK	36MJ	0100	TURBIDITY	SWTR	MONITORING, RTN/RPT MAJOR (SWTR-FILTER)	10/1/2018	10/31/2018		2/14/2019

Total Number of Violations for this Water System: 16

NV0005021	LAHONTAN DAM STATE PARK BEACH 7	45	0700	GROUNDWATER RULE	GWR	FAILURE ADDRESS DEFICIENCY (GWR)	1/17/2017	5/14/2019		5/14/2019
-----------	---------------------------------	----	------	------------------	-----	----------------------------------	-----------	-----------	--	-----------

Total Number of Violations for this Water System: 1

NV0000928	LAMOILLE VALLEY PLAZA	02	1005	ARSENIC	IOC	MCL, AVERAGE	1/1/2019	3/31/2019	0.023 MG/L	
NV0000928	LAMOILLE VALLEY PLAZA	02	1005	ARSENIC	IOC	MCL, AVERAGE	4/1/2019	6/30/2019	0.024 MG/L	
NV0000928	LAMOILLE VALLEY PLAZA	02	1005	ARSENIC	IOC	MCL, AVERAGE	7/1/2019	9/30/2019	0.024 MG/L	

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0000928	LAMOILLE VALLEY PLAZA	02	1005	ARSENIC	IOC	MCL, AVERAGE	10/1/2019	12/31/2019	0.024 MG/L	
NV0000928	LAMOILLE VALLEY PLAZA	03MJ	CDAS	ARSENIC (AS)	IOC	MONITORING, ROUTINE MAJOR	7/1/2019	9/30/2019		12/23/2019
NV0000928	LAMOILLE VALLEY PLAZA	03MJ	CDAS	ARSENIC (AS)	IOC	MONITORING, ROUTINE MAJOR	7/1/2019	9/30/2019		10/9/2019
NV0000928	LAMOILLE VALLEY PLAZA	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2018	12/31/2018		12/31/2019
NV0000928	LAMOILLE VALLEY PLAZA	03MJ	CNO2	NITRITE	IOC	MONITORING, ROUTINE MAJOR	1/1/2017	12/31/2019		
NV0000928	LAMOILLE VALLEY PLAZA	52	5000	LEAD & COPPER RULE	LCR	FOLLOW-UP OR ROUTINE TAP M/R (LCR)	10/1/2018	8/20/2019		8/20/2019
NV0000928	LAMOILLE VALLEY PLAZA	52	5000	LEAD & COPPER RULE	LCR	FOLLOW-UP OR ROUTINE TAP M/R (LCR)	10/1/2017	8/20/2019		8/20/2019
Total Number of Violations for this Water System:										10

NV0000273	LAMOILLE WATER USERS ASSOC	S1	1028	IRON	SECONDARIES	STATE MCL EXCEDENCE	4/1/2018	6/30/2018	1.2 MG/L	2/27/2019
Total Number of Violations for this Water System:										1

NV0000006	LANDER CO SEWER AND WATER DIST 2	02	4006	COMBINED URANIUM	RAD	MCL, AVERAGE	7/1/2019	9/30/2019	36 UG/L	3/31/2020
NV0000006	LANDER CO SEWER AND WATER DIST 2	02	4006	COMBINED URANIUM	RAD	MCL, AVERAGE	10/1/2019	12/31/2019	38 UG/L	3/31/2020
NV0000006	LANDER CO SEWER AND WATER DIST 2	03MJ	CRUR	RADS URANIUM	RAD	MONITORING, ROUTINE MAJOR	4/1/2019	6/30/2019		7/16/2019
NV0000006	LANDER CO SEWER AND WATER DIST 2	27MJ	0999	CHLORINE	ST1 DBP	MONITORING, ROUTINE (DBP), MAJOR	7/1/2018	9/30/2018		9/26/2019
Total Number of Violations for this Water System:										4

NV0000090	LAS VEGAS VALLEY WATER DISTRICT	03MJ	2105	2,4-D	SOC	MONITORING, ROUTINE MAJOR	1/1/2017	12/31/2019		
NV0000090	LAS VEGAS VALLEY WATER DISTRICT	03MJ	2946	ETHYLENE DIBROMIDE	SOC	MONITORING, ROUTINE MAJOR	1/1/2017	12/31/2019		

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0000090	LAS VEGAS VALLEY WATER DISTRICT	03MJ	CS08	SOCS PH5 DIOXIN	SOC	MONITORING, ROUTINE MAJOR	1/1/2017	12/31/2019		
NV0000090	LAS VEGAS VALLEY WATER DISTRICT	03MJ	CS08	SOCS PH5 DIOXIN	SOC	MONITORING, ROUTINE MAJOR	1/1/2017	12/31/2019		
NV0000090	LAS VEGAS VALLEY WATER DISTRICT	03MJ	CSOC	SOCS PHASE 2 & 5	SOC	MONITORING, ROUTINE MAJOR	1/1/2017	12/31/2019		
Total Number of Violations for this Water System:										5
NV0004005	LDS LEE RECREATION CAMP	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	6/1/2019	6/30/2019		7/15/2019
NV0004005	LDS LEE RECREATION CAMP	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	10/1/2019	10/31/2019		
NV0004005	LDS LEE RECREATION CAMP	93	1002	ALUMINUM	SECONDARIES	STATE FAILURE TO MONITOR	7/1/2019	9/30/2019		
NV0004005	LDS LEE RECREATION CAMP	93	1930	TDS	SECONDARIES	STATE FAILURE TO MONITOR	8/1/2019	8/31/2019		
NV0004005	LDS LEE RECREATION CAMP	S1	1930	TDS	SECONDARIES	STATE MCL EXCEDENCE	7/1/2019	9/30/2019	1187 MG/L	
Total Number of Violations for this Water System:										5
NV0002192	LITTLE A LE INN	45	0700	GROUNDWATER RULE	GWR	FAILURE ADDRESS DEFICIENCY (GWR)	1/19/2020			
NV0002192	LITTLE A LE INN	93	CSC2	SECONDARY IOCS	SECONDARIES	STATE FAILURE TO MONITOR	1/1/2017	12/31/2019		
Total Number of Violations for this Water System:										2
NV0002050	LOGAN CREEK ESTATES GID	71	7000	CONSUMER CONFIDENCE RULE		CCR REPORT	7/1/2019	7/5/2019		7/5/2019
Total Number of Violations for this Water System:										1
NV0001185	LOGOS CHRISTIAN ACADEMY	02	1005	ARSENIC	IOC	MCL, AVERAGE	7/1/2019	9/30/2019	0.016 MG/L	
NV0001185	LOGOS CHRISTIAN ACADEMY	02	1005	ARSENIC	IOC	MCL, AVERAGE	10/1/2019	12/31/2019	0.032 MG/L	
NV0001185	LOGOS CHRISTIAN ACADEMY	51	5000	LEAD & COPPER RULE	LCR	INITIAL TAP SAMPLING (LCR)	7/1/2019			

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
Total Number of Violations for this Water System:										3
NV0000871	LONGSTREET INN AND CASINO	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	6/1/2019	6/30/2019		7/30/2019
Total Number of Violations for this Water System:										1
NV0000861	LOVELOCK CORRECTIONAL	71	7000	CONSUMER CONFIDENCE RULE		CCR REPORT	7/1/2019			
Total Number of Violations for this Water System:										1
NV0000140	LUNA VISTA	71	7000	CONSUMER CONFIDENCE RULE		CCR REPORT	7/1/2019	9/28/2019		9/28/2019
Total Number of Violations for this Water System:										1
NV0004101	LUND MEETINGHOUSE LDS	45	0700	GROUNDWATER RULE	GWR	FAILURE ADDRESS DEFICIENCY (GWR)	10/26/2019			
Total Number of Violations for this Water System:										1
NV0002220	LYE CREEK CAMPGROUND USFS	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	8/1/2019	8/31/2019		
NV0002220	LYE CREEK CAMPGROUND USFS	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	9/1/2019	9/30/2019		
Total Number of Violations for this Water System:										2
NV0005019	MABELS BAR	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2018	12/31/2018		5/3/2019
Total Number of Violations for this Water System:										1
NV0000738	MAGIC CARPET GOLF	45	0700	GROUNDWATER RULE	GWR	FAILURE ADDRESS DEFICIENCY (GWR)	4/29/2019	6/12/2019		6/12/2019
NV0000738	MAGIC CARPET GOLF	93	CSC2	SECONDARY IOCS	SECONDARIES	STATE FAILURE TO MONITOR	1/1/2017	12/31/2019		
Total Number of Violations for this Water System:										2
NV0000162	MCDERMITT WATER SYSTEM	02	1005	ARSENIC	IOC	MCL, AVERAGE	1/1/2019	3/31/2019	0.012 MG/L	

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0000162	MCDERMITT WATER SYSTEM	02	1005	ARSENIC	IOC	MCL, AVERAGE	4/1/2019	6/30/2019	0.013 MG/L	
NV0000162	MCDERMITT WATER SYSTEM	02	1005	ARSENIC	IOC	MCL, AVERAGE	7/1/2019	9/30/2019	13 UG/L	
NV0000162	MCDERMITT WATER SYSTEM	02	1005	ARSENIC	IOC	MCL, AVERAGE	10/1/2019	12/31/2019	13 UG/L	
NV0000162	MCDERMITT WATER SYSTEM	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	6/1/2019	6/30/2019		7/11/2019
Total Number of Violations for this Water System:										5
NV0002508	MCWILLIAMS WATER SYSTEM	93	1028	IRON	SECONDARIES	STATE FAILURE TO MONITOR	7/1/2018	9/30/2018		3/29/2019
NV0002508	MCWILLIAMS WATER SYSTEM	93	1028	IRON	SECONDARIES	STATE FAILURE TO MONITOR	4/1/2019	6/30/2019		12/23/2019
NV0002508	MCWILLIAMS WATER SYSTEM	93	1028	IRON	SECONDARIES	STATE FAILURE TO MONITOR	7/1/2019	9/30/2019		12/23/2019
NV0002508	MCWILLIAMS WATER SYSTEM	S1	1028	IRON	SECONDARIES	STATE MCL EXCEDENCE	1/1/2017	12/31/2017	8.7 MG/L	3/29/2019
Total Number of Violations for this Water System:										4
NV0000950	MEMORIAL POINT STATE PARK	S1	1017	CHLORIDE	SECONDARIES	STATE MCL EXCEDENCE	7/1/2019	9/30/2019	475 MG/L	1/30/2020
NV0000950	MEMORIAL POINT STATE PARK	S1	1028	IRON	SECONDARIES	STATE MCL EXCEDENCE	10/1/2019	12/31/2019	0.7 MG/L	
Total Number of Violations for this Water System:										2
NV0003071	MIDAS WATER COOPERATIVE	2C	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	CORRECTIVE/EXPEDITED ACTIONS (RTCR)	10/31/2018	5/1/2019		5/1/2019
NV0003071	MIDAS WATER COOPERATIVE	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	5/1/2019	5/31/2019		6/18/2019
Total Number of Violations for this Water System:										2
NV0000169	MONTELLO WATER SYSTEM	4B	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	REPORT SAMPLE RESULT/FAIL MONITOR RTCR	8/1/2019	8/31/2019		9/26/2019
NV0000169	MONTELLO WATER SYSTEM	S1	1920	ODOR	SECONDARIES	STATE MCL EXCEDENCE	10/1/2018	12/31/2018	200 TON	5/28/2019

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
Total Number of Violations for this Water System:										2
NV0000732	MOUNT ROSE BOWL PROPERTY OWNERS	53	1925	PH	LCR	WATER QUALITY PARAMETER M/R (LCR)	7/1/2019	12/31/2019		
NV0000732	MOUNT ROSE BOWL PROPERTY OWNERS	53	1996	TEMPERATURE (CENTIGRADE)	LCR	WATER QUALITY PARAMETER M/R (LCR)	1/1/2019	6/30/2019		
NV0000732	MOUNT ROSE BOWL PROPERTY OWNERS	53	1996	TEMPERATURE (CENTIGRADE)	LCR	WATER QUALITY PARAMETER M/R (LCR)	7/1/2019	12/31/2019		
NV0000732	MOUNT ROSE BOWL PROPERTY OWNERS	57	5000	LEAD & COPPER RULE	LCR	OCCT/SOWT RECOMMENDATION/STUDY	7/22/2016			
NV0000732	MOUNT ROSE BOWL PROPERTY OWNERS	58	5000	LEAD & COPPER RULE	LCR	OCCT/SOWT INSTALL DEMONSTRATION (LCR)	7/22/2016	3/4/2020		3/4/2020
Total Number of Violations for this Water System:										5
NV0000170	MOUNTAIN CITY WATER AND SEWER	27MJ	0999	CHLORINE	ST1 DBP	MONITORING, ROUTINE (DBP), MAJOR	4/1/2019	6/30/2019		7/1/2019
NV0000170	MOUNTAIN CITY WATER AND SEWER	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	6/1/2019	6/30/2019		7/1/2019
Total Number of Violations for this Water System:										2
NV0001082	MOUNTAIN SPRINGS BAR INC	45	0700	GROUNDWATER RULE	GWR	FAILURE ADDRESS DEFICIENCY (GWR)	10/22/2018	5/31/2019		5/31/2019
Total Number of Violations for this Water System:										1
NV0000789	MSJK PROPERTIES LLC	03MJ	CNO2	NITRITE	IOC	MONITORING, ROUTINE MAJOR	1/1/2017	12/31/2019		
NV0000789	MSJK PROPERTIES LLC	3AMJ	3014	E. COLI	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	1/1/2019	1/31/2019		2/26/2019
NV0000789	MSJK PROPERTIES LLC	3AMJ	3014	E. COLI	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	7/1/2019	7/31/2019		8/27/2019
NV0000789	MSJK PROPERTIES LLC	93	CSC2	SECONDARY IOCS	SECONDARIES	STATE FAILURE TO MONITOR	1/1/2017	12/31/2019		
Total Number of Violations for this Water System:										4
NV0001010	MT CHARLESTON PUB LLC	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	2/1/2019	2/28/2019		3/13/2019

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
Total Number of Violations for this Water System:										1
NV0001015	MT CHARLESTON WATER COMPANY	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	2/1/2019	2/28/2019		3/13/2019
Total Number of Violations for this Water System:										1
NV0000743	MT ROSE CAMPGROUND USFS	93	CSC2	SECONDARY IOCS	SECONDARIES	STATE FAILURE TO MONITOR	1/1/2014	12/31/2016		11/12/2019
Total Number of Violations for this Water System:										1
NV0000876	NARCONON NEVADA RAINBOW CANYON	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	1/1/2019	3/31/2019		
NV0000876	NARCONON NEVADA RAINBOW CANYON	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	4/1/2019	6/30/2019		
NV0000876	NARCONON NEVADA RAINBOW CANYON	93	CSC2	SECONDARY IOCS	SECONDARIES	STATE FAILURE TO MONITOR	1/1/2017	12/31/2019		
Total Number of Violations for this Water System:										3
NV0000869	NATCHEZ GYM	S1	1028	IRON	SECONDARIES	STATE MCL EXCEDENCE	1/1/2019	3/31/2019	2.4 MG/L	
NV0000869	NATCHEZ GYM	S1	1028	IRON	SECONDARIES	STATE MCL EXCEDENCE	4/1/2019	6/30/2019	5.8 MG/L	
NV0000869	NATCHEZ GYM	S1	1028	IRON	SECONDARIES	STATE MCL EXCEDENCE	10/1/2019	12/31/2019	10 MG/L	
Total Number of Violations for this Water System:										3
NV0000943	NDOT SUNNYSIDE ROADSIDE PARK	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	7/1/2019	9/30/2019		10/23/2019
NV0000943	NDOT SUNNYSIDE ROADSIDE PARK	3BMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ADD. ROUTINE, MAJOR (RTCR)	12/1/2019	12/31/2019		1/22/2020
Total Number of Violations for this Water System:										2
NV0004022	NDOT WADSWORTH REST STOP	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2018	12/31/2018		5/7/2019
NV0004022	NDOT WADSWORTH REST STOP	3AMJ	3014	E. COLI	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	3/1/2019	3/31/2019		4/22/2019

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0004022	NDOT WADSWORTH REST STOP	3AMJ	3014	E. COLI	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	9/1/2019	9/30/2019		11/1/2019
NV0004022	NDOT WADSWORTH REST STOP	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	12/1/2018	12/31/2018		1/31/2019
NV0004022	NDOT WADSWORTH REST STOP	45	0700	GROUNDWATER RULE	GWR	FAILURE ADDRESS DEFICIENCY (GWR)	7/21/2018	5/20/2019		5/20/2019
Total Number of Violations for this Water System:										5
NV0002014	NEVADA LIVESTOCK MARKETING	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2018	12/31/2018		6/5/2019
NV0002014	NEVADA LIVESTOCK MARKETING	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	1/1/2019	3/31/2019		6/5/2019
NV0002014	NEVADA LIVESTOCK MARKETING	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	5/1/2019	5/31/2019		6/5/2019
NV0002014	NEVADA LIVESTOCK MARKETING	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	11/1/2019	11/30/2019		12/12/2019
Total Number of Violations for this Water System:										4
NV0000699	NEVADA STATE VETERANS HOME	27MJ	0999	CHLORINE	ST1 DBP	MONITORING, ROUTINE (DBP), MAJOR	10/1/2019	12/31/2019		11/1/2019
NV0000699	NEVADA STATE VETERANS HOME	3AMJ	3014	E. COLI	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	10/1/2019	10/31/2019		11/1/2019
Total Number of Violations for this Water System:										2
NV0000903	NEW MILLENNIUM BUILDING SYSTEMS,	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2018	12/31/2018		1/16/2019
Total Number of Violations for this Water System:										1
NV0002603	NEWMONT GOLD NORTH AREA LEACH	27MJ	CDB2	DBPR STAGE 2	ST2 DBP	MONITORING, ROUTINE (DBP), MAJOR	10/1/2016	9/30/2019		
Total Number of Violations for this Water System:										1
NV0003005	NPS BOULDER BEACH	27MJ	0999	CHLORINE	ST1 DBP	MONITORING, ROUTINE (DBP), MAJOR	7/1/2018	9/30/2018		8/1/2019
Total Number of Violations for this Water System:										1

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0002506	NPS CALLVILLE BAY	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2019	12/31/2019		4/29/2020
Total Number of Violations for this Water System:										1
NV0000921	OASIS SPRINGS	S1	1032	MANGANESE	SECONDARIES	STATE MCL EXCEDENCE	4/1/2019	6/30/2019	0.34 MG/L	3/31/2020
Total Number of Violations for this Water System:										1
NV0004028	OLAM SVI	4B	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	REPORT SAMPLE RESULT/FAIL MONITOR RTCR	10/11/2019	10/21/2019		10/21/2019
Total Number of Violations for this Water System:										1
NV0000797	OLD FORTY WEST MOTEL	02	1005	ARSENIC	IOC	MCL, AVERAGE	1/1/2019	3/31/2019	0.072 MG/L	
NV0000797	OLD FORTY WEST MOTEL	02	1005	ARSENIC	IOC	MCL, AVERAGE	4/1/2019	6/30/2019	0.067 MG/L	
NV0000797	OLD FORTY WEST MOTEL	02	1005	ARSENIC	IOC	MCL, AVERAGE	7/1/2019	9/30/2019	0.066 MG/L	
NV0000797	OLD FORTY WEST MOTEL	02	1005	ARSENIC	IOC	MCL, AVERAGE	10/1/2019	12/31/2019	0.063 MG/L	
NV0000797	OLD FORTY WEST MOTEL	03MJ	CRAU	RADIONUCLIDES	RAD	MONITORING, ROUTINE MAJOR	7/1/2018	9/30/2018		3/19/2019
NV0000797	OLD FORTY WEST MOTEL	03MJ	CRAU	RADIONUCLIDES	RAD	MONITORING, ROUTINE MAJOR	10/1/2018	12/31/2018		3/19/2019
NV0000797	OLD FORTY WEST MOTEL	03MJ	CSOC	SOCS PHASE 2 & 5	SOC	MONITORING, ROUTINE MAJOR	7/1/2018	9/30/2018		3/19/2019
NV0000797	OLD FORTY WEST MOTEL	03MJ	CSOC	SOCS PHASE 2 & 5	SOC	MONITORING, ROUTINE MAJOR	10/1/2018	12/31/2018		3/19/2019
NV0000797	OLD FORTY WEST MOTEL	03MJ	CVOC	VOCS PHASE 2 & 5	VOC	MONITORING, ROUTINE MAJOR	7/1/2018	9/30/2018		3/19/2019
NV0000797	OLD FORTY WEST MOTEL	03MJ	CVOC	VOCS PHASE 2 & 5	VOC	MONITORING, ROUTINE MAJOR	10/1/2018	12/31/2018		3/19/2019
NV0000797	OLD FORTY WEST MOTEL	03MJ	CVOC	VOCS PHASE 2 & 5	VOC	MONITORING, ROUTINE MAJOR	10/1/2019	12/31/2019		

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0000797	OLD FORTY WEST MOTEL	45	0700	GROUNDWATER RULE	GWR	FAILURE ADDRESS DEFICIENCY (GWR)	7/29/2017			
Total Number of Violations for this Water System:										12

NV0000303	OLD RIVER WATER COMPANY	02	1005	ARSENIC	IOC	MCL, AVERAGE	7/1/2019	9/30/2019	0.013 MG/L	10/20/2019
NV0000303	OLD RIVER WATER COMPANY	02	1005	ARSENIC	IOC	MCL, AVERAGE	7/1/2019	9/30/2019	0.016 MG/L	
NV0000303	OLD RIVER WATER COMPANY	02	1005	ARSENIC	IOC	MCL, AVERAGE	10/1/2019	12/31/2019	0.019 MG/L	
NV0000303	OLD RIVER WATER COMPANY	03MJ	CDAS	ARSENIC (AS)	IOC	MONITORING, ROUTINE MAJOR	1/1/2019	3/31/2019		8/1/2019
NV0000303	OLD RIVER WATER COMPANY	03MJ	CDAS	ARSENIC (AS)	IOC	MONITORING, ROUTINE MAJOR	1/1/2019	3/31/2019		10/20/2019
NV0000303	OLD RIVER WATER COMPANY	03MJ	CDAS	ARSENIC (AS)	IOC	MONITORING, ROUTINE MAJOR	4/1/2019	6/30/2019		10/20/2019
NV0000303	OLD RIVER WATER COMPANY	03MJ	CDAS	ARSENIC (AS)	IOC	MONITORING, ROUTINE MAJOR	4/1/2019	6/30/2019		8/15/2019
NV0000303	OLD RIVER WATER COMPANY	03MJ	CDAS	ARSENIC (AS)	IOC	MONITORING, ROUTINE MAJOR	4/1/2019	6/30/2019		8/1/2019
NV0000303	OLD RIVER WATER COMPANY	03MJ	CDAS	ARSENIC (AS)	IOC	MONITORING, ROUTINE MAJOR	1/1/2017	12/31/2019		
NV0000303	OLD RIVER WATER COMPANY	03MJ	CDAS	ARSENIC (AS)	IOC	MONITORING, ROUTINE MAJOR	1/1/2017	12/31/2019		
NV0000303	OLD RIVER WATER COMPANY	03MJ	CDAS	ARSENIC (AS)	IOC	MONITORING, ROUTINE MAJOR	1/1/2017	12/31/2019		
NV0000303	OLD RIVER WATER COMPANY	03MJ	CDAS	ARSENIC (AS)	IOC	MONITORING, ROUTINE MAJOR	1/1/2017	12/31/2019		
NV0000303	OLD RIVER WATER COMPANY	03MJ	CDAS	ARSENIC (AS)	IOC	MONITORING, ROUTINE MAJOR	1/1/2017	12/31/2019		
NV0000303	OLD RIVER WATER COMPANY	03MJ	CIOC	IOC PH 5 CYANIDE	IOC	MONITORING, ROUTINE MAJOR	1/1/2011	12/31/2019		
NV0000303	OLD RIVER WATER COMPANY	03MJ	CIO5	IOCS PHASE 5	IOC	MONITORING, ROUTINE MAJOR	1/1/2011	12/31/2019		
NV0000303	OLD RIVER WATER COMPANY	03MJ	CIO5	IOCS PHASE 5	IOC	MONITORING, ROUTINE MAJOR	1/1/2011	12/31/2019		

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0000303	OLD RIVER WATER COMPANY	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2019	12/31/2019		
NV0000303	OLD RIVER WATER COMPANY	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2019	12/31/2019		
NV0000303	OLD RIVER WATER COMPANY	03MJ	CNO2	NITRITE	IOC	MONITORING, ROUTINE MAJOR	1/1/2017	12/31/2019		
NV0000303	OLD RIVER WATER COMPANY	03MJ	CNO2	NITRITE	IOC	MONITORING, ROUTINE MAJOR	1/1/2017	12/31/2019		
NV0000303	OLD RIVER WATER COMPANY	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	11/1/2019	11/30/2019		12/9/2019
NV0000303	OLD RIVER WATER COMPANY	52	5000	LEAD & COPPER RULE	LCR	FOLLOW-UP OR ROUTINE TAP M/R (LCR)	10/1/2018	7/23/2019		8/12/2019
NV0000303	OLD RIVER WATER COMPANY	52	5000	LEAD & COPPER RULE	LCR	FOLLOW-UP OR ROUTINE TAP M/R (LCR)	10/1/2018	7/23/2019		7/23/2019
Total Number of Violations for this Water System:										22

NV0004106	PAHRANAGAT NATIONAL WILDLIFE	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2019	12/31/2019		
NV0004106	PAHRANAGAT NATIONAL WILDLIFE	03MJ	CNO2	NITRITE	IOC	MONITORING, ROUTINE MAJOR	1/1/2017	12/31/2019		4/29/2020
NV0004106	PAHRANAGAT NATIONAL WILDLIFE	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	10/1/2019	12/31/2019		1/6/2020
NV0004106	PAHRANAGAT NATIONAL WILDLIFE	4B	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	REPORT SAMPLE RESULT/FAIL MONITOR RTCR	7/11/2019	8/6/2019		8/6/2019
NV0004106	PAHRANAGAT NATIONAL WILDLIFE	93	CDAS	ARSENIC (AS)	SECONDARIES	STATE FAILURE TO MONITOR	1/1/2019	12/31/2019		1/6/2020
NV0004106	PAHRANAGAT NATIONAL WILDLIFE	93	CSC2	SECONDARY IOCS	SECONDARIES	STATE FAILURE TO MONITOR	1/1/2019	12/31/2019		5/7/2020
Total Number of Violations for this Water System:										6

NV0004018	PAHRUMP FIRE STATION BLM	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2018	12/31/2018		8/27/2019
NV0004018	PAHRUMP FIRE STATION BLM	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	10/1/2018	12/31/2018		2/19/2019

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0004018	PAHRUMP FIRE STATION BLM	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	4/1/2019	6/30/2019		8/27/2019
NV0004018	PAHRUMP FIRE STATION BLM	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	9/1/2019	9/30/2019		10/30/2019
NV0004018	PAHRUMP FIRE STATION BLM	45	0700	GROUNDWATER RULE	GWR	FAILURE ADDRESS DEFICIENCY (GWR)	10/6/2019			
Total Number of Violations for this Water System:										5
NV0003036	PAHRUMP SENIOR CENTER INC	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2018	12/31/2018		9/19/2019
NV0003036	PAHRUMP SENIOR CENTER INC	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	4/1/2019	6/30/2019		7/10/2019
Total Number of Violations for this Water System:										2
NV0000819	PALM GARDENS WATER CO OP	03MJ	CVOC	VOCS PHASE 2 & 5	VOC	MONITORING, ROUTINE MAJOR	1/1/2017	12/31/2019		
Total Number of Violations for this Water System:										1
NV0000185	PANACA FARMSTEAD WATER ASSOCIATION	52	5000	LEAD & COPPER RULE	LCR	FOLLOW-UP OR ROUTINE TAP M/R (LCR)	10/1/2018	7/10/2019		7/10/2019
NV0000185	PANACA FARMSTEAD WATER ASSOCIATION	93	CNO3	NITRATE	SECONDARIES	STATE FAILURE TO MONITOR	1/1/2018	12/31/2018		7/10/2019
Total Number of Violations for this Water System:										2
NV0002186	PARADISE VALLEY ELEMENTARY	03MJ	CDAS	ARSENIC (AS)	IOC	MONITORING, ROUTINE MAJOR	1/1/2014	12/31/2016		6/12/2019
Total Number of Violations for this Water System:										1
NV0001166	PARIS LAS VEGAS HOTEL AND CASINO	27MJ	0999	CHLORINE	ST1 DBP	MONITORING, ROUTINE (DBP), MAJOR	7/1/2019	9/30/2019		
NV0001166	PARIS LAS VEGAS HOTEL AND CASINO	27MJ	CDB2	DBPR STAGE 2	ST2 DBP	MONITORING, ROUTINE (DBP), MAJOR	7/1/2019	9/30/2019		1/15/2020
NV0001166	PARIS LAS VEGAS HOTEL AND CASINO	3AMJ	3014	E. COLI	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	7/1/2019	7/31/2019		8/31/2019
Total Number of Violations for this Water System:										3

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0004067	PEACOX CHARITABLE REMAINDER UNITRUST	02	1005	ARSENIC	IOC	MCL, AVERAGE	1/1/2019	3/31/2019	0.033 MG/L	
NV0004067	PEACOX CHARITABLE REMAINDER UNITRUST	02	1005	ARSENIC	IOC	MCL, AVERAGE	4/1/2019	6/30/2019	0.033 MG/L	
NV0004067	PEACOX CHARITABLE REMAINDER UNITRUST	02	1005	ARSENIC	IOC	MCL, AVERAGE	7/1/2019	9/30/2019	0.033 MG/L	
NV0004067	PEACOX CHARITABLE REMAINDER UNITRUST	02	1005	ARSENIC	IOC	MCL, AVERAGE	10/1/2019	12/31/2019	0.032 MG/L	
NV0004067	PEACOX CHARITABLE REMAINDER UNITRUST	27MJ	CDB2	DBPR STAGE 2	ST2 DBP	MONITORING, ROUTINE (DBP), MAJOR	7/1/2016	6/30/2017		6/3/2019
NV0004067	PEACOX CHARITABLE REMAINDER UNITRUST	S1	1025	FLUORIDE	SECONDARIES	STATE MCL EXCEDENCE	1/1/2019	3/31/2019	2.8 MG/L	
NV0004067	PEACOX CHARITABLE REMAINDER UNITRUST	S1	1025	FLUORIDE	SECONDARIES	STATE MCL EXCEDENCE	4/1/2019	6/30/2019	3.1 MG/L	
NV0004067	PEACOX CHARITABLE REMAINDER UNITRUST	S1	1025	FLUORIDE	SECONDARIES	STATE MCL EXCEDENCE	7/1/2019	9/30/2019	2.7 MG/L	
NV0004067	PEACOX CHARITABLE REMAINDER UNITRUST	S1	1025	FLUORIDE	SECONDARIES	STATE MCL EXCEDENCE	10/1/2019	12/31/2019	2.9 MG/L	
Total Number of Violations for this Water System:										9
NV0004063	PICK AND SHOVEL INVESTMENTS	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	7/1/2018	9/30/2018		2/22/2019
NV0004063	PICK AND SHOVEL INVESTMENTS	45	0700	GROUNDWATER RULE	GWR	FAILURE ADDRESS DEFICIENCY (GWR)	11/3/2017	2/4/2019		2/4/2019
Total Number of Violations for this Water System:										2
NV0002095	PILOT TRAVEL CENTER 485	34MJ	3014	E. COLI	GWR	MONITOR GWR TRIGGERED/ADDITONAL, MAJOR	12/12/2019	12/12/2019		12/12/2019
Total Number of Violations for this Water System:										1
NV0000067	PINION PINES MHP	34MJ	3014	E. COLI	GWR	MONITOR GWR TRIGGERED/ADDITONAL, MAJOR	3/15/2019	3/18/2019		3/18/2019
Total Number of Violations for this Water System:										1
NV0000186	PIOCHE PUBLIC UTILITIES	03MJ	1036	NICKEL	IOC	MONITORING, ROUTINE MAJOR	1/1/2011	12/31/2019		

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
Total Number of Violations for this Water System:										1
NV0001170	PREMIER MAGNESIA	S1	1025	FLUORIDE	SECONDARIES	STATE MCL EXCEDENCE	1/1/2019	3/31/2019	9.4 MG/L	
NV0001170	PREMIER MAGNESIA	S1	1025	FLUORIDE	SECONDARIES	STATE MCL EXCEDENCE	4/1/2019	6/30/2019	9.1 MG/L	
NV0001170	PREMIER MAGNESIA	S1	1025	FLUORIDE	SECONDARIES	STATE MCL EXCEDENCE	7/1/2019	9/30/2019	9.3 MG/L	
NV0001170	PREMIER MAGNESIA	S1	1025	FLUORIDE	SECONDARIES	STATE MCL EXCEDENCE	10/1/2019	12/31/2019	10.0 MG/L	
NV0001170	PREMIER MAGNESIA	S6				CERTIFIED OPERATOR FAILURE (STATE)	11/22/2019			
Total Number of Violations for this Water System:										5
NV0001073	PRIMM VALLEY CASINO RESORTS	03MJ	CDAS	ARSENIC (AS)	IOC	MONITORING, ROUTINE MAJOR	1/1/2017	12/31/2019		5/20/2020
NV0001073	PRIMM VALLEY CASINO RESORTS	03MJ	CIOF	IOC FLUORIDE	IOC	MONITORING, ROUTINE MAJOR	1/1/2017	12/31/2019		5/20/2020
NV0001073	PRIMM VALLEY CASINO RESORTS	03MJ	CIOC	IOC PH 5 CYANIDE	IOC	MONITORING, ROUTINE MAJOR	1/1/2017	12/31/2019		5/20/2020
NV0001073	PRIMM VALLEY CASINO RESORTS	03MJ	CIO2	IOCS PHASE 2	IOC	MONITORING, ROUTINE MAJOR	1/1/2017	12/31/2019		5/20/2020
NV0001073	PRIMM VALLEY CASINO RESORTS	03MJ	CIO5	IOCS PHASE 5	IOC	MONITORING, ROUTINE MAJOR	1/1/2017	12/31/2019		5/20/2020
NV0001073	PRIMM VALLEY CASINO RESORTS	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2019	12/31/2019		5/20/2020
NV0001073	PRIMM VALLEY CASINO RESORTS	03MJ	CNO2	NITRITE	IOC	MONITORING, ROUTINE MAJOR	1/1/2017	12/31/2019		5/20/2020
NV0001073	PRIMM VALLEY CASINO RESORTS	03MJ	CSOD	SODIUM (NA)	IOC	MONITORING, ROUTINE MAJOR	1/1/2017	12/31/2019		5/20/2020
NV0001073	PRIMM VALLEY CASINO RESORTS	93	CSC2	SECONDARY IOCS	SECONDARIES	STATE FAILURE TO MONITOR	1/1/2017	12/31/2019		5/20/2020
NV0001073	PRIMM VALLEY CASINO RESORTS	S1	1920	ODOR	SECONDARIES	STATE MCL EXCEDENCE	10/1/2019	12/31/2019	17 TON	
Total Number of Violations for this Water System:										10

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0000054	R AND M MOBILE HOME PARK	S1	1028	IRON	SECONDARIES	STATE MCL EXCEDENCE	10/1/2018	12/31/2018	0.7 MG/L	6/25/2019
Total Number of Violations for this Water System:										1
NV0000129	RANCHO COOPERATIVE WATER	71	7000	CONSUMER CONFIDENCE RULE		CCR REPORT	7/1/2019	7/9/2019		7/9/2019
Total Number of Violations for this Water System:										1
NV0002571	RANCHO VISTA 4	45	0700	GROUNDWATER RULE	GWR	FAILURE ADDRESS DEFICIENCY (GWR)	7/20/2018	12/6/2019		12/6/2019
NV0002571	RANCHO VISTA 4	71	7000	CONSUMER CONFIDENCE RULE		CCR REPORT	7/1/2019			
Total Number of Violations for this Water System:										2
NV0005011	RED ROCK CANYON VISITOR CENTER BLM	3AMJ	3014	E. COLI	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	7/1/2019	7/31/2019		10/31/2019
NV0005011	RED ROCK CANYON VISITOR CENTER BLM	3AMJ	3014	E. COLI	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	8/1/2019	8/31/2019		10/31/2019
NV0005011	RED ROCK CANYON VISITOR CENTER BLM	3AMJ	3014	E. COLI	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	9/1/2019	9/30/2019		10/31/2019
Total Number of Violations for this Water System:										3
NV0003101	RED ROCK FIRE STN AND LAW ENF BLM	03MJ	1040	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2018	12/31/2018		4/3/2019
NV0003101	RED ROCK FIRE STN AND LAW ENF BLM	3AMJ	3014	E. COLI	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	1/1/2019	3/31/2019		4/3/2019
Total Number of Violations for this Water System:										2
NV0004029	RITCHIE BROTHERS	45	0700	GROUNDWATER RULE	GWR	FAILURE ADDRESS DEFICIENCY (GWR)	2/16/2017			
Total Number of Violations for this Water System:										1
NV0000244	RIVERBELLE PROPERTIES LLC MHP	27MJ	0999	CHLORINE	ST1 DBP	MONITORING, ROUTINE (DBP), MAJOR	7/1/2019	9/30/2019		
NV0000244	RIVERBELLE PROPERTIES LLC MHP	3AMJ	3014	E. COLI	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	8/1/2019	8/31/2019		9/20/2019

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
Total Number of Violations for this Water System:										2
NV0000068	RIVERVIEW MOBILE HOME PARK	71	7000	CONSUMER CONFIDENCE RULE		CCR REPORT	7/1/2019			
Total Number of Violations for this Water System:										1
NV0000319	ROARK ESTATES WATER ASSOC	03MJ	CDAS	ARSENIC (AS)	IOC	MONITORING, ROUTINE MAJOR	1/1/2016	12/31/2016		12/30/2019
Total Number of Violations for this Water System:										1
NV0000767	ROSEMOUNT WATER CO	02	4006	COMBINED URANIUM	RAD	MCL, AVERAGE	4/1/2018	6/30/2018	36 UG/L	9/1/2019
NV0000767	ROSEMOUNT WATER CO	02	4006	COMBINED URANIUM	RAD	MCL, AVERAGE	7/1/2018	9/30/2018	69 UG/L	9/1/2019
NV0000767	ROSEMOUNT WATER CO	02	4006	COMBINED URANIUM	RAD	MCL, AVERAGE	10/1/2018	12/31/2018	33 UG/L	11/3/2019
NV0000767	ROSEMOUNT WATER CO	02	4006	COMBINED URANIUM	RAD	MCL, AVERAGE	10/1/2018	12/31/2018	46 UG/L	6/17/2019
NV0000767	ROSEMOUNT WATER CO	02	4006	COMBINED URANIUM	RAD	MCL, AVERAGE	1/1/2019	3/31/2019	33 UG/L	11/3/2019
NV0000767	ROSEMOUNT WATER CO	02	4006	COMBINED URANIUM	RAD	MCL, AVERAGE	1/1/2019	3/31/2019	46 UG/L	6/17/2019
NV0000767	ROSEMOUNT WATER CO	02	4006	COMBINED URANIUM	RAD	MCL, AVERAGE	4/1/2019	6/30/2019	31 UG/L	11/3/2019
NV0000767	ROSEMOUNT WATER CO	02	4006	COMBINED URANIUM	RAD	MCL, AVERAGE	7/1/2019	9/30/2019	0.031 MG/L	11/3/2019
NV0000767	ROSEMOUNT WATER CO	03MJ	CDAS	ARSENIC (AS)	IOC	MONITORING, ROUTINE MAJOR	1/1/2017	12/31/2019		
NV0000767	ROSEMOUNT WATER CO	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2019	12/31/2019		
NV0000767	ROSEMOUNT WATER CO	03MJ	CRUR	RADS URANIUM	RAD	MONITORING, ROUTINE MAJOR	7/1/2017	12/31/2017		10/6/2019
NV0000767	ROSEMOUNT WATER CO	03MJ	CRUR	RADS URANIUM	RAD	MONITORING, ROUTINE MAJOR	1/1/2018	6/30/2018		10/6/2019

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0000767	ROSEMOUNT WATER CO	03MJ	CRUR	RADS URANIUM	RAD	MONITORING, ROUTINE MAJOR	1/1/2018	6/30/2018		2/8/2019
NV0000767	ROSEMOUNT WATER CO	03MJ	CRUR	RADS URANIUM	RAD	MONITORING, ROUTINE MAJOR	1/1/2018	6/30/2018		2/8/2019
NV0000767	ROSEMOUNT WATER CO	03MJ	CRUR	RADS URANIUM	RAD	MONITORING, ROUTINE MAJOR	1/1/2018	6/30/2018		2/8/2019
NV0000767	ROSEMOUNT WATER CO	03MJ	CRUR	RADS URANIUM	RAD	MONITORING, ROUTINE MAJOR	1/1/2018	6/30/2018		6/17/2019
NV0000767	ROSEMOUNT WATER CO	03MJ	CRUR	RADS URANIUM	RAD	MONITORING, ROUTINE MAJOR	1/1/2018	6/30/2018		2/8/2019
NV0000767	ROSEMOUNT WATER CO	03MJ	CRUR	RADS URANIUM	RAD	MONITORING, ROUTINE MAJOR	7/1/2018	12/31/2018		5/29/2019
NV0000767	ROSEMOUNT WATER CO	03MJ	CRUR	RADS URANIUM	RAD	MONITORING, ROUTINE MAJOR	7/1/2018	12/31/2018		6/17/2019
NV0000767	ROSEMOUNT WATER CO	03MJ	CRUR	RADS URANIUM	RAD	MONITORING, ROUTINE MAJOR	7/1/2018	12/31/2018		10/6/2019
NV0000767	ROSEMOUNT WATER CO	03MJ	CRUR	RADS URANIUM	RAD	MONITORING, ROUTINE MAJOR	1/1/2019	6/30/2019		7/1/2019
NV0000767	ROSEMOUNT WATER CO	03MJ	CRUR	RADS URANIUM	RAD	MONITORING, ROUTINE MAJOR	1/1/2019	6/30/2019		10/13/2019
NV0000767	ROSEMOUNT WATER CO	03MJ	CRUR	RADS URANIUM	RAD	MONITORING, ROUTINE MAJOR	1/1/2019	6/30/2019		10/6/2019
NV0000767	ROSEMOUNT WATER CO	03MJ	CRUR	RADS URANIUM	RAD	MONITORING, ROUTINE MAJOR	1/1/2019	6/30/2019		10/6/2019
NV0000767	ROSEMOUNT WATER CO	03MJ	CRUR	RADS URANIUM	RAD	MONITORING, ROUTINE MAJOR	1/1/2019	6/30/2019		10/6/2019
NV0000767	ROSEMOUNT WATER CO	03MJ	CRUR	RADS URANIUM	RAD	MONITORING, ROUTINE MAJOR	1/1/2019	6/30/2019		8/29/2019
NV0000767	ROSEMOUNT WATER CO	03MJ	CRUR	RADS URANIUM	RAD	MONITORING, ROUTINE MAJOR	7/1/2019	12/31/2019		
NV0000767	ROSEMOUNT WATER CO	03MJ	CRUR	RADS URANIUM	RAD	MONITORING, ROUTINE MAJOR	7/1/2019	12/31/2019		
NV0000767	ROSEMOUNT WATER CO	03MJ	CRUR	RADS URANIUM	RAD	MONITORING, ROUTINE MAJOR	7/1/2019	12/31/2019		

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0000767	ROSEMOUNT WATER CO	03MJ	CRUR	RADS URANIUM	RAD	MONITORING, ROUTINE MAJOR	7/1/2019	12/31/2019		
NV0000767	ROSEMOUNT WATER CO	03MJ	CSOD	SODIUM (NA)	IOC	MONITORING, ROUTINE MAJOR	1/1/2017	12/31/2019		
NV0000767	ROSEMOUNT WATER CO	27MJ	CDB2	DBPR STAGE 2	ST2 DBP	MONITORING, ROUTINE (DBP), MAJOR	7/1/2018	6/30/2019		11/14/2019
NV0000767	ROSEMOUNT WATER CO	75	7500	PUBLIC NOTICE		PUBLIC NOTICE RULE LINKED TO VIOLATION	4/1/2018	10/11/2019		10/11/2019
Total Number of Violations for this Water System:										33
NV0002542	ROYAL PEACOCK RV PARK	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	5/1/2019	5/31/2019		6/18/2019
Total Number of Violations for this Water System:										1
NV0004112	RUBY 360 LODGE	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	10/1/2018	12/31/2018		1/2/2019
Total Number of Violations for this Water System:										1
NV0000885	RUBY HILL MINE	27MJ	CDB2	DBPR STAGE 2	ST2 DBP	MONITORING, ROUTINE (DBP), MAJOR	7/1/2018	6/30/2019		11/14/2019
Total Number of Violations for this Water System:										1
NV0002222	RYE PATCH PETROLEUM	2C	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	CORRECTIVE/EXPEDITED ACTIONS (RTCR)	12/1/2018	2/3/2019		2/3/2019
NV0002222	RYE PATCH PETROLEUM	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	8/1/2019	8/31/2019		10/23/2019
NV0002222	RYE PATCH PETROLEUM	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	9/1/2019	9/30/2019		10/23/2019
Total Number of Violations for this Water System:										3
NV0002223	RYE PATCH STATE PARK	45	0700	GROUNDWATER RULE	GWR	FAILURE ADDRESS DEFICIENCY (GWR)	8/11/2018	7/18/2019		7/18/2019
Total Number of Violations for this Water System:										1
NV0005023	RYE PATCH STATE PARK PICNIC AREA	45	0700	GROUNDWATER RULE	GWR	FAILURE ADDRESS DEFICIENCY (GWR)	9/12/2018	9/11/2019		9/11/2019

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
Total Number of Violations for this Water System:										1
NV0001092	RYNDON GAS & FOOD LLC	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	1/1/2019	3/31/2019		4/2/2019
Total Number of Violations for this Water System:										1
NV0002566	SAGE SCHOOLS	27MJ	0999	CHLORINE	ST1 DBP	MONITORING, ROUTINE (DBP), MAJOR	4/1/2019	6/30/2019		7/12/2019
NV0002566	SAGE SCHOOLS	3AMN	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MINOR (RTCR)	6/1/2019	6/30/2019		7/15/2019
Total Number of Violations for this Water System:										2
NV0002023	SAGE VALLEY PARK LLC	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2019	12/31/2019		
NV0002023	SAGE VALLEY PARK LLC	27MJ	0999	CHLORINE	ST1 DBP	MONITORING, ROUTINE (DBP), MAJOR	7/1/2018	9/30/2018		9/27/2019
NV0002023	SAGE VALLEY PARK LLC	27MJ	0999	CHLORINE	ST1 DBP	MONITORING, ROUTINE (DBP), MAJOR	7/1/2019	9/30/2019		8/21/2019
NV0002023	SAGE VALLEY PARK LLC	27MJ	CDB2	DBPR STAGE 2	ST2 DBP	MONITORING, ROUTINE (DBP), MAJOR	1/1/2018	12/31/2018		11/14/2019
NV0002023	SAGE VALLEY PARK LLC	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	7/1/2019	7/31/2019		8/21/2019
NV0002023	SAGE VALLEY PARK LLC	4B	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	REPORT SAMPLE RESULT/FAIL MONITOR RTCR	10/11/2019	11/15/2019		11/13/2019
NV0002023	SAGE VALLEY PARK LLC	52	5000	LEAD & COPPER RULE	LCR	FOLLOW-UP OR ROUTINE TAP M/R (LCR)	10/1/2019			
NV0002023	SAGE VALLEY PARK LLC	71	7000	CONSUMER CONFIDENCE RULE		CCR REPORT	7/1/2019			
NV0002023	SAGE VALLEY PARK LLC	93	1032	MANGANESE	SECONDARIES	STATE FAILURE TO MONITOR	7/1/2019	7/31/2019		
NV0002023	SAGE VALLEY PARK LLC	S1	1032	MANGANESE	SECONDARIES	STATE MCL EXCEDENCE	1/1/2019	3/31/2019	0.73 MG/L	4/27/2020
NV0002023	SAGE VALLEY PARK LLC	S1	1032	MANGANESE	SECONDARIES	STATE MCL EXCEDENCE	4/1/2019	6/30/2019	0.87 MG/L	4/27/2020

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0002023	SAGE VALLEY PARK LLC	S1	1032	MANGANESE	SECONDARIES	STATE MCL EXCEDENCE	7/1/2019	9/30/2019	0.85 MG/L	4/27/2020
NV0002023	SAGE VALLEY PARK LLC	S1	1032	MANGANESE	SECONDARIES	STATE MCL EXCEDENCE	10/1/2019	12/31/2019	0.47 MG/L	4/27/2020
Total Number of Violations for this Water System:										13
NV0000872	SAGE VALLEY RV PARK LLC	19MJ	3014	E. COLI	GWR	MONITOR GWR ASSESSMENT, MAJOR	5/1/2019	5/31/2019		5/30/2019
NV0000872	SAGE VALLEY RV PARK LLC	19MJ	3014	E. COLI	GWR	MONITOR GWR ASSESSMENT, MAJOR	7/1/2019	7/31/2019		8/1/2019
NV0000872	SAGE VALLEY RV PARK LLC	93	CNO3	NITRATE	SECONDARIES	STATE FAILURE TO MONITOR	1/1/2019	3/31/2019		5/30/2019
Total Number of Violations for this Water System:										3
NV0001096	SANDERS WINERY	4B	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	REPORT SAMPLE RESULT/FAIL MONITOR RTCR	7/11/2019	7/30/2019		7/30/2019
Total Number of Violations for this Water System:										1
NV0004001	SANDY VALLEY ELEMENTARY SCHOOL	27MJ	2950	TTHM	ST2 DBP	MONITORING, ROUTINE (DBP), MAJOR	10/1/2018	9/30/2019		9/10/2019
Total Number of Violations for this Water System:										1
NV0000897	SCHURZ ELEMENTARY SCHOOL	03MJ	CDAS	ARSENIC (AS)	IOC	MONITORING, ROUTINE MAJOR	6/1/2019	6/30/2019		7/23/2019
Total Number of Violations for this Water System:										1
NV0005036	SHERIS RANCH	02	1005	ARSENIC	IOC	MCL, AVERAGE	4/1/2019	6/30/2019	0.011 MG/L	
NV0005036	SHERIS RANCH	02	1005	ARSENIC	IOC	MCL, AVERAGE	7/1/2019	9/30/2019	0.012 MG/L	
NV0005036	SHERIS RANCH	02	1005	ARSENIC	IOC	MCL, AVERAGE	10/1/2019	12/31/2019	0.012 MG/L	
Total Number of Violations for this Water System:										3
NV0000126	SHETLAND WATER DISTRICT	3AMJ	3014	E. COLI	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	4/1/2019	4/30/2019		6/25/2019

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0000126	SHETLAND WATER DISTRICT	3AMJ	3014	E. COLI	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	5/1/2019	5/31/2019		6/25/2019
NV0000126	SHETLAND WATER DISTRICT	71	7000	CONSUMER CONFIDENCE RULE		CCR REPORT	7/1/2019			
Total Number of Violations for this Water System:										3
NV0003074	SHORT BRANCH	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2019	12/31/2019		
Total Number of Violations for this Water System:										1
NV0005028	SHOSHONE ESTATES WATER CO INC	02	1005	ARSENIC	IOC	MCL, AVERAGE	1/1/2019	3/31/2019	0.032 MG/L	
NV0005028	SHOSHONE ESTATES WATER CO INC	02	1005	ARSENIC	IOC	MCL, AVERAGE	4/1/2019	6/30/2019	0.031 MG/L	
NV0005028	SHOSHONE ESTATES WATER CO INC	02	1005	ARSENIC	IOC	MCL, AVERAGE	7/1/2019	9/30/2019	0.030 MG/L	
NV0005028	SHOSHONE ESTATES WATER CO INC	02	1005	ARSENIC	IOC	MCL, AVERAGE	10/1/2019	12/31/2019	0.030 MG/L	
Total Number of Violations for this Water System:										4
NV0004125	SIERRA SAFARI ZOO	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	7/1/2019	9/30/2019		11/14/2019
Total Number of Violations for this Water System:										1
NV0004021	SILVER KNOLLS MUTUAL WATER	02	1005	ARSENIC	IOC	MCL, AVERAGE	1/1/2019	3/31/2019	11 UG/L	
NV0004021	SILVER KNOLLS MUTUAL WATER	02	1005	ARSENIC	IOC	MCL, AVERAGE	4/1/2019	6/30/2019	0.011 MG/L	
NV0004021	SILVER KNOLLS MUTUAL WATER	02	1005	ARSENIC	IOC	MCL, AVERAGE	7/1/2019	9/30/2019	0.011 MG/L	
NV0004021	SILVER KNOLLS MUTUAL WATER	02	1005	ARSENIC	IOC	MCL, AVERAGE	10/1/2019	12/31/2019	11 UG/L	
NV0004021	SILVER KNOLLS MUTUAL WATER	27MJ	CDB2	DBPR STAGE 2	ST2 DBP	MONITORING, ROUTINE (DBP), MAJOR	1/1/2016	9/30/2018		11/14/2019
NV0004021	SILVER KNOLLS MUTUAL WATER	45	0700	GROUNDWATER RULE	GWR	FAILURE ADDRESS DEFICIENCY (GWR)	3/1/2018			

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
Total Number of Violations for this Water System:										6
NV0000363	SILVER PEAK WATER SYSTEM	27MJ	CDB2	DBPR STAGE 2	ST2 DBP	MONITORING, ROUTINE (DBP), MAJOR	10/1/2016	9/30/2019		
NV0000363	SILVER PEAK WATER SYSTEM	71	7000	CONSUMER CONFIDENCE RULE		CCR REPORT	7/1/2019	8/1/2019		8/1/2019
Total Number of Violations for this Water System:										2
NV0004031	SKY RANCH ESTATES	71	7000	CONSUMER CONFIDENCE RULE		CCR REPORT	7/1/2019	7/2/2019		7/2/2019
Total Number of Violations for this Water System:										1
NV0000760	SKY TAVERN	45	0700	GROUNDWATER RULE	GWR	FAILURE ADDRESS DEFICIENCY (GWR)	4/2/2019	8/27/2019		8/27/2019
Total Number of Violations for this Water System:										1
NV0000761	SLIDE MOUNTAIN SKI AREA	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2018	12/31/2018		2/12/2019
Total Number of Violations for this Water System:										1
NV0001140	SLOAN ARMY RESERVE CENTER	S1	1930	TDS	SECONDARIES	STATE MCL EXCEDENCE	1/1/2019	3/31/2019	1050 MG/L	
NV0001140	SLOAN ARMY RESERVE CENTER	S1	1930	TDS	SECONDARIES	STATE MCL EXCEDENCE	4/1/2019	6/30/2019	1040 MG/L	
NV0001140	SLOAN ARMY RESERVE CENTER	S1	1930	TDS	SECONDARIES	STATE MCL EXCEDENCE	7/1/2019	9/30/2019	1050 MG/L	
NV0001140	SLOAN ARMY RESERVE CENTER	S1	1930	TDS	SECONDARIES	STATE MCL EXCEDENCE	10/1/2019	12/31/2019	1020 MG/L	
Total Number of Violations for this Water System:										4
NV0000929	SONIC BURGER	93	1028	IRON	SECONDARIES	STATE FAILURE TO MONITOR	10/1/2019	12/31/2019		
NV0000929	SONIC BURGER	93	1032	MANGANESE	SECONDARIES	STATE FAILURE TO MONITOR	10/1/2019	12/31/2019		
Total Number of Violations for this Water System:										2

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0002209	SOUTH RUBY CAMPGROUND USFS	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	9/1/2019	9/30/2019		
Total Number of Violations for this Water System:										1
NV0005062	SOUTHERN DESERT CORRECTIONAL CTR	45	0700	GROUNDWATER RULE	GWR	FAILURE ADDRESS DEFICIENCY (GWR)	4/17/2020			
NV0005062	SOUTHERN DESERT CORRECTIONAL CTR	71	7000	CONSUMER CONFIDENCE RULE		CCR REPORT	7/1/2019			
Total Number of Violations for this Water System:										2
NV0004071	SPENCER W KIMBALL SCOUT RESERVATION	93	CSC2	SECONDARY IOCS	SECONDARIES	STATE FAILURE TO MONITOR	1/1/2011	12/31/2013		12/10/2019
NV0004071	SPENCER W KIMBALL SCOUT RESERVATION	S7MN	CSC2	SECONDARY IOCS	SECONDARIES	FAILURE TO REPORT (STATE)	1/1/2017	12/31/2019		1/11/2018
Total Number of Violations for this Water System:										2
NV0000221	SPIRIT MOUNTAIN UTILITY	45	0700	GROUNDWATER RULE	GWR	FAILURE ADDRESS DEFICIENCY (GWR)	12/11/2019	3/31/2020		3/31/2020
NV0000221	SPIRIT MOUNTAIN UTILITY	45	0700	GROUNDWATER RULE	GWR	FAILURE ADDRESS DEFICIENCY (GWR)	12/11/2019	4/7/2020		4/7/2020
NV0000221	SPIRIT MOUNTAIN UTILITY	71	7000	CONSUMER CONFIDENCE RULE		CCR REPORT	7/1/2019	8/1/2019		8/1/2019
Total Number of Violations for this Water System:										3
NV0004041	SPOONER LAKE STATE PARK	4B	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	REPORT SAMPLE RESULT/FAIL MONITOR RTCR	10/11/2019	10/16/2019		10/16/2019
Total Number of Violations for this Water System:										1
NV0003103	SPRING MOUNTAINS VISITOR GATEWAY	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2016	12/31/2016		9/24/2019
NV0003103	SPRING MOUNTAINS VISITOR GATEWAY	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2018	12/31/2018		9/24/2019
Total Number of Violations for this Water System:										2
NV0002124	SPRING VALLEY STATE PARK	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	11/1/2019	11/30/2019		12/10/2019

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0002124	SPRING VALLEY STATE PARK	S1	1032	MANGANESE	SECONDARIES	STATE MCL EXCEDENCE	1/1/2019	3/31/2019	1.2 MG/L	
NV0002124	SPRING VALLEY STATE PARK	S1	1032	MANGANESE	SECONDARIES	STATE MCL EXCEDENCE	4/1/2019	6/30/2019	0.2 MG/L	
NV0002124	SPRING VALLEY STATE PARK	S1	1032	MANGANESE	SECONDARIES	STATE MCL EXCEDENCE	7/1/2019	9/30/2019	0.22 MG/L	
NV0002124	SPRING VALLEY STATE PARK	S1	1032	MANGANESE	SECONDARIES	STATE MCL EXCEDENCE	10/1/2019	12/31/2019	0.30 MG/L	
Total Number of Violations for this Water System:										5
NV0004061	SPRINGWOOD EQUESTRIAN CENTER	52	5000	LEAD & COPPER RULE	LCR	FOLLOW-UP OR ROUTINE TAP M/R (LCR)	10/1/2018	7/18/2019		7/18/2019
Total Number of Violations for this Water System:										1
NV0000224	STAGECOACH GID	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	7/1/2019	9/30/2019		11/5/2019
NV0000224	STAGECOACH GID	27MJ	CDB2	DBPR STAGE 2	ST2 DBP	MONITORING, ROUTINE (DBP), MAJOR	10/1/2018	9/30/2019		
Total Number of Violations for this Water System:										2
NV0000282	STEAMBOAT SPRINGS WATERWORKS INC	45	0700	GROUNDWATER RULE	GWR	FAILURE ADDRESS DEFICIENCY (GWR)	10/31/2019			
Total Number of Violations for this Water System:										1
NV0000124	SUNRISE ACRES WATER ASSOCIATION	71	7000	CONSUMER CONFIDENCE RULE		CCR REPORT	7/1/2019	7/6/2019		7/6/2019
Total Number of Violations for this Water System:										1
NV0000765	SUTCLIFFE MOBILE PARK	3AMJ	3014	E. COLI	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	9/1/2019	9/30/2019		10/16/2019
Total Number of Violations for this Water System:										1
NV0000329	T AND J INVESTMENTS DBA THE GROVE	34MJ	3014	E. COLI	GWR	MONITOR GWR TRIGGERED/ADDITONAL, MAJOR	9/25/2019	9/25/2019		9/25/2019
Total Number of Violations for this Water System:										1

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0002076	TAYLOR CANYON CLUB	2C	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	CORRECTIVE/EXPEDITED ACTIONS (RTCR)	12/1/2018			
Total Number of Violations for this Water System:										1
NV0000028	TERRACE GARDEN APARTMENTS	71	7000	CONSUMER CONFIDENCE RULE		CCR REPORT	7/1/2019			
Total Number of Violations for this Water System:										1
NV0002227	THE CLUB AT CLEAR CREEK TAHOE	27MJ	CDB2	DBPR STAGE 2	ST2 DBP	MONITORING, ROUTINE (DBP), MAJOR	1/1/2019	12/31/2019		11/19/2019
NV0002227	THE CLUB AT CLEAR CREEK TAHOE	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	5/1/2019	5/31/2019		6/25/2019
Total Number of Violations for this Water System:										2
NV0000306	THE GRID	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	4/1/2019	6/30/2019		7/8/2019
NV0000306	THE GRID	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	10/1/2019	12/31/2019		
NV0000306	THE GRID	93	1032	MANGANESE	SECONDARIES	STATE FAILURE TO MONITOR	3/1/2019	3/31/2019		7/10/2019
NV0000306	THE GRID	93	1032	MANGANESE	SECONDARIES	STATE FAILURE TO MONITOR	4/1/2019	4/30/2019		7/10/2019
NV0000306	THE GRID	93	1032	MANGANESE	SECONDARIES	STATE FAILURE TO MONITOR	5/1/2019	5/31/2019		7/10/2019
Total Number of Violations for this Water System:										5
NV0003035	THE HUBB	45	0700	GROUNDWATER RULE	GWR	FAILURE ADDRESS DEFICIENCY (GWR)	12/17/2016	4/10/2019		4/10/2019
Total Number of Violations for this Water System:										1
NV0004076	THE LODGE AT GALENA	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2019	12/31/2019		
NV0004076	THE LODGE AT GALENA	3AMJ	3014	E. COLI	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	1/1/2019	3/31/2019		5/22/2019
Total Number of Violations for this Water System:										2

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0000414	THE LODGE AT PINE VALLEY	27MJ	CDB2	DBPR STAGE 2	ST2 DBP	MONITORING, ROUTINE (DBP), MAJOR	8/31/2018	8/30/2019		
Total Number of Violations for this Water System:										1
NV0000727	THE VINE	03MJ	CIOC	IOC PH 5 CYANIDE	IOC	MONITORING, ROUTINE MAJOR	1/1/2017	12/31/2019		
NV0000727	THE VINE	03MJ	CIO2	IOCS PHASE 2	IOC	MONITORING, ROUTINE MAJOR	1/1/2017	12/31/2019		
NV0000727	THE VINE	03MJ	CIO5	IOCS PHASE 5	IOC	MONITORING, ROUTINE MAJOR	1/1/2017	12/31/2019		
NV0000727	THE VINE	03MJ	CSO8	SOCS PH5 DIOXIN	SOC	MONITORING, ROUTINE MAJOR	1/1/2019	3/31/2019		
NV0000727	THE VINE	03MJ	CSOC	SOCS PHASE 2 & 5	SOC	MONITORING, ROUTINE MAJOR	1/1/2019	3/31/2019		
NV0000727	THE VINE	03MJ	CSOC	SOCS PHASE 2 & 5	SOC	MONITORING, ROUTINE MAJOR	4/1/2019	6/30/2019		
NV0000727	THE VINE	03MJ	CSOC	SOCS PHASE 2 & 5	SOC	MONITORING, ROUTINE MAJOR	7/1/2019	9/30/2019		
NV0000727	THE VINE	03MJ	CSOC	SOCS PHASE 2 & 5	SOC	MONITORING, ROUTINE MAJOR	10/1/2019	12/31/2019		
NV0000727	THE VINE	03MJ	CVOC	VOCS PHASE 2 & 5	VOC	MONITORING, ROUTINE MAJOR	1/1/2019	3/31/2019		
NV0000727	THE VINE	03MJ	CVOC	VOCS PHASE 2 & 5	VOC	MONITORING, ROUTINE MAJOR	4/1/2019	6/30/2019		
NV0000727	THE VINE	03MJ	CVOC	VOCS PHASE 2 & 5	VOC	MONITORING, ROUTINE MAJOR	7/1/2019	9/30/2019		
NV0000727	THE VINE	03MJ	CVOC	VOCS PHASE 2 & 5	VOC	MONITORING, ROUTINE MAJOR	10/1/2019	12/31/2019		
NV0000727	THE VINE	3AMJ	3014	E. COLI	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	11/1/2019	11/30/2019		12/1/2019
NV0000727	THE VINE	45	0700	GROUNDWATER RULE	GWR	FAILURE ADDRESS DEFICIENCY (GWR)	3/2/2019	3/11/2020		3/11/2020
NV0000727	THE VINE	45	0700	GROUNDWATER RULE	GWR	FAILURE ADDRESS DEFICIENCY (GWR)	3/2/2019	4/28/2020		4/28/2020

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0000727	THE VINE	51	5000	LEAD & COPPER RULE	LCR	INITIAL TAP SAMPLING (LCR)	1/1/2019	6/30/2019		
NV0000727	THE VINE	51	5000	LEAD & COPPER RULE	LCR	INITIAL TAP SAMPLING (LCR)	7/1/2019	12/31/2019		
NV0000727	THE VINE	S6				CERTIFIED OPERATOR FAILURE (STATE)	10/28/2019	2/5/2020		
Total Number of Violations for this Water System:										18
NV0003043	THOMAS CANYON CAMPGROUND USFS	03MJ	CNO2	NITRITE	IOC	MONITORING, ROUTINE MAJOR	1/1/2017	12/31/2019		
Total Number of Violations for this Water System:										1
NV0001139	TIMET CORPORATION	02	2950	TTHM	ST2 DBP	MCL, LRAA	7/1/2019	9/30/2019	86 UG/L	
NV0001139	TIMET CORPORATION	02	2950	TTHM	ST2 DBP	MCL, LRAA	10/1/2019	12/31/2019	0.085 MG/L	
Total Number of Violations for this Water System:										2
NV0002586	TOP GUN SKATE	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2018	12/31/2018		5/7/2019
NV0002586	TOP GUN SKATE	03MJ	CNO2	NITRITE	IOC	MONITORING, ROUTINE MAJOR	1/1/2017	12/31/2019		
NV0002586	TOP GUN SKATE	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	11/1/2018	11/30/2018		2/20/2019
NV0002586	TOP GUN SKATE	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	12/1/2018	12/31/2018		2/20/2019
NV0002586	TOP GUN SKATE	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	1/1/2019	1/31/2019		2/20/2019
NV0002586	TOP GUN SKATE	93	1032	MANGANESE	SECONDARIES	STATE FAILURE TO MONITOR	7/1/2018	9/30/2018		2/25/2019
NV0002586	TOP GUN SKATE	93	1032	MANGANESE	SECONDARIES	STATE FAILURE TO MONITOR	10/1/2018	12/31/2018		2/25/2019
NV0002586	TOP GUN SKATE	S1	1032	MANGANESE	SECONDARIES	STATE MCL EXCEDENCE	10/1/2019	12/31/2019	0.28 MG/L	4/21/2020
Total Number of Violations for this Water System:										8

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0000239	TOPAZ RANCH ESTATES GID AND	03MJ	CDAS	ARSENIC (AS)	IOC	MONITORING, ROUTINE MAJOR	1/1/2017	12/31/2019		
NV0000239	TOPAZ RANCH ESTATES GID AND	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2019	12/31/2019		
NV0000239	TOPAZ RANCH ESTATES GID AND	03MJ	CNO2	NITRITE	IOC	MONITORING, ROUTINE MAJOR	1/1/2017	12/31/2019		
NV0000239	TOPAZ RANCH ESTATES GID AND	03MJ	CSOD	SODIUM (NA)	IOC	MONITORING, ROUTINE MAJOR	1/1/2017	12/31/2019		
NV0000239	TOPAZ RANCH ESTATES GID AND	93	CSEF	SEC IOC FLUORIDE	SECONDARIES	STATE FAILURE TO MONITOR	1/1/2017	12/31/2019		
NV0000239	TOPAZ RANCH ESTATES GID AND	93	CSC2	SECONDARY IOCS	SECONDARIES	STATE FAILURE TO MONITOR	1/1/2017	12/31/2019		

Total Number of Violations for this Water System: 6

NV0002518	TOPAZ SUMMIT SPRING	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	1/1/2017	3/31/2017		8/22/2019
NV0002518	TOPAZ SUMMIT SPRING	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	5/1/2017	5/31/2017		8/22/2019
NV0002518	TOPAZ SUMMIT SPRING	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	5/1/2019	5/31/2019		8/22/2019
NV0002518	TOPAZ SUMMIT SPRING	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	6/1/2019	6/30/2019		8/22/2019
NV0002518	TOPAZ SUMMIT SPRING	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	7/1/2019	7/31/2019		8/22/2019
NV0002518	TOPAZ SUMMIT SPRING	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	11/1/2019	11/30/2019		12/3/2019

Total Number of Violations for this Water System: 6

NV0000314	TORREY PINES TINA LN WTR ASSOC	71	7000	CONSUMER CONFIDENCE RULE		CCR REPORT	7/1/2019	7/3/2019		7/3/2019
-----------	--------------------------------	----	------	--------------------------	--	------------	----------	----------	--	----------

Total Number of Violations for this Water System: 1

NV0000913	TRI GENERAL IMPROVEMENT	03MJ	CSOC	SOCS PHASE 2 & 5	SOC	MONITORING, ROUTINE MAJOR	1/1/2017	12/31/2019		
-----------	-------------------------	------	------	------------------	-----	---------------------------	----------	------------	--	--

Total Number of Violations for this Water System: 1

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0000403	TS POWER PLANT	27MJ	CDB2	DBPR STAGE 2	ST2 DBP	MONITORING, ROUTINE (DBP), MAJOR	10/1/2016	9/30/2019		5/7/2020
Total Number of Violations for this Water System:										1
NV0001145	US ECOLOGY NEVADA	S1	1025	FLUORIDE	SECONDARIES	STATE MCL EXCEDENCE	10/1/2016	12/31/2016	3.0 MG/L	1/16/2019
NV0001145	US ECOLOGY NEVADA	S1	1025	FLUORIDE	SECONDARIES	STATE MCL EXCEDENCE	1/1/2017	3/31/2017	2.99 MG/L	1/16/2019
NV0001145	US ECOLOGY NEVADA	S1	1025	FLUORIDE	SECONDARIES	STATE MCL EXCEDENCE	4/1/2017	6/30/2017	3.0 MG/L	1/16/2019
NV0001145	US ECOLOGY NEVADA	S1	1025	FLUORIDE	SECONDARIES	STATE MCL EXCEDENCE	7/1/2017	9/30/2017	3.1 MG/L	1/16/2019
NV0001145	US ECOLOGY NEVADA	S1	1025	FLUORIDE	SECONDARIES	STATE MCL EXCEDENCE	10/1/2017	12/31/2017	3.2 MG/L	1/16/2019
NV0001145	US ECOLOGY NEVADA	S1	1025	FLUORIDE	SECONDARIES	STATE MCL EXCEDENCE	1/1/2018	3/31/2018	3 MG/L	1/16/2019
NV0001145	US ECOLOGY NEVADA	S1	1025	FLUORIDE	SECONDARIES	STATE MCL EXCEDENCE	4/1/2018	6/30/2018	2.89 MG/L	1/16/2019
Total Number of Violations for this Water System:										7
NV0000805	VALLEY VIEW RV PARK	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	7/1/2019	7/31/2019		8/5/2019
Total Number of Violations for this Water System:										1
NV0002112	VALMY FUEL STOP INC	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2019	12/31/2019		
NV0002112	VALMY FUEL STOP INC	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	12/1/2018	12/31/2018		1/2/2019
NV0002112	VALMY FUEL STOP INC	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	6/1/2019	6/30/2019		7/29/2019
Total Number of Violations for this Water System:										3
NV0003016	VALMY STATION MOBILE HOME PARK	03MJ	CVOC	VOCS PHASE 2 & 5	VOC	MONITORING, ROUTINE MAJOR	1/1/2017	12/31/2019		
NV0003016	VALMY STATION MOBILE HOME PARK	4B	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	REPORT SAMPLE RESULT/FAIL MONITOR RTCR	10/11/2019	11/15/2019		11/15/2019

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
Total Number of Violations for this Water System:										2
NV0000773	VERDI MUTUAL WATER COMPANY	45	0700	GROUNDWATER RULE	GWR	FAILURE ADDRESS DEFICIENCY (GWR)	12/29/2016	5/29/2019		5/29/2019
Total Number of Violations for this Water System:										1
NV0003000	VERDI SCHOOL	03MJ	CNO2	NITRITE	IOC	MONITORING, ROUTINE MAJOR	1/1/2017	12/31/2019		
Total Number of Violations for this Water System:										1
NV0000167	VIRGIN VALLEY WATER DISTRICT	03MJ	CRAU	RADIONUCLIDES	RAD	MONITORING, ROUTINE MAJOR	7/1/2019	9/30/2019		12/4/2019
NV0000167	VIRGIN VALLEY WATER DISTRICT	03MJ	CSOC	SOCS PHASE 2 & 5	SOC	MONITORING, ROUTINE MAJOR	1/1/2017	12/31/2019		
NV0000167	VIRGIN VALLEY WATER DISTRICT	03MJ	CSOC	SOCS PHASE 2 & 5	SOC	MONITORING, ROUTINE MAJOR	1/1/2017	12/31/2019		
NV0000167	VIRGIN VALLEY WATER DISTRICT	03MJ	CSOC	SOCS PHASE 2 & 5	SOC	MONITORING, ROUTINE MAJOR	1/1/2017	12/31/2019		
Total Number of Violations for this Water System:										4
NV0001172	WALDORF ASTORIA HOTEL LAS VEGAS	27MJ	CDB2	DBPR STAGE 2	ST2 DBP	MONITORING, ROUTINE (DBP), MAJOR	10/1/2019	12/31/2019		1/22/2020
Total Number of Violations for this Water System:										1
NV0001109	WALDORF ASTORIA RESIDENCES	02	2950	TTHM	ST2 DBP	MCL, LRAA	1/1/2019	3/31/2019	81 UG/L	
NV0001109	WALDORF ASTORIA RESIDENCES	66	5000	LEAD & COPPER RULE	LCR	LEAD CONSUMER NOTICE (LCR)	9/8/2018			
Total Number of Violations for this Water System:										2
NV0004048	WALKER RIVER RESORT	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2019	12/31/2019		5/16/2020
NV0004048	WALKER RIVER RESORT	03MJ	CNO2	NITRITE	IOC	MONITORING, ROUTINE MAJOR	1/1/2017	12/31/2019		5/16/2020
NV0004048	WALKER RIVER RESORT	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	1/1/2019	3/31/2019		4/29/2019

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0004048	WALKER RIVER RESORT	93	CSC2	SECONDARY IOCS	SECONDARIES	STATE FAILURE TO MONITOR	1/1/2017	12/31/2019		5/16/2020
Total Number of Violations for this Water System:										4
NV0000922	WARD CHARCOAL OVENS STATE PARK	93	1905	COLOR	SECONDARIES	STATE FAILURE TO MONITOR	7/1/2018	7/31/2018		7/23/2019
NV0000922	WARD CHARCOAL OVENS STATE PARK	93	1028	IRON	SECONDARIES	STATE FAILURE TO MONITOR	7/1/2018	9/30/2018		3/25/2019
NV0000922	WARD CHARCOAL OVENS STATE PARK	93	1028	IRON	SECONDARIES	STATE FAILURE TO MONITOR	10/1/2018	12/31/2018		3/25/2019
NV0000922	WARD CHARCOAL OVENS STATE PARK	93	1028	IRON	SECONDARIES	STATE FAILURE TO MONITOR	4/1/2019	6/30/2019		
Total Number of Violations for this Water System:										4
NV0003046	WARD MOUNTAIN CAMPGROUND USFS	93	1930	TDS	SECONDARIES	STATE FAILURE TO MONITOR	1/1/2017	12/31/2019		
Total Number of Violations for this Water System:										1
NV0000793	WASHOE LAKE STATE PARK	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2017	12/31/2017		1/31/2019
NV0000793	WASHOE LAKE STATE PARK	S1	1032	MANGANESE	SECONDARIES	STATE MCL EXCEDENCE	1/1/2019	3/31/2019	0.3 MG/L	12/17/2019
Total Number of Violations for this Water System:										2
NV0000318	WASHOE LAKE STATE PARK NORTH BOAT	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2017	12/31/2017		1/31/2019
NV0000318	WASHOE LAKE STATE PARK NORTH BOAT	45	0700	GROUNDWATER RULE	GWR	FAILURE ADDRESS DEFICIENCY (GWR)	8/12/2015	7/16/2019		7/16/2019
NV0000318	WASHOE LAKE STATE PARK NORTH BOAT	S1	1028	IRON	SECONDARIES	STATE MCL EXCEDENCE	4/1/2014	6/30/2014	1.5 MG/L	12/17/2019
NV0000318	WASHOE LAKE STATE PARK NORTH BOAT	S1	1028	IRON	SECONDARIES	STATE MCL EXCEDENCE	7/1/2014	9/30/2014	3.1 MG/L	12/17/2019
NV0000318	WASHOE LAKE STATE PARK NORTH BOAT	S1	1028	IRON	SECONDARIES	STATE MCL EXCEDENCE	10/1/2014	12/31/2014	1.8 MG/L	12/17/2019
NV0000318	WASHOE LAKE STATE PARK NORTH BOAT	S1	1028	IRON	SECONDARIES	STATE MCL EXCEDENCE	1/1/2015	3/31/2015	2.2 MG/L	12/17/2019

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0000318	WASHOE LAKE STATE PARK NORTH BOAT	S1	1028	IRON	SECONDARIES	STATE MCL EXCEDENCE	4/1/2015	6/30/2015	0.8 MG/L	12/17/2019
NV0000318	WASHOE LAKE STATE PARK NORTH BOAT	S1	1028	IRON	SECONDARIES	STATE MCL EXCEDENCE	4/1/2016	6/30/2016	1.5 MG/L	12/17/2019
NV0000318	WASHOE LAKE STATE PARK NORTH BOAT	S1	1028	IRON	SECONDARIES	STATE MCL EXCEDENCE	7/1/2016	9/30/2016	7.4 MG/L	12/17/2019
NV0000318	WASHOE LAKE STATE PARK NORTH BOAT	S1	1028	IRON	SECONDARIES	STATE MCL EXCEDENCE	4/1/2017	6/30/2017	1.4 MG/L	12/17/2019
NV0000318	WASHOE LAKE STATE PARK NORTH BOAT	S1	1028	IRON	SECONDARIES	STATE MCL EXCEDENCE	7/1/2017	9/30/2017	1.8 MG/L	12/17/2019
NV0000318	WASHOE LAKE STATE PARK NORTH BOAT	S1	1028	IRON	SECONDARIES	STATE MCL EXCEDENCE	10/1/2017	12/31/2017	0.65 MG/L	12/17/2019
NV0000318	WASHOE LAKE STATE PARK NORTH BOAT	S1	1028	IRON	SECONDARIES	STATE MCL EXCEDENCE	1/1/2018	3/31/2018	1.8 MG/L	12/17/2019
NV0000318	WASHOE LAKE STATE PARK NORTH BOAT	S1	1028	IRON	SECONDARIES	STATE MCL EXCEDENCE	4/1/2018	6/30/2018	1.8 MG/L	12/17/2019
NV0000318	WASHOE LAKE STATE PARK NORTH BOAT	S1	1028	IRON	SECONDARIES	STATE MCL EXCEDENCE	1/1/2019	3/31/2019	2.0 MG/L	12/17/2019
NV0000318	WASHOE LAKE STATE PARK NORTH BOAT	S1	1032	MANGANESE	SECONDARIES	STATE MCL EXCEDENCE	4/1/2014	6/30/2014	0.2 MG/L	12/17/2019
NV0000318	WASHOE LAKE STATE PARK NORTH BOAT	S1	1032	MANGANESE	SECONDARIES	STATE MCL EXCEDENCE	7/1/2014	9/30/2014	0.23 MG/L	12/17/2019
NV0000318	WASHOE LAKE STATE PARK NORTH BOAT	S1	1032	MANGANESE	SECONDARIES	STATE MCL EXCEDENCE	10/1/2014	12/31/2014	0.19 MG/L	12/17/2019
NV0000318	WASHOE LAKE STATE PARK NORTH BOAT	S1	1032	MANGANESE	SECONDARIES	STATE MCL EXCEDENCE	1/1/2015	3/31/2015	0.23 MG/L	12/17/2019
NV0000318	WASHOE LAKE STATE PARK NORTH BOAT	S1	1032	MANGANESE	SECONDARIES	STATE MCL EXCEDENCE	7/1/2015	9/30/2015	0.16 MG/L	12/17/2019
NV0000318	WASHOE LAKE STATE PARK NORTH BOAT	S1	1032	MANGANESE	SECONDARIES	STATE MCL EXCEDENCE	4/1/2016	6/30/2016	0.17 MG/L	12/17/2019
NV0000318	WASHOE LAKE STATE PARK NORTH BOAT	S1	1032	MANGANESE	SECONDARIES	STATE MCL EXCEDENCE	7/1/2016	9/30/2016	0.32 MG/L	12/17/2019
NV0000318	WASHOE LAKE STATE PARK NORTH BOAT	S1	1032	MANGANESE	SECONDARIES	STATE MCL EXCEDENCE	4/1/2017	6/30/2017	0.19 MG/L	12/17/2019

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0000318	WASHOE LAKE STATE PARK NORTH BOAT	S1	1032	MANGANESE	SECONDARIES	STATE MCL EXCEDENCE	7/1/2017	9/30/2017	0.19 MG/L	12/17/2019
NV0000318	WASHOE LAKE STATE PARK NORTH BOAT	S1	1032	MANGANESE	SECONDARIES	STATE MCL EXCEDENCE	10/1/2017	12/31/2017	0.15 MG/L	12/17/2019
NV0000318	WASHOE LAKE STATE PARK NORTH BOAT	S1	1032	MANGANESE	SECONDARIES	STATE MCL EXCEDENCE	1/1/2018	3/31/2018	0.22 MG/L	12/17/2019
NV0000318	WASHOE LAKE STATE PARK NORTH BOAT	S1	1032	MANGANESE	SECONDARIES	STATE MCL EXCEDENCE	4/1/2018	6/30/2018	0.22 MG/L	12/17/2019
NV0000318	WASHOE LAKE STATE PARK NORTH BOAT	S1	1032	MANGANESE	SECONDARIES	STATE MCL EXCEDENCE	1/1/2019	3/31/2019	0.2 MG/L	12/17/2019
Total Number of Violations for this Water System:										28
NV0004113	WASHOE VALLEY CHRISTIAN CHURCH	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2017	12/31/2017		1/31/2019
NV0004113	WASHOE VALLEY CHRISTIAN CHURCH	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	1/1/2019	3/31/2019		4/23/2019
NV0004113	WASHOE VALLEY CHRISTIAN CHURCH	45	0700	GROUNDWATER RULE	GWR	FAILURE ADDRESS DEFICIENCY (GWR)	3/30/2018			
Total Number of Violations for this Water System:										3
NV0004065	WASHOE VALLEY MEETINGHOUSE	01	1040	NITRATE	IOC	MCL, SINGLE SAMPLE	10/1/2019	12/31/2019	29 MG/L	
NV0004065	WASHOE VALLEY MEETINGHOUSE	03MJ	1905	COLOR	SECONDARIES	MONITORING, ROUTINE MAJOR	11/1/2013	11/30/2013		2/28/2019
NV0004065	WASHOE VALLEY MEETINGHOUSE	03MJ	1920	ODOR	SECONDARIES	MONITORING, ROUTINE MAJOR	11/1/2013	11/30/2013		2/28/2019
NV0004065	WASHOE VALLEY MEETINGHOUSE	3AMJ	3014	E. COLI	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	7/1/2019	9/30/2019		11/11/2019
Total Number of Violations for this Water System:										4
NV0000242	WEED HEIGHTS DEVELOPMENT	71	7000	CONSUMER CONFIDENCE RULE		CCR REPORT	7/1/2019	7/3/2019		7/3/2019
Total Number of Violations for this Water System:										1
NV0000245	WELLS MUNICIPAL WATER DEPARTMENT	S1	1002	ALUMINUM	SECONDARIES	STATE MCL EXCEDENCE	10/1/2019	12/31/2019	0.45 MG/L	4/7/2020

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
Total Number of Violations for this Water System:										1
NV0002054	WEST VALLEY WATER SYSTEM	03MJ	CRAU	RADIONUCLIDES	RAD	MONITORING, ROUTINE MAJOR	7/1/2019	9/30/2019		12/12/2019
NV0002054	WEST VALLEY WATER SYSTEM	03MJ	CSOC	SOCS PHASE 2 & 5	SOC	MONITORING, ROUTINE MAJOR	7/1/2019	9/30/2019		12/12/2019
NV0002054	WEST VALLEY WATER SYSTEM	03MJ	CVOC	VOCS PHASE 2 & 5	VOC	MONITORING, ROUTINE MAJOR	7/1/2019	9/30/2019		12/12/2019
Total Number of Violations for this Water System:										3
NV0000946	WHOS DUNES	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2019	12/31/2019		
Total Number of Violations for this Water System:										1
NV0000058	WILDES MANOR	S6				CERTIFIED OPERATOR FAILURE (STATE)	9/26/2016			
Total Number of Violations for this Water System:										1
NV0002080	WILDHORSE RESORT	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	10/1/2018	12/31/2018		2/27/2019
Total Number of Violations for this Water System:										1
NV0001128	WILDKAT RANCH	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	7/1/2019	9/30/2019		
Total Number of Violations for this Water System:										1
NV0002211	WILSON RESERVOIR BLM CAMPGROUND	03MJ	CNO2	NITRITE	IOC	MONITORING, ROUTINE MAJOR	1/1/2017	12/31/2019		
NV0002211	WILSON RESERVOIR BLM CAMPGROUND	93	CSC2	SECONDARY IOCS	SECONDARIES	STATE FAILURE TO MONITOR	1/1/2017	12/31/2019		
Total Number of Violations for this Water System:										2
NV0000399	WINDMILL RIDGE RESTAURANT AND	03MJ	CNO2	NITRITE	IOC	MONITORING, ROUTINE MAJOR	1/1/2017	12/31/2019		
NV0000399	WINDMILL RIDGE RESTAURANT AND	4B	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	REPORT SAMPLE RESULT/FAIL MONITOR RTCR	12/11/2019	12/16/2019		12/16/2019

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0000399	WINDMILL RIDGE RESTAURANT AND	93	CNO3	NITRATE	SECONDARIES	STATE FAILURE TO MONITOR	1/1/2019	12/31/2019		3/17/2020
NV0000399	WINDMILL RIDGE RESTAURANT AND	93	CSC2	SECONDARY IOCS	SECONDARIES	STATE FAILURE TO MONITOR	1/1/2017	12/31/2019		
Total Number of Violations for this Water System:										4
NV0000255	YERINGTON CITY OF	03MJ	CDAS	ARSENIC (AS)	IOC	MONITORING, ROUTINE MAJOR	4/1/2018	6/30/2018		2/28/2019
NV0000255	YERINGTON CITY OF	03MJ	2046	CARBOFURAN	SOC	MONITORING, ROUTINE MAJOR	1/1/2017	12/31/2019		
NV0000255	YERINGTON CITY OF	03MJ	2039	DI(2-ETHYLHEXYL) PHTHALATE	SOC	MONITORING, ROUTINE MAJOR	1/1/2018	12/31/2018		6/27/2019
NV0000255	YERINGTON CITY OF	03MJ	2034	GLYPHOSATE	SOC	MONITORING, ROUTINE MAJOR	1/1/2017	12/31/2019		
NV0000255	YERINGTON CITY OF	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2019	12/31/2019		
NV0000255	YERINGTON CITY OF	03MJ	2036	OXAMYL	SOC	MONITORING, ROUTINE MAJOR	1/1/2017	12/31/2019		
NV0000255	YERINGTON CITY OF	03MJ	CVOC	VOCS PHASE 2 & 5	VOC	MONITORING, ROUTINE MAJOR	1/1/2017	12/31/2019		
NV0000255	YERINGTON CITY OF	03MJ	CVOC	VOCS PHASE 2 & 5	VOC	MONITORING, ROUTINE MAJOR	1/1/2017	12/31/2019		
NV0000255	YERINGTON CITY OF	27MJ	0999	CHLORINE	ST1 DBP	MONITORING, ROUTINE (DBP), MAJOR	1/1/2018	3/31/2018		6/30/2019
NV0000255	YERINGTON CITY OF	27MJ	0999	CHLORINE	ST1 DBP	MONITORING, ROUTINE (DBP), MAJOR	7/1/2019	9/30/2019		10/25/2019
NV0000255	YERINGTON CITY OF	27MJ	CDB2	DBPR STAGE 2	ST2 DBP	MONITORING, ROUTINE (DBP), MAJOR	1/1/2019	9/30/2019		
NV0000255	YERINGTON CITY OF	3AMN	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MINOR (RTCR)	9/1/2019	9/30/2019		10/17/2019
NV0000255	YERINGTON CITY OF	4B	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	REPORT SAMPLE RESULT/FAIL MONITOR RTCR	7/1/2019	7/31/2019		8/19/2019
NV0000255	YERINGTON CITY OF	52	5000	LEAD & COPPER RULE	LCR	FOLLOW-UP OR ROUTINE TAP M/R (LCR)	10/1/2018			9/18/2019

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0000255	YERINGTON CITY OF	52	5000	LEAD & COPPER RULE	LCR	FOLLOW-UP OR ROUTINE TAP M/R (LCR)	10/1/2017	9/18/2019		9/18/2019
NV0000255	YERINGTON CITY OF	93	CSC2	SECONDARY IOCS	SECONDARIES	STATE FAILURE TO MONITOR	1/1/2017	12/31/2019		
NV0000255	YERINGTON CITY OF	S1	1920	ODOR	SECONDARIES	STATE MCL EXCEDENCE	10/1/2019	12/31/2019	35 TON	
Total Number of Violations for this Water System:										17

Attachment A

RULE-SPECIFIC VIOLATION CRITERIA FOR THE ANNUAL PUBLIC WATER SYSTEMS COMPLIANCE REPORT¹

Chemical Contaminant Group Maximum Contaminant Level (MCL)

MCL - Single Sample or MCL Average (Violation Types 01 and 02).

Only Community Water Systems can have a MCL for the following contaminant codes: 1025, 4000, 4006, 4010, and 4100.

Both Community and Non-transient Non-community (NTNC) water systems can have an MCL for the following contaminant codes: 2051, 2050, 2046, 2959, 2946, 2931, 2065, 2067, 2010, 2015, 2020, 2383, 2105, 2110, 2306, 2031, 2035, 2039, 2041, 2032, 2033, 2005, 2034, 2274, 2042, 2036, 2040, 2037, 2063, 2990, 2982, 2984, 2976, 2981, 2977, 2980, 2380, 2992, 2989, 2968, 2996, 2987, 2991, 2979, 2955, 2983, 2326, 2964, 2985, 2378, 2969, 1005, 1094, 1010, 1015, 1020, 1035, 1036, 1045, 1074, 1075, 1024, 1085.

All systems can have an MCL for Nitrate (contaminant codes 1038, 1040, and 1041).

Chemical Contaminant Group Monitoring and Reporting (M/R)

M/R - Monitoring, Regular (Violation Types 03 and 04 and Major Indicator Flag = Y).

Only Community Water Systems can have an M/R for the following contaminant codes: 1025, 4000, 4006, 4010, and 4100.

Both Community and NTNC water systems can have an M/R for the following contaminant codes: 2051, 2050, 2046, 2959, 2946, 2931, 2065, 2067, 2010, 2015, 2020, 2383, 2105, 2110, 2306, 2031, 2035, 2039, 2041, 2032, 2033, 2005, 2034, 2274, 2042, 2036, 2040, 2037, 2063, 2990, 2982, 2984, 2976, 2981, 2977, 2980, 2380, 2992, 2989, 2968, 2996, 2987, 2991, 2979, 2955, 2983, 2326, 2964, 2985, 2378, 2969, 2950, 2456, 0999, 1005, 1094, 1010, 1015, 1020, 1035, 1045, 1074, 1075, 1024, 1085.

¹ For violations that extend beyond the calendar year, the violation is counted in each of the calendar years in which it occurred, unless it has returned to compliance prior to the beginning of the calendar year.

All systems can have an M/R for Nitrate (contaminant codes 1038, 1040, and 1041).

Chemical Contaminant Group Treatment Technique (TT)

Both Community and NTNC water systems can have a TT violation for Acrylamide and Epichlorohydrine (Violation type 07, contaminant codes 2265 and 2257).

Total Coliform Rule (TCR) MCLs

Any violation that is either Acute or Monthly (Violation types 21 and 22). The contaminant code for TCR is 3100.

TCR Significant M/R

Any major Routine or Repeat M/R violation (Violation types 23 and 25). The contaminant code for TCR is 3100.

Revised Total Coliform Rule (RTCR) MCLs

Any violation that is either Acute or Monthly (Violation type 1A). The contaminant code for RTCR is 8000.

RTCR Significant M/R

Any major Routine or Repeat M/R violation (Violation types 3A, 3B, 3C, 3D, 4D, 4E, 4F, 5A, and 5B). The contaminant code for RTCR is 8000.

RTCR TT

Violation types (2A, 2B, 2C, and 2D). The contaminant code for RTCR is 8000.

Surface Water Treatment Rule (SWTR) TT

Any TT violation for a filtered system (Violation type 41) and all unfiltered systems who are required to install filtration if at some point during the calendar year they were unfiltered. (Violation type 42 violations - these may not be in your state data systems). The contaminant code for SWTR is 0200.

SWTR Significant M/R

Any Significant surface water M/R violation by a filtered or unfiltered system (Violation Types 36 and 31 and Major Indicator Flag = Y, respectively). The contaminant code for SWTR is 0200.

Turbidity MCL

Any MCL Average violation for an unfiltered system (Violation type 02). The contaminant code for turbidity is 0100.

Turbidity Significant M/R

Any major regular M/R violation for an unfiltered system (Violation type 03 and Major Indicator Flag = Y). The contaminant code for turbidity is 0100.

Lead and Copper Rule (LCR) TT

Any Community or NTNC water system with a TT violation at any time during the calendar year (Violation Types 58, 62 and 65). Note: Violation type 62 has been combined under Violation type 58 in SDWIS.

LCR Significant M/R

Any Community or NTNC water system with a follow-up or routine tap sampling violation (Violation type 52) or any Community or NTNC water system who incurred an initial tap monitoring violation (Violation type 51) during the calendar year, or who incurred the initial tap violation prior to the calendar year, but failed to return to compliance prior to January 1 of the calendar year. Note: a system cannot have more than one initial tap monitoring violation counted in a calendar year.

In general: Count all violations above where any date in the violation compliance period begin and end date range falls within the calendar year **except** those that returned to compliance prior to the first day of the calendar year regardless of current system status.

Note: EPA has changed the state submitted compliance period end date of Violation types 51, 58, 62 and 65 to reflect either the date the violation returned to compliance or the date of 12/31/2015.

Consumer Confidence Report Rule (CCR) Significant Consumer Notification Violations and Public Notification Violations

Any Community water system that completely failed to provide a required consumer confidence report is in violation (Violation type 71). Because the violation continues until the system provides the report, the violation must also be reported in each subsequent year until the system returns to compliance. Public Notification violations are Violation type codes 75 for NPDWR and 76 for other potential health risk situations PN Violation (Non-NPDWR). For the Public Notice Violations the violation must be linked to a specific rule. The contaminant code for IESWTR is 0300. The contaminant codes for Stage 1 DBPR are 1009, 1011, 2456, 2950, 1006, 1008 and 0999.

Interim Enhanced Surface Water Treatment Rule (IESWTR) TT

Any public water system that uses surface water or ground water under the direct influence of surface water (GWUDI) and serving at least 10,000 people with a TT violation (Violations 37, 43, 44, and 47). The contaminant code for IESWTR is 0300. See Section II of the Implementation Guidance for Interim Enhanced Surface Water Treatment Rule (EPA 816-R-01-11, June 2001)

<http://www.epa.gov/safewater/mdbp/ieswtrimplguid.pdf> for additional information

IESWTR Significant Recordkeeping and M/R Violations

Any public water system that uses surface water or GWUDI and serving at least 10,000 people with an M/R violation (Violation 29 and Violation 38 and Major Indicator Flag = Y). The contaminant code for IESWTR is 0300. Any recordkeeping violation where system fails to maintain the results of individual filter monitoring for 3 years. Violation type is 09. The contaminant code is for IESWTR is 0300. See Section II of the Implementation Guidance for Interim Enhanced Surface Water Treatment Rule (EPA 816-R-01-11, June 2001) <http://www.epa.gov/safewater/mdbp/ieswtrimplguid.pdf> for additional information.

Filter Backwash Recycle Rule (FBRR) TT

Public water systems that use surface water or GWUDI, practice conventional or direct filtration, and recycle spent filter backwash, thickener supernatant, or liquids from dewatering processes. The violation code is 40. The contaminant code is 0500. See the Implementation Guide for the Filter Backwash Recycle Rule www.epa.gov/safewater/mdbp/guide_fbrr_ig_fnl_06-16-04.pdf [EPA 816-R-04-006, June 2004] for additional information.

Filter Backwash Recycle Rule (FBRR) M/R and Recordkeeping

Public water systems that use surface water or GWUDI, practice conventional or direct filtration, and recycle spent filter backwash, thickener supernatant, or liquids from dewatering processes. The violation code for M/R is 39 and for recordkeeping is 09. The contaminant code is 0500. See the Implementation Guide for the Filter Backwash Recycle Rule (EPA 816-R-04-006, June 2004) www.epa.gov/safewater/mdbp/guide_fbrr_ig_fnl_06-16-04.pdf for additional information.

Ground Water Rule (GWR)

All systems can have Ground Water Rule violations. The violation code for failure to collect triggered source water samples for E. coli after a TCR positive sample is 34.

Long Term 1 Enhanced Surface Water Treatment Rule (LT1ESWTR) TT

Public water systems that use surface water or GWUDI and serve fewer than 10,000 people. The violation codes are 37 and 47. Like the IESWTR The contaminant code for LT1ESTR the contaminant code is 0300. See Section V of the Long Term Enhanced Surface Water **Treatment** Rule (LT1ESWTR) Implementation Guide for additional information at the website: www.epa.gov/safewater/mdbp/pdfs/lt1eswtr/guidance_lt1_ig.pdf

Stage 1 and 2 Disinfectants and Disinfection Byproducts Rule (Stage 1 DBPR) TT

All CWS and NTNCWS that add a chemical disinfectant in any part of the drinking water treatment process and transient NCWS

using chlorine dioxide with TT violations (Violations 12, 37 and 46). The contaminant codes for Stage 1 DBPR are 0400 and 2920. See Section II of the Implementation Guidance for Stage 1 Disinfectants and Disinfection Byproducts Rule (EPA 816-R-01-12, June 2001) <http://www.epa.gov/safewater/mdbp/s1dbprimplguid.pdf> for additional information.

Stage 1 and 2 DBPR MCL and Maximum Residual Disinfectant Levels (MRDL)

All CWS and NTNCWS that add a chemical disinfectant in any part of the drinking water treatment process and transient NCWS using chlorine dioxide with MCL/MRDL violations (Violations 02 and 11). The contaminant codes for Stage 1 DBPR are 1009, 1011, 2456, 2950, 1006, 1008 and 0999. See Section II of the Implementation Guidance for Stage 1 Disinfectants and Disinfection Byproducts Rule (EPA 816-R-01-12, June 2001) <http://www.epa.gov/safewater/mdbp/s1dbprimplguid.pdf> for additional information.

Stage 1 and 2 DBPR M/R Violations

All CWS and NTNCWS that add a chemical disinfectant in any part of the drinking water treatment process and transient NCWS using chlorine dioxide with M/R violations (Violation 27 and Major Indicator Flag = Y). The contaminant codes for Stage 1 DBPR are 0400, 2920, 1009, 1011, 2456, 2950, 1006, 1008 and 0999. See Section II of the Implementation Guidance for Stage 1 Disinfectants and Disinfection Byproducts Rule (EPA 816-R-01-12, June 2001) at: <http://www.epa.gov/safewater/mdbp/s1dbprimplguid.pdf> for additional information.

Public Notification

The violation code for failure to notify the public after a violation is 06 for IESWTR, LT1ESWTR, and Stage 1 DBPR. The contaminant code for Stage 1 DBPR corresponds with the appropriate MCL/MRDL/TOC (1009, 1011, 2456, 2950, 1006, 1008 and 0999). The contaminant code for IESWTR and LT1ESWTR is 0300. For FBRR the violation code is 75 and the contaminant code is 0500.

Secondary Drinking Water Standard M/R Violations

All Nevada public water systems can have M/R (Violation type 93) for Secondary Drinking Water Standards, which consists of the following contaminant codes: 1002, 1017, 1022, 1028, 1031, 1032, 1050, 1055, 1089, 1095, 1905, 1920, 1925, and 1930.

Secondary Drinking Water Standard MCL Violations

All Nevada public water systems can have MCL average (Violation type S1) for Secondary Drinking Water Standards, which consists of the following contaminant codes: 1002, 1017, 1022, 1028, 1031, 1032, 1050, 1055, 1089, 1095, 1905, 1920, 1925, and 1930.

VIOLATION TYPES

State or EPA HQ	Type Code	VIOLATION NAME	ALTERNATE DESCRIPTION
HQ	01	MAXIMUM CONTAMINANT LEVEL (MCL), SINGLE SAMPLE	Excedence of MAXIMUM CONTAMINANT LEVEL (MCL) per 5-1.52
HQ	02	MAXIMUM CONTAMINANT LEVEL (MCL), AVERAGE, WITHOUT NUMBER OF EXCEDENCE	Excedence of MAXIMUM CONTAMINANT LEVEL (MCL) per 5-1.52
HQ	02	MAXIMUM CONTAMINANT LEVEL (MCL), AVERAGE, WITH NUMBER OF EXCEDENCE	Public Water Supply (PWS) Using Chlorine Dioxide - Chlorite - Average of any 3 sample set exceeds the MAXIMUM CONTAMINANT LEVEL (MCL) of 1.0 mg/L
HQ	03	MONITORING, ROUTINE MAJOR	Failure to monitor in accordance with section 5-1.51(b) and 5-1.52 Tables or perform analysis with approved methods
HQ	04	MONITORING, CONFIRMATION/CHECK MAJOR	No repeat samples were taken in response to a positive monitoring sample result.
HQ	05	NOTIFICATION, STATE	Failure to notify state
HQ	07	TREATMENT TECHNIQUES NON-SURFACE WATER TREATMENT RULE (Non-SWTR)	Failure to maintain free chlorine residual in distribution system.
HQ	08	VARIANCE / EXEMPTION / OTHER COMPLIANCE	Failure to abide by the authorized terms and conditions of a valid variance, waiver, or any other exemption.
HQ	09	RECORD KEEPING	Failure to retain proper records.
HQ	09	RECORD KEEPING FOR INDIVIDUAL FILTER /Filter Backwash Rule (FBR)	Failure to maintain filter monitoring records for 3 years (filter results every 15 minutes)
HQ	1A	E. COLI MCL	E. coli positive routine with insufficient repeat samples, or a combination of E. coli positive and Total Coliform positive results between routine and repeat samples, or Total Coliform positive routine with Total Coliform positive repeat sample not tested for E.coli.
HQ	2A	LEVEL 1 ASSESSMENT TREATMENT TECHNIQUE	Failure to conduct Level 1 assessment.
HQ	2B	LEVEL 2 ASSESSMENT TREATMENT TECHNIQUE	Failure to conduct Level 2 assessment.
HQ	2C	CORRECTIVE ACTIONS/EXPEDITED ACTIONS TREATMENT TECHNIQUE	Failure to complete corrective actions withn the required timeframe when a Level 1 or Level 2 assessment is triggered.
HQ	2D	STARTUP PROCEDURES TREATMENT TECHNIQUE	Failure to complete seasonal startup procedures
HQ	3A	ROUTINE MONITORING	Failure to collect routine samples at appropriate site/frequency.
HQ	3B	ADDITIONAL ROUTINE MONITORING	Failure to collect additional routine samples required the next month after any Total Coliform positive happens in water systems not on a baseline monthly monitoring
HQ	3C	TC SAMPLES (TRIGGERED BY TURBIDITY EXCEEDANCE) MONITORING	Failure to collect required extra total coliform samples due to turbidity exceedance.
HQ	3D	MONITORING VIOLATION DUE TO LAB AND/OR ANALYTICAL ERRORS	Failure to use the required/approved analytical methods, or follow holding times, or sample preparation, or collection methods, or failure to use certified and/or State-approved Laboratory.

VIOLATION TYPES

State or EPA HQ	Type Code	VIOLATION NAME	ALTERNATE DESCRIPTION
HQ	4D	E. COLI POSITIVE NOTIFICATION REPORTING	Failure to notify the State by the end of the day or the end of the next business day (based on State office closure communication procedures) about an E. coli positive compliance sample result.
HQ	4E	E. COLI MCL REPORTING	Failure to provide notification to the State that an E. coli MCL violation happened.
HQ	4F	NOTIFICATION OF VIOLATIONS - ASSESSMENTS, ASSESSMENT FORMS, CORRECTIVE/EXPEDITED ACTIONS REPORTING	Failure to provide notification to the State that violations related to Level 1 and 2 assessments, assessment forms, and corrective actions have happened.
HQ	5A	ERRORS WITH SAMPLE SITING PLAN	Failure to develop Sampling Site Plan or to revise Smapling Site Plan to include a sample collection schedule.
HQ	5B	RTCR RECORD KEEPING VIOLATIONS	Failure to keep records for Level 1 and Level2 assessments and corrective/expedited actions for 5 years, or failure to keep recoreds for 5 years on repest sample results that the State approved and extended the timeframe for sample collection, or failure to keep records on Samplng Site Plan.
HQ	11	MAXIMUM RESIDUAL DISINFECTANT LEVEL (MRDL) - Public Water Supply (PWS) Using Chlorine	Excedence of Maximum Residual Disinfectant Level (MRDL) of 4.0 mg/L (exception if microbial contamination problems in distribution system)
HQ	11	MAXIMUM RESIDUAL DISINFECTANT LEVEL (MRDL) MONITORING	Failure to perform minimum monitoring requirements.
HQ	12	QUALIFIED OPERATOR FAILURE	No certified operator in charge of operation of a water treatment plant.
HQ	13	MAXIMUM RESIDUAL DISINFECTANT LEVEL (MRDL) ACUTE - Public Water Supply (PWS) Using Chlorine Dioxide	ACUTE: If any of 3 required distribution samples taken on day after a daily entry point sample Maximum Residual Disinfectant Level (MRDL) exceeds 0.8 mg/L
HQ	19	MONITOR GWR ASSESSMENT	A system that fails to conduct assessment source water monitoring required by the state according to State-determined requirements for such monitoring [141.130(c)]
HQ	20	FAILURE TO CONSULT/RESPOND	A system that fails to consult with the State within 30 days regarding notice from the State of a significant deficiency, or written notice from a laboratory of a ground water source sample being fecal indicator-positive, or that corrective action is required after a fecal indicator-positive sample result. [141.403(a)(4)]
HQ	21	MAXIMUM CONTAMINANT LEVEL (MCL) - TOTAL COLIFORM RULE (TCR) ACUTE	Excedence of MAXIMUM CONTAMINANT LEVEL (MCL) per 5-1.52 Table 6--Microbiological Contaminants
HQ	22	MAXIMUM CONTAMINANT LEVEL (MCL) - TOTAL COLIFORM RULE (TCR), MONTHLY	Excedence of MAXIMUM CONTAMINANT LEVEL (MCL) per 5-1.52 Table 6--Microbiological Contaminants

VIOLATION TYPES

State or EPA HQ	Type Code	VIOLATION NAME	ALTERNATE DESCRIPTION
HQ	23	MONITORING TOTAL COLIFORM RULE (TCR), ROUTINE MAJOR	Failure to perform Table 11 Microbiological Minimum Monitoring Requirements
HQ	24	MONITORING (TCR), ROUTINE MINOR	A system collects some but not all of the scheduled routine total coliform samples at sites approved in the written sample siting plan according to the determined monitoring frequency. [141.21(a)(1)-(2)]
HQ	25	MONITORING TOTAL COLIFORM RULE (TCR), REPEAT MAJOR	Failure to perform Table 11 Microbiological Minimum Monitoring Requirements
HQ	26	MONITORING (TCR), REPEAT MINOR	A system notified of total coliform positive repeat sample and analyzes some but not all of the total coliform positive samples for fecal coliform/E. coli. [141.32(e)(1)]
HQ	27	MONITORING, ROUTINE DISINFECTION BYPRODUCT RULE (DBP), MAJOR - Bromate Monitoring / Reporting (M/R) - Public Water Supply (PWS) Using Ozone	Failure to collect 100% of required bromate samples
HQ	27	MONITORING, ROUTINE DISINFECTION BYPRODUCT RULE (DBP), MAJOR - Chlorine Monitoring / Reporting (M/R)	Collecting <90% of chlorine samples
HQ	27	MONITORING, ROUTINE DISINFECTION BYPRODUCT RULE (DBP), MAJOR - Total Organic Carbon (TOC) Monitoring / Reporting (M/R) - Surface / Groundwater Under Direct Influence of Surface Water (GUDI) Using Conventional Filtration	Failure to collect source & finished water TOC samples and alkalinity sample
HQ	27	HALOACETIC ACID / TOTAL TRIHALOMETHANE (HAA5/TTHM)- MAJOR Monitoring / Reporting (M/R) - SURFACE WATER / Groundwater Under Direct Influence of Surface Water (GUDI) Greater Than or Equal to 10,000 Population	Collecting <90% of (HAA5/TTHM) samples
HQ	27	HALOACETIC ACID / TOTAL TRIHALOMETHANE (HAA5/TTHM) - MAJOR Monitoring / Reporting (M/R) Surface / Groundwater Under Direct Influence of Surface Water (GUDI) Population between 500 and 9999	Collecting <90% of (HAA5/TTHM) samples
HQ	27	HALOACETIC ACID / TOTAL TRIHALOMETHANE (HAA5/TTHM) - MAJOR Monitoring / Reporting (M/R) - Surface / Groundwater Under Direct Influence of Surface Water (GUDI) < 500	Failure to collect/report at least 1 sample per plant per year during month of warmest water temperature
HQ	27	HALOACETIC ACID / TOTAL TRIHALOMETHANE (HAA5/TTHM) - MAJOR Monitoring / Reporting (M/R) - Groundwater Systems Greater Than or Equal to 10,000 Population	Collecting <90% of (HAA5/TTHM) samples
HQ	27	HALOACETIC ACID / TOTAL TRIHALOMETHANE (HAA5/TTHM) - MAJOR Monitoring / Reporting (M/R) - Groundwater Systems < 10,000 Population	Failure to collect/report all required samples

VIOLATION TYPES

State or EPA HQ	Type Code	VIOLATION NAME	ALTERNATE DESCRIPTION
HQ	27	FAILURE TO HAVE MONITORING PLAN DISINFECTION BYPRODUCT RULE (DBP)	Failure to develop, implement or submit monitoring plan
HQ	28	SANITARY SURVEY COOPERATION FAILURE	A system that does not collect 5 or more routine samples per month and fails to undergo an initial sanitary survey by June 29, 1994, for community water systems, and June 29, 1999 for non-community water systems; or fails to undergo another sanitary survey every five years for community water systems and every 10 years for non-community water systems. [141.21(d)(1)(i)]
HQ	29	FAILURE TO PRODUCE COMPREHENSIVE PERFORMANCE EVALUATION (CPE) - Interim Enhanced Surface Water Treatment Rule (IESWTR)	Failure to produce CPE evaluation documentation
HQ	30	FAILURE TO HAVE MONITORING PLAN (IDSE)	A system that fails to monitor for each quarter that a monitoring result would be used in calculating an LRAA. [141.621(e)]
HQ	30	MONITORING, ROUTINE (IDSE), MAJOR	A system that fails to conduct standard monitoring according to 141.601 or a system specific study that meets the requirements in 141.602. [141.600]
HQ	30	MONITORING, ROUTINE (IDSE), MINOR	Failure to submit an IDSE standard monitoring plan, System Specific Study plan, 40/30 waiver, or submitted plan found to be deficient. [141.600(c);141.601(a); 141.602(a)]
HQ	31	MONITORING, ROUTINE/REPEAT - MAJOR - Surface Water Treatment Rule - UNFILTERED (SWTR - Unfiltered)	Failure to collect < 90% of require samples per monitoring period
HQ	32	FAILURE TO HAVE MONITORING PLAN (LT2)	A system that fails to submit a complete source water monitoring plan, including a sampling schedule and description of sampling location. [141.702(a) & 141.703(f)]
HQ	32	MONITORING, SOURCE (LT2)	A system that fails to collect any source water sample required in accordance with the sampling schedule, sampling location, analytical method, approved laboratory, and reporting requirements of the rule. [141.701 - 141.706]
HQ	34	MONITORING, SOURCE (GWR), MAJOR	Failure to collect triggered source water sample after a Total Coliform Rule positive sample.
HQ	35	FAILURE SUBMIT IDSE/SUBPT V PLAN (DBPR2)	A system that fails to submit an IDSE report or Subpart V monitoring plan, or submitted plan found to be missing required elements. [141.601(c)(1-4); 141.602(b)(1-6); 141.605; and 141.622]
HQ	36	MONITORING, Routine/Repeat MAJOR Surface Water Treatment Rule -FILTER	Failure to collect < 90% of require samples per monitoring period

VIOLATION TYPES

State or EPA HQ	Type Code	VIOLATION NAME	ALTERNATE DESCRIPTION
HQ	37	FAILURE TO PROFILE / CONSULT - Interim Enhanced Surface Water Treatment Rule (IESWTR)	Failure to collect applicability data Treatment Technique (TT) violation
HQ	38	MONITORING, ROUTINE Interim Enhanced Surface Water Treatment Rule (IESWTR), MAJOR - Filtration/Combined Filter Effluent Surface/Groundwater Under Direct Influence of Surface Water (GUDI) >= 10,000 Population with Conventional/Direct Filtration	Collecting <90% of filter effluent samples for turbidity and reporting within 10 days after end of month
HQ	38	MONITORING, ROUTINE Interim Enhanced Surface Water Treatment Rule (IESWTR), MAJOR - Filtration/Combined Filter Effluent - Surface/Groundwater Under Direct Influence of Surface Water (GUDI) Serving >= 10,000 Population with Conventional/Direct Filtration	Failure to report that Public Water Supply (PWS) has conducted all filter monitoring to state within 10 days after end of each month
HQ	39	FAILURE TO SUBMIT PLANT SCHEMATIC (FBR)	A system that fails to notify the State in writing by December 8, 2003 if the system recycles spent filter backwash water, thickener supernatant, or liquids from dewatering processes and/or include a plant schematic and typical recycle flow in the notification. [141.76(b)]
HQ	40	FAILURE TO PROPERLY RECYCLE (FBR)	Failure to meet treatment technique requirements. [141.76(c)]
HQ	41	RESIDUAL DISINFECT CONCENTRATION - Surface Water Treatment Rule (SWTR) Surface or Groundwater Under Direct Influence (Groundwater Under Direct Influence of Surface Water (GUDI)) Serving Less Than 10,000 Population.	Cl ₂ Residual fell below 0.2 mg/l for more than 4 hours.
HQ	41	SINGLE COMBINED FILTER EFFLUENT (SWTR) - Surface or Groundwater Under Direct Influence (Groundwater Under Direct Influence of Surface Water (GUDI) Serving Less Than 10,000 Population.	Failure to maintain turbidity readings below 0.5 NTU in 95% of all measurements performed every 4 hours
HQ	41	MONTHLY COMBINED FILTER EFFLUENT (SWTR) - Surface or Groundwater Under Direct Influence (Groundwater Under Direct Influence of Surface Water (GUDI) Serving Less Than 10,000 Population.	Failure to meet performance standard of 0.5 NTU at the 95th percentile monthly.
HQ	42	FAILURE TO FILTER (SWTR)	Failure to provide filtration on a surface source after 6/29/93, unless avoidance criteria is met.
HQ	42	FAILURE TO PROVIDE GWR TREATMENT	Failure to meet GWR treatment requirements
HQ	42	FAILURE TO PROVIDE LT2 TREATMENT	Failure to meet Long Term 2 treatment requirements

VIOLATION TYPES

State or EPA HQ	Type Code	VIOLATION NAME	ALTERNATE DESCRIPTION
HQ	43	SINGLE COMB. FILTER EFFLUENT Interim Enhanced Surface Water Treatment Rule (IESWTR) Surface/Groundwater Under Direct Influence of Surface Water (GUDI) Greater Than or Equal to 10,000 Population with conventional / direct filtration.	Failure to achieve turbidity <1.0 NTU, in 100% of samples
HQ	43	SINGLE COMB. FILTER EFFLUENT Interim Enhanced Surface Water Treatment Rule (IESWTR) Surface/Groundwater Under Direct Influence of Surface Water (GUDI) Greater Than or Equal to 10,000 Population with alternative filtration.	Failure to achieve turbidity <State set limit, in 100% of samples
HQ	44	MONTHLY COMB. FILTER EFFLUENT Interim Enhanced Surface Water Treatment Rule (IESWTR) - Surface/Groundwater Under Direct Influence of Surface Water (GUDI) Greater Than or Equal to 10,000 Population with conventional or direct filtration	Failure to achieve turbidity <0.3 NTU in 95% of samples
HQ	44	MONTHLY COMB. FILTER EFFLUENT Interim Enhanced Surface Water Treatment Rule (IESWTR) - Surface / Groundwater Under Direct Influence of Surface Water (GUDI) Greater Than or Equal to 10,000 Population with alternative filtration.	Failure to achieve turbidity <State set limit in 95% of samples
HQ	45	FAILURE ADDRESS DEFICIENCY	A system with a significant deficiency that after 120 days of receiving written notification of the significant deficiency from the State fails to: 1) complete corrective action in accordance with any applicable State plan review processes or other State guidance and direction. [141.404(a)(1)]
HQ	46	INADEQUATE DBP PRECURSOR REMOVAL - Surface / Groundwater Under Direct Influence of Surface Water (GUDI) using conventional filtration	Failure to meet DBP precursor removal (TOC)
HQ	47	UNCOVERED STORAGE FACILITY - Interim Enhanced Surface Water Treatment Rule (IESWTR)	Uncovered reservoir without adequate post disinfection.
HQ	48	FAILURE TO ADDRESS CONTAMINATION (GWR)	A system with a fecal indicator positive sample (that has not been invalidated by the State) and after 120 days of receiving notice of the fecal indicator positive sample has failed to: 1) complete corrective action in accordance with any applicable State plan review processes or other State guidance and direction. [141.404(b)(1)]
HQ	51	INITIAL TAP SAMPLING (PB/CU)	Failure to monitor for lead and copper in accordance with 5-1.42
HQ	52	FOLLOW-UP OR ROUTINE TAP Monitoring / Reporting (M/R) (PB/CU)	Failure to monitor for lead and copper in accordance with 5-1.42

VIOLATION TYPES

State or EPA HQ	Type Code	VIOLATION NAME	ALTERNATE DESCRIPTION
HQ	53	WATER QUALITY PARAMETER M/R (LCR)	Failure to collect the required number of WQP samples using correct sampling procedures and conduct analyses using the correct procedures. [141.87(a) - (e)]
HQ	56	INITIAL/FOLLOW-UP/ROUTINE SOWT M/R (LCR)	Failure to collect the required number of source water samples using correct sampling procedures and conduct analyses using the correct procedures in accordance with 141.88(a)(1) - (e)(1). [141.88(a)(1) - (e)(1)]
	57	OCCT/SOWT RECOMMENDATION/STUDY (LCR)	For an SOWT Recommendation violation, failure to submit a SOWT recommendation no later than 180 days after the end of the monitoring period during which the lead or copper action level was exceeded. [141.83(a)(1) & 141.90(d)(1)]
HQ	58	OPTIMAL CORROSION CONTROL TREATMENT / SOURCE WATER TREATMENT (OCCT/SOWT) INSTALLATION DEMONSTRATION	Failure to install and operate Optimal Corrosion Control Treatment (OCCT) or fail to demonstrate that OCCT already is in place.
HQ	59	WQP LEVEL NON-COMPLIANCE (LCR)	Failure to: Maintain OWQP minimum or ranges in accordance with 141.82(g). Also, If you adopted the OWQP compliance method from the LCRMR, the violation definition also includes failure to: Meet daily values for more than 9 days in a 6-month monitoring period. [141.82(g)]
HQ	63	MPL LEVEL NON-COMPLIANCE (LCR)	Failure to meet either State-designated or approved MPL in accordance with 141.83(b)(5).
HQ	64	LEAD SERVICE LINE REPLACEMENT (LCR)	A system which exceeds the lead action level after implementation of applicable corrosion control and/or source water treatment requirements (whichever sampling occurs later) and fails to complete the lead service line replacement requirements. [141.84(a)]
HQ	65	PUBLIC EDUCATION LEAD / COPPER (PB/CU)	Failure to deliver public education materials where lead action level is exceeded.
HQ	71	CONSUMER CONFIDENCE REPORT (CCR)	Failure to provide Consumer Confidence Report
HQ	72	CCR ADEQUACY/AVAILABILITY/CONTENT	Delivery of a CCR that is significantly deficient in content to the extent that the CCR does not meet the requirements of the SDWA and the Federal regulations. [141.205]
HQ	75	PUBLIC NOTICE RULE LINKED TO VIOLATION	Failure to Public Notice Violation of National Primary Drinking Water Regulations (NPDWR)
ST	93	MONITORING, ROUTINE MAJOR	Failure to monitor in accordance with section NAC 445.1.456 or perform analysis with approved methods

VIOLATION TYPES

State or EPA HQ	Type Code	VIOLATION NAME	ALTERNATE DESCRIPTION
ST	S1	MAXIMUM CONTAMINANT LEVEL (MCL), AVERAGE, WITH NUMBER OF EXCEDENCE	Excedence of MAXIMUM CONTAMINANT LEVEL (MCL) per NAC 445A.455