

**STATE OF NEVADA
PUBLIC WATER SYSTEMS
ANNUAL COMPLIANCE REPORT
FOR
THE YEAR 2018**



NEVADA DIVISION OF

**ENVIRONMENTAL
PROTECTION**

**NEVADA DIVISION OF ENVIRONMENTAL PROTECTION
BUREAU OF SAFE DRINKING WATER**

**901 S. STEWART ST., Ste. 4001
CARSON CITY, NV 89701**

TABLE OF CONTENTS

The Drinking Water Program: An Overview	page 1
Nevada Public Water Systems General Information	page 5
2018 Violation Statistics	page 6
2018 Violations Summary Report	page 7
Nevada Public Water Systems And Water Sources	Section 2
Annual Compliance Report by Chemical.....	Appendix A
Annual Compliance Detail Report by Water System	Appendix B
Attachment A: Rule-Specific Violation Criteria	A-1
Attachment V: Violation Type Codes.	V-1

The Drinking Water Program: An Overview

The EPA established the Public Water System Supervision (PWSS) Program under the authority of the 1974 Safe Drinking Water Act (SDWA). Under the SDWA and the 1986 Amendments, EPA sets national limits on contaminant levels in drinking water to ensure that the water is safe for human consumption. These limits are known as Maximum Contaminant Levels (MCLs) and the Maximum Residual Disinfectant Levels (MRDLs). For some regulations, EPA establishes treatment techniques in lieu of an MCL to control unacceptable levels of contaminants in water. The Agency also regulates how often public water systems (PWSs) monitor their water for contaminants and report the monitoring results to the states or EPA. Generally, the larger the population served by a water system, the more frequent the monitoring and reporting (M/R) requirements. In addition, EPA requires PWSs to monitor for unregulated contaminants to provide data for future regulatory development. Finally, EPA requires PWSs to notify their consumers when they have violated these regulations. The 1996 Amendments to the SDWA require consumer notification to include a clear and understandable explanation of the nature of the violation, its potential adverse health effects, steps that the PWS is undertaking to correct the violation and the possibility of alternative water supplies during the violation.

The SDWA applies to the 50 states, the District of Columbia, Indian Lands, Puerto Rico, the Virgin Islands, American Samoa, Guam, and the Commonwealth of the Northern Mariana Islands.

The SDWA allows states and territories to seek EPA approval to administer their own PWSS Programs. The authority to run a PWSS Program is called primacy. For a state to receive primacy, EPA must determine that the state meets certain requirements laid out in the SDWA and the regulations, including the adoption of drinking water regulations that are at least as stringent as the Federal regulations and a demonstration that they can enforce the program requirements. Of the 56 states and territories, all but Wyoming and the District of Columbia have primacy. The EPA Regional Offices administer the PWSS Programs within these two jurisdictions.

The 1986 SDWA Amendments gave Indian Tribes the right to apply for and receive primacy. EPA currently administers PWSS Programs on all Indian lands except the Navaho Nation, which was granted primacy in late 2000.

Annual State PWS Report

Each quarter, primacy states submit data to the Safe Drinking Water Information System (SDWIS/FED), an automated database maintained by EPA. The data submitted include, but are not limited to, PWS inventory information, the incidence of Maximum Contaminant Level, Maximum Residual Disinfectant Level, monitoring, and treatment technique violations; and information on enforcement activity related to these violations. Section 1414(c)(3) of the Safe Drinking Water Act requires states to provide EPA with an annual report of violations of the primary drinking water standards. This report provides the numbers of violations in each of six categories: MCLs, MRDLs treatment techniques, variances and exemptions, significant monitoring violations, and significant consumer notification violations. The EPA Regional Offices report the information for Wyoming, the District of Columbia, and all Indian Lands but the Navaho Nation. EPA Regional offices also report Federal enforcement actions taken. Data retrieved from SDWIS/FED form the basis of this report.

Public Water System

A Public Water System (PWS) is defined as a system that provides water via piping or other constructed conveyances for human consumption to at least 15 service connections or serves an average of at least 25 people for at least 60 days each year. There are three types of PWSs. PWSs can be community (such as towns), non-transient non-community (such as schools or factories), or transient non-community systems (such as rest stops or parks). For this report when the acronym "PWS" is used, it means systems of all types unless specified in greater detail.

Maximum Contaminant Level

Under the Safe Drinking Water Act (SDWA), the EPA sets national limits on contaminant levels in drinking water to ensure that the water is safe for human consumption. These limits are known as Maximum Contaminant Levels (MCLs).

Maximum Residual Disinfectant Level

The EPA sets national limits on residual disinfectant levels in drinking water to reduce the risk of exposure to disinfectant byproducts formed, when public water systems add chemical disinfectant for either primary or residual treatment. These limits are known as Maximum Residual Disinfectant Levels (MRDLs).

Treatment Techniques

For some regulations, the EPA establishes treatment techniques (TTs) in lieu of an MCL to control unacceptable levels of certain contaminants. For example, treatment techniques have been established for viruses, some bacteria, and turbidity.

Variations and Exemptions

A primacy state can grant a PWS a variance from a primary drinking water regulation if the characteristics of the raw water sources reasonably available to the PWS do not allow the system to meet the MCL. To obtain a variance, the system must agree to install the best available technology, treatment techniques, or other means of limiting drinking water contamination that the Administrator finds are available (taking costs into account), and the state must find that the variance will not result in an unreasonable risk to public health. The variance shall be reviewed not less than every 5 years to determine if the system remains eligible for the variance.

A primacy state can grant an exemption temporarily relieving a PWS of its obligation to comply with an MCL, treatment technique, or both if the system's noncompliance results from compelling factors (which may include economic factors) and the system was in operation on the effective date of the MCL or treatment technique requirement. The state will require the PWS to comply with the MCL or treatment technique as expeditiously as practicable, but not later than 3 years after the otherwise applicable compliance date.

Monitoring

A PWS is required to monitor and verify that the levels of contaminants present in the water do not exceed the MCL. If a PWS fails to have its water tested as required or fails to report test results correctly to the primacy agent, a monitoring violation occurs.

Significant Monitoring Violations

For this report, significant monitoring violations are generally defined as any significant monitoring violation that occurred during the calendar year of the report. A Significant monitoring violation, with rare exceptions, occurs when no samples were taken or no results were reported during a compliance period.

Consumer Notification

Every Community Water System is required to deliver to its customers a brief annual water quality report. This report is to include some educational material, and will provide information on the source water, the levels of any detected contaminants, and compliance with drinking water regulations.

Significant Consumer Notification Violations

For this report, a significant public notification violation occurred if a community water system completely failed to provide its customers the required annual water quality report.

Public Notice Violations

The Public Notification Rule requires all PWS to notify their consumers any time a PWS violated a national primary drinking water regulation or has a situation posing a risk to public health. Notices must be provided to persons served (not just billing consumers).

NEVADA PUBLIC WATER SYSTEMS
GENERAL INFORMATION

There are **594 Active Public Water Systems in Nevada:**

197 Community Systems serving **2,634,430** people.

163 systems serve between 25 and 3,300 people.
22 systems serve between 3,301 and 10,000 people.
7 systems serve between 10,001 and 50,000 people.
5 systems serve more than 50,001 people.

24 of the Community Water Systems use surface water and serve **2,377,942** of the **2,634,230** people that are served by Community water systems.

147 Non-Transient Non-Community Systems (NTNC) serving **196,214** people.

131 systems serve between 25 and 3,300 people.
11 systems serve between 3,301 and 10,000 people.
5 systems serve more than 10,001 people.

29 of the Non-Transient Non-Community Systems use surface water and serve **153,517** of the **196,214** people served by NTNC systems.

250 Transient Non-Community Systems (NC) serving **31,483** people.

All of the Transient Non-Community Systems serve between 25 and 3,300 people.

3 of the Transient Non-Community Systems use surface water and serve **142** of the **31,553** people served by NC systems.

Where to Obtain the 2018 Annual State Public Water Systems Report

NEVADA publishes their Annual Compliance Report and distributes them to the county libraries in the state. It is also available on the Bureau of Safe Drinking Water web site at: <https://ndep.nv.gov/water/drinking-water>

2018 VIOLATION STATISTICS FOR NEVADA WATER SYSTEMS

Total number of regulated systems	594
Total number of violations	756
Total number of systems that had one or more violations	226
Total number of systems that returned to compliance	483
Total number of systems still in violation	101

State of Nevada 2018 PWS Compliance Report
Violations for Compliance Year 2018

Violations Category	Systems in Violation	Violations
Maximum Contaminant Level Exceedance Violations	34	123
Chemical Contaminant Group Monitoring Violations	101	151
Maximum Containment Level Violations, E.coli (RTCR)	4	6
Total Coliform Rule Monitoring Violations	1	2
Revised Total Coliform Rule Monitoring Violations	75	113
Revised Total Coliform Rule Treatment Technique Violations	12	19
Surface Water Treatment Rule, Interim Enhanced Surface Water	2	14
Treatment Rule and Filter Backwash Recycling Rule	0	0
Lead and Copper Rule	34	40
Consumer Confidence Report	8	8
Disinfection Byproducts Rule – Stage 1	18	27
Disinfection Byproducts Rule – Stage 2	27	37
Ground Water Rule	34	59
Public Notice Violations	3	3
State Secondary Maximum Contaminant Level Exceedance Violations	38	112
State Secondary Chemical Contaminant Group Monitoring Violations	22	42

2018 Nevada Annual Compliance Summary Report

Maximum Contaminant Violations							
Epa Region	Primacy Agency Code	Violation Category	Rule Group	Rule Name	# of Viols	# of RTC Viols	# of PWS in Viols
9	NV	Maximum Contaminant Level Violation	Chems	Arsenic	103	48	25
9	NV	Maximum Contaminant Level Violation	Chems	IOC	4	0	1
9	NV	Maximum Contaminant Level Violation	Chems	Nitrates	8	2	6
9	NV	Maximum Contaminant Level Violation	Chems	Rads	4	0	1
9	NV	Maximum Contaminant Level Violation	Chems	Organics	4	4	1
9	NV	Maximum Contaminant Level Violation	DBPs	St2 DBP	6	6	2
9	NV	Maximum Contaminant Level Violation	Microbial	RTCR	6	6	4
	NV	State Maximum Contaminant Level Violation	Secondaries	Secondaries	112	44	38
Total =					247	110	78

Monitoring and Reporting Violations							
Epa Region	Primacy Agency Code	Violation Category	Rule Group	Rule Name	# of Viols	# of RTC Viols	# of PWS in Viols
9	NV	Monitoring and Reporting	Chems	IOC	13	9	8
9	NV	Monitoring and Reporting	Chems	LCR	38	28	33
9	NV	Monitoring and Reporting	Chems	Nitrates	58	37	45
9	NV	Monitoring and Reporting	Chems	Rads	15	8	2
9	NV	Monitoring and Reporting	Chems	Organics	65	45	13
9	NV	Monitoring and Reporting	DBPs	St1 DBP	26	14	17
9	NV	Monitoring and Reporting	DBPs	St2 DBP	30	21	24
9	NV	Monitoring and Reporting	Microbial	GWR	8	8	7
9	NV	Monitoring and Reporting	Microbial	TCR	2	2	1
9	NV	Monitoring and Reporting	Microbial	RTCR	113	105	75
9	NV	Monitoring and Reporting	SWTR	SWTR	10	10	1
	NV	State Monitoring and Reporting	Secondaries	Secondaries	42	30	22
Total =					420	317	248

2018 Nevada Annual Compliance Summary Report

Other Violations							
Epa Region	Primacy Agency Code	Violation Category	Rule Group	Rule Name	# of Viols	# of RTC Viols	# of PWS in Viols
9	NV	Other Violation	DBPs	St2 DBP	1	1	1
9	NV	Other Violation	SWTR	SWTR	4	4	1
9	NV	Other Violation	Other	CCR	8	6	8
9	NV	Other Violation	Other	PN rule	3	0	3
Total =					16	11	13

Treatment Technique Violations							
Epa Region	Primacy Agency Code	Violation Category	Rule Group	Rule Name	# of Viols	# of RTC Viols	# of PWS in Viols
9	NV	Treatment Technique Violation	Microbial	RTCR	19	11	12
9	NV	Treatment Technique Violation	Microbial	GWR	51	22	34
9	NV	Treatment Technique Violation	DBPs	St1 DBP	1	1	1
9	NV	Treatment Technique Violation	Chems	LCR	2	0	1
Total =					73	34	48

Acronym	Description
CCR	Consumer Compliance Rule
GWR	Ground Water Rule
LCR	Lead and Copper Rule
IOC	Inorganic Chemicals
PN Rule	Public Notice Rule
Rads	Radionuclides
St1 DBP	Stage 1 Disinfection By-Products
St2 DBP	Stage 2 Disinfection By-Products
TCR	Total Coliform Rule
RTCR	Revised Total Coliform Rule
SWTR	Surface Water Treatment Rule

Nevada Water Systems and Water Sources

County	Water System Type	Water System ID	Water System Name	Population Served	Primary Water Source	Primary Sources Type	Number of Sources	Additional Source Type	Number of Sources
WASHOE	NC	NV0000735	4TH STREET BISTRO	30	GROUNDWATER	WELL(S)	1		
LINCOLN	NC	NV0002563	A COWBOYS DREAM	26	GROUNDWATER	WELL(S)	1		
HUMBOLDT	NC	NV0000915	A1 FUEL STOP	25	GROUNDWATER	WELL(S)	1		
WASHOE	NC	NV0000703	AIR BASE INN	25	GROUNDWATER	WELL(S)	1		
WASHOE	NC	NV0000866	AIR SAILING INC GLIDERPORT	25	GROUNDWATER	WELL(S)	1		
LINCOLN	C	NV0000005	ALAMO SEWER AND WATER GID	900	GROUNDWATER	WELL(S)	2		
								CONSECUTIVE	
NYE	NTNC	NV0002190	AMARGOSA ELEMENTARY SCHOOL	200	GROUNDWATER	WELL(S)	1	CONNECTION(S)	1
NYE	NC	NV0000828	AMARGOSA PARK	25	GROUNDWATER	WELL(S)	1		
NYE	NTNC	NV0003061	AMARGOSA SENIOR CENTER	25	GROUNDWATER	WELL(S)	1		
NYE	NTNC	NV0005037	AMARGOSA TOWN COMPLEX	25	GROUNDWATER	WELL(S)	1		
NYE	NC	NV0000155	AMARGOSA VALLEY RV PARK	25	GROUNDWATER	WELL(S)	1		
NYE	NC	NV0000811	AMARGOSA VALLEY VFW POST 6826	25	GROUNDWATER	WELL(S)	1		
NYE	C	NV0002558	AMARGOSA WATER COMPANY	54	GROUNDWATER	WELL(S)	2		
NYE	C	NV0005033	ANCHOR IN MHP	36	GROUNDWATER	WELL(S)	1		
ELKO	NC	NV0002088	ANGEL CREEK CAMPGROUND USFS	75	GROUNDWATER	WELL(S)	1		
ELKO	NC	NV0003037	ANGEL LAKE CAMPGROUND USFS	100	GROUNDWATER	SPRING(S)	1		
WASHOE	NC	NV0004088	ANIMAL ARK	100	GROUNDWATER	WELL(S)	1		
LANDER	NC	NV0004105	ANTELOPE VALLEY MEETINGHOUSE LDS	25	GROUNDWATER	WELL(S)	1		
CLARK	NTNC	NV0000379	APEX REGIONAL WASTE MGMT CENTER	107	GROUNDWATER	WELL(S)	1		
			ASH MEADOWS NATIONAL WILDLIFE REFUGE						
NYE	NC	NV0004027	FWS	25	GROUNDWATER	WELL(S)	1		
STOREY	NTNC	NV0000879	ASIA UNION ELECTRONIC CHEMICALS-RENO	25	GROUNDWATER	WELL(S)	1		
NYE	NC	NV0003010	BAILEYS HOT SPRINGS	25	GROUNDWATER	SPRING(S)	1		
WHITE PINE	NC	NV0003052	BAKER CREEK CAMPGROUND NPS	45	GROUNDWATER	SPRING(S)	1		
WHITE PINE	C	NV0000863	BAKER WATER AND SEWER GID	85	GROUNDWATER	WELL(S)	1		
WHITE PINE	NTNC	NV0000982	BALD MOUNTAIN MINE	110	GROUNDWATER	WELL(S)	1		
					PURCHASED SURFACE	CONSECUTIVE			
CLARK	NTNC	NV0001162	BALLYS	7850	WATER	CONNECTION(S)	1		
WASHOE	NC	NV0000720	BAR M BAR	25	GROUNDWATER	WELL(S)	1		
LANDER	NTNC	NV0000892	BARRICK CORTEZ GOLD MINES PIPELINE	555	GROUNDWATER	WELL(S)	1		
LANDER	NTNC	NV0001097	BARRICK CORTEZ HILLS	611	GROUNDWATER	WELL(S)	1		
EUREKA	NTNC	NV0005077	BARRICK GOLDSTRIKE FACILITY	2100	GROUNDWATER	WELL(S)	1		
HUMBOLDT	NTNC	NV0002528	BARRICK TURQUOISE RIDGE INC	480	GROUNDWATER	WELL(S)	2		
NYE	NC	NV0004026	BASE CAMP US AIR FORCE	25	GROUNDWATER	WELL(S)	2		
NYE	NC	NV0005038	BEATTY RV PARK	25	GROUNDWATER	WELL(S)	1		
NYE	C	NV0000009	BEATTY WATER AND SANITATION DISTRICT	1024	GROUNDWATER	WELL(S)	6		
LINCOLN	NC	NV0002120	BEAVER DAM STATE PARK	25	GROUNDWATER	WELL(S)	1		
					PURCHASED SURFACE	CONSECUTIVE			
CLARK	NTNC	NV0001117	BELLAGIO RESORT AND CASINO	17171	WATER	CONNECTION(S)	1		

Nevada Water Systems and Water Sources

County	Water System Type	Water System ID	Water System Name	Population Served	Primary Water Source	Primary Sources Type	Number of Sources	Additional Source Type	Number of Sources
CLARK	NTNC	NV0001155	BERKLEY	672	PURCHASED SURFACE WATER	CONSECUTIVE CONNECTION(S)	1		
NYE	NC	NV0002151	BERLIN ICHTHYOSAUR STATE PARK	50	GROUNDWATER	WELL(S)	1		
CLARK	C	NV0000147	BERMUDA PALMS MANAGEMENT LLC	60	GROUNDWATER	WELL(S)	1		
DOUGLAS	NC	NV0002041	BEST WESTERN TOPAZ LAKE INN	300	GROUNDWATER	WELL(S)	1		
CLARK	C	NV0004092	BIG BEND WATER DISTRICT	8800	SURFACE WATER	INTAKE(S)	1		
NYE	C	NV0000362	BIG FIVE PARK	65	GROUNDWATER	WELL(S)	1		
NYE	C	NV0000369	BIG VALLEY MHP	50	GROUNDWATER	WELL(S)	2		
WHITE PINE	NC	NV0003053	BIRD CREEK CAMPGROUND USFS	30	GROUNDWATER	WELL(S)	1		
WASHOE	NC	NV0000381	BLACK ROCK STATION	25	GROUNDWATER	WELL(S)	1		
CLARK	NC	NV0000323	BLUE DIAMOND RAINBOW SW PLAZA WATER	100	GROUNDWATER	WELL(S)	1		
CLARK	NC	NV0000955	BLUE DIAMOND TRAVEL CENTER H-325	33	GROUNDWATER	WELL(S)	1		
CLARK	C	NV0000092	BLUE DIAMOND WATER CO OP INC	85	GROUNDWATER	SPRING(S)	1		
CLARK	C	NV0000010	BLUE DIAMOND WATER COMPANY	527	PURCHASED GROUNDWATER	CONSECUTIVE CONNECTION(S)	1		
LANDER	NC	NV0003066	BOB SCOTT CAMPGROUND USFS	25	GROUNDWATER	WELL(S)	1		
CLARK	NTNC	NV0001001	BONNIE SPRINGS OLD NEVADA	500	GROUNDWATER	WELL(S)	1		
ESMERALDA	NC	NV0002090	BOONIES	50	GROUNDWATER	WELL(S)	1		
WHITE PINE	NC	NV0005059	BORDER INN	25	GROUNDWATER	WELL(S)	1		
CLARK	C	NV0000011	BOULDER CITY	15000	PURCHASED SURFACE WATER	CONSECUTIVE CONNECTION(S)	1		
WASHOE	NC	NV0000710	BOWERS MANSION	100	GROUNDWATER	WELL(S)	1		
CLARK	NC	NV0000321	BRANDOS SPORTS BAR	105	GROUNDWATER	WELL(S)	1		
LYON	NC	NV0000389	BUCKBOARD GENERAL STORE	25	GROUNDWATER	WELL(S)	1		
NYE	C	NV0002538	C VALLEY MHP	54	GROUNDWATER	WELL(S)	2		
LINCOLN	C	NV0000013	CALIENTE PUBLIC UTILITIES	1100	GROUNDWATER	WELL(S)	3		
ELKO	NC	NV0001091	CALIFORNIA NATIONAL HISTORIC TRAILS CTR	178	GROUNDWATER	WELL(S)	1		
NYE	C	NV0000408	CALVADA MEADOWS GBWC	77	GROUNDWATER	WELL(S)	1		
DOUGLAS	NC	NV0004033	CAMP GALILEE	30	GROUNDWATER	WELL(S)	1		
CLARK	NC	NV0002509	CAMP LADY OF THE SNOWS	60	GROUNDWATER	WELL(S)	1		
ELKO	NC	NV0004050	CAMP LAMOILLE LIONS CLUB	50	GROUNDWATER	WELL(S)	1		
CLARK	NC	NV0005009	CAMP LEE CANYON CCPR	30	GROUNDWATER	WELL(S)	1		
CLARK	NC	NV0002502	CAMP POTOSI CCPR	26	GROUNDWATER	WELL(S)	1		
STOREY	C	NV0005056	CANYON GID	1310	GROUNDWATER	WELL(S)	2		
NYE	NC	NV0000405	CARBERRY SQUARE	50	GROUNDWATER	WELL(S)	1		
ELKO	NTNC	NV0002524	CARLIN HONOR CAMP NDOC	147	GROUNDWATER	WELL(S)	1		
ELKO	C	NV0000014	CARLIN UTILITIES	2500	GROUNDWATER	WELL(S)	1	1 SPRING(S)	1
LYON	NC	NV0000341	CARMENS MEXICAN RESTAURANT	25	GROUNDWATER	WELL(S)	1		
CARSON CITY	C	NV0000015	CARSON CITY PUBLIC WORKS	56000	SURFACE WATER	WELL(S)	30	INTAKE(S)	3

Nevada Water Systems and Water Sources

County	Water System Type	Water System ID	Water System Name	Population Served	Primary Water Source	Primary Sources Type	Number of Sources	Additional Source Type	Number of Sources
CHURCHILL	C	NV0003068	CARSON RIVER ESTATES	90	GROUNDWATER	WELL(S)	3		
NYE	NC	NV0002140	CARVERS CAFE	50	GROUNDWATER	WELL(S)	1		
NYE	C	NV0000218	CARVERS SMOKEY VALLEY RV AND MHP	250	GROUNDWATER	WELL(S)	1		
WHITE PINE	NC	NV0004035	CAVE LAKE STATE PARK	2000	GROUNDWATER	SPRING(S)	1		
DOUGLAS	C	NV0000259	CAVE ROCK SKYLAND	1267	SURFACE WATER	INTAKE(S)	1		
WHITE PINE	NC	NV0000301	CAVE SPRINGS WATER SYSTEM NPS	1000	GROUNDWATER	SPRING(S)	3		
NYE	NTNC	NV0001095	CEDAR PASS WATER SYSTEM	250	GROUNDWATER	WELL(S)	1		
CLARK	NTNC	NV0000364	CERTAIN TEED GYPSUM	85	GROUNDWATER	WELL(S)	2		
LYON	NC	NV0002128	CG BAR	25	GROUNDWATER	WELL(S)	1		
NYE	NC	NV0002555	CHAMPIONS	25	GROUNDWATER	WELL(S)	1		
WHITE PINE	NC	NV0002165	CHERRY CREEK WATER DISTRICT	25	GROUNDWATER	WELL(S)	1		
NYE	NC	NV0003060	CHERRY PATCH LOVE RANCH	25	GROUNDWATER	WELL(S)	1		
NYE	NC	NV0004085	CHICKEN RANCH	25	GROUNDWATER	WELL(S)	2		
DOUGLAS	NTNC	NV0005078	CHINA SPRINGS YOUTH CAMP	92	GROUNDWATER	WELL(S)	1		
NYE	C	NV0002554	CHIPMUNK RETREAT	44	GROUNDWATER	WELL(S)	1		
CLARK	NTNC	NV0002533	CHUCK LENZIE GENERATING STATION	54	GROUNDWATER	WELL(S)	3		
WASHOE	NC	NV0004079	CHUCKS CIRCLE C MARKET	25	GROUNDWATER	WELL(S)	1		
LYON	NC	NV0005020	CHURCHILL BUTTE COMPLEX	25	GROUNDWATER	WELL(S)	1		
CLARK	NTNC	NV0001113	CIRCUS CIRCUS CASINO	2668	PURCHASED SURFACE WATER	CONSECUTIVE CONNECTION(S)	1		
CLARK	NTNC	NV0001106	CITY CENTER HOTELS	8900	PURCHASED SURFACE WATER	CONSECUTIVE CONNECTION(S)	1		
PERSHING	NTNC	NV0003076	COEUR ROCHESTER INC	32	GROUNDWATER	WELL(S)	1		
CLARK	C	NV0004000	COLD CREEK CANYON HOMEOWNERS	180	GROUNDWATER	WELL(S)	2		
WHITE PINE	C	NV0005057	COLD CREEK MHP	35	GROUNDWATER	WELL(S)	1		
WASHOE	NC	NV0004103	COLD SPRINGS MEETINGHOUSE LDS	25	GROUNDWATER	WELL(S)	1		
CHURCHILL	NC	NV0002017	COLD SPRINGS STATION RESORT	25	GROUNDWATER	WELL(S)	1		
HUMBOLDT	NC	NV0002113	COMMUNITY HALL PARADISE VALLEY	72	GROUNDWATER	WELL(S)	1		
WASHOE	C	NV0000277	CONESTOGA MHP	120	GROUNDWATER	WELL(S)	1		
CLARK	NC	NV0001024	CORN CREEK FIELD STATION FWS	25	GROUNDWATER	WELL(S)	1		
LANDER	NTNC	NV0002570	CORTEZ MILL 1 POTABLE WATER SYSTEM	83	GROUNDWATER	WELL(S)	1		
CLARK	NTNC	NV0001137	COSMOPOLITAN HOTEL	5534	PURCHASED SURFACE WATER	CONSECUTIVE CONNECTION(S)	1		
CARSON CITY	C	NV0000017	COTTONWOOD MHP	250	GROUNDWATER	WELL(S)	3		
NYE	C	NV0005032	COUNTRY VIEW ESTATES GBWC	1292	GROUNDWATER	WELL(S)	3		
NYE	NC	NV0000385	COYOTE CORNER III	25	GROUNDWATER	WELL(S)	1		
NYE	NC	NV0002565	COYOTE CORNER MARKET	25	GROUNDWATER	WELL(S)	1		
CLARK	NTNC	NV0001081	CREECH AIR FORCE BASE	300	GROUNDWATER	WELL(S)	3		
NYE	NTNC	NV0000418	CRESCENT DUNES SOLAR ENERGY	40	GROUNDWATER	WELL(S)	2		
EUREKA	C	NV0000043	CRESCENT VALLEY WATER SYSTEM	340	GROUNDWATER	WELL(S)	2		
WASHOE	NC	NV0000717	CROSBYS LODGE	25	GROUNDWATER	WELL(S)	1		

Nevada Water Systems and Water Sources

County	Water System Type	Water System ID	Water System Name	Population Served	Primary Water Source	Primary Sources Type	Number of Sources	Additional Source Type	Number of Sources
WASHOE	NC	NV0000718	CRYSTAL PEAK PARK	30	GROUNDWATER	WELL(S)	1		
WASHOE	C	NV0000193	CRYSTAL TP	80	GROUNDWATER	WELL(S)	2		
WASHOE	NC	NV0000719	DAVIS CREEK PARK	100	GROUNDWATER	WELL(S)	1		
LYON	C	NV0000032	DAYTON VALLEY WATER SYSTEM	15005	GROUNDWATER	WELL(S)	8	CONSECUTIVE CONNECTION(S)	1
HUMBOLDT	NC	NV0000001	DENIO JUNCTION	25	GROUNDWATER	WELL(S)	1		
MINERAL	NTNC	NV0001156	DENTON RAWHIDE MINE	75	GROUNDWATER	WELL(S)	2		
NYE	NC	NV0002196	DESERT CENTER PLAZA	300	GROUNDWATER	WELL(S)	1		
WASHOE	NC	NV0000736	DESERT INVESTMENT GROUP LTD DESERT MIRAGE HOMEOWNERS ASSOCIATION	250	GROUNDWATER	WELL(S)	2		
CLARK	C	NV0000831	DESERT PARADISE MHP	230	GROUNDWATER	WELL(S)	2		
CLARK	C	NV0000149	DESERT PARADISE MHP	70	GROUNDWATER	WELL(S)	1		
CLARK	NC	NV0001008	DESERT SOUTHWEST CONFERENCE	30	GROUNDWATER	WELL(S)	1		
NYE	C	NV0000300	DESERT UTILITIES	1086	GROUNDWATER	WELL(S)	3		
EUREKA	C	NV0002574	DEVILS GATE GID DISTRICT 1	65	GROUNDWATER	WELL(S)	1		
EUREKA	C	NV0002573	DEVILS GATE WATER SYSTEM GID 2	70	GROUNDWATER	CONSECUTIVE CONNECTION(S)	1		
HUMBOLDT	NC	NV0002094	DIAMOND INN BAR	25	GROUNDWATER	WELL(S)	1		
HUMBOLDT	NTNC	NV0001148	DIAMOND PLASTICS	38	GROUNDWATER	WELL(S)	1		
WASHOE	NC	NV0002609	DOLLAR GENERAL	123	GROUNDWATER	WELL(S)	1		
ELKO	NC	NV0004096	DOUBLE D BAR & GRILL	25	GROUNDWATER	WELL(S)	1		
DOUGLAS	NC	NV0002043	DOUGLAS COUNTY LAMPE PARK	200	GROUNDWATER	WELL(S)	1		
DOUGLAS	NC	NV0002044	DOUGLAS COUNTY TOPAZ PARK	100	GROUNDWATER	WELL(S)	1		
ELKO	NC	NV0000949	DOVETAIL RANCH	25	GROUNDWATER	WELL(S)	1		
LYON	NC	NV0002593	DRESSLER PARK	25	GROUNDWATER	WELL(S)	1		
PERSHING	C	NV0000809	DUTCHMAN ACRES	260	GROUNDWATER	WELL(S)	2		
ESMERALDA	NTNC	NV0002184	DYER ELEMENTARY SCHOOL	70	GROUNDWATER	WELL(S)	2		
LINCOLN	NC	NV0000188	EAGLE VALLEY RESORT	25	GROUNDWATER	WELL(S)	2		
LYON	NC	NV0003098	EAST 50 BAR	25	GROUNDWATER	WELL(S)	1		
DOUGLAS	NC	NV0002218	EAST PEAK LODGE	2000	GROUNDWATER	WELL(S)	1		
DOUGLAS	C	NV0002216	EAST VALLEY WATER SYSTEM	4030	GROUNDWATER	WELL(S)	1	CONSECUTIVE CONNECTION(S)	3
CLARK	C	NV0000106	EASTLAND HEIGHTS WATER ASSOCIATION	400	GROUNDWATER	WELL(S)	2		
LINCOLN	NC	NV0002123	ECHO CANYON STATE PARK	196	GROUNDWATER	WELL(S)	1		
WASHOE	NC	NV0004135	ECOLOGICA CORPORATION	25	GROUNDWATER	WELL(S)	1		
DOUGLAS	NTNC	NV0000235	EDGEWOOD WATER COMPANY	3800	SURFACE WATER	INTAKE(S)	1	CONSECUTIVE CONNECTION(S)	1
CLARK	NC	NV0004111	EL DORADO CANYON MINE TOURS	25	GROUNDWATER	WELL(S)	1		
NYE	NC	NV0001105	EL VALLE RESTAURANT	25	GROUNDWATER	WELL(S)	1		
DOUGLAS	C	NV0000271	ELK POINT COUNTRY CLUB	325	GROUNDWATER	WELL(S)	2		
ELKO	C	NV0000272	ELKO CITY OF	20451	GROUNDWATER	WELL(S)	17		

Nevada Water Systems and Water Sources

County	Water System Type	Water System ID	Water System Name	Population Served	Primary Water Source	Primary Sources Type	Number of Sources	Additonal Source Type	Number of Sources
ELKO	C	NV0002075	ELKO RV PARK AT RYNDON	357	GROUNDWATER	WELL(S)	2		
NYE	NC	NV0000923	ELKS LODGE PAHRUMP	25	GROUNDWATER	WELL(S)	1		
WHITE PINE	NTNC	NV0004083	ELY CONSERVATION CAMP NDOC	150	GROUNDWATER	WELL(S)	1		
WHITE PINE	C	NV0005071	ELY MAXIMUM SECURITY PRISON NDOC	1099	GROUNDWATER	WELL(S)	2		
WHITE PINE	C	NV0000038	ELY MUNICIPAL WATER DEPARTMENT	5000	GROUNDWATER	WELL(S)	7		
WASHOE	C	NV0000042	EMPIRE MINING COMPANY	350	GROUNDWATER	WELL(S)	2		
STOREY	NTNC	NV0003075	EP MINERALS LLC CLARK	50	GROUNDWATER	WELL(S)	1		
CHURCHILL	NTNC	NV0004120	EP MINERALS LLC FERNLEY	41	GROUNDWATER	WELL(S)	1		
CLARK	C	NV0000109	EQUESTRIAN ESTATES CO OP WATER ASSOC	108	GROUNDWATER	WELL(S)	2		
NYE	C	NV0002552	ESCAPEE CO OP OF NEVADA	200	GROUNDWATER	WELL(S)	2		
ESMERALDA	NC	NV0000890	ESMERALDA MARKET	25	GROUNDWATER	WELL(S)	2		
EUREKA	NC	NV0004104	EUREKA MEETINGHOUSE LDS	25	GROUNDWATER	WELL(S)	1		
EUREKA	C	NV0000044	EUREKA WATER ASSOCIATION	450	GROUNDWATER	WELL(S)	2	SPRING(S)	10
CLARK	NTNC	NV0001114	EXCALIBUR RESORT AND CASINO	2607	PURCHASED SURFACE WATER	CONSECUTIVE CONNECTION(S)	1		
DOUGLAS	C	NV0002540	FAIRGROUNDS/SUNRISE ESTATES	911	GROUNDWATER	WELL(S)	3		
CHURCHILL	C	NV0000045	FALLON CITY OF	8500	GROUNDWATER	WELL(S)	4	CONSECUTIVE CONNECTION(S)	1
CHURCHILL	NC	NV0002594	FALLON LIVESTOCK LLC	25	GROUNDWATER	WELL(S)	1		
CHURCHILL	C	NV0000350	FALLON NAVAL AIR STATION	3000	GROUNDWATER	WELL(S)	3	CONSECUTIVE CONNECTION(S)	1
CHURCHILL	NC	NV0002534	FALLON RV PARK	25	GROUNDWATER	WELL(S)	1		
LYON	C	NV0000062	FERNLEY PUBLIC WORKS	18000	GROUNDWATER	WELL(S)	6		
WHITE PINE	NTNC	NV0001142	FIORE GOLD PAN MINE	100	GROUNDWATER	WELL(S)	1		
LANDER	NTNC	NV0001100	FIRE CREEK MINE	60	GROUNDWATER	WELL(S)	1		
WHITE PINE	NC	NV0002170	FIRESIDE INN	50	GROUNDWATER	WELL(S)	1		
ESMERALDA	NC	NV0000916	FISH LAKE VALLEY SALOON	25	GROUNDWATER	WELL(S)	1		
PERSHING	NTNC	NV0000884	FLORIDA CANYON MINING INC	180	GROUNDWATER	WELL(S)	1		
CLARK	NC	NV0001053	FLOYD LAMB PARK	100	GROUNDWATER	WELL(S)	2		
WASHOE	C	NV0000200	FOOTHILL TRAILER PARK	35	GROUNDWATER	WELL(S)	1		
DOUGLAS	C	NV0000959	FOOTHILL WATER SYSTEM	346	GROUNDWATER	WELL(S)	3		
LYON	NC	NV0002132	FORT CHURCHILL HISTORIC STATE PARK	207	GROUNDWATER	WELL(S)	1		
LYON	NTNC	NV0000806	FORT CHURCHILL POWER PLANT	37	GROUNDWATER	WELL(S)	2		
WASHOE	NC	NV0000893	FRANKTOWN MEADOWS	25	GROUNDWATER	WELL(S)	2		
NYE	C	NV0000063	GABBS WATER SYSTEM	411	GROUNDWATER	WELL(S)	2		
DOUGLAS	C	NV0000066	GARDNERVILLE RANCHOS GID	9500	GROUNDWATER	WELL(S)	7		
DOUGLAS	C	NV0000065	GARDNERVILLE WATER COMPANY	4500	GROUNDWATER	WELL(S)	7	CONSECUTIVE CONNECTION(S)	1
CHURCHILL	NC	NV0002587	GAS STORE WEST	25	GROUNDWATER	WELL(S)	1		
CLARK	NTNC	NV0000372	GEORGIA PACIFIC GYPSUM LLC	100	GROUNDWATER	WELL(S)	1		
WASHOE	C	NV0000071	GERLACH GID	180	GROUNDWATER	SPRING(S)	2		

Nevada Water Systems and Water Sources

County	Water System Type	Water System ID	Water System Name	Population Served	Primary Water Source	Primary Sources Type	Number of Sources	Additional Source Type	Number of Sources
CLARK	NC	NV0003029	GIRL SCOUTS NV CAMP FOXTAIL	250	GROUNDWATER	WELL(S)	1		
DOUGLAS	C	NV0000356	GLENBROOK HOMEOWNERS ASSOCIATION	1000	SURFACE WATER	INTAKE(S)	1		
HUMBOLDT	C	NV0005029	GOLCONDA GID	300	GROUNDWATER	WELL(S)	2	SPRING(S)	1
LYON	NC	NV0000881	GOLD CANYON CAFE	25	GROUNDWATER	WELL(S)	1		
HUMBOLDT	C	NV0003079	GOLD COUNTRY ESTATES	1695	GROUNDWATER	WELL(S)	4	CONSECUTIVE CONNECTION(S)	1
PERSHING	NC	NV0001124	GOLD DIGGERS SALOON & GRUBB HOUSE	25	GROUNDWATER	WELL(S)	1		
WASHOE	NTNC	NV0000751	GOLD RANCH CASINO	1000	GROUNDWATER	WELL(S)	1		
WASHOE	NC	NV0004064	GOLDEN VALLEY PARK	25	GROUNDWATER	WELL(S)	1		
ESMERALDA	C	NV0000072	GOLDFIELD TOWN WATER	350	GROUNDWATER	WELL(S)	2		
CLARK	NTNC	NV0001045	GOODSPRINGS SCHOOL CCSD	25	GROUNDWATER	WELL(S)	1		
CLARK	NTNC	NV0001144	GRANDVIEW AT LAS VEGAS	5750	PURCHASED SURFACE WATER	CONSECUTIVE CONNECTION(S)	1		
WASHOE	C	NV0000035	GRANDVIEW TERRACE WATER DISTRICT	328	GROUNDWATER	WELL(S)	3		
WASHOE	NTNC	NV0002202	GRANITE CONSTRUCTION	50	GROUNDWATER	WELL(S)	1		
WASHOE	NC	NV0004109	GRANITE HILLS BAPTIST CHURCH	94	GROUNDWATER	WELL(S)	1		
WASHOE	C	NV0000207	GREAT BASIN WATER CO COLD SPRINGS	7962	GROUNDWATER	WELL(S)	5		
WASHOE	C	NV0001086	GREAT BASIN WATER CO SPANISH SPRINGS	2030	GROUNDWATER	WELL(S)	2		
ELKO	C	NV0000036	GREAT BASIN WATER CO SPRING CREEK	6708	GROUNDWATER	WELL(S)	9		
ELKO	C	NV0005027	GREAT BASIN WATER CO SPRING CREEK MHP	7545	GROUNDWATER	WELL(S)	3		
NYE	C	NV0000270	GREAT BASIN WATER COMPANY	8538	GROUNDWATER	WELL(S)	5		
LINCOLN	NC	NV0002119	GREEN VALLEY GROCERY	25	GROUNDWATER	SPRING(S)	1		
LANDER	NTNC	NV0004117	GREYSTONE MINE	36	GROUNDWATER	WELL(S)	1	CONSECUTIVE CONNECTION(S)	1
EUREKA	NTNC	NV0001131	HALLIBURTON DUNPHY MILL	90	GROUNDWATER	WELL(S)	1		
CHURCHILL	NC	NV0002580	HARMON JUNCTION	150	GROUNDWATER	WELL(S)	1		
CLARK	C	NV0001080	HARRIS SPRINGS RANCH	40	GROUNDWATER	WELL(S)	1		
MINERAL	C	NV0000357	HAWTHORNE ARMY DEPOT	300	SURFACE WATER	WELL(S)	2	INTAKE(S)	1
MINERAL	C	NV0000073	HAWTHORNE UTILITIES	2900	GROUNDWATER	WELL(S)	5		
CLARK	C	NV0000076	HENDERSON CITY OF	275000	SURFACE WATER	INTAKE(S)	1	CONSECUTIVE CONNECTION(S)	2
LYON	NC	NV0004037	HEYDAY INN	25	GROUNDWATER	WELL(S)	1		
WHITE PINE	NC	NV0000961	HIDDEN CANYON RANCH	140	GROUNDWATER	WELL(S)	1		
NYE	NC	NV0002141	HIGHWAY 95 FUEL & FOOD	25	GROUNDWATER	WELL(S)	1		
CLARK	C	NV0000145	HILLCREST MANOR WATER USERS ASSOCIATION	450	GROUNDWATER	WELL(S)	2	CONSECUTIVE CONNECTION(S)	1
CLARK	NTNC	NV0001160	HILTON GRAND VACATIONS CONVENTION	982	PURCHASED SURFACE WATER	CONSECUTIVE CONNECTION(S)	1		

Nevada Water Systems and Water Sources

County	Water System Type	Water System ID	Water System Name	Population Served	Primary Water Source	Primary Sources Type	Number of Sources	Additonal Source Type	Number of Sources
CLARK	NTNC	NV0001143	HILTON GRAND VACATIONS ELARA	2544	PURCHASED SURFACE WATER	CONSECUTIVE CONNECTION(S)	1		
CLARK	NTNC	NV0001136	HILTON GRAND VACATIONS FLAMINGO	712	PURCHASED SURFACE WATER	CONSECUTIVE CONNECTION(S)	1		
CLARK	NTNC	NV0001150	HILTON GRAND VACATIONS LAS VEGAS BLVD	2488	PURCHASED SURFACE WATER	CONSECUTIVE CONNECTION(S)	1		
CLARK	C	NV0000146	HITCHIN POST MOTEL AND RV PARK	571	GROUNDWATER	WELL(S)	2	CONSECUTIVE CONNECTION(S)	1
LYON	NTNC	NV0004053	HODGES TRANSPORTATION CO	160	GROUNDWATER	WELL(S)	3		
DOUGLAS	C	NV0002046	HOLBROOK STATION RV AND MHP	180	GROUNDWATER	WELL(S)	2		
CLARK	NTNC	NV0003006	HOOVER DAM	3000	SURFACE WATER	INTAKE(S)	2		
CLARK	NTNC	NV0001083	HOOVER DAM LODGE DBA HACIENDA	141	PURCHASED SURFACE WATER	CONSECUTIVE CONNECTION(S)	1		
NYE	NC	NV0000833	HORIZON C STORES 1 PAHRUMP VALLEY BLVD	25	GROUNDWATER	WELL(S)	1		
NYE	NC	NV0000827	HORIZON C STORES 2 TUMBLEWEED TAVERN	357	GROUNDWATER	WELL(S)	1		
NYE	NC	NV0000918	HORIZON C STORES 3 LINDA STREET	25	GROUNDWATER	WELL(S)	1		
HUMBOLDT	NTNC	NV0005069	HUMBOLDT CONSERVATION CAMP NDOC	140	GROUNDWATER	WELL(S)	1		
HUMBOLDT	NC	NV0004062	HUMBOLDT COUNTY LIBRARY DENIO BRANCH	25	GROUNDWATER	WELL(S)	1		
PERSHING	NC	NV0001125	HUMBOLDT RIVER RANCH ASSOCIATION	150	GROUNDWATER	WELL(S)	1		
HUMBOLDT	NTNC	NV0000864	HYCROFT RESOURCES & DEVELOPMENT	921	GROUNDWATER	WELL(S)	1	CONSECUTIVE CONNECTION(S)	1
CLARK	NC	NV0004073	IDLE SPURS LOUNGE AND RESTAURANT	58	GROUNDWATER	WELL(S)	1		
PERSHING	C	NV0000226	IMLAY WATER SYSTEM	200	GROUNDWATER	WELL(S)	2		
WASHOE	C	NV0000158	INCLINE VILLAGE GID	9313	SURFACE WATER	INTAKE(S)	1		
DOUGLAS	C	NV0000355	INDIAN HILLS GID	5700	GROUNDWATER	WELL(S)	3	CONSECUTIVE CONNECTION(S)	2
CLARK	C	NV0000082	INDIAN SPRINGS WATER CO INC	900	GROUNDWATER	WELL(S)	2		
ELKO	NC	NV0002069	JACK CREEK LODGE	25	GROUNDWATER	WELL(S)	1		
ELKO	C	NV0000088	JACKPOT WATER SYSTEM	1240	GROUNDWATER	WELL(S)	5		
ELKO	C	NV0002070	JARBIDGE WATER SYSTEM	200	SURFACE WATER	INTAKE(S)	2		
CLARK	C	NV0000089	JEAN UTILITY SERVICES INC	560	GROUNDWATER	WELL(S)	3		
ELKO	NTNC	NV0003013	JERRITT CANYON GOLD JERRITT CANYON MINE	125	GROUNDWATER	WELL(S)	2		
ELKO	NTNC	NV0000313	JERRITT CANYON GOLD SSX MINE	125	GROUNDWATER	WELL(S)	1		
ELKO	NC	NV0002071	JIGGS BAR	25	GROUNDWATER	WELL(S)	1		
WASHOE	NC	NV0000731	JOHNNY CASSINARIS RESTAURANT	150	GROUNDWATER	WELL(S)	1		
ELKO	NTNC	NV0001126	JOYGLOBAL SURFACE MINING INC	25	GROUNDWATER	WELL(S)	1		
CLARK	NTNC	NV0001107	KAPEX WATER SYSTEM CITY OF NLV	25	GROUNDWATER	WELL(S)	1		

Nevada Water Systems and Water Sources

County	Water System Type	Water System ID	Water System Name	Population Served	Primary Water Source	Primary Sources Type	Number of Sources	Additional Source Type	Number of Sources
WASHOE	C	NV0000199	KE TA MOBILE HOME PARK	60	GROUNDWATER	WELL(S)	2		
CHURCHILL	NTNC	NV0002024	KENNAMETAL INC	75	GROUNDWATER	WELL(S)	1		
LINCOLN	NC	NV0002121	KERSHAW RYAN STATE PARK	25	GROUNDWATER	WELL(S)	1		
CLARK	NC	NV0000932	KEYSTONE CENTER	30	GROUNDWATER	WELL(S)	1		
HUMBOLDT	NTNC	NV0002198	KINGS RIVER ELEMENTARY SCHOOL	27	GROUNDWATER	WELL(S)	1		
CONSECUTIVE									
CLARK	C	NV0000287	KINGS ROW TP	860	GROUNDWATER	WELL(S)	1	CONNECTION(S)	1
DOUGLAS	C	NV0000004	KINGSBURY GID	3839	SURFACE WATER	INTAKE(S)	1		
LANDER	C	NV0000265	KINGSTON TOWN WATER UTILITIES	350	GROUNDWATER	WELL(S)	2		
ELKO	NTNC	NV0000349	KLONDEX HOLLISTER MINE INC	150	GROUNDWATER	WELL(S)	1		
ELKO	NTNC	NV0000908	KLONDEX MIDAS OPERATIONS INC	80	GROUNDWATER	WELL(S)	2		
WHITE PINE	C	NV0002174	KOA OF ELY CAMPGROUND	80	GROUNDWATER	WELL(S)	2		
WASHOE	NC	NV0000700	KRUSE FEED AND HARDWARE	1000	GROUNDWATER	WELL(S)	1		
CLARK	C	NV0000142	KYLE CANYON WATER DISTRICT	1040	GROUNDWATER	WELL(S)	4		
GROUNDWATER UNDER INFLUENCE OF SURFACE									
CHURCHILL	NC	NV0002028	LAHONTAN DAM STATE PARK	26	WATER	SPRING(S)	2		
LYON	NC	NV0002133	LAHONTAN DAM STATE PARK BEACH 3	25	GROUNDWATER	WELL(S)	1		
LYON	NC	NV0005021	LAHONTAN DAM STATE PARK BEACH 7	50	GROUNDWATER	WELL(S)	1		
PURCHASED SURFACE									
CONSECUTIVE									
CLARK	NC	NV0000942	LAKER PLAZA INC	27	WATER	WELL(S)	1	CONNECTION(S)	1
NYE	NTNC	NV0000834	LAKESIDE CASINO AND RV PARK	175	GROUNDWATER	WELL(S)	1		
ELKO	NTNC	NV0000928	LAMOILLE VALLEY PLAZA	351	GROUNDWATER	WELL(S)	1		
ELKO	C	NV0000273	LAMOILLE WATER USERS ASSOC	200	GROUNDWATER	WELL(S)	2		
LANDER	C	NV0000008	LANDER CO SEWER AND WATER DIST 1 BM	3635	GROUNDWATER	WELL(S)	4		
LANDER CO SEWER AND WATER DIST 2									
LANDER	C	NV0000006	AUSTIN	350	GROUNDWATER	WELL(S)	2	SPRING(S)	1
WHITE PINE	NC	NV0004055	LANES TRAVEL CENTER	50	GROUNDWATER	WELL(S)	1		
CONSECUTIVE									
CLARK	C	NV0000090	LAS VEGAS VALLEY WATER DISTRICT	1347550	SURFACE WATER	WELL(S)	57	CONNECTION(S)	2
CHURCHILL	NC	NV0000938	LATTIN FARMS	25	GROUNDWATER	WELL(S)	1		
NYE	NC	NV0005068	LDS CHURCH PAHRUMP WARD	175	GROUNDWATER	WELL(S)	1		
ELKO	NC	NV0004005	LDS LEE RECREATION CAMP	100	GROUNDWATER	WELL(S)	1		
CLARK	NC	NV0000307	LEE CANYON SKI AREA	1005	GROUNDWATER	WELL(S)	2		
EUREKA	NTNC	NV0000338	LEEVILLE POTABLE WATER SYSTEM	147	GROUNDWATER	WELL(S)	2		
WHITE PINE	NC	NV0003051	LEHMAN CREEK CAMPGROUND NPS	60	GROUNDWATER	SPRING(S)	1		
WASHOE	NC	NV0004077	LEMMON VALLEY HORSEMANS PARK	100	GROUNDWATER	WELL(S)	1		
CLARK	NTNC	NV0001000	LHOIST NORTH AMERICA	136	GROUNDWATER	WELL(S)	2		
WASHOE	C	NV0000865	LIGHTNING W	163	GROUNDWATER	WELL(S)	3		
LINCOLN	NC	NV0002192	LITTLE A LE INN	60	GROUNDWATER	WELL(S)	1		
DOUGLAS	C	NV0002050	LOGAN CREEK ESTATES GID	60	GROUNDWATER	WELL(S)	1		

Nevada Water Systems and Water Sources

County	Water System Type	Water System ID	Water System Name	Population Served	Primary Water Source	Primary Sources Type	Number of Sources	Additional Source Type	Number of Sources
CHURCHILL	NTNC	NV0001185	LOGOS CHRISTIAN ACADEMY	25	GROUNDWATER	WELL(S)	1		
HUMBOLDT	NTNC	NV0000907	LONE TREE MINE	150	GROUNDWATER	WELL(S)	1		
NYE	NTNC	NV0000871	LONGSTREET INN AND CASINO	72	GROUNDWATER	WELL(S)	1		
CLARK	NC	NV0000392	LOVELL CANYON RESIDENTIAL LLC	35	GROUNDWATER	WELL(S)	1		
					PURCHASED	CONSECUTIVE			
PERSHING	C	NV0000861	LOVELOCK CORRECTIONAL CENTER NDOC	1630	GROUNDWATER	CONNECTION(S)	1		
PERSHING	C	NV0000161	LOVELOCK MEADOWS WATER DISTRICT	3562	GROUNDWATER	WELL(S)	3		
CLARK	NTNC	NV0002602	LOVES TRAVEL STOP AND COUNTRY STORE	3025	GROUNDWATER	WELL(S)	1		
			LOW LOW LIQUOR CIGARETTES AND						
NYE	NC	NV0000917	GOODIES	25	GROUNDWATER	WELL(S)	1		
CLARK	C	NV0000140	LUNA VISTA	66	GROUNDWATER	WELL(S)	1		
WHITE PINE	NC	NV0004101	LUND MEETINGHOUSE LDS	25	GROUNDWATER	WELL(S)	1		
WHITE PINE	NTNC	NV0000979	LUND SCHOOL	140	GROUNDWATER	WELL(S)	1		
					PURCHASED SURFACE	CONSECUTIVE			
CLARK	NTNC	NV0001111	LUXOR RESORT AND CASINO	3196	WATER	CONNECTION(S)	1		
HUMBOLDT	NC	NV0002220	LYE CREEK CAMPGROUND USFS	25	GROUNDWATER	SPRING(S)	1		
					PURCHASED SURFACE	CONSECUTIVE			
CLARK	NTNC	NV0001130	M RESORT SPA AND CASINO	3550	WATER	CONNECTION(S)	1		
NYE	NC	NV0005019	MABELS BAR	25	GROUNDWATER	WELL(S)	1		
WASHOE	NC	NV0000738	MAGIC CARPET GOLF	25	GROUNDWATER	WELL(S)	1		
WHITE PINE	NC	NV0002175	MAJORS STATION	25	GROUNDWATER	WELL(S)	1		
					PURCHASED SURFACE	CONSECUTIVE			
CLARK	NTNC	NV0001119	MANDALAY BAY RESORT AND CASINO	10549	WATER	CONNECTION(S)	1		
NYE	C	NV0000165	MANHATTAN TOWN WATER	40	GROUNDWATER	WELL(S)	1		
HUMBOLDT	NTNC	NV0001103	MARIGOLD MINE POTABLE WATER SYSTEM	300	GROUNDWATER	WELL(S)	1		
STOREY	NTNC	NV0000878	MARS PETCARE US INC	140	GROUNDWATER	WELL(S)	1		
HUMBOLDT	C	NV0000162	MCDERMITT WATER SYSTEM	200	GROUNDWATER	WELL(S)	2		
WHITE PINE	C	NV0000163	MCGILL WATER AND SEWER DIST	1200	GROUNDWATER	WELL(S)	2		
								CONSECUTIVE	
CLARK	NC	NV0002508	MCWILLIAMS WATER SYSTEM	25	GROUNDWATER	WELL(S)	1	CONNECTION(S)	1
WASHOE	NC	NV0000757	MELS DINER	1000	GROUNDWATER	WELL(S)	1		
WASHOE	NC	NV0000950	MEMORIAL POINT STATE PARK	25	GROUNDWATER	WELL(S)	1		
					PURCHASED SURFACE	CONSECUTIVE			
CLARK	NTNC	NV0001121	MGM GRAND HOTEL AND CASINO	15500	WATER	CONNECTION(S)	1		
ELKO	NC	NV0003071	MIDAS WATER COOPERATIVE	25	GROUNDWATER	WELL(S)	2		
CHURCHILL	NC	NV0002027	MIDDLEGATE STATION	25	GROUNDWATER	WELL(S)	1		
CARSON CITY	NC	NV0002006	MILL HOUSE INN MOTEL	50	GROUNDWATER	WELL(S)	1		
MINERAL	C	NV0000074	MINA LUNING WATER SYSTEM	300	GROUNDWATER	WELL(S)	3		

Nevada Water Systems and Water Sources

County	Water System Type	Water System ID	Water System Name	Population Served	Primary Water Source	Primary Sources Type	Number of Sources	Additional Source Type	Number of Sources
CLARK	NTNC	NV0001120	MIRAGE RESORT AND CASINO	4400	PURCHASED SURFACE WATER	CONSECUTIVE CONNECTION(S)	1		
CLARK	C	NV0000160	MOAPA VALLEY WATER DISTRICT	8500	GROUNDWATER	WELL(S)	4	SPRING(S)	2
DOUGLAS	C	NV0002564	MONTANA	330	GROUNDWATER	WELL(S)	2	CONSECUTIVE CONNECTION(S)	1
CLARK	NTNC	NV0001118	MONTE CARLO RESORT AND CASINO	1980	PURCHASED SURFACE WATER	CONSECUTIVE CONNECTION(S)	1		
ELKO	C	NV0000169	MONTELLO WATER SYSTEM	287	GROUNDWATER	SPRING(S)	2		
NYE	NC	NV0002142	MOOSE LODGE 808	25	GROUNDWATER	WELL(S)	1		
WASHOE	C	NV0000732	MOUNT ROSE BOWL PROPERTY OWNERS WATER CO	40	GROUNDWATER	WELL(S)	1	SPRING(S)	1
ELKO	C	NV0000170	MOUNTAIN CITY WATER AND SEWER	30	GROUNDWATER	SPRING(S)	1		
NYE	C	NV0000920	MOUNTAIN FALLS WATER SYSTEM GBWC	1718	GROUNDWATER	WELL(S)	2		
CLARK	NC	NV0001082	MOUNTAIN SPRINGS BAR INC	75	GROUNDWATER	WELL(S)	1		
DOUGLAS	C	NV0003081	MOUNTAIN VIEW MHP	45	GROUNDWATER	WELL(S)	1		
NYE	C	NV0005067	MOUNTAIN VIEW MHP GBWC	65	GROUNDWATER	WELL(S)	1		
WASHOE	NC	NV0000789	MSJK PROPERTIES LLC	50	GROUNDWATER	WELL(S)	1		
CLARK	NC	NV0001010	MT CHARLESTON PUB LLC	450	GROUNDWATER	WELL(S)	1		
CLARK	C	NV0001015	MT CHARLESTON WATER COMPANY	535	GROUNDWATER	WELL(S)	1		
WASHOE	NC	NV0000743	MT ROSE CAMPGROUND USFS	25	GROUNDWATER	WELL(S)	1		
WASHOE	NC	NV0000744	MT ROSE SKI AREA SKI RENO	800	GROUNDWATER	SPRING(S)	1		
LINCOLN	NC	NV0000876	NARCONON NEVADA RAINBOW CANYON	44	GROUNDWATER	WELL(S)	1		
CHURCHILL	NTNC	NV0002541	NAS CENTROID EW RANGE	80	GROUNDWATER	WELL(S)	1		
WASHOE	NTNC	NV0000869	NATCHEZ GYM	175	GROUNDWATER	WELL(S)	1		
WASHOE	NTNC	NV0000774	NATCHEZ SCHOOL	200	GROUNDWATER	WELL(S)	1		
EUREKA	NC	NV0002214	NDOT BEOWAWE ROADSIDE PARK RP802 EU	100	GROUNDWATER	WELL(S)	1		
NYE	NC	NV0002147	NDOT BIG SMOKEY ROADSIDE PARK RP807NY	25	GROUNDWATER	WELL(S)	1		
HUMBOLDT	NC	NV0001054	NDOT BUTTON POINT ROADSIDE PARK RP808HU	600	GROUNDWATER	WELL(S)	1		
PERSHING	NC	NV0002160	NDOT COSGRAVE ROADSIDE PARK RP804PE	600	GROUNDWATER	WELL(S)	1		
NYE	NC	NV0002146	NDOT LATHROP WELLS ROADSIDE PARK RP801NY	200	GROUNDWATER	WELL(S)	1		
ESMERALDA	NC	NV0002089	NDOT MILLERS NV ROADSIDE PARK RP801ES	200	GROUNDWATER	WELL(S)	1		
CLARK	NC	NV0001101	NDOT SEARCHLIGHT WELCOME CENTER	50	GROUNDWATER	WELL(S)	1		
NYE	NC	NV0000943	NDOT SUNNYSIDE ROADSIDE PARK RP810NY	25	GROUNDWATER	WELL(S)	1		

Nevada Water Systems and Water Sources

County	Water System Type	Water System ID	Water System Name	Population Served	Primary Water Source	Primary Sources Type	Number of Sources	Additional Source Type	Number of Sources
CHURCHILL	NC	NV0002034	NDOT TRINITY ROADSIDE PARK RP806CH	100	GROUNDWATER	PURCHASED CONSECUTIVE CONNECTION(S)	1		
HUMBOLDT	NC	NV0002102	NDOT VALMY ROADSIDE PARK RP809HU	367	GROUNDWATER	WELL(S)	1		
WASHOE	NC	NV0004022	NDOT WADSWORTH REST STOP	25	GROUNDWATER	WELL(S)	1		
CLARK	C	NV0003028	NELLIS AIR FORCE BASE	19081	PURCHASED SURFACE WATER	WELL(S)	7	CONSECUTIVE CONNECTION(S)	2
CHURCHILL	NC	NV0002014	NEVADA LIVESTOCK MARKETING	25	GROUNDWATER	WELL(S)	1		
NYE	NTNC	NV0000360	NEVADA NATIONAL SECURITY SITE	1700	GROUNDWATER	WELL(S)	3		
CLARK	C	NV0000699	NEVADA STATE VETERANS HOME BOULDER CITY	708	PURCHASED SURFACE WATER	CONSECUTIVE CONNECTION(S)	1		
CLARK	NTNC	NV0005006	NEVADA TEST AND TRAINING RANGE PT BRAVO	50	GROUNDWATER	WELL(S)	1		
CLARK	NC	NV0000378	NEVADA TEST AND TRAINING RANGE SILVER FL	35	GROUNDWATER	WELL(S)	1		
ELKO	C	NV0000037	NEVADA YOUTH TRAINING CENTER	100	GROUNDWATER	WELL(S)	1		
CHURCHILL	NTNC	NV0000903	NEW MILLENNIUM BUILDING SYSTEMS, LLC	50	GROUNDWATER	WELL(S)	1		
CLARK	NTNC	NV0001112	NEW YORK NEW YORK HOTEL AND CASINO	7000	PURCHASED SURFACE WATER	CONSECUTIVE CONNECTION(S)	1		
EUREKA	NTNC	NV0002600	NEWMONT GOLD GOLD QUARRY	700	GROUNDWATER	WELL(S)	3		
EUREKA	NTNC	NV0002603	NEWMONT GOLD NORTH AREA LEACH	300	GROUNDWATER	WELL(S)	1		
ELKO	NTNC	NV0001138	NEWMONT LONG CANYON MINE	110	GROUNDWATER	WELL(S)	1		
NYE	NC	NV0004099	NNSS AREA 12	25	GROUNDWATER	WELL(S)	1		
NYE	NC	NV0004098	NNSS AREA 25	120	GROUNDWATER	WELL(S)	2		
DOUGLAS	NTNC	NV0000977	NORTH COUNTY WATER SYSTEM	200	GROUNDWATER	WELL(S)	2	CONSECUTIVE CONNECTION(S)	3
CLARK	C	NV0000175	NORTH LAS VEGAS UTILITIES	306570	PURCHASED SURFACE WATER	WELL(S)	2	CONSECUTIVE CONNECTION(S)	2
WASHOE	NTNC	NV0000870	NORTH VALLEY BUS FACILITY	60	GROUNDWATER	WELL(S)	1		
HUMBOLDT	NTNC	NV0002513	NORTH VALMY POWER PLANT	120	GROUNDWATER	WELL(S)	2		
CLARK	C	NV0003005	NPS BOULDER BEACH	722	PURCHASED SURFACE WATER	CONSECUTIVE CONNECTION(S)	1		
CLARK	C	NV0002506	NPS CALLVILLE BAY	250	SURFACE WATER	INTAKE(S)	1		
CLARK	NTNC	NV0002501	NPS COTTONWOOD COVE	592	GROUNDWATER	WELL(S)	2		
CLARK	C	NV0002503	NPS ECHO BAY	274	SURFACE WATER	INTAKE(S)	1		
CLARK	NC	NV0003004	NPS LAS VEGAS BAY	25	PURCHASED SURFACE WATER	CONSECUTIVE CONNECTION(S)	1		
NYE	NTNC	NV0002152	NYE COUNTY COMPLEX	100	GROUNDWATER	WELL(S)	2		
ELKO	C	NV0004017	OASIS MHP	46	GROUNDWATER	WELL(S)	1		
CHURCHILL	NC	NV0000921	OASIS SPRINGS	25	GROUNDWATER	WELL(S)	1		
CHURCHILL	C	NV0000052	OK MOBILE HOME PARK	90	GROUNDWATER	WELL(S)	1		
CHURCHILL	NC	NV0004028	OLAM SVI	98	GROUNDWATER	WELL(S)	1		

Nevada Water Systems and Water Sources

County	Water System Type	Water System ID	Water System Name	Population Served	Primary Water Source	Primary Sources Type	Number of Sources	Additional Source Type	Number of Sources
WASHOE	C	NV0000797	OLD FORTY WEST MOTEL	40	GROUNDWATER	WELL(S)	2		
CHURCHILL	C	NV0000303	OLD RIVER WATER COMPANY	300	GROUNDWATER	WELL(S)	2		
WASHOE	C	NV0002526	OLD WASHOE ESTATES	135	GROUNDWATER	WELL(S)	2		
HUMBOLDT	C	NV0003032	OROVADA WATER DISTRICT	200	GROUNDWATER	WELL(S)	2		
			PAHRANAGAT NATIONAL WILDLIFE REFUGE						
LINCOLN	NC	NV0004106	FWS	25	GROUNDWATER	WELL(S)	1		
NYE	NC	NV0004018	PAHRUMP FIRE STATION BLM	25	GROUNDWATER	WELL(S)	1		
NYE	NC	NV0005034	PAHRUMP RV PARK	120	GROUNDWATER	WELL(S)	1		
NYE	NTNC	NV0003036	PAHRUMP SENIOR CENTER INC	70	GROUNDWATER	WELL(S)	1		
NYE	C	NV0000926	PAHRUMP UTILITY COMPANY INC	985	GROUNDWATER	WELL(S)	5		
CLARK	C	NV0000819	PALM GARDENS WATER CO OP	42	GROUNDWATER	WELL(S)	2		
LINCOLN	C	NV0000185	PANACA FARMSTEAD WATER ASSOCIATION	900	GROUNDWATER	WELL(S)	2		
HUMBOLDT	NTNC	NV0002186	PARADISE VALLEY ELEMENTARY	35	GROUNDWATER	WELL(S)	1		
HUMBOLDT	NC	NV0002106	PARADISE VALLEY PARK	40	GROUNDWATER	WELL(S)	1		
NYE	NC	NV0001094	PATCH OF HEAVEN	50	GROUNDWATER	WELL(S)	1		
NYE	NTNC	NV0004067	PEACOX CHARITABLE REMAINDER UNITRUST	50	GROUNDWATER	WELL(S)	1		
ELKO	NC	NV0002064	PETES TRAILER COURT	24	GROUNDWATER	WELL(S)	1		
LANDER	NTNC	NV0000902	PHOENIX MINE POTABLE WATER SYSTEM	400	GROUNDWATER	WELL(S)	1		
NYE	NC	NV0004063	PICK AND SHOVEL INVESTMENTS	25	GROUNDWATER	WELL(S)	1		
HUMBOLDT	NTNC	NV0002095	PILOT TRAVEL CENTER 485	1448	GROUNDWATER	WELL(S)	1		
DOUGLAS	C	NV0000067	PINION PINES MHP	30	GROUNDWATER	WELL(S)	1		
LINCOLN	C	NV0000186	PIOCHE PUBLIC UTILITIES	700	GROUNDWATER	WELL(S)	3		
LINCOLN	C	NV0000187	PIOCHE PUBLIC UTILITIES CASTLETON	60	GROUNDWATER	SPRING(S)	1		
CLARK	NC	NV0001012	PIONEER SALOON	25	GROUNDWATER	WELL(S)	1		
NYE	C	NV0000402	PLEASANT VALLEY	110	GROUNDWATER	WELL(S)	2		
WASHOE	NTNC	NV0000750	PLEASANT VALLEY SCHOOL	300	GROUNDWATER	WELL(S)	1		
					PURCHASED SURFACE	CONSECUTIVE			
CLARK	NTNC	NV0001127	POLO TOWERS	2125	WATER	CONNECTION(S)	1		
NYE	NTNC	NV0001170	PREMIER MAGNESIA	114	GROUNDWATER	WELL(S)	1		
CLARK	C	NV0001073	PRIMM VALLEY CASINO RESORTS	7000	GROUNDWATER	WELL(S)	2		
CHURCHILL	C	NV0000054	R AND M MOBILE HOME PARK	130	GROUNDWATER	WELL(S)	2		
CLARK	C	NV0000370	RAINBOW GARDENS WATER USERS	45	GROUNDWATER	WELL(S)	1		
CLARK	NC	NV0001069	RANCH HOUSE	25	GROUNDWATER	WELL(S)	1		
CLARK	C	NV0000129	RANCHO COOPERATIVE WATER COMPANY	112	GROUNDWATER	WELL(S)	2		
NYE	C	NV0002571	RANCHO VISTA 4	25	GROUNDWATER	WELL(S)	2		
LINCOLN	NC	NV0000898	RAPPORT EXECUTIVE RETREAT	25	GROUNDWATER	WELL(S)	2		
								CONSECUTIVE	
CLARK	NC	NV0003100	RED ROCK CAMPGROUND BLM	25	GROUNDWATER	WELL(S)	1	CONNECTION(S)	1

Nevada Water Systems and Water Sources

County	Water System Type	Water System ID	Water System Name	Population Served	Primary Water Source	Primary Sources Type	Number of Sources	Additional Source Type	Number of Sources
CLARK	NC	NV0005011	RED ROCK CANYON VISITOR CENTER BLM	844	GROUNDWATER	WELL(S)	1	CONSECUTIVE CONNECTION(S)	1
CLARK	NC	NV0003101	RED ROCK FIRE STN AND LAW ENF BLM	25	GROUNDWATER	WELL(S)	1		
WASHOE	C	NV0000701	RENO SAHARA TRAILER PARK	60	GROUNDWATER	WELL(S)	2		
WASHOE	NTNC	NV0001132	RENO TECHNOLOGY PARK WATER COMPANY	30	GROUNDWATER	WELL(S)	2		
CLARK	NTNC	NV0001167	RIO RESORT AND CASINO	7132	PURCHASED SURFACE WATER	CONSECUTIVE CONNECTION(S)	1		
WASHOE	C	NV0000191	RIO VISTA MHC LLC	65	GROUNDWATER	WELL(S)	2		
CLARK	NC	NV0004029	RITCHIE BROTHERS	1013	GROUNDWATER	WELL(S)	1		
WASHOE	C	NV0000754	RIVER BEND MHP	45	GROUNDWATER	WELL(S)	1		
WASHOE	C	NV0000244	RIVERBELLE PROPERTIES LLC MHP	150	GROUNDWATER	WELL(S)	1		
WASHOE	NC	NV0003001	RIVERBELLE PROPERTIES LLC SASQUATCH INN	25	GROUNDWATER	WELL(S)	1		
CLARK	NTNC	NV0001042	RIVERSIDE RESORT	1772	GROUNDWATER	WELL(S)	3		
DOUGLAS	C	NV0000068	RIVERVIEW MOBILE HOME PARK	59	GROUNDWATER	WELL(S)	1		
CLARK	C	NV0000319	ROARK ESTATES WATER ASSOC	62	GROUNDWATER	WELL(S)	1		
WHITE PINE	NTNC	NV0000855	ROBINSON NEVADA MINING COMPANY	437	GROUNDWATER	WELL(S)	1		
LYON	NC	NV0000858	ROGELIO M GARCIA	25	GROUNDWATER	WELL(S)	1		
WASHOE	C	NV0000767	ROSEMOUNT WATER CO	54	GROUNDWATER	SPRING(S)	1		
LYON	NC	NV0000951	ROSIES PLACE	25	GROUNDWATER	WELL(S)	1		
DOUGLAS	C	NV0000260	ROUND HILL GID	1200	SURFACE WATER	INTAKE(S)	1		
NYE	NTNC	NV0001122	ROUND MOUNTAIN GOLD HILL WATER SYSTEM	250	GROUNDWATER	WELL(S)	2		
NYE	C	NV0004074	ROUND MOUNTAIN PUC	1200	GROUNDWATER	WELL(S)	2		
NYE	NTNC	NV0002535	ROUND MOUNTAIN SMOKY VALLEY MINE	380	GROUNDWATER	WELL(S)	3		
HUMBOLDT	NC	NV0002542	ROYAL PEACOCK RV PARK	53	GROUNDWATER	WELL(S)	1		
ELKO	NC	NV0004112	RUBY 360 LODGE	25	GROUNDWATER	WELL(S)	1		
EUREKA	NTNC	NV0000885	RUBY HILL MINE	125	GROUNDWATER	WELL(S)	1		
ELKO	NC	NV0003070	RUBY VALLEY LDS CHAPEL	90	GROUNDWATER	WELL(S)	1		
ELKO	NTNC	NV0002084	RUBY VALLEY SCHOOL	30	GROUNDWATER	WELL(S)	1		
WHITE PINE	C	NV0000164	RUTH WATER DISTRICT	470	PURCHASED GROUNDWATER	CONSECUTIVE CONNECTION(S)	1		
PERSHING	NC	NV0002222	RYE PATCH PETROLEUM	40	GROUNDWATER	WELL(S)	1		
PERSHING	NC	NV0002223	RYE PATCH STATE PARK	25	GROUNDWATER	WELL(S)	1		
PERSHING	NC	NV0005023	RYE PATCH STATE PARK PICNIC AREA	27	GROUNDWATER	WELL(S)	1		
ELKO	NC	NV0001092	RYNDON GAS & FOOD LLC	25	GROUNDWATER	WELL(S)	1		
DOUGLAS	NC	NV0002047	S AND J VENTURES DBA JUNCTION BAR	35	GROUNDWATER	WELL(S)	1		
ELKO	NTNC	NV0002566	SAGE SCHOOLS	2200	GROUNDWATER	WELL(S)	2		
CHURCHILL	C	NV0002023	SAGE VALLEY MHP	188	GROUNDWATER	WELL(S)	1		
CHURCHILL	NC	NV0000872	SAGE VALLEY RV PARK	25	GROUNDWATER	WELL(S)	1		

Nevada Water Systems and Water Sources

County	Water System Type	Water System ID	Water System Name	Population Served	Primary Water Source	Primary Sources Type	Number of Sources	Additional Source Type	Number of Sources
CHURCHILL	C	NV0000406	SAND CREEK	953	GROUNDWATER	WELL(S)	1		
WASHOE	NC	NV0000746	SAND HARBOR STATE PARK	1000	GROUNDWATER	WELL(S)	1		
NYE	NC	NV0001096	SANDERS WINERY	25	GROUNDWATER	WELL(S)	1		
CHURCHILL	NC	NV0000306	SANDWINDS RESTAURANT SPORTS BAR	70	GROUNDWATER	WELL(S)	1		
CLARK	NC	NV0000380	SANDY VALLEY CENTER	25	GROUNDWATER	WELL(S)	1		
CLARK	NTNC	NV0004001	SANDY VALLEY ELEMENTARY SCHOOL CCSD	230	GROUNDWATER	WELL(S)	1		
CLARK	NC	NV0000317	SANDY VALLEY LIBRARY COMM CTR	50	GROUNDWATER	WELL(S)	1		
CLARK	NC	NV0004102	SANDY VALLEY MEETINGHOUSE LDS	25	GROUNDWATER	WELL(S)	1		
MINERAL	NTNC	NV0000897	SCHURZ ELEMENTARY SCHOOL	70	GROUNDWATER	WELL(S)	1		
HUMBOLDT	NC	NV0000352	SCOTT SHADY COURT	90	GROUNDWATER	WELL(S)	3		
CLARK	NTNC	NV0002577	SCPPA APEX GENERATING STATION	25	GROUNDWATER	WELL(S)	1		
CLARK	C	NV0000219	SEARCHLIGHT WATER COMPANY	760	GROUNDWATER	WELL(S)	3		
DOUGLAS	NC	NV0000844	SEVEN ELEVEN NO 23074	734	GROUNDWATER	WELL(S)	1		
NYE	NTNC	NV0005036	SHERIS RANCH	33	GROUNDWATER	WELL(S)	2		
CLARK	C	NV0000126	SHETLAND WATER DISTRICT	38	GROUNDWATER	WELL(S)	1		
NYE	NC	NV0003074	SHORT BRANCH	25	GROUNDWATER	WELL(S)	1		
NYE	C	NV0005028	SHOSHONE ESTATES WATER CO INC	240	GROUNDWATER	WELL(S)	2		
DOUGLAS	C	NV0000931	SIERRA COUNTRY ESTATES	47	GROUNDWATER	WELL(S)	2		
DOUGLAS	C	NV0000030	SIERRA ESTATES GID	160	GROUNDWATER	WELL(S)	1	CONSECUTIVE CONNECTION(S)	1
WASHOE	NC	NV0004125	SIERRA SAFARI ZOO	35	GROUNDWATER	WELL(S)	1		
CLARK	C	NV0001116	SIGNATURE TOWERS	516	PURCHASED SURFACE WATER	CONSECUTIVE CONNECTION(S)	1		
WASHOE	C	NV0004021	SILVER KNOLLS MUTUAL WATER COMPANY	120	GROUNDWATER	WELL(S)	2		
ESMERALDA	C	NV0000363	SILVER PEAK WATER SYSTEM	138	GROUNDWATER	WELL(S)	2		
LYON	NC	NV0004100	SILVER SPRINGS MEETINGHOUSE LDS	25	GROUNDWATER	WELL(S)	1		
LYON	C	NV0000223	SILVER SPRINGS MUTUAL WATER COMPANY	3070	GROUNDWATER	WELL(S)	3		
CLARK	NTNC	NV0000342	SILVERHAWK POWER PLANT	25	GROUNDWATER	WELL(S)	1		
CHURCHILL	NC	NV0002581	SKIPS MINI MARKET	25	GROUNDWATER	WELL(S)	1		
CLARK	C	NV0004031	SKY RANCH ESTATES	110	GROUNDWATER	WELL(S)	2		
WASHOE	NC	NV0000760	SKY TAVERN	50	GROUNDWATER	SPRING(S)	1		
WASHOE	NC	NV0000761	SLIDE MOUNTAIN SKI AREA	200	GROUNDWATER	SPRING(S)	3		
CLARK	NTNC	NV0001140	SLOAN ARMY RESERVE CENTER	348	GROUNDWATER	WELL(S)	1		
LYON	NC	NV0004107	SMITH VALLEY BAPTIST CHURCH	500	GROUNDWATER	WELL(S)	1		
LYON	NTNC	NV0002189	SMITH VALLEY SCHOOLS	500	GROUNDWATER	WELL(S)	1		
CLARK	C	NV0001102	SNWA COYOTE SPRING VALLEY-MOAPA PWS	25	GROUNDWATER	WELL(S)	1		
LYON	NTNC	NV0002515	SNYDER LIVESTOCK COMPANY INC	40	GROUNDWATER	WELL(S)	1		
CHURCHILL	NC	NV0000929	SONIC BURGER	265	GROUNDWATER	WELL(S)	1		

Nevada Water Systems and Water Sources

County	Water System Type	Water System ID	Water System Name	Population Served	Primary Water Source	Primary Sources Type	Number of Sources	Additional Source Type	Number of Sources
ELKO	C	NV0000351	SOUTH CRESTVIEW HOMEOWNERS	60	GROUNDWATER	WELL(S)	3		
ELKO	NC	NV0002209	SOUTH RUBY CAMPGROUND USFS	30	GROUNDWATER	WELL(S)	1		
			SOUTHERN DESERT CORRECTIONAL CTR						
CLARK	C	NV0005062	NDOC	4842	GROUNDWATER	WELL(S)	4		
CLARK	NTNC	NV0000289	SOUTHERN NEVADA WATER SYSTEM	200	SURFACE WATER	INTAKE(S)	1		
			SOUTHFORK STATE PARK AND RECREATION						
ELKO	NC	NV0000873	AREA	25	GROUNDWATER	WELL(S)	1		
					PURCHASED	CONSECUTIVE			
CLARK	NC	NV0004108	SPEED VEGAS	200	GROUNDWATER	CONNECTION(S)	1		
CLARK	NC	NV0004071	SPENCER W KIMBALL SCOUT RESERVATION	300	GROUNDWATER	WELL(S)	2		
CLARK	C	NV0000221	SPIRIT MOUNTAIN UTILITY	375	GROUNDWATER	WELL(S)	2		
DOUGLAS	NC	NV0004041	SPOONER LAKE STATE PARK	207	GROUNDWATER	WELL(S)	1		
NYE	NTNC	NV0001093	SPRING MOUNTAIN MOTOR SPORTS RANCH	450	GROUNDWATER	WELL(S)	1		
CLARK	NC	NV0001071	SPRING MOUNTAIN RANCH STATE PARK	235	GROUNDWATER	WELL(S)	1		
CLARK	C	NV0000292	SPRING MOUNTAIN YOUTH CAMP	120	GROUNDWATER	SPRING(S)	1		
CLARK	NC	NV0003103	SPRING MOUNTAINS VISITOR GATEWAY	215	GROUNDWATER	WELL(S)	1		
LINCOLN	NC	NV0002124	SPRING VALLEY STATE PARK	386	GROUNDWATER	WELL(S)	1		
WASHOE	NTNC	NV0004061	SPRINGWOOD EQUESTRIAN CENTER	175	GROUNDWATER	WELL(S)	1		
LYON	NC	NV0002608	STAGECOACH COUNTRY MARKET	25	GROUNDWATER	WELL(S)	1		
LYON	C	NV0000224	STAGECOACH GID	1411	GROUNDWATER	WELL(S)	4		
LYON	NC	NV0004040	STAGECOACH MARKET	25	GROUNDWATER	WELL(S)	1		

Nevada Water Systems and Water Sources

County	Water System Type	Water System ID	Water System Name	Population Served	Primary Water Source	Primary Sources Type	Number of Sources	Additional Source Type	Number of Sources
NYE	NC	NV0002598	STAGESTOP RESTAURANT	25	GROUNDWATER	WELL(S)	1		
WASHOE	C	NV0000801	STAMPMILL	118	GROUNDWATER	WELL(S)	2		
HUMBOLDT	C	NV0000252	STAR CITY PROPERTIES	285	GROUNDWATER	WELL(S)	2		
PERSHING	NC	NV0002517	STAR POINT MHP RV PARK	25	GROUNDWATER	WELL(S)	1		
WASHOE	C	NV0000282	STEAMBOAT SPRINGS WATERWORKS INC	998	GROUNDWATER	WELL(S)	2		
CARSON CITY	NTNC	NV0004084	STEWART COMPLEX	300	GROUNDWATER	WELL(S)	1		
STOREY	C	NV0000240	STOREY COUNTY WATER DISTRICT	1420	SURFACE WATER	INTAKE(S)	1		
NYE	NC	NV0000829	SULLIVANS PUB	25	GROUNDWATER	WELL(S)	1		
WASHOE	C	NV0000211	SUN VALLEY GID	17000	PURCHASED SURFACE WATER	CONSECUTIVE CONNECTION(S)	2		
CLARK	C	NV0000124	SUNRISE ACRES WATER ASSOCIATION	231	GROUNDWATER	WELL(S)	2		

2018 Nevada Annual Compliance Report By Chemical

EPA Region	9	Primacy Agency Code	NV	Rule Family	IOC	Violation Category	Maximum Contaminant Level Violation
Contaminant Code		Contaminant		# of Violations		# of RTC Violations	# of PWS in Violation
1074		Antimony		4		0	1
1005		Arsenic		103		48	25
1040		Nitrate		8		2	6
		Total =		115		50	

EPA Region	9	Primacy Agency Code	NV	Rule Family	IOC	Violation Category	Monitoring and Reporting
Contaminant Code		Contaminant		# of Violations		# of RTC Violations	# of PWS in Violation
1005		Arsenic		7		3	5
CIO2		IOC Phase 2		1		1	1
CIO5		IOC Phase 5		1		1	1
CIOC		Cyanide		1		1	1
1040		Nitrate		58		37	45
1041		Nitrite		3		3	3
		Total =		71		46	

2018 Nevada Annual Compliance Report By Chemical

EPA Region	9	Primacy Agency Code	NV	Rule Family	SOC	Violation Category	Monitoring and Reporting
Contaminant Code	Contaminant	# of Violations	# of RTC Violations	# of PWS in Violation			
2931	1,2-Dibromo-3-Chloropropane	1	1	1			
2110	2,4,5-TP	2	2	1			
2105	2,4-D	2	2	1			
2050	Atrazine	1	1	1			
2306	Benzo(a)pyrene	1	1	1			
2010	BHC-Gamma	1	1	1			
2046	Carbofuran	1	1	1			
2959	Chlordane	1	1	1			
2031	Dalapon	2	2	1			
2035	DI(2-Ethylexyl) Adipate	1	1	1			
2039	DI(2-Ethylexyl) Phthalate	4	2	4			
2041	Dinoseb	2	2	2			
2032	Diquat	1	1	1			
2033	Endothall	1	1	1			
2005	Endrin	1	1	1			
2946	Ethylene Dibromide	1	1	1			
2034	Glyphosphate	1	1	1			
2065	Heptachlor	1	1	1			
2067	Heptachlor Epoxide	1	1	1			
2274	Hexachlorobenzene	1	1	1			
2042	Hexachlorocyclopentadiene	1	1	1			
2051	Lasso	1	1	1			
2015	Methoxychlor	1	1	1			
2036	Oxamyl	1	1	1			
2326	Pentachlorophenol	2	2	2			
2040	Picloram	3	3	3			
2037	Simazine	1	1	1			
CSO8	SOCS PH5 Dioxin	2	2	1			
CSOC	SOCS PHASE 2 & 5	8	5	4			
2383	Total Polychlorinated Biphenyls	1	1	1			
2020	Toxaphene	1	1	1			
		Total =	49	43			

2018 Nevada Annual Compliance Report By Chemical

EPA Region	9	Primacy Agency Code	NV	Rule Family	VOC	Violation Category	Maximum Contaminant Level Violation
Contaminant Code		Contaminant		# of Violations		# of RTC Violations	# of PWS in Violation
2987		Tetrachloroethylene		4		4	1
		Total =		4		4	

EPA Region	9	Primacy Agency Code	NV	Rule Family	VOC	Violation Category	Monitoring and Reporting
Contaminant Code		Contaminant		# of Violations		# of RTC Violations	# of PWS in Violation
2992		Ethylbenzene		1		1	1
CVOC		VOCS Phase 2 & 5		13		0	8
2955		Xylenes, Total		2		1	1
		Total =		16		2	

EPA Region	9	Primacy Agency Code	NV	Rule Family	RADS	Violation Category	Maximum Contaminant Level Violation
Contaminant Code		Contaminant		# of Violations		# of RTC Violations	# of PWS in Violation
4006		Combined Uranium		4		0	1
		Total =		4		0	

EPA Region	9	Primacy Agency Code	NV	Rule Family	RADS	Violation Category	Monitoring and Reporting
Contaminant Code		Contaminant		# of Violations		# of RTC Violations	# of PWS in Violation
CRAU		Radionuclides		2		0	1
CRUR		RADS Uranium		13		8	1
		Total =		15		8	

EPA Region	9	Primacy Agency Code	NV	Rule Family	ST1 DBP	Violation Category	Monitoring and Reporting
Contaminant Code		Contaminant		# of Violations		# of RTC Violations	# of PWS in Violation
0999		Chlorine		26		14	17
		Total =		26		14	

EPA Region	9	Primacy Agency Code	NV	Rule Family	ST2 DBP	Violation Category	Maximum Contaminant Level Violation
Contaminant Code		Contaminant		# of Violations		# of RTC Violations	# of PWS in Violation
2950		DBPR Stage 2 TTHM		6		6	2
		Total =		6		6	

2018 Nevada Annual Compliance Report By Chemical

EPA Region	9	Primacy Agency Code	NV	Rule Family	ST2 DBP	Violation Category	Monitoring and Reporting
Contaminant Code		Contaminant		# of Violations		# of RTC Violations	# of PWS in Violation
2456		DBPR Stage 2 TTHM		1		1	1
2950		DBPR Stage 2 HAA5		3		2	3
CDB2		Disinfection Byprod Stage 2		26		18	21
Total =				30		21	

EPA Region	9	Primacy Agency Code	NV	Rule Family	ST2 DBP	Violation Category	Failure to Submit OEL
Contaminant Code		Contaminant		# of Violations		# of RTC Violations	# of PWS in Violation
2456		DBPR Stage 2 TTHM		1		1	1
Total =				1		1	

EPA Region	9	Primacy Agency Code	NV	Rule Family	ST1 DBP	Violation Category	Treatment Technique
Contaminant Code		Contaminant		# of Violations		# of RTC Violations	# of PWS in Violation
2456		DBP STAGE 1		1		1	1
Total =				1		1	

EPA Region	9	Primacy Agency Code	NV	Rule Family	SWT Rule	Violation Category	Monitoring and Reporting
Contaminant Code		Contaminant		# of Violations		# of RTC Violations	# of PWS in Violation
LT2D		LT2 E. Coli		10		10	1
Total =				10		10	

EPA Region	9	Primacy Agency Code	NV	Rule Family	SWT Rule	Violation Category	Failure to Filter
Contaminant Code		Contaminant		# of Violations		# of RTC Violations	# of PWS in Violation
0200		SWTR		4		4	1
Total =				4		4	1

EPA Region	9	Primacy Agency Code	NV	Rule Family	rTCR	Violation Category	Maximum Contaminant Level Violation
Contaminant Code		Contaminant		# of Violations		# of RTC Violations	# of PWS in Violation
8000		Coliform (rTCR)		6		6	4
Total =				6		6	

2018 Nevada Annual Compliance Report By Chemical

EPA Region	9	Primacy Agency Code	NV	Rule Family	rTCR	Violation Category	Monitoring and Reporting
Contaminant Code		Contaminant		# of Violations		# of RTC Violations	# of PWS in Violation
3100		Coliform (TCR)		2		2	1
		Total =		2		2	

EPA Region	9	Primacy Agency Code	NV	Rule Family	rTCR	Violation Category	Monitoring and Reporting
Contaminant Code		Contaminant		# of Violations		# of RTC Violations	# of PWS in Violation
8000		Coliform (rTCR)		113		105	75
		Total =		113		105	

EPA Region	9	Primacy Agency Code	NV	Rule Family	rTCR	Violation Category	Treatment Technique
Contaminant Code		Contaminant		# of Violations		# of RTC Violations	# of PWS in Violation
8000		Coliform (rTCR)		19		11	12
		Total =		19		11	

EPA Region	9	Primacy Agency Code	NV	Rule Family	GWR	Violation Category	Monitoring and Reporting
Contaminant Code		Contaminant		# of Violations		# of RTC Violations	# of PWS in Violation
3014		E.Coli (GWR Assesement)		1		1	1
3014		E.Coli (GWR Triggered/Additional		7		7	6
		Total =		8		8	

EPA Region	9	Primacy Agency Code	NV	Rule Family	GWR	Violation Category	Treatment Technique
Contaminant Code		Contaminant		# of Violations		# of RTC Violations	# of PWS in Violation
0700		Groundwater Rule		51		22	34
		Total =		51		22	

EPA Region	9	Primacy Agency Code	NV	Rule Family	LCR	Violation Category	Monitoring and Reporting
Contaminant Code		Contaminant		# of Violations		# of RTC Violations	# of PWS in Violation
5000		Lead and Copper Rule		30		20	27
CWQP		Water Quality Parameters		8		8	6
		Total =		38		28	

2018 Nevada Annual Compliance Report By Chemical

EPA Region	9	Primacy Agency Code	NV	Rule Family	LCR	Violation Category	Treatment Technique
Contaminant Code		Contaminant		# of Violations		# of RTC Violations	# of PWS in Violation
5000		Lead and Copper Rule		2		0	1
		Total =		2		0	

EPA Region	9	Primacy Agency Code	NV	Rule Family	N/A	Violation Category	Other Violation
Contaminant Code		Contaminant		# of Violations		# of RTC Violations	# of PWS in Violation
7000		Consumer Confidence Rule		8		6	8
7500		Public Notice		3		0	3
		Total =		11		6	

EPA Region	9	Primacy Agency Code	NV	Rule Family	SECONDARIES	Violation Category	Maximum Contaminant Level Violation
Contaminant Code		Contaminant		# of Violations		# of RTC Violations	# of PWS in Violation
1002		Aluminum		1		0	1
1017		Chloride		2		2	1
1905		Color		1		1	1
1025		Fluoride		18		2	6
1028		Iron		15		7	12
1031		Magnesium		1		1	1
1032		Manganese		39		18	13
1920		Odor		8		2	5
1055		Sulfate		9		3	4
1930		TDS		18		8	8
		Total =		112		44	

2018 Nevada Annual Compliance Report By Chemical

EPA Region	9	Primacy Agency Code	NV	Rule Family	SECONDARIES	Violation Category	Monitoring and Reporting
Contaminant Code		Contaminant		# of Violations	# of RTC Violations	# of PWS in Violation	
1905		Color		4	4	3	
1025		Secondary IOC Fluoride		1	1	1	
1028		Iron		10	5	7	
1032		Manganese		13	9	8	
1040		Nitrate		1	0	1	
1920		Odor		3	3	3	
1925		pH		3	3	2	
CSC2		SECONDARY IOCS		4	4	4	
1055		Sulfate		1	0	1	
1930		TDS		2	1	2	
		Total =		42	30		

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0000915	A1 FUEL STOP	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	4/1/2018	6/30/2018		8/2/2018
NV0000915	A1 FUEL STOP	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	10/1/2018	12/31/2018		1/28/2019
Total Number of Violations for this Water System:										2
NV0000005	ALAMO SEWER AND WATER GID	03MJ	CIOC	IOC PH 5 CYANIDE	IOC	MONITORING, ROUTINE MAJOR	1/1/2014	12/31/2016		9/12/2018
NV0000005	ALAMO SEWER AND WATER GID	03MJ	CIO2	IOCS PHASE 2	IOC	MONITORING, ROUTINE MAJOR	1/1/2014	12/31/2016		9/12/2018
NV0000005	ALAMO SEWER AND WATER GID	03MJ	CIO5	IOCS PHASE 5	IOC	MONITORING, ROUTINE MAJOR	1/1/2014	12/31/2016		9/12/2018
NV0000005	ALAMO SEWER AND WATER GID	03MJ	CNO2	NITRITE	IOC	MONITORING, ROUTINE MAJOR	1/1/2014	12/31/2016		7/11/2018
Total Number of Violations for this Water System:										4
NV0002190	AMARGOSA ELEMENTARY SCHOOL	23MJ	3100	COLIFORM (TCR)	TCR	MONITORING (TCR), ROUTINE MAJOR	7/1/1992	9/30/1992		2/23/2018
Total Number of Violations for this Water System:										1
NV0000155	AMARGOSA VALLEY RV PARK	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2018	12/31/2018		
NV0000155	AMARGOSA VALLEY RV PARK	1A	3014	E. COLI	RTCR	MCL, E. COLI, POS E COLI (RTCR)	4/1/2018	4/30/2018		
NV0000155	AMARGOSA VALLEY RV PARK	1A	3014	E. COLI	RTCR	MCL, E. COLI, POS E COLI (RTCR)	6/1/2018	6/30/2018		
NV0000155	AMARGOSA VALLEY RV PARK	1A	3014	E. COLI	RTCR	MCL, E. COLI, POS E COLI (RTCR)	11/1/2018	11/30/2018		12/20/2018
NV0000155	AMARGOSA VALLEY RV PARK	2C	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	CORRECTIVE/EXPEDITED ACTIONS (RTCR)	8/1/2018			
NV0000155	AMARGOSA VALLEY RV PARK	2C	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	CORRECTIVE/EXPEDITED ACTIONS (RTCR)	8/1/2018			
NV0000155	AMARGOSA VALLEY RV PARK	2C	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	CORRECTIVE/EXPEDITED ACTIONS (RTCR)	11/22/2018	11/22/2018		11/22/2018

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0000155	AMARGOSA VALLEY RV PARK	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	10/1/2018	10/31/2018		11/29/2018
NV0000155	AMARGOSA VALLEY RV PARK	45	0700	GROUNDWATER RULE	GWR	FAILURE ADDRESS DEFICIENCY (GWR)	8/4/2018			
Total Number of Violations for this Water System:										9
NV0002558	AMARGOSA WATER COMPANY	71	7000	CONSUMER CONFIDENCE RULE		CCR REPORT	7/1/2018	7/5/2018		7/5/2018
Total Number of Violations for this Water System:										1
NV0005033	ANCHOR IN MHP	52	5000	LEAD & COPPER RULE	LCR	FOLLOW-UP OR ROUTINE TAP M/R (LCR)	10/1/2018			
Total Number of Violations for this Water System:										1
NV0002088	ANGEL CREEK CAMPGROUND USFS	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	5/1/2018	5/31/2018		6/4/2018
Total Number of Violations for this Water System:										1
NV0004088	ANIMAL ARK	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2017	12/31/2017		1/2/2018
NV0004088	ANIMAL ARK	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	12/1/2017	12/31/2017		1/2/2018
NV0004088	ANIMAL ARK	93	1905	COLOR	SECONDARIES	STATE FAILURE TO MONITOR	10/1/2017	12/31/2017		1/2/2018
NV0004088	ANIMAL ARK	93	1028	IRON	SECONDARIES	STATE FAILURE TO MONITOR	10/1/2017	12/31/2017		1/2/2018
NV0004088	ANIMAL ARK	93	1032	MANGANESE	SECONDARIES	STATE FAILURE TO MONITOR	12/1/2017	12/31/2017		1/2/2018
NV0004088	ANIMAL ARK	93	1920	ODOR	SECONDARIES	STATE FAILURE TO MONITOR	10/1/2017	12/31/2017		1/2/2018
NV0004088	ANIMAL ARK	93	1925	PH	SECONDARIES	STATE FAILURE TO MONITOR	10/1/2017	12/31/2017		1/2/2018
NV0004088	ANIMAL ARK	S1	1032	MANGANESE	SECONDARIES	STATE MCL EXCEDENCE	1/1/2018	3/31/2018	0.36 MG/L	
NV0004088	ANIMAL ARK	S1	1032	MANGANESE	SECONDARIES	STATE MCL EXCEDENCE	1/1/2018	3/31/2018	0.36 MG/L	1/31/2019

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0004088	ANIMAL ARK	S1	1032	MANGANESE	SECONDARIES	STATE MCL EXCEDENCE	4/1/2018	6/30/2018	0.2 MG/L	1/31/2019
Total Number of Violations for this Water System:										10
NV0004105	ANTELOPE VALLEY MEETINGHOUSE LDS	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2017	12/31/2017		2/6/2018
Total Number of Violations for this Water System:										1
NV0000379	APEX REGIONAL WASTE MGMT CENTER	45	0700	GROUNDWATER RULE	GWR	FAILURE ADDRESS DEFICIENCY (GWR)	10/30/2018			
NV0000379	APEX REGIONAL WASTE MGMT CENTER	45	0700	GROUNDWATER RULE	GWR	FAILURE ADDRESS DEFICIENCY (GWR)	10/31/2018			
NV0000379	APEX REGIONAL WASTE MGMT CENTER	45	0700	GROUNDWATER RULE	GWR	FAILURE ADDRESS DEFICIENCY (GWR)	10/30/2018			
Total Number of Violations for this Water System:										3
NV0004027	ASH MEADOWS NATIONAL WILDLIFE	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2018	12/31/2018		
NV0004027	ASH MEADOWS NATIONAL WILDLIFE	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	11/1/2018	11/30/2018		12/5/2018
Total Number of Violations for this Water System:										2
NV0000863	BAKER WATER AND SEWER GID	71	7000	CONSUMER CONFIDENCE RULE		CCR REPORT	7/1/2018	7/2/2018		7/2/2018
Total Number of Violations for this Water System:										1
NV0001097	BARRICK CORTEZ HILLS	27MJ	CDB2	DBPR STAGE 2	ST2 DBP	MONITORING, ROUTINE (DBP), MAJOR	9/1/2016	8/31/2017		8/27/2018
Total Number of Violations for this Water System:										1
NV0005038	BEATTY RV PARK	45	0700	GROUNDWATER RULE	GWR	FAILURE ADDRESS DEFICIENCY (GWR)	9/14/2018			
Total Number of Violations for this Water System:										1
NV0000009	BEATTY WATER AND SANITATION DISTRICT	02	1005	ARSENIC	IOC	MCL, AVERAGE	4/1/2017	6/30/2017	0.011 MG/L	10/8/2018

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0000009	BEATTY WATER AND SANITATION DISTRICT	02	1005	ARSENIC	IOC	MCL, AVERAGE	10/1/2017	12/31/2017	0.011 MG/L	10/8/2018
NV0000009	BEATTY WATER AND SANITATION DISTRICT	02	1005	ARSENIC	IOC	MCL, AVERAGE	1/1/2018	3/31/2018	0.011 MG/L	10/8/2018
NV0000009	BEATTY WATER AND SANITATION DISTRICT	02	1005	ARSENIC	IOC	MCL, AVERAGE	4/1/2018	6/30/2018	0.012 MG/L	10/8/2018
NV0000009	BEATTY WATER AND SANITATION DISTRICT	02	1005	ARSENIC	IOC	MCL, AVERAGE	7/1/2018	9/30/2018	0.013 MG/L	10/8/2018
NV0000009	BEATTY WATER AND SANITATION DISTRICT	S1	1025	FLUORIDE	SECONDARIES	STATE MCL EXCEDENCE	7/1/2017	9/30/2017	2.1 MG/L	8/16/2018
NV0000009	BEATTY WATER AND SANITATION DISTRICT	S1	1025	FLUORIDE	SECONDARIES	STATE MCL EXCEDENCE	10/1/2017	12/31/2017	2.6 MG/L	8/16/2018

Total Number of Violations for this Water System: 7

NV0000369	BIG VALLEY MHP	S1	1930	TDS	SECONDARIES	STATE MCL EXCEDENCE	7/1/2017	9/30/2017	1055 MG/L	1/8/2018
NV0000369	BIG VALLEY MHP	S1	1930	TDS	SECONDARIES	STATE MCL EXCEDENCE	7/1/2018	9/30/2018	1080 MG/L	

Total Number of Violations for this Water System: 2

NV0000381	BLACK ROCK STATION	34MJ	3014	E. COLI	GWR	MONITOR GWR TRIGGERED/ADDITONAL, MAJOR	7/11/2018	8/10/2018		8/10/2018
-----------	--------------------	------	------	---------	-----	--	-----------	-----------	--	-----------

Total Number of Violations for this Water System: 1

NV0000323	BLUE DIAMOND RAINBOW SW PLAZA	45	0700	GROUNDWATER RULE	GWR	FAILURE ADDRESS DEFICIENCY (GWR)	10/1/2018			
NV0000323	BLUE DIAMOND RAINBOW SW PLAZA	45	0700	GROUNDWATER RULE	GWR	FAILURE ADDRESS DEFICIENCY (GWR)	9/29/2018	9/29/2018		9/26/2018
NV0000323	BLUE DIAMOND RAINBOW SW PLAZA	S1	1055	SULFATE	SECONDARIES	STATE MCL EXCEDENCE	1/1/2018	3/31/2018	530 MG/L	
NV0000323	BLUE DIAMOND RAINBOW SW PLAZA	S1	1055	SULFATE	SECONDARIES	STATE MCL EXCEDENCE	7/1/2018	9/30/2018	520 MG/L	
NV0000323	BLUE DIAMOND RAINBOW SW PLAZA	S1	1930	TDS	SECONDARIES	STATE MCL EXCEDENCE	1/1/2018	3/31/2018	1125 MG/L	

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0000323	BLUE DIAMOND RAINBOW SW PLAZA	S1	1930	TDS	SECONDARIES	STATE MCL EXCEDENCE	4/1/2018	6/30/2018	1020 MG/L	
Total Number of Violations for this Water System:										6

NV0002090	BOONIES	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2017	12/31/2017		5/14/2018
NV0002090	BOONIES	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	7/1/2018	9/30/2018		12/5/2018
Total Number of Violations for this Water System:										2

NV0000389	BUCKBOARD GENERAL STORE	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2018	12/31/2018		
NV0000389	BUCKBOARD GENERAL STORE	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	7/1/2017	9/30/2017		4/3/2018
NV0000389	BUCKBOARD GENERAL STORE	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	10/1/2017	12/31/2017		4/3/2018
NV0000389	BUCKBOARD GENERAL STORE	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	1/1/2018	1/31/2018		4/3/2018
NV0000389	BUCKBOARD GENERAL STORE	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	2/1/2018	2/28/2018		4/3/2018
NV0000389	BUCKBOARD GENERAL STORE	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	3/1/2018	3/31/2018		4/3/2018
NV0000389	BUCKBOARD GENERAL STORE	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	5/1/2018	5/31/2018		8/28/2018
NV0000389	BUCKBOARD GENERAL STORE	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	6/1/2018	6/30/2018		8/28/2018
NV0000389	BUCKBOARD GENERAL STORE	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	7/1/2018	7/31/2018		8/28/2018
NV0000389	BUCKBOARD GENERAL STORE	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	9/1/2018	9/30/2018		4/29/2019
NV0000389	BUCKBOARD GENERAL STORE	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	10/1/2018	10/31/2018		4/29/2019
NV0000389	BUCKBOARD GENERAL STORE	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	11/1/2018	11/30/2018		4/29/2019

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0000389	BUCKBOARD GENERAL STORE	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	12/1/2018	12/31/2018		4/29/2019
NV0000389	BUCKBOARD GENERAL STORE	45	0700	GROUNDWATER RULE	GWR	FAILURE ADDRESS DEFICIENCY (GWR)	1/2/2018	4/3/2018		4/3/2018
Total Number of Violations for this Water System:										14
NV0001091	CALIFORNIA NATIONAL HISTORIC TRAILS CTR	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	8/1/2018	8/31/2018		10/30/2018
NV0001091	CALIFORNIA NATIONAL HISTORIC TRAILS CTR	3AMN	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MINOR (RTCR)	9/1/2018	9/30/2018		10/30/2018
NV0001091	CALIFORNIA NATIONAL HISTORIC TRAILS CTR	3AMN	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MINOR (RTCR)	11/1/2018	11/30/2018		12/12/2018
Total Number of Violations for this Water System:										3
NV0000405	CARBERRY SQUARE	01	1040	NITRATE	IOC	MCL, SINGLE SAMPLE	10/1/2018	12/31/2018	13 MG/L	
NV0000405	CARBERRY SQUARE	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	11/1/2018	11/30/2018		12/12/2018
Total Number of Violations for this Water System:										2
NV0000014	CARLIN UTILITIES	27MJ	2456	TOTAL HALOACETIC ACIDS (HAAS)	ST2 DBP	MONITORING, ROUTINE (DBP), MAJOR	1/1/2018	12/31/2018		
Total Number of Violations for this Water System:										1
NV0000341	CARMENS MEXICAN RESTAURANT	2C	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	CORRECTIVE/EXPEDITED ACTIONS (RTCR)	10/19/2018	12/17/2018		12/17/2018
NV0000341	CARMENS MEXICAN RESTAURANT	2C	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	CORRECTIVE/EXPEDITED ACTIONS (RTCR)	10/19/2018	12/17/2018		12/17/2018
NV0000341	CARMENS MEXICAN RESTAURANT	3BMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ADD. ROUTINE, MAJOR (RTCR)	7/1/2018	7/31/2018		8/27/2018
Total Number of Violations for this Water System:										3
NV0003068	CARSON RIVER ESTATES	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2018	12/31/2018		
NV0003068	CARSON RIVER ESTATES	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2018	12/31/2018		

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0003068	CARSON RIVER ESTATES	27MJ	0999	CHLORINE	ST1 DBP	MONITORING, ROUTINE (DBP), MAJOR	4/1/2018	6/30/2018		12/17/2018
NV0003068	CARSON RIVER ESTATES	27MJ	CDB2	DBPR STAGE 2	ST2 DBP	MONITORING, ROUTINE (DBP), MAJOR	1/1/2018	12/31/2018		
NV0003068	CARSON RIVER ESTATES	52	5000	LEAD & COPPER RULE	LCR	FOLLOW-UP OR ROUTINE TAP M/R (LCR)	10/1/2018			
Total Number of Violations for this Water System:										5
NV0004035	CAVE LAKE STATE PARK	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2018	12/31/2018		
NV0004035	CAVE LAKE STATE PARK	34MJ	3014	E. COLI	GWR	MONITOR GWR TRIGGERED/ADDITONAL, MAJOR	1/12/2018	1/16/2018		1/16/2018
Total Number of Violations for this Water System:										2
NV0000364	CERTAIN TEED GYPSUM	27MJ	CDB2	DBPR STAGE 2	ST2 DBP	MONITORING, ROUTINE (DBP), MAJOR	1/1/2017	12/31/2017		11/29/2018
NV0000364	CERTAIN TEED GYPSUM	45	0700	GROUNDWATER RULE	GWR	FAILURE ADDRESS DEFICIENCY (GWR)	9/29/2015	10/25/2018		10/25/2018
NV0000364	CERTAIN TEED GYPSUM	45	0700	GROUNDWATER RULE	GWR	FAILURE ADDRESS DEFICIENCY (GWR)	3/4/2015	10/26/2018		10/26/2018
Total Number of Violations for this Water System:										3
NV0002555	CHAMPIONS	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	10/1/2018	12/31/2018		
Total Number of Violations for this Water System:										1
NV0003060	CHERRY PATCH LOVE RANCH	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2018	12/31/2018		
Total Number of Violations for this Water System:										1
NV0001113	CIRCUS CIRCUS CASINO	53	1996	TEMPERATURE (CENTIGRADE)	LCR	WATER QUALITY PARAMETER M/R (LCR)	7/1/2017	12/31/2017		6/18/2018
Total Number of Violations for this Water System:										1
NV0002570	CORTEZ MILL 1 POTABLE WATER	02	1005	ARSENIC	IOC	MCL, AVERAGE	4/1/2018	6/30/2018	0.014 MG/L	3/4/2019

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0002570	CORTEZ MILL 1 POTABLE WATER	02	1005	ARSENIC	IOC	MCL, AVERAGE	7/1/2018	9/30/2018	0.012 MG/L	3/4/2019
NV0002570	CORTEZ MILL 1 POTABLE WATER	02	1005	ARSENIC	IOC	MCL, AVERAGE	10/1/2018	12/31/2018	0.012 MG/L	3/4/2019
Total Number of Violations for this Water System:										3
NV0000017	COTTONWOOD MHP	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	9/1/2018	9/30/2018		10/23/2018
Total Number of Violations for this Water System:										1
NV0000385	COYOTE CORNER III	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	2/1/2018	2/28/2018		4/30/2018
NV0000385	COYOTE CORNER III	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	3/1/2018	3/31/2018		4/30/2018
NV0000385	COYOTE CORNER III	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	5/1/2018	5/31/2018		6/19/2018
NV0000385	COYOTE CORNER III	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	10/1/2018	10/31/2018		12/18/2018
NV0000385	COYOTE CORNER III	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	11/1/2018	11/30/2018		12/18/2018
NV0000385	COYOTE CORNER III	93	1055	SULFATE	SECONDARIES	STATE FAILURE TO MONITOR	10/1/2018	12/31/2018		
NV0000385	COYOTE CORNER III	93	1930	TDS	SECONDARIES	STATE FAILURE TO MONITOR	10/1/2018	12/31/2018		
Total Number of Violations for this Water System:										7
NV0002565	COYOTE CORNER MARKET	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	10/1/2018	12/31/2018		3/28/2019
Total Number of Violations for this Water System:										1
NV0001081	CREECH AIR FORCE BASE	52	5000	LEAD & COPPER RULE	LCR	FOLLOW-UP OR ROUTINE TAP M/R (LCR)	10/1/2017	7/3/2018		7/3/2018
Total Number of Violations for this Water System:										1
NV0000418	CRESCENT DUNES SOLAR ENERGY	02	1005	ARSENIC	IOC	MCL, AVERAGE	1/1/2018	3/31/2018	0.011 MG/L	12/17/2018

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0000418	CRESCENT DUNES SOLAR ENERGY	02	1005	ARSENIC	IOC	MCL, AVERAGE	4/1/2018	6/30/2018	0.011 MG/L	12/17/2018
NV0000418	CRESCENT DUNES SOLAR ENERGY	02	1005	ARSENIC	IOC	MCL, AVERAGE	7/1/2018	9/30/2018	0.011 MG/L	12/17/2018
NV0000418	CRESCENT DUNES SOLAR ENERGY	03MJ	2110	2,4,5-TP	SOC	MONITORING, ROUTINE MAJOR	4/1/2017	6/30/2017		6/26/2018
NV0000418	CRESCENT DUNES SOLAR ENERGY	03MJ	2105	2,4-D	SOC	MONITORING, ROUTINE MAJOR	4/1/2017	6/30/2017		6/26/2018
NV0000418	CRESCENT DUNES SOLAR ENERGY	03MJ	2031	DALAPON	SOC	MONITORING, ROUTINE MAJOR	4/1/2017	6/30/2017		6/26/2018
NV0000418	CRESCENT DUNES SOLAR ENERGY	03MJ	2041	DINOSEB	SOC	MONITORING, ROUTINE MAJOR	4/1/2017	6/30/2017		6/26/2018
NV0000418	CRESCENT DUNES SOLAR ENERGY	03MJ	2326	PENTACHLOROPHENOL	SOC	MONITORING, ROUTINE MAJOR	4/1/2017	6/30/2017		6/26/2018
NV0000418	CRESCENT DUNES SOLAR ENERGY	03MJ	2040	PICLORAM	SOC	MONITORING, ROUTINE MAJOR	4/1/2017	6/30/2017		6/26/2018

Total Number of Violations for this Water System: 9

NV0000043	CRESCENT VALLEY WATER SYSTEM	27MJ	CDB2	DBPR STAGE 2	ST2 DBP	MONITORING, ROUTINE (DBP), MAJOR	1/1/2016	12/31/2018		
-----------	------------------------------	------	------	--------------	---------	----------------------------------	----------	------------	--	--

Total Number of Violations for this Water System: 1

NV0000718	CRYSTAL PEAK PARK	S1	1028	IRON	SECONDARIES	STATE MCL EXCEDENCE	4/1/2018	6/30/2018	0.7 MG/L	
NV0000718	CRYSTAL PEAK PARK	S1	1032	MANGANESE	SECONDARIES	STATE MCL EXCEDENCE	10/1/2018	12/31/2018	0.2 MG/L	
NV0000718	CRYSTAL PEAK PARK	S1	1920	ODOR	SECONDARIES	STATE MCL EXCEDENCE	4/1/2018	6/30/2018	8 TON	
NV0000718	CRYSTAL PEAK PARK	S1	1920	ODOR	SECONDARIES	STATE MCL EXCEDENCE	7/1/2018	9/30/2018	50 TON	

Total Number of Violations for this Water System: 4

NV0000193	CRYSTAL TP	02	1005	ARSENIC	IOC	MCL, AVERAGE	1/1/2018	3/31/2018	0.057 MG/L	
-----------	------------	----	------	---------	-----	--------------	----------	-----------	------------	--

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0000193	CRYSTAL TP	02	1005	ARSENIC	IOC	MCL, AVERAGE	1/1/2018	3/31/2018	0.051 MG/L	
NV0000193	CRYSTAL TP	02	1005	ARSENIC	IOC	MCL, AVERAGE	4/1/2018	6/30/2018	0.050 MG/L	
NV0000193	CRYSTAL TP	02	1005	ARSENIC	IOC	MCL, AVERAGE	4/1/2018	6/30/2018	0.057 MG/L	
NV0000193	CRYSTAL TP	02	1005	ARSENIC	IOC	MCL, AVERAGE	4/1/2018	6/30/2018	0.051 MG/L	
NV0000193	CRYSTAL TP	02	1005	ARSENIC	IOC	MCL, AVERAGE	7/1/2018	9/30/2018	0.057 MG/L	
NV0000193	CRYSTAL TP	02	1005	ARSENIC	IOC	MCL, AVERAGE	7/1/2018	9/30/2018	0.025 MG/L	
NV0000193	CRYSTAL TP	02	1005	ARSENIC	IOC	MCL, AVERAGE	7/1/2018	9/30/2018	0.051 MG/L	
NV0000193	CRYSTAL TP	02	1005	ARSENIC	IOC	MCL, AVERAGE	10/1/2018	12/31/2018	0.029 MG/L	
NV0000193	CRYSTAL TP	02	1005	ARSENIC	IOC	MCL, AVERAGE	10/1/2018	12/31/2018	0.019 MG/L	5/1/2019
NV0000193	CRYSTAL TP	02	1005	ARSENIC	IOC	MCL, AVERAGE	10/1/2018	12/31/2018	0.017 MG/L	
NV0000193	CRYSTAL TP	02	1005	ARSENIC	IOC	MCL, AVERAGE	10/1/2018	12/31/2018	0.051 MG/L	
NV0000193	CRYSTAL TP	45	0700	GROUNDWATER RULE	GWR	FAILURE ADDRESS DEFICIENCY (GWR)	12/23/2017	7/5/2018		7/5/2018
Total Number of Violations for this Water System:										13
NV0000719	DAVIS CREEK PARK	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	5/1/2018	5/31/2018		6/11/2018
Total Number of Violations for this Water System:										1
NV0001078	DEER CREEK SPRING	23MJ	3100	COLIFORM (TCR)	TCR	MONITORING (TCR), ROUTINE MAJOR	4/1/2006	6/30/2006		
NV0001078	DEER CREEK SPRING	93	CSC2	SECONDARY IOCS	SECONDARIES	STATE FAILURE TO MONITOR	1/1/2011	12/31/2013		3/14/2018
Total Number of Violations for this Water System:										2

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0001156	DENTON RAWHIDE MINE	02	1005	ARSENIC	IOC	MCL, AVERAGE	1/1/2018	3/31/2018	0.069 MG/L	
NV0001156	DENTON RAWHIDE MINE	02	1005	ARSENIC	IOC	MCL, AVERAGE	1/1/2018	3/31/2018	0.083 MG/L	
NV0001156	DENTON RAWHIDE MINE	02	1005	ARSENIC	IOC	MCL, AVERAGE	4/1/2018	6/30/2018	0.083 MG/L	
NV0001156	DENTON RAWHIDE MINE	02	1005	ARSENIC	IOC	MCL, AVERAGE	7/1/2018	9/30/2018	0.083 MG/L	
NV0001156	DENTON RAWHIDE MINE	02	1005	ARSENIC	IOC	MCL, AVERAGE	10/1/2018	12/31/2018	0.083 MG/L	
NV0001156	DENTON RAWHIDE MINE	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2017	12/31/2017		1/22/2018
NV0001156	DENTON RAWHIDE MINE	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2017	12/31/2017		1/22/2018
NV0001156	DENTON RAWHIDE MINE	03MJ	CSO8	SOCS PH5 DIOXIN	SOC	MONITORING, ROUTINE MAJOR	4/1/2017	6/30/2017		1/22/2018
NV0001156	DENTON RAWHIDE MINE	03MJ	CSO8	SOCS PH5 DIOXIN	SOC	MONITORING, ROUTINE MAJOR	4/1/2017	6/30/2017		1/22/2018
NV0001156	DENTON RAWHIDE MINE	03MJ	CSOC	SOCS PHASE 2 & 5	SOC	MONITORING, ROUTINE MAJOR	4/1/2017	6/30/2017		1/22/2018
NV0001156	DENTON RAWHIDE MINE	03MJ	CSOC	SOCS PHASE 2 & 5	SOC	MONITORING, ROUTINE MAJOR	4/1/2017	6/30/2017		1/22/2018
NV0001156	DENTON RAWHIDE MINE	03MJ	CSOC	SOCS PHASE 2 & 5	SOC	MONITORING, ROUTINE MAJOR	10/1/2017	12/31/2017		1/22/2018
NV0001156	DENTON RAWHIDE MINE	03MJ	CSOC	SOCS PHASE 2 & 5	SOC	MONITORING, ROUTINE MAJOR	10/1/2017	12/31/2017		1/22/2018
NV0001156	DENTON RAWHIDE MINE	03MJ	CVOC	VOCS PHASE 2 & 5	VOC	MONITORING, ROUTINE MAJOR	4/1/2017	6/30/2017		6/5/2018
NV0001156	DENTON RAWHIDE MINE	03MJ	CVOC	VOCS PHASE 2 & 5	VOC	MONITORING, ROUTINE MAJOR	4/1/2017	6/30/2017		6/5/2018
NV0001156	DENTON RAWHIDE MINE	03MJ	CVOC	VOCS PHASE 2 & 5	VOC	MONITORING, ROUTINE MAJOR	10/1/2017	12/31/2017		6/5/2018
NV0001156	DENTON RAWHIDE MINE	03MJ	CVOC	VOCS PHASE 2 & 5	VOC	MONITORING, ROUTINE MAJOR	10/1/2017	12/31/2017		6/5/2018

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0001156	DENTON RAWHIDE MINE	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	10/1/2017	12/31/2017		3/27/2018
NV0001156	DENTON RAWHIDE MINE	51	5000	LEAD & COPPER RULE	LCR	INITIAL TAP SAMPLING (LCR)	1/1/2018	6/5/2018		6/5/2018
NV0001156	DENTON RAWHIDE MINE	51	5000	LEAD & COPPER RULE	LCR	INITIAL TAP SAMPLING (LCR)	7/1/2017	6/5/2018		6/5/2018
NV0001156	DENTON RAWHIDE MINE	S1	1025	FLUORIDE	SECONDARIES	STATE MCL EXCEEDENCE	1/1/2018	3/31/2018	3.1 MG/L	
NV0001156	DENTON RAWHIDE MINE	S1	1025	FLUORIDE	SECONDARIES	STATE MCL EXCEEDENCE	4/1/2018	6/30/2018	3.1 MG/L	
NV0001156	DENTON RAWHIDE MINE	S1	1025	FLUORIDE	SECONDARIES	STATE MCL EXCEEDENCE	7/1/2018	9/30/2018	3.1 MG/L	
NV0001156	DENTON RAWHIDE MINE	S1	1025	FLUORIDE	SECONDARIES	STATE MCL EXCEEDENCE	10/1/2018	12/31/2018	3.1 MG/L	

Total Number of Violations for this Water System: 24

NV0002196	DESERT CENTER PLAZA	45	0700	GROUNDWATER RULE	GWR	FAILURE ADDRESS DEFICIENCY (GWR)	7/16/2018	12/18/2018		12/18/2018
-----------	---------------------	----	------	------------------	-----	----------------------------------	-----------	------------	--	------------

Total Number of Violations for this Water System: 1

NV0000736	DESERT INVESTMENT GROUP LTD	01	1040	NITRATE	IOC	MCL, SINGLE SAMPLE	10/1/2018	12/31/2018	11 MG/L	
-----------	-----------------------------	----	------	---------	-----	--------------------	-----------	------------	---------	--

Total Number of Violations for this Water System: 1

NV0000149	DESERT PARADISE MHP	02	1005	ARSENIC	IOC	MCL, AVERAGE	1/1/2018	3/31/2018	0.015 MG/L	
NV0000149	DESERT PARADISE MHP	02	1005	ARSENIC	IOC	MCL, AVERAGE	4/1/2018	6/30/2018	0.016 MG/L	
NV0000149	DESERT PARADISE MHP	02	1005	ARSENIC	IOC	MCL, AVERAGE	7/1/2018	9/30/2018	0.016 MG/L	
NV0000149	DESERT PARADISE MHP	02	1005	ARSENIC	IOC	MCL, AVERAGE	10/1/2018	12/31/2018	0.015 MG/L	
NV0000149	DESERT PARADISE MHP	45	0700	GROUNDWATER RULE	GWR	FAILURE ADDRESS DEFICIENCY (GWR)	10/8/2018			

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0000149	DESERT PARADISE MHP	45	0700	GROUNDWATER RULE	GWR	FAILURE ADDRESS DEFICIENCY (GWR)	10/8/2018			
NV0000149	DESERT PARADISE MHP	45	0700	GROUNDWATER RULE	GWR	FAILURE ADDRESS DEFICIENCY (GWR)	10/8/2018			
NV0000149	DESERT PARADISE MHP	45	0700	GROUNDWATER RULE	GWR	FAILURE ADDRESS DEFICIENCY (GWR)	10/8/2018			
NV0000149	DESERT PARADISE MHP	45	0700	GROUNDWATER RULE	GWR	FAILURE ADDRESS DEFICIENCY (GWR)	10/8/2018			
NV0000149	DESERT PARADISE MHP	45	0700	GROUNDWATER RULE	GWR	FAILURE ADDRESS DEFICIENCY (GWR)	10/8/2018			
NV0000149	DESERT PARADISE MHP	45	0700	GROUNDWATER RULE	GWR	FAILURE ADDRESS DEFICIENCY (GWR)	10/8/2018			

Total Number of Violations for this Water System: 11

NV0001148	DIAMOND PLASTICS	02	1074	ANTIMONY, TOTAL	IOC	MCL, AVERAGE	1/1/2018	3/31/2018	0.010 MG/L	
NV0001148	DIAMOND PLASTICS	02	1074	ANTIMONY, TOTAL	IOC	MCL, AVERAGE	4/1/2018	6/30/2018	0.009 MG/L	
NV0001148	DIAMOND PLASTICS	02	1074	ANTIMONY, TOTAL	IOC	MCL, AVERAGE	7/1/2018	9/30/2018	0.008 MG/L	
NV0001148	DIAMOND PLASTICS	02	1074	ANTIMONY, TOTAL	IOC	MCL, AVERAGE	10/1/2018	12/31/2018	0.007 MG/L	
NV0001148	DIAMOND PLASTICS	02	1005	ARSENIC	IOC	MCL, AVERAGE	1/1/2018	3/31/2018	0.025 MG/L	
NV0001148	DIAMOND PLASTICS	02	1005	ARSENIC	IOC	MCL, AVERAGE	4/1/2018	6/30/2018	0.024 MG/L	
NV0001148	DIAMOND PLASTICS	02	1005	ARSENIC	IOC	MCL, AVERAGE	7/1/2018	9/30/2018	0.023 MG/L	
NV0001148	DIAMOND PLASTICS	02	1005	ARSENIC	IOC	MCL, AVERAGE	10/1/2018	12/31/2018	0.020 MG/L	
NV0001148	DIAMOND PLASTICS	03MJ	CVOC	VOCS PHASE 2 & 5	VOC	MONITORING, ROUTINE MAJOR	1/1/2018	12/31/2018		
NV0001148	DIAMOND PLASTICS	51	5000	LEAD & COPPER RULE	LCR	INITIAL TAP SAMPLING (LCR)	7/1/2017	5/24/2018		5/24/2018

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0001148	DIAMOND PLASTICS	S1	1025	FLUORIDE	SECONDARIES	STATE MCL EXCEDENCE	1/1/2018	3/31/2018	2.6 MG/L	
NV0001148	DIAMOND PLASTICS	S1	1025	FLUORIDE	SECONDARIES	STATE MCL EXCEDENCE	4/1/2018	6/30/2018	2.6 MG/L	
NV0001148	DIAMOND PLASTICS	S1	1025	FLUORIDE	SECONDARIES	STATE MCL EXCEDENCE	7/1/2018	9/30/2018	2.3 MG/L	
NV0001148	DIAMOND PLASTICS	S1	1032	MANGANESE	SECONDARIES	STATE MCL EXCEDENCE	1/1/2018	3/31/2018	0.43 MG/L	
NV0001148	DIAMOND PLASTICS	S1	1032	MANGANESE	SECONDARIES	STATE MCL EXCEDENCE	4/1/2018	6/30/2018	1.2 MG/L	
NV0001148	DIAMOND PLASTICS	S1	1032	MANGANESE	SECONDARIES	STATE MCL EXCEDENCE	7/1/2018	9/30/2018	1.0 MG/L	

Total Number of Violations for this Water System: 16

NV0000949	DOVETAIL RANCH	93	1028	IRON	SECONDARIES	STATE FAILURE TO MONITOR	1/1/2016	12/31/2016		3/20/2018
NV0000949	DOVETAIL RANCH	93	1028	IRON	SECONDARIES	STATE FAILURE TO MONITOR	11/1/2017	11/30/2017		3/20/2018
NV0000949	DOVETAIL RANCH	93	1032	MANGANESE	SECONDARIES	STATE FAILURE TO MONITOR	1/1/2016	12/31/2016		3/20/2018
NV0000949	DOVETAIL RANCH	93	1032	MANGANESE	SECONDARIES	STATE FAILURE TO MONITOR	10/1/2017	10/31/2017		3/20/2018
NV0000949	DOVETAIL RANCH	93	1032	MANGANESE	SECONDARIES	STATE FAILURE TO MONITOR	11/1/2017	11/30/2017		3/20/2018
NV0000949	DOVETAIL RANCH	93	1032	MANGANESE	SECONDARIES	STATE FAILURE TO MONITOR	12/1/2017	12/31/2017		3/20/2018
NV0000949	DOVETAIL RANCH	S1	1028	IRON	SECONDARIES	STATE MCL EXCEDENCE	4/1/2018	6/30/2018	0.73 MG/L	2/1/2019
NV0000949	DOVETAIL RANCH	S1	1032	MANGANESE	SECONDARIES	STATE MCL EXCEDENCE	4/1/2018	6/30/2018	0.39 MG/L	2/1/2019

Total Number of Violations for this Water System: 8

NV0000809	DUTCHMAN ACRES	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2017	12/31/2017		7/13/2018
-----------	----------------	------	------	---------	-----	---------------------------	----------	------------	--	-----------

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0000809	DUTCHMAN ACRES	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2017	12/31/2017		7/16/2018
NV0000809	DUTCHMAN ACRES	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	12/1/2017	12/31/2017		1/18/2018
NV0000809	DUTCHMAN ACRES	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	4/1/2018	4/30/2018		5/30/2018
NV0000809	DUTCHMAN ACRES	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	6/1/2018	6/30/2018		7/16/2018
NV0000809	DUTCHMAN ACRES	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	9/1/2018	9/30/2018		11/29/2018
NV0000809	DUTCHMAN ACRES	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	10/1/2018	10/31/2018		11/29/2018
NV0000809	DUTCHMAN ACRES	45	0700	GROUNDWATER RULE	GWR	FAILURE ADDRESS DEFICIENCY (GWR)	11/2/2018	3/21/2019		3/21/2019
NV0000809	DUTCHMAN ACRES	71	7000	CONSUMER CONFIDENCE RULE		CCR REPORT	7/1/2018			

Total Number of Violations for this Water System: 9

NV0000188	EAGLE VALLEY RESORT	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	10/1/2018	12/31/2018		1/29/2019
-----------	---------------------	------	------	------------------------------------	------	-----------------------------------	-----------	------------	--	-----------

Total Number of Violations for this Water System: 1

NV0003098	EAST 50 BAR	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2018	12/31/2018		
NV0003098	EAST 50 BAR	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	1/1/2018	3/31/2018		4/26/2018
NV0003098	EAST 50 BAR	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	10/1/2018	12/31/2018		2/11/2019

Total Number of Violations for this Water System: 3

NV0001105	EL VALLE RESTAURANT	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	7/1/2018	9/30/2018		10/3/2018
NV0001105	EL VALLE RESTAURANT	93	CSC2	SECONDARY IOCS	SECONDARIES	STATE FAILURE TO MONITOR	1/1/2014	12/31/2016		3/28/2018

Total Number of Violations for this Water System: 2

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0000271	ELK POINT COUNTRY CLUB	27MJ	0999	CHLORINE	ST1 DBP	MONITORING, ROUTINE (DBP), MAJOR	4/1/2018	6/30/2018		
NV0000271	ELK POINT COUNTRY CLUB	27MJ	0999	CHLORINE	ST1 DBP	MONITORING, ROUTINE (DBP), MAJOR	4/1/2018	6/30/2018		
NV0000271	ELK POINT COUNTRY CLUB	27MJ	0999	CHLORINE	ST1 DBP	MONITORING, ROUTINE (DBP), MAJOR	4/1/2018	6/30/2018		
NV0000271	ELK POINT COUNTRY CLUB	27MJ	0999	CHLORINE	ST1 DBP	MONITORING, ROUTINE (DBP), MAJOR	7/1/2018	9/30/2018		
NV0000271	ELK POINT COUNTRY CLUB	27MJ	2456	TOTAL HALOACETIC ACIDS (HAA5)	ST2 DBP	MONITORING, ROUTINE (DBP), MAJOR	8/1/2016	7/31/2017		11/19/2018
Total Number of Violations for this Water System:										5
NV0000272	ELKO CITY OF	27MJ	CDB2	DBPR STAGE 2	ST2 DBP	MONITORING, ROUTINE (DBP), MAJOR	1/1/2017	12/31/2017		2/6/2018
Total Number of Violations for this Water System:										1
NV0005071	ELY MAXIMUM SECURITY PRISON	S1	1028	IRON	SECONDARIES	STATE MCL EXCEDENCE	4/1/2018	6/30/2018	0.67 MG/L	
Total Number of Violations for this Water System:										1
NV0000038	ELY MUNICIPAL WATER DEPARTMENT	03MJ	2039	DI(2-ETHYLHEXYL) PHTHALATE	SOC	MONITORING, ROUTINE MAJOR	1/1/2017	3/31/2017		3/28/2018
NV0000038	ELY MUNICIPAL WATER DEPARTMENT	03MJ	2040	PICLORAM	SOC	MONITORING, ROUTINE MAJOR	1/1/2017	3/31/2017		3/28/2018
NV0000038	ELY MUNICIPAL WATER DEPARTMENT	27MJ	CHA2	DBPR STAGE 2 HAA5	ST2 DBP	MONITORING, ROUTINE (DBP), MAJOR	1/1/2017	12/31/2017		7/19/2018
NV0000038	ELY MUNICIPAL WATER DEPARTMENT	27MJ	CTT2	DBPR STAGE 2 TTHM	ST2 DBP	MONITORING, ROUTINE (DBP), MAJOR	1/1/2017	12/31/2017		10/11/2018
Total Number of Violations for this Water System:										4
NV0000042	EMPIRE MINING COMPANY	27MJ	CDB2	DBPR STAGE 2	ST2 DBP	MONITORING, ROUTINE (DBP), MAJOR	1/1/2018	9/30/2018		
NV0000042	EMPIRE MINING COMPANY	52	5000	LEAD & COPPER RULE	LCR	FOLLOW-UP OR ROUTINE TAP M/R (LCR)	10/1/2017	9/20/2018		9/20/2018
Total Number of Violations for this Water System:										2

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0003075	EP MINERALS LLC CLARK	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2018	12/31/2018		
Total Number of Violations for this Water System:										1

NV0004120	EP MINERALS LLC FERNLEY	02	1005	ARSENIC	IOC	MCL, AVERAGE	1/1/2018	3/31/2018	0.123 MG/L	1/24/2019
NV0004120	EP MINERALS LLC FERNLEY	02	1005	ARSENIC	IOC	MCL, AVERAGE	4/1/2018	6/30/2018	0.118 MG/L	1/24/2019
NV0004120	EP MINERALS LLC FERNLEY	02	1005	ARSENIC	IOC	MCL, AVERAGE	7/1/2018	9/30/2018	0.118 MG/L	1/24/2019
NV0004120	EP MINERALS LLC FERNLEY	02	1005	ARSENIC	IOC	MCL, AVERAGE	10/1/2018	12/31/2018	0.094 MG/L	
NV0004120	EP MINERALS LLC FERNLEY	S1	1017	CHLORIDE	SECONDARIES	STATE MCL EXCEDENCE	1/1/2018	3/31/2018	640 MG/L	1/24/2019
NV0004120	EP MINERALS LLC FERNLEY	S1	1017	CHLORIDE	SECONDARIES	STATE MCL EXCEDENCE	4/1/2018	6/30/2018	570 MG/L	1/24/2019
NV0004120	EP MINERALS LLC FERNLEY	S1	1930	TDS	SECONDARIES	STATE MCL EXCEDENCE	1/1/2018	3/31/2018	1600 MG/L	1/24/2019
NV0004120	EP MINERALS LLC FERNLEY	S1	1930	TDS	SECONDARIES	STATE MCL EXCEDENCE	4/1/2018	6/30/2018	1700 MG/L	1/24/2019
Total Number of Violations for this Water System:										8

NV0000045	FALLON CITY OF	27MJ	CDB2	DBPR STAGE 2	ST2 DBP	MONITORING, ROUTINE (DBP), MAJOR	10/1/2016	9/30/2017		7/12/2018
Total Number of Violations for this Water System:										1

NV0002594	FALLON LIVESTOCK LLC	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2017	12/31/2017		4/6/2018
NV0002594	FALLON LIVESTOCK LLC	93	1032	MANGANESE	SECONDARIES	STATE FAILURE TO MONITOR	12/1/2017	12/31/2017		1/26/2018
NV0002594	FALLON LIVESTOCK LLC	93	1032	MANGANESE	SECONDARIES	STATE FAILURE TO MONITOR	9/1/2018	9/30/2018		2/8/2019
NV0002594	FALLON LIVESTOCK LLC	S1	1032	MANGANESE	SECONDARIES	STATE MCL EXCEDENCE	7/1/2017	9/30/2017	0.25 MG/L	5/29/2018

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0002594	FALLON LIVESTOCK LLC	S1	1032	MANGANESE	SECONDARIES	STATE MCL EXCEDENCE	7/1/2018	9/30/2018	0.16 MG/L	
NV0002594	FALLON LIVESTOCK LLC	S1	1032	MANGANESE	SECONDARIES	STATE MCL EXCEDENCE	10/1/2018	12/31/2018	0.16 MG/L	
Total Number of Violations for this Water System:										6
NV0000350	FALLON NAVAL AIR STATION	27MJ	0999	CHLORINE	ST1 DBP	MONITORING, ROUTINE (DBP), MAJOR	10/1/2018	12/31/2018		
NV0000350	FALLON NAVAL AIR STATION	3AMN	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MINOR (RTCR)	12/1/2018	12/31/2018		1/23/2019
Total Number of Violations for this Water System:										2
NV0001142	FIORE GOLD PAN MINE	03MJ	CSOC	SOCS PHASE 2 & 5	SOC	MONITORING, ROUTINE MAJOR	1/1/2017	3/31/2017		3/7/2018
NV0001142	FIORE GOLD PAN MINE	03MJ	CVOC	VOCS PHASE 2 & 5	VOC	MONITORING, ROUTINE MAJOR	1/1/2017	3/31/2017		3/7/2018
Total Number of Violations for this Water System:										2
NV0001100	FIRE CREEK MINE	27MJ	0999	CHLORINE	ST1 DBP	MONITORING, ROUTINE (DBP), MAJOR	4/1/2018	6/30/2018		
NV0001100	FIRE CREEK MINE	3BMJ	3014	E. COLI	RTCR	MONITORING, ADD. ROUTINE, MAJOR (RTCR)	4/1/2018	4/30/2018		5/10/2018
NV0001100	FIRE CREEK MINE	S1	1920	ODOR	SECONDARIES	STATE MCL EXCEDENCE	4/1/2018	6/30/2018	17 TON	
NV0001100	FIRE CREEK MINE	S1	1920	ODOR	SECONDARIES	STATE MCL EXCEDENCE	10/1/2018	12/31/2018	6 TON	
Total Number of Violations for this Water System:										4
NV0001053	FLOYD LAMB PARK	27MJ	0999	CHLORINE	ST1 DBP	MONITORING, ROUTINE (DBP), MAJOR	4/1/2018	6/30/2018		
NV0001053	FLOYD LAMB PARK	3AMJ	3014	E. COLI	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	5/1/2018	5/31/2018		5/31/2019
Total Number of Violations for this Water System:										2
NV0000200	FOOTHILL TRAILER PARK	52	5000	LEAD & COPPER RULE	LCR	FOLLOW-UP OR ROUTINE TAP M/R (LCR)	1/1/2015	12/31/2017		6/7/2018

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
Total Number of Violations for this Water System:										1
NV0002132	FORT CHURCHILL HISTORIC STATE PARK	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	11/1/2018	11/30/2018		12/3/2018
Total Number of Violations for this Water System:										1
NV0000893	FRANKTOWN MEADOWS	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2018	12/31/2018		
NV0000893	FRANKTOWN MEADOWS	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2018	12/31/2018		
NV0000893	FRANKTOWN MEADOWS	93	1028	IRON	SECONDARIES	STATE FAILURE TO MONITOR	10/1/2018	12/31/2018		
Total Number of Violations for this Water System:										3
NV0000066	GARDNERVILLE RANCHOS GID	03MJ	2039	DI(2-ETHYLHEXYL) PHTHALATE	SOC	MONITORING, ROUTINE MAJOR	1/1/2018	12/31/2018		
Total Number of Violations for this Water System:										1
NV0000327	GAYE HAVEN CARE HOME	01	1040	NITRATE	IOC	MCL, SINGLE SAMPLE	1/1/2018	3/31/2018	13 MG/L	
NV0000327	GAYE HAVEN CARE HOME	01	1040	NITRATE	IOC	MCL, SINGLE SAMPLE	4/1/2018	6/30/2018	12 MG/L	
Total Number of Violations for this Water System:										2
NV0000071	GERLACH GID	27MJ	0999	CHLORINE	ST1 DBP	MONITORING, ROUTINE (DBP), MAJOR	4/1/2018	6/30/2018		6/19/2018
NV0000071	GERLACH GID	27MJ	CDB2	DBPR STAGE 2	ST2 DBP	MONITORING, ROUTINE (DBP), MAJOR	1/1/2018	12/31/2018		
Total Number of Violations for this Water System:										2
NV0003029	GIRL SCOUTS NV CAMP FOXTAIL	03MN	1040	NITRATE	IOC	MONITORING, ROUTINE MINOR	1/1/2017	12/31/2017		1/11/2018
Total Number of Violations for this Water System:										1
NV0000356	GLENBROOK HOMEOWNERS	93	1905	COLOR	SECONDARIES	STATE FAILURE TO MONITOR	1/1/2012	12/31/2012		6/5/2018

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0000356	GLENBROOK HOMEOWNERS	93	1920	ODOR	SECONDARIES	STATE FAILURE TO MONITOR	1/1/2012	12/31/2012		6/5/2018
Total Number of Violations for this Water System:										2
NV0000881	GOLD CANYON CAFE	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2017	12/31/2017		3/28/2018
NV0000881	GOLD CANYON CAFE	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	4/1/2018	6/30/2018		7/26/2018
Total Number of Violations for this Water System:										2
NV0001124	GOLD DIGGERS SALOON & GRUBB	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	4/1/2018	6/30/2018		8/7/2018
Total Number of Violations for this Water System:										1
NV0004064	GOLDEN VALLEY PARK	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	7/1/2017	9/30/2017		2/21/2018
Total Number of Violations for this Water System:										1
NV0000072	GOLDFIELD TOWN WATER	02	1005	ARSENIC	IOC	MCL, AVERAGE	10/1/2018	12/31/2018	0.013 MG/L	
Total Number of Violations for this Water System:										1
NV0001045	GOODSPRINGS SCHOOL CCSD	27MJ	CDB2	DBPR STAGE 2	ST2 DBP	MONITORING, ROUTINE (DBP), MAJOR	1/1/2014	9/30/2016		9/5/2018
Total Number of Violations for this Water System:										1
NV0002202	GRANITE CONSTRUCTION	02	1005	ARSENIC	IOC	MCL, AVERAGE	4/1/2017	6/30/2017	0.014 MG/L	4/9/2018
NV0002202	GRANITE CONSTRUCTION	02	1005	ARSENIC	IOC	MCL, AVERAGE	7/1/2017	9/30/2017	0.013 MG/L	4/9/2018
NV0002202	GRANITE CONSTRUCTION	02	1005	ARSENIC	IOC	MCL, AVERAGE	10/1/2017	12/31/2017	0.014 MG/L	4/9/2018
NV0002202	GRANITE CONSTRUCTION	02	1005	ARSENIC	IOC	MCL, AVERAGE	1/1/2018	3/31/2018	0.014 MG/L	4/9/2018
NV0002202	GRANITE CONSTRUCTION	52	5000	LEAD & COPPER RULE	LCR	FOLLOW-UP OR ROUTINE TAP M/R (LCR)	10/1/2018			4/9/2018

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0002202	GRANITE CONSTRUCTION	93	1925	PH	SECONDARIES	STATE FAILURE TO MONITOR	7/1/2017	9/30/2017		3/28/2018
NV0002202	GRANITE CONSTRUCTION	93	1925	PH	SECONDARIES	STATE FAILURE TO MONITOR	10/1/2017	12/31/2017		3/28/2018
Total Number of Violations for this Water System:										7
NV0004117	GREYSTONE MINE	03MJ	2931	1,2-DIBROMO-3-CHLOROPROPANE	SOC	MONITORING, ROUTINE MAJOR	1/1/2018	3/31/2018		5/23/2018
NV0004117	GREYSTONE MINE	03MJ	2110	2,4,5-TP	SOC	MONITORING, ROUTINE MAJOR	1/1/2018	3/31/2018		5/23/2018
NV0004117	GREYSTONE MINE	03MJ	2105	2,4-D	SOC	MONITORING, ROUTINE MAJOR	1/1/2018	3/31/2018		5/23/2018
NV0004117	GREYSTONE MINE	03MJ	2050	ATRAZINE	SOC	MONITORING, ROUTINE MAJOR	10/1/2017	12/31/2017		1/16/2018
NV0004117	GREYSTONE MINE	03MJ	2306	BENZO(A)PYRENE	SOC	MONITORING, ROUTINE MAJOR	10/1/2017	12/31/2017		1/16/2018
NV0004117	GREYSTONE MINE	03MJ	2010	BHC-GAMMA	SOC	MONITORING, ROUTINE MAJOR	1/1/2018	3/31/2018		5/23/2018
NV0004117	GREYSTONE MINE	03MJ	2046	CARBOFURAN	SOC	MONITORING, ROUTINE MAJOR	1/1/2018	3/31/2018		5/23/2018
NV0004117	GREYSTONE MINE	03MJ	2959	CHLORDANE	SOC	MONITORING, ROUTINE MAJOR	1/1/2018	3/31/2018		5/23/2018
NV0004117	GREYSTONE MINE	03MJ	2031	DALAPON	SOC	MONITORING, ROUTINE MAJOR	1/1/2018	3/31/2018		5/23/2018
NV0004117	GREYSTONE MINE	03MJ	2035	DI(2-ETHYLHEXYL) ADIPATE	SOC	MONITORING, ROUTINE MAJOR	10/1/2017	12/31/2017		1/16/2018
NV0004117	GREYSTONE MINE	03MJ	2039	DI(2-ETHYLHEXYL) PHTHALATE	SOC	MONITORING, ROUTINE MAJOR	10/1/2017	12/31/2017		1/16/2018
NV0004117	GREYSTONE MINE	03MJ	2041	DINOSEB	SOC	MONITORING, ROUTINE MAJOR	1/1/2018	3/31/2018		5/23/2018
NV0004117	GREYSTONE MINE	03MJ	2032	DIQUAT	SOC	MONITORING, ROUTINE MAJOR	1/1/2018	3/31/2018		5/23/2018
NV0004117	GREYSTONE MINE	03MJ	2033	ENDOTHALL	SOC	MONITORING, ROUTINE MAJOR	1/1/2018	3/31/2018		5/23/2018

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0004117	GREYSTONE MINE	03MJ	2005	ENDRIN	SOC	MONITORING, ROUTINE MAJOR	1/1/2018	3/31/2018		5/23/2018
NV0004117	GREYSTONE MINE	03MJ	2946	ETHYLENE DIBROMIDE	SOC	MONITORING, ROUTINE MAJOR	1/1/2018	3/31/2018		5/23/2018
NV0004117	GREYSTONE MINE	03MJ	2034	GLYPHOSATE	SOC	MONITORING, ROUTINE MAJOR	1/1/2018	3/31/2018		5/23/2018
NV0004117	GREYSTONE MINE	03MJ	2065	HEPTACHLOR	SOC	MONITORING, ROUTINE MAJOR	1/1/2018	3/31/2018		5/23/2018
NV0004117	GREYSTONE MINE	03MJ	2067	HEPTACHLOR EPOXIDE	SOC	MONITORING, ROUTINE MAJOR	1/1/2018	3/31/2018		5/23/2018
NV0004117	GREYSTONE MINE	03MJ	2274	HEXACHLORO BENZENE	SOC	MONITORING, ROUTINE MAJOR	10/1/2017	12/31/2017		1/16/2018
NV0004117	GREYSTONE MINE	03MJ	2042	HEXACHLOROCYCLOPE NTADIENE	SOC	MONITORING, ROUTINE MAJOR	10/1/2017	12/31/2017		1/16/2018
NV0004117	GREYSTONE MINE	03MJ	2051	LASSO	SOC	MONITORING, ROUTINE MAJOR	1/1/2018	3/31/2018		5/23/2018
NV0004117	GREYSTONE MINE	03MJ	2015	METHOXYCHLOR	SOC	MONITORING, ROUTINE MAJOR	1/1/2018	3/31/2018		5/23/2018
NV0004117	GREYSTONE MINE	03MJ	2036	OXAMYL	SOC	MONITORING, ROUTINE MAJOR	1/1/2018	3/31/2018		5/23/2018
NV0004117	GREYSTONE MINE	03MJ	2326	PENTACHLOROPHENOL	SOC	MONITORING, ROUTINE MAJOR	1/1/2018	3/31/2018		5/23/2018
NV0004117	GREYSTONE MINE	03MJ	2040	PICLORAM	SOC	MONITORING, ROUTINE MAJOR	1/1/2018	3/31/2018		5/23/2018
NV0004117	GREYSTONE MINE	03MJ	2037	SIMAZINE	SOC	MONITORING, ROUTINE MAJOR	10/1/2017	12/31/2017		1/16/2018
NV0004117	GREYSTONE MINE	03MJ	2383	TOTAL POLYCHLORINATED	SOC	MONITORING, ROUTINE MAJOR	1/1/2018	3/31/2018		5/23/2018
NV0004117	GREYSTONE MINE	03MJ	2020	TOXAPHENE	SOC	MONITORING, ROUTINE MAJOR	1/1/2018	3/31/2018		5/23/2018
NV0004117	GREYSTONE MINE	03MJ	CVOC	VOCS PHASE 2 & 5	VOC	MONITORING, ROUTINE MAJOR	1/1/2018	3/31/2018		5/23/2018
Total Number of Violations for this Water System:										30

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0001131	HALLIBURTON DUNPHY MILL	S1	1032	MANGANESE	SECONDARIES	STATE MCL EXCEDENCE	1/1/2018	3/31/2018	0.7 MG/L	
NV0001131	HALLIBURTON DUNPHY MILL	S1	1032	MANGANESE	SECONDARIES	STATE MCL EXCEDENCE	4/1/2018	4/30/2018	0.58 MG/L	
NV0001131	HALLIBURTON DUNPHY MILL	S1	1032	MANGANESE	SECONDARIES	STATE MCL EXCEDENCE	10/1/2018	12/31/2018	0.5 MG/L	
Total Number of Violations for this Water System:										3

NV0002580	HARMON JUNCTION	S1	1055	SULFATE	SECONDARIES	STATE MCL EXCEDENCE	1/1/2018	3/31/2018	1200 MG/L	
NV0002580	HARMON JUNCTION	S1	1055	SULFATE	SECONDARIES	STATE MCL EXCEDENCE	4/1/2018	6/30/2018	1100 MG/L	
NV0002580	HARMON JUNCTION	S1	1055	SULFATE	SECONDARIES	STATE MCL EXCEDENCE	7/1/2018	9/30/2018	1100 MG/L	
NV0002580	HARMON JUNCTION	S1	1055	SULFATE	SECONDARIES	STATE MCL EXCEDENCE	7/1/2018	9/30/2018	1100 MG/L	
NV0002580	HARMON JUNCTION	S1	1930	TDS	SECONDARIES	STATE MCL EXCEDENCE	1/1/2018	3/31/2018	3600 MG/L	
NV0002580	HARMON JUNCTION	S1	1930	TDS	SECONDARIES	STATE MCL EXCEDENCE	4/1/2018	6/30/2018	2200 MG/L	
NV0002580	HARMON JUNCTION	S1	1930	TDS	SECONDARIES	STATE MCL EXCEDENCE	7/1/2018	9/30/2018	2500 MG/L	
NV0002580	HARMON JUNCTION	S1	1930	TDS	SECONDARIES	STATE MCL EXCEDENCE	7/1/2018	9/30/2018	2500 MG/L	
Total Number of Violations for this Water System:										8

NV0004037	HEYDAY INN	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2018	12/31/2018		
NV0004037	HEYDAY INN	2C	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	CORRECTIVE/EXPEDITED ACTIONS (RTCR)	9/5/2018	5/10/2019		5/10/2019
NV0004037	HEYDAY INN	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	2/1/2018	2/28/2018		3/21/2018
NV0004037	HEYDAY INN	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	6/1/2018	6/30/2018		7/25/2018

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0004037	HEYDAY INN	45	0700	GROUNDWATER RULE	GWR	FAILURE ADDRESS DEFICIENCY (GWR)	3/17/2018	1/25/2019		1/25/2019
Total Number of Violations for this Water System:										5
NV0000961	HIDDEN CANYON RANCH	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2017	12/31/2017		3/14/2018
NV0000961	HIDDEN CANYON RANCH	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	10/1/2018	12/31/2018		2/12/2019
Total Number of Violations for this Water System:										2
NV0001150	HILTON GRAND VACATIONS LAS VEGAS	02	2950	TTHM	ST2 DBP	MCL, LRAA	10/1/2017	12/31/2017	0.081 MG/L	1/31/2018
NV0001150	HILTON GRAND VACATIONS LAS VEGAS	02	2950	TTHM	ST2 DBP	MCL, LRAA	4/1/2018	6/30/2018	0.081 MG/L	7/30/2018
NV0001150	HILTON GRAND VACATIONS LAS VEGAS	35	2950	TTHM	ST2 DBP	FAILURE SUBMIT OEL REPORT FOR TTHM	7/1/2017	9/30/2017	0.103 MG/L	3/28/2018
NV0001150	HILTON GRAND VACATIONS LAS VEGAS	53	5000	LEAD & COPPER RULE	LCR	WATER QUALITY PARAMETER M/R (LCR)	1/1/2017	6/30/2017		6/13/2018
NV0001150	HILTON GRAND VACATIONS LAS VEGAS	53	1996	TEMPERATURE (CENTIGRADE)	LCR	WATER QUALITY PARAMETER M/R (LCR)	7/1/2017	12/31/2017		7/30/2018
Total Number of Violations for this Water System:										5
NV0000146	HITCHIN POST MOTEL AND RV PARK	02	1005	ARSENIC	IOC	MCL, AVERAGE	4/1/2017	6/30/2017	0.011 MG/L	12/31/2018
NV0000146	HITCHIN POST MOTEL AND RV PARK	02	1005	ARSENIC	IOC	MCL, AVERAGE	10/1/2017	12/31/2017	0.012 MG/L	12/31/2018
NV0000146	HITCHIN POST MOTEL AND RV PARK	02	1005	ARSENIC	IOC	MCL, AVERAGE	1/1/2018	3/31/2018	0.011 MG/L	12/31/2018
NV0000146	HITCHIN POST MOTEL AND RV PARK	02	1005	ARSENIC	IOC	MCL, AVERAGE	4/1/2018	6/30/2018	0.013 MG/L	12/31/2018
NV0000146	HITCHIN POST MOTEL AND RV PARK	02	1005	ARSENIC	IOC	MCL, AVERAGE	7/1/2018	9/30/2018	0.013 MG/L	12/31/2018
NV0000146	HITCHIN POST MOTEL AND RV PARK	1A	3014	E. COLI	RTCR	MCL, E. COLI, POS E COLI (RTCR)	8/1/2018	8/31/2018		9/7/2018

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0000146	HITCHIN POST MOTEL AND RV PARK	71	7000	CONSUMER CONFIDENCE RULE		CCR REPORT	7/1/2018	7/17/2018		7/17/2018
Total Number of Violations for this Water System:										7
NV0004053	HODGES TRANSPORTATION CO	52	5000	LEAD & COPPER RULE	LCR	FOLLOW-UP OR ROUTINE TAP M/R (LCR)	10/1/2018			
Total Number of Violations for this Water System:										1
NV0002046	HOLBROOK STATION RV AND MHP	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	7/1/2017	9/30/2017		2/21/2018
NV0002046	HOLBROOK STATION RV AND MHP	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	7/1/2017	9/30/2017		2/21/2018
NV0002046	HOLBROOK STATION RV AND MHP	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	7/1/2018	9/30/2018		10/8/2018
NV0002046	HOLBROOK STATION RV AND MHP	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	7/1/2018	9/30/2018		10/16/2018
NV0002046	HOLBROOK STATION RV AND MHP	52	5000	LEAD & COPPER RULE	LCR	FOLLOW-UP OR ROUTINE TAP M/R (LCR)	10/1/2017	9/10/2018		9/10/2018
Total Number of Violations for this Water System:										5
NV0001083	HOOVER DAM LODGE DBA HACIENDA	53	5000	LEAD & COPPER RULE	LCR	WATER QUALITY PARAMETER M/R (LCR)	7/1/2017	12/31/2017		7/18/2018
Total Number of Violations for this Water System:										1
NV0000833	HORIZON C STORES 1 PAHRUMP VALLEY	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	8/1/2018	8/31/2018		8/8/2018
NV0000833	HORIZON C STORES 1 PAHRUMP VALLEY	45	0700	GROUNDWATER RULE	GWR	FAILURE ADDRESS DEFICIENCY (GWR)	6/1/2018			
NV0000833	HORIZON C STORES 1 PAHRUMP VALLEY	75	7500	PUBLIC NOTICE		PUBLIC NOTICE RULE LINKED TO VIOLATION	8/22/2018			
Total Number of Violations for this Water System:										3
NV0000827	HORIZON C STORES 2 TUMBLEWEED TAVERN	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	9/1/2018	9/30/2018		9/12/2018
Total Number of Violations for this Water System:										1

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0000918	HORIZON C STORES 3 LINDA STREET	45	0700	GROUNDWATER RULE	GWR	FAILURE ADDRESS DEFICIENCY (GWR)	7/21/2018			
NV0000918	HORIZON C STORES 3 LINDA STREET	75	7500	PUBLIC NOTICE		PUBLIC NOTICE RULE LINKED TO VIOLATION	4/30/2018			
Total Number of Violations for this Water System:										2
NV0005069	HUMBOLDT CONSERVATION CAMP	01	1040	NITRATE	IOC	MCL, SINGLE SAMPLE	3/1/2018	3/31/2018	24 MG/L	10/30/2018
NV0005069	HUMBOLDT CONSERVATION CAMP	45	0700	GROUNDWATER RULE	GWR	FAILURE ADDRESS DEFICIENCY (GWR)	10/24/2016	5/23/2019		5/23/2019
Total Number of Violations for this Water System:										2
NV0000158	INCLINE VILLAGE GID	27MJ	0999	CHLORINE	ST1 DBP	MONITORING, ROUTINE (DBP), MAJOR	1/1/2018	3/31/2018		8/9/2018
Total Number of Violations for this Water System:										1
NV0000088	JACKPOT WATER SYSTEM	03MJ	2992	ETHYLBENZENE	VOC	MONITORING, ROUTINE MAJOR	1/1/2018	12/31/2018		
NV0000088	JACKPOT WATER SYSTEM	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2017	12/31/2017		7/19/2018
NV0000088	JACKPOT WATER SYSTEM	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2017	12/31/2017		6/27/2018
NV0000088	JACKPOT WATER SYSTEM	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2017	12/31/2017		6/27/2018
NV0000088	JACKPOT WATER SYSTEM	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2017	12/31/2017		6/27/2018
NV0000088	JACKPOT WATER SYSTEM	03MJ	2955	XYLENES, TOTAL	VOC	MONITORING, ROUTINE MAJOR	1/1/2017	12/31/2017		2/26/2018
NV0000088	JACKPOT WATER SYSTEM	03MJ	2955	XYLENES, TOTAL	VOC	MONITORING, ROUTINE MAJOR	1/1/2018	12/31/2018		
NV0000088	JACKPOT WATER SYSTEM	93	1920	ODOR	SECONDARIES	STATE FAILURE TO MONITOR	4/1/2018	6/30/2018		7/16/2018
NV0000088	JACKPOT WATER SYSTEM	S1	1920	ODOR	SECONDARIES	STATE MCL EXCEDENCE	7/1/2018	9/30/2018	12 TON	
Total Number of Violations for this Water System:										9

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0000313	JERRITT CANYON GOLD SSX MINE	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2018	12/31/2018		
NV0000313	JERRITT CANYON GOLD SSX MINE	27MJ	0999	CHLORINE	ST1 DBP	MONITORING, ROUTINE (DBP), MAJOR	1/1/2018	3/31/2018		5/24/2018
NV0000313	JERRITT CANYON GOLD SSX MINE	27MJ	CDB2	DBPR STAGE 2	ST2 DBP	MONITORING, ROUTINE (DBP), MAJOR	1/1/2018	12/31/2018		
Total Number of Violations for this Water System:										3

NV0002071	JIGGS BAR	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2018	12/31/2018		
NV0002071	JIGGS BAR	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	4/1/2018	6/30/2018		9/20/2018
NV0002071	JIGGS BAR	93	1032	MANGANESE	SECONDARIES	STATE FAILURE TO MONITOR	4/1/2018	6/30/2018		9/20/2018
NV0002071	JIGGS BAR	S1	1032	MANGANESE	SECONDARIES	STATE MCL EXCEDENCE	7/1/2018	9/30/2018	0.19 MG/L	
NV0002071	JIGGS BAR	S1	1032	MANGANESE	SECONDARIES	STATE MCL EXCEDENCE	7/1/2018	9/30/2018	0.19 MG/L	
NV0002071	JIGGS BAR	S1	1032	MANGANESE	SECONDARIES	STATE MCL EXCEDENCE	10/1/2018	12/31/2018	0.15 MG/L	
Total Number of Violations for this Water System:										6

NV0000731	JOHNNY CASSINARIS RESTAURANT	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	12/1/2017	12/31/2017		1/9/2018
Total Number of Violations for this Water System:										1

NV0002024	KENNAMETAL INC	02	1005	ARSENIC	IOC	MCL, AVERAGE	10/1/2017	12/31/2017	0.015 MG/L	10/16/2018
NV0002024	KENNAMETAL INC	02	1005	ARSENIC	IOC	MCL, AVERAGE	1/1/2018	3/31/2018	0.016 MG/L	10/16/2018
NV0002024	KENNAMETAL INC	02	1005	ARSENIC	IOC	MCL, AVERAGE	4/1/2018	6/30/2018	0.016 MG/L	10/16/2018
NV0002024	KENNAMETAL INC	02	1005	ARSENIC	IOC	MCL, AVERAGE	7/1/2018	9/30/2018	0.016 MG/L	10/16/2018
Total Number of Violations for this Water System:										4

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0000932	KEYSTONE CENTER	03MJ	CNO2	NITRITE	IOC	MONITORING, ROUTINE MAJOR	1/1/2014	12/31/2016		10/29/2018
NV0000932	KEYSTONE CENTER	2C	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	CORRECTIVE/EXPEDITED ACTIONS (RTCR)	12/24/2018			
NV0000932	KEYSTONE CENTER	2C	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	CORRECTIVE/EXPEDITED ACTIONS (RTCR)	12/24/2018			
NV0000932	KEYSTONE CENTER	3AMJ	3014	E. COLI	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	2/1/2018	2/28/2018		3/30/2018
NV0000932	KEYSTONE CENTER	3AMJ	3014	E. COLI	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	5/1/2018	5/31/2018		7/23/2018
NV0000932	KEYSTONE CENTER	3AMJ	3014	E. COLI	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	6/1/2018	6/30/2018		7/23/2018
NV0000932	KEYSTONE CENTER	3AMJ	3014	E. COLI	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	9/1/2018	9/30/2018		11/5/2018
NV0000932	KEYSTONE CENTER	3AMJ	3014	E. COLI	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	10/1/2018	10/31/2018		11/5/2018

Total Number of Violations for this Water System: 8

NV0002198	KINGS RIVER ELEMENTARY SCHOOL	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2017	12/31/2017		6/11/2018
NV0002198	KINGS RIVER ELEMENTARY SCHOOL	03MJ	CVOC	VOCS PHASE 2 & 5	VOC	MONITORING, ROUTINE MAJOR	1/1/2017	12/31/2017		3/21/2018
NV0002198	KINGS RIVER ELEMENTARY SCHOOL	03MJ	CVOC	VOCS PHASE 2 & 5	VOC	MONITORING, ROUTINE MAJOR	7/1/2018	9/30/2018		12/27/2018
NV0002198	KINGS RIVER ELEMENTARY SCHOOL	51	5000	LEAD & COPPER RULE	LCR	INITIAL TAP SAMPLING (LCR)	1/1/2018			

Total Number of Violations for this Water System: 4

NV0002174	KOA OF ELY CAMPGROUND	52	5000	LEAD & COPPER RULE	LCR	FOLLOW-UP OR ROUTINE TAP M/R (LCR)	10/1/2017	8/2/2018		8/2/2018
NV0002174	KOA OF ELY CAMPGROUND	S1	1028	IRON	SECONDARIES	STATE MCL EXCEDENCE	7/1/2018	9/30/2018	2.7 MG/L	1/25/2019

Total Number of Violations for this Water System: 2

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0000700	KRUSE FEED AND HARDWARE	01	1040	NITRATE	IOC	MCL, SINGLE SAMPLE	7/1/2018	9/30/2018	13 MG/L	1/2/2019
NV0000700	KRUSE FEED AND HARDWARE	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	12/1/2018	12/31/2018		1/2/2019
Total Number of Violations for this Water System:										2
NV0002028	LAHONTAN DAM STATE PARK	36MJ	0999	CHLORINE	SWTR	MONITORING, RTN/RPT MAJOR (SWTR-FILTER)	3/1/2018	3/31/2018		2/14/2019
NV0002028	LAHONTAN DAM STATE PARK	36MJ	0999	CHLORINE	SWTR	MONITORING, RTN/RPT MAJOR (SWTR-FILTER)	10/1/2018	10/31/2018		2/14/2019
NV0002028	LAHONTAN DAM STATE PARK	36MJ	0100	TURBIDITY	SWTR	MONITORING, RTN/RPT MAJOR (SWTR-FILTER)	4/1/2018	4/30/2018		2/14/2019
NV0002028	LAHONTAN DAM STATE PARK	36MJ	0100	TURBIDITY	SWTR	MONITORING, RTN/RPT MAJOR (SWTR-FILTER)	7/1/2018	7/31/2018		2/14/2019
Total Number of Violations for this Water System:										4
NV0005021	LAHONTAN DAM STATE PARK BEACH 7	45	0700	GROUNDWATER RULE	GWR	FAILURE ADDRESS DEFICIENCY (GWR)	1/17/2017	5/14/2019		5/14/2019
Total Number of Violations for this Water System:										1
NV0000942	LAKER PLAZA INC	3AMJ	3014	E. COLI	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	4/1/2018	6/30/2018		7/30/2018
Total Number of Violations for this Water System:										1
NV0000928	LAMOILLE VALLEY PLAZA	02	1005	ARSENIC	IOC	MCL, AVERAGE	1/1/2018	3/31/2018	0.024 MG/L	
NV0000928	LAMOILLE VALLEY PLAZA	02	1005	ARSENIC	IOC	MCL, AVERAGE	4/1/2018	6/30/2018	0.022 MG/L	
NV0000928	LAMOILLE VALLEY PLAZA	02	1005	ARSENIC	IOC	MCL, AVERAGE	7/1/2018	9/30/2018	0.022 MG/L	
NV0000928	LAMOILLE VALLEY PLAZA	02	1005	ARSENIC	IOC	MCL, AVERAGE	10/1/2018	12/31/2018	0.023 MG/L	
NV0000928	LAMOILLE VALLEY PLAZA	03MJ	CDAS	ARSENIC (AS)	IOC	MONITORING, ROUTINE MAJOR	7/1/2018	9/30/2018		
NV0000928	LAMOILLE VALLEY PLAZA	03MJ	CDAS	ARSENIC (AS)	IOC	MONITORING, ROUTINE MAJOR	7/1/2018	9/30/2018		

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0000928	LAMOILLE VALLEY PLAZA	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2018	12/31/2018		
NV0000928	LAMOILLE VALLEY PLAZA	27MJ	0999	CHLORINE	ST1 DBP	MONITORING, ROUTINE (DBP), MAJOR	4/1/2017	6/30/2017		7/20/2018
NV0000928	LAMOILLE VALLEY PLAZA	27MJ	0999	CHLORINE	ST1 DBP	MONITORING, ROUTINE (DBP), MAJOR	10/1/2018	12/31/2018		
NV0000928	LAMOILLE VALLEY PLAZA	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	11/1/2018	11/30/2018		12/11/2018
NV0000928	LAMOILLE VALLEY PLAZA	52	5000	LEAD & COPPER RULE	LCR	FOLLOW-UP OR ROUTINE TAP M/R (LCR)	10/1/2018			
Total Number of Violations for this Water System:										11

NV0000273	LAMOILLE WATER USERS ASSOC	27MJ	0999	CHLORINE	ST1 DBP	MONITORING, ROUTINE (DBP), MAJOR	7/1/2017	9/30/2017		10/29/2018
NV0000273	LAMOILLE WATER USERS ASSOC	27MJ	0999	CHLORINE	ST1 DBP	MONITORING, ROUTINE (DBP), MAJOR	7/1/2017	9/30/2017		10/29/2018
NV0000273	LAMOILLE WATER USERS ASSOC	27MJ	0999	CHLORINE	ST1 DBP	MONITORING, ROUTINE (DBP), MAJOR	10/1/2017	12/31/2017		10/29/2018
NV0000273	LAMOILLE WATER USERS ASSOC	27MJ	CDB2	DBPR STAGE 2	ST2 DBP	MONITORING, ROUTINE (DBP), MAJOR	1/1/2014	12/31/2016		8/27/2018
NV0000273	LAMOILLE WATER USERS ASSOC	27MJ	CDB2	DBPR STAGE 2	ST2 DBP	MONITORING, ROUTINE (DBP), MAJOR	1/1/2017	7/31/2017		8/27/2018
NV0000273	LAMOILLE WATER USERS ASSOC	27MJ	CDBP	DISINFECTION BYPROD	ST2 DBP	MONITORING, ROUTINE (DBP), MAJOR	1/1/2011	12/31/2013		8/27/2018
NV0000273	LAMOILLE WATER USERS ASSOC	S1	1028	IRON	SECONDARIES	STATE MCL EXCEDENCE	7/1/2017	9/30/2017	4.4 MG/L	1/15/2018
NV0000273	LAMOILLE WATER USERS ASSOC	S1	1028	IRON	SECONDARIES	STATE MCL EXCEDENCE	4/1/2018	6/30/2018	1.2 MG/L	2/27/2019
Total Number of Violations for this Water System:										8

NV0000006	LANDER CO SEWER AND WATER DIST 2	27MJ	0999	CHLORINE	ST1 DBP	MONITORING, ROUTINE (DBP), MAJOR	7/1/2018	9/30/2018		
NV0000006	LANDER CO SEWER AND WATER DIST 2	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	9/1/2018	9/30/2018		10/29/2018
Total Number of Violations for this Water System:										2

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0004055	LANES TRAVEL CENTER	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	7/1/2018	9/30/2018		10/1/2018
Total Number of Violations for this Water System:										1
NV0004005	LDS LEE RECREATION CAMP	2D	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	STARTUP PROCEDURES TT (RTCR)	7/11/2018	9/26/2018		9/26/2018
NV0004005	LDS LEE RECREATION CAMP	S1	1002	ALUMINUM	SECONDARIES	STATE MCL EXCEDENCE	4/1/2018	6/30/2018	320 MG/L	
Total Number of Violations for this Water System:										2
NV0000307	LEE CANYON SKI AREA	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2017	12/31/2017		4/12/2018
NV0000307	LEE CANYON SKI AREA	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2017	12/31/2017		4/12/2018
Total Number of Violations for this Water System:										2
NV0002050	LOGAN CREEK ESTATES GID	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	12/1/2017	12/31/2017		1/9/2018
Total Number of Violations for this Water System:										1
NV0002602	LOVES TRAVEL STOP AND COUNTRY STORE	02	1005	ARSENIC	IOC	MCL, AVERAGE	4/1/2017	6/30/2017	0.011 MG/L	8/2/2018
NV0002602	LOVES TRAVEL STOP AND COUNTRY STORE	02	1005	ARSENIC	IOC	MCL, AVERAGE	7/1/2017	9/30/2017	0.011 MG/L	8/2/2018
NV0002602	LOVES TRAVEL STOP AND COUNTRY STORE	02	1005	ARSENIC	IOC	MCL, AVERAGE	10/1/2017	12/31/2017	0.014 MG/L	8/2/2018
NV0002602	LOVES TRAVEL STOP AND COUNTRY STORE	02	1005	ARSENIC	IOC	MCL, AVERAGE	1/1/2018	3/31/2018	0.014 MG/L	8/2/2018
NV0002602	LOVES TRAVEL STOP AND COUNTRY STORE	02	1005	ARSENIC	IOC	MCL, AVERAGE	4/1/2018	6/30/2018	0.015 MG/L	8/2/2018
Total Number of Violations for this Water System:										5
NV0000140	LUNA VISTA	02	1005	ARSENIC	IOC	MCL, AVERAGE	7/1/2017	9/30/2017	0.022 MG/L	7/2/2018

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0000140	LUNA VISTA	02	1005	ARSENIC	IOC	MCL, AVERAGE	10/1/2017	12/31/2017	0.022 MG/L	7/2/2018
NV0000140	LUNA VISTA	02	1005	ARSENIC	IOC	MCL, AVERAGE	1/1/2018	3/31/2018	0.022 MG/L	7/2/2018
NV0000140	LUNA VISTA	02	1005	ARSENIC	IOC	MCL, AVERAGE	4/1/2018	6/30/2018	0.014 MG/L	7/2/2018
Total Number of Violations for this Water System:										4
NV0004101	LUND MEETINGHOUSE LDS	45	0700	GROUNDWATER RULE	GWR	FAILURE ADDRESS DEFICIENCY (GWR)	2/1/2018	8/14/2018		8/14/2018
Total Number of Violations for this Water System:										1
NV0000979	LUND SCHOOL	27MJ	CDB2	DBPR STAGE 2	ST2 DBP	MONITORING, ROUTINE (DBP), MAJOR	9/1/2016	8/31/2017		8/14/2018
Total Number of Violations for this Water System:										1
NV0005019	MABELS BAR	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2018	12/31/2018		
Total Number of Violations for this Water System:										1
NV0000738	MAGIC CARPET GOLF	45	0700	GROUNDWATER RULE	GWR	FAILURE ADDRESS DEFICIENCY (GWR)	4/29/2019			
Total Number of Violations for this Water System:										1
NV0000162	MCDERMITT WATER SYSTEM	02	1005	ARSENIC	IOC	MCL, AVERAGE	1/1/2018	3/31/2018	0.012 MG/L	
NV0000162	MCDERMITT WATER SYSTEM	02	1005	ARSENIC	IOC	MCL, AVERAGE	4/1/2018	6/30/2018	0.012 MG/L	
NV0000162	MCDERMITT WATER SYSTEM	02	1005	ARSENIC	IOC	MCL, AVERAGE	7/1/2018	9/30/2018	0.012 MG/L	
NV0000162	MCDERMITT WATER SYSTEM	02	1005	ARSENIC	IOC	MCL, AVERAGE	10/1/2018	12/31/2018	0.012 MG/L	
Total Number of Violations for this Water System:										4
NV0002508	MCWILLIAMS WATER SYSTEM	93	1028	IRON	SECONDARIES	STATE FAILURE TO MONITOR	7/1/2018	9/30/2018		

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
Total Number of Violations for this Water System:										1
NV0003071	MIDAS WATER COOPERATIVE	19MJ	3014	E. COLI	GWR	MONITOR GWR ASSESSMENT, MAJOR	11/1/2017	11/30/2017		8/27/2018
NV0003071	MIDAS WATER COOPERATIVE	2C	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	CORRECTIVE/EXPEDITED ACTIONS (RTCR)	10/31/2018	5/1/2019		5/1/2019
Total Number of Violations for this Water System:										2
NV0000169	MONTELLO WATER SYSTEM	S1	1920	ODOR	SECONDARIES	STATE MCL EXCEDENCE	10/1/2018	12/31/2018	200 TON	
Total Number of Violations for this Water System:										1
NV0000732	MOUNT ROSE BOWL PROPERTY OWNERS	53	5000	LEAD & COPPER RULE	LCR	WATER QUALITY PARAMETER M/R (LCR)	1/1/2017	6/30/2017		4/23/2018
NV0000732	MOUNT ROSE BOWL PROPERTY OWNERS	53	5000	LEAD & COPPER RULE	LCR	WATER QUALITY PARAMETER M/R (LCR)	7/1/2017	12/31/2017		4/23/2018
NV0000732	MOUNT ROSE BOWL PROPERTY OWNERS	57	5000	LEAD & COPPER RULE	LCR	OCCT/SOWT RECOMMENDATION/STUDY	7/22/2016			
NV0000732	MOUNT ROSE BOWL PROPERTY OWNERS	58	5000	LEAD & COPPER RULE	LCR	OCCT/SOWT INSTALL DEMONSTRATION (LCR)	7/22/2016			
Total Number of Violations for this Water System:										4
NV0001082	MOUNTAIN SPRINGS BAR INC	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	12/1/2017	12/31/2017		1/5/2018
NV0001082	MOUNTAIN SPRINGS BAR INC	45	0700	GROUNDWATER RULE	GWR	FAILURE ADDRESS DEFICIENCY (GWR)	10/22/2018			
Total Number of Violations for this Water System:										2
NV0001015	MT CHARLESTON WATER COMPANY	71	7000	CONSUMER CONFIDENCE RULE		CCR REPORT	7/1/2018			
Total Number of Violations for this Water System:										1
NV0000869	NATCHEZ GYM	S1	1028	IRON	SECONDARIES	STATE MCL EXCEDENCE	7/1/2018	9/30/2018	0.73 MG/L	
Total Number of Violations for this Water System:										1

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0002214	NDOT BEOWAWE ROADSIDE PARK RP802	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2017	12/31/2017		4/10/2018
Total Number of Violations for this Water System:										1
NV0002102	NDOT VALMY ROADSIDE PARK	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	12/1/2017	12/31/2017		1/2/2018
Total Number of Violations for this Water System:										1
NV0004022	NDOT WADSWORTH REST STOP	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2018	12/31/2018		5/7/2019
NV0004022	NDOT WADSWORTH REST STOP	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	4/1/2018	4/30/2018		5/7/2018
NV0004022	NDOT WADSWORTH REST STOP	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	12/1/2018	12/31/2018		1/31/2019
NV0004022	NDOT WADSWORTH REST STOP	45	0700	GROUNDWATER RULE	GWR	FAILURE ADDRESS DEFICIENCY (GWR)	7/21/2018	5/20/2019		5/20/2019
Total Number of Violations for this Water System:										4
NV0002014	NEVADA LIVESTOCK MARKETING	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2018	12/31/2018		
NV0002014	NEVADA LIVESTOCK MARKETING	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	4/1/2018	6/30/2018		9/27/2018
Total Number of Violations for this Water System:										2
NV0000699	NEVADA STATE VETERANS HOME	27MJ	0999	CHLORINE	ST1 DBP	MONITORING, ROUTINE (DBP), MAJOR	4/1/2018	6/30/2018		7/5/2018
NV0000699	NEVADA STATE VETERANS HOME	27MJ	0999	CHLORINE	ST1 DBP	MONITORING, ROUTINE (DBP), MAJOR	4/1/2018	6/30/2018		7/5/2018
NV0000699	NEVADA STATE VETERANS HOME	3AMJ	3014	E. COLI	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	5/1/2018	5/31/2018		7/5/2018
NV0000699	NEVADA STATE VETERANS HOME	3AMJ	3014	E. COLI	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	6/1/2018	6/30/2018		7/5/2018
Total Number of Violations for this Water System:										4
NV0005006	NEVADA TEST AND TRAINING RANGE PT	52	5000	LEAD & COPPER RULE	LCR	FOLLOW-UP OR ROUTINE TAP M/R (LCR)	10/1/2017	7/3/2018		7/3/2018

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
Total Number of Violations for this Water System:										1
NV0000903	NEW MILLENNIUM BUILDING SYSTEMS,	02	1005	ARSENIC	IOC	MCL, AVERAGE	1/1/2018	3/31/2018	0.015 MG/L	5/9/2018
NV0000903	NEW MILLENNIUM BUILDING SYSTEMS,	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2018	12/31/2018		1/16/2019
Total Number of Violations for this Water System:										2
NV0004110	NEW PARADISE MB CHURCH	34MJ	3014	E. COLI	GWR	MONITOR GWR TRIGGERED/ADDITONAL, MAJOR	9/22/2017	2/21/2018		2/21/2018
NV0004110	NEW PARADISE MB CHURCH	34MJ	3014	E. COLI	GWR	MONITOR GWR TRIGGERED/ADDITONAL, MAJOR	9/22/2017	2/21/2018		2/21/2018
NV0004110	NEW PARADISE MB CHURCH	3BMJ	3014	E. COLI	RTCR	MONITORING, ADD. ROUTINE, MAJOR (RTCR)	10/1/2017	10/31/2017		2/21/2018
NV0004110	NEW PARADISE MB CHURCH	S1	1905	COLOR	SECONDARIES	STATE MCL EXCEDENCE	4/1/2017	6/30/2017	40 CU	2/21/2018
NV0004110	NEW PARADISE MB CHURCH	S1	1028	IRON	SECONDARIES	STATE MCL EXCEDENCE	4/1/2017	6/30/2017	2.99 MG/L	2/21/2018
NV0004110	NEW PARADISE MB CHURCH	S1	1031	MAGNESIUM	SECONDARIES	STATE MCL EXCEDENCE	4/1/2017	6/30/2017	223 MG/L	2/21/2018
NV0004110	NEW PARADISE MB CHURCH	S1	1055	SULFATE	SECONDARIES	STATE MCL EXCEDENCE	4/1/2017	6/30/2017	1040 MG/L	2/21/2018
NV0004110	NEW PARADISE MB CHURCH	S1	1930	TDS	SECONDARIES	STATE MCL EXCEDENCE	4/1/2017	6/30/2017	2050 MG/L	2/21/2018
Total Number of Violations for this Water System:										8
NV0000870	NORTH VALLEY BUS FACILITY	34MJ	3014	E. COLI	GWR	MONITOR GWR TRIGGERED/ADDITONAL, MAJOR	11/9/2017	1/9/2018		1/9/2018
Total Number of Violations for this Water System:										1
NV0003005	NPS BOULDER BEACH	27MJ	0999	CHLORINE	ST1 DBP	MONITORING, ROUTINE (DBP), MAJOR	7/1/2018	9/30/2018		
NV0003005	NPS BOULDER BEACH	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	7/1/2018	7/31/2018		9/17/2018
Total Number of Violations for this Water System:										2

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0002503	NPS ECHO BAY	52	5000	LEAD & COPPER RULE	LCR	FOLLOW-UP OR ROUTINE TAP M/R (LCR)	10/1/2016			8/9/2018
Total Number of Violations for this Water System:										1
NV0000797	OLD FORTY WEST MOTEL	02	1005	ARSENIC	IOC	MCL, AVERAGE	1/1/2018	3/31/2018	0.011 MG/L	
NV0000797	OLD FORTY WEST MOTEL	02	1005	ARSENIC	IOC	MCL, AVERAGE	4/1/2018	6/30/2018	0.114 MG/L	
NV0000797	OLD FORTY WEST MOTEL	02	1005	ARSENIC	IOC	MCL, AVERAGE	7/1/2018	9/30/2018	0.076 MG/L	
NV0000797	OLD FORTY WEST MOTEL	02	1005	ARSENIC	IOC	MCL, AVERAGE	10/1/2018	12/31/2018	0.073 MG/L	
NV0000797	OLD FORTY WEST MOTEL	03MJ	CRAU	RADIONUCLIDES	RAD	MONITORING, ROUTINE MAJOR	7/1/2018	9/30/2018		
NV0000797	OLD FORTY WEST MOTEL	03MJ	CRAU	RADIONUCLIDES	RAD	MONITORING, ROUTINE MAJOR	10/1/2018	12/31/2018		
NV0000797	OLD FORTY WEST MOTEL	03MJ	CSOC	SOCS PHASE 2 & 5	SOC	MONITORING, ROUTINE MAJOR	7/1/2018	9/30/2018		
NV0000797	OLD FORTY WEST MOTEL	03MJ	CSOC	SOCS PHASE 2 & 5	SOC	MONITORING, ROUTINE MAJOR	10/1/2018	12/31/2018		
NV0000797	OLD FORTY WEST MOTEL	03MJ	CVOC	VOCS PHASE 2 & 5	VOC	MONITORING, ROUTINE MAJOR	7/1/2018	9/30/2018		
NV0000797	OLD FORTY WEST MOTEL	03MJ	CVOC	VOCS PHASE 2 & 5	VOC	MONITORING, ROUTINE MAJOR	10/1/2018	12/31/2018		
NV0000797	OLD FORTY WEST MOTEL	45	0700	GROUNDWATER RULE	GWR	FAILURE ADDRESS DEFICIENCY (GWR)	7/29/2017			
Total Number of Violations for this Water System:										11
NV0000303	OLD RIVER WATER COMPANY	52	5000	LEAD & COPPER RULE	LCR	FOLLOW-UP OR ROUTINE TAP M/R (LCR)	10/1/2018			
Total Number of Violations for this Water System:										1
NV0004106	PAHRANAGAT NATIONAL WILDLIFE	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2018	12/31/2018		
Total Number of Violations for this Water System:										1

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0004018	PAHRUMP FIRE STATION BLM	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2018	12/31/2018		
NV0004018	PAHRUMP FIRE STATION BLM	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	10/1/2018	12/31/2018		2/19/2019
Total Number of Violations for this Water System:										2
NV0003036	PAHRUMP SENIOR CENTER INC	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2018	12/31/2018		
Total Number of Violations for this Water System:										1
NV0000185	PANACA FARMSTEAD WATER ASSOCIATION	52	5000	LEAD & COPPER RULE	LCR	FOLLOW-UP OR ROUTINE TAP M/R (LCR)	10/1/2018			
NV0000185	PANACA FARMSTEAD WATER ASSOCIATION	93	CNO3	NITRATE	SECONDARIES	STATE FAILURE TO MONITOR	1/1/2018	12/31/2018		
Total Number of Violations for this Water System:										2
NV0002186	PARADISE VALLEY ELEMENTARY	03MJ	CNO2	NITRITE	IOC	MONITORING, ROUTINE MAJOR	1/1/2014	12/31/2016		6/11/2018
NV0002186	PARADISE VALLEY ELEMENTARY	03MJ	CVOC	VOCS PHASE 2 & 5	VOC	MONITORING, ROUTINE MAJOR	1/1/2014	12/31/2016		6/11/2018
NV0002186	PARADISE VALLEY ELEMENTARY	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	10/1/2017	12/31/2017		1/23/2018
NV0002186	PARADISE VALLEY ELEMENTARY	52	5000	LEAD & COPPER RULE	LCR	FOLLOW-UP OR ROUTINE TAP M/R (LCR)	10/1/2016	12/19/2018		12/19/2018
NV0002186	PARADISE VALLEY ELEMENTARY	52	5000	LEAD & COPPER RULE	LCR	FOLLOW-UP OR ROUTINE TAP M/R (LCR)	10/1/2017	12/19/2018		12/19/2018
NV0002186	PARADISE VALLEY ELEMENTARY	93	CSEF	SEC IOC FLUORIDE	SECONDARIES	STATE FAILURE TO MONITOR	1/1/2014	12/31/2016		6/11/2018
NV0002186	PARADISE VALLEY ELEMENTARY	93	CSC2	SECONDARY IOCS	SECONDARIES	STATE FAILURE TO MONITOR	1/1/2014	12/31/2016		6/11/2018
Total Number of Violations for this Water System:										7
NV0002106	PARADISE VALLEY PARK	93	1028	IRON	SECONDARIES	STATE FAILURE TO MONITOR	6/1/2018	6/30/2018		8/30/2018
NV0002106	PARADISE VALLEY PARK	93	1028	IRON	SECONDARIES	STATE FAILURE TO MONITOR	7/1/2018	7/31/2018		8/30/2018

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
Total Number of Violations for this Water System:										2
NV0004067	PEACOX CHARITABLE REMAINDER UNITRUST	02	1005	ARSENIC	IOC	MCL, AVERAGE	1/1/2018	3/31/2018	0.055 MG/L	
NV0004067	PEACOX CHARITABLE REMAINDER UNITRUST	02	1005	ARSENIC	IOC	MCL, AVERAGE	4/1/2018	6/30/2018	0.048 MG/L	
NV0004067	PEACOX CHARITABLE REMAINDER UNITRUST	02	1005	ARSENIC	IOC	MCL, AVERAGE	7/1/2018	9/30/2018	0.031 MG/L	
NV0004067	PEACOX CHARITABLE REMAINDER UNITRUST	02	1005	ARSENIC	IOC	MCL, AVERAGE	10/1/2018	12/31/2018	0.032 MG/L	
NV0004067	PEACOX CHARITABLE REMAINDER UNITRUST	S1	1025	FLUORIDE	SECONDARIES	STATE MCL EXCEDENCE	1/1/2018	3/31/2018	3.1 MG/L	
NV0004067	PEACOX CHARITABLE REMAINDER UNITRUST	S1	1025	FLUORIDE	SECONDARIES	STATE MCL EXCEDENCE	4/1/2018	6/30/2018	3.2 MG/L	
NV0004067	PEACOX CHARITABLE REMAINDER UNITRUST	S1	1025	FLUORIDE	SECONDARIES	STATE MCL EXCEDENCE	7/1/2018	9/30/2018	3.8 MG/L	
NV0004067	PEACOX CHARITABLE REMAINDER UNITRUST	S1	1025	FLUORIDE	SECONDARIES	STATE MCL EXCEDENCE	10/1/2018	12/31/2018	2.9 MG/L	
Total Number of Violations for this Water System:										8
NV0004063	PICK AND SHOVEL INVESTMENTS	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	7/1/2018	9/30/2018		2/22/2019
NV0004063	PICK AND SHOVEL INVESTMENTS	45	0700	GROUNDWATER RULE	GWR	FAILURE ADDRESS DEFICIENCY (GWR)	11/3/2017	2/4/2019		2/4/2019
Total Number of Violations for this Water System:										2
NV0000067	PINION PINES MHP	52	5000	LEAD & COPPER RULE	LCR	FOLLOW-UP OR ROUTINE TAP M/R (LCR)	10/1/2017	9/10/2018		9/10/2018
Total Number of Violations for this Water System:										1
NV0001127	POLO TOWERS	53	5000	LEAD & COPPER RULE	LCR	WATER QUALITY PARAMETER M/R (LCR)	7/1/2017	12/31/2017		7/17/2018
Total Number of Violations for this Water System:										1
NV0001170	PREMIER MAGNESIA	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	10/1/2017	12/31/2017		2/7/2018

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0001170	PREMIER MAGNESIA	S1	1025	FLUORIDE	SECONDARIES	STATE MCL EXCEDENCE	4/1/2018	6/30/2018	9.2 MG/L	
NV0001170	PREMIER MAGNESIA	S1	1025	FLUORIDE	SECONDARIES	STATE MCL EXCEDENCE	7/1/2018	9/30/2018	9.6 MG/L	
NV0001170	PREMIER MAGNESIA	S1	1025	FLUORIDE	SECONDARIES	STATE MCL EXCEDENCE	10/1/2018	12/31/2018	9.8 MG/L	
Total Number of Violations for this Water System:										4
NV0000054	R AND M MOBILE HOME PARK	S1	1028	IRON	SECONDARIES	STATE MCL EXCEDENCE	10/1/2018	12/31/2018	0.7 MG/L	
Total Number of Violations for this Water System:										1
NV0001069	RANCH HOUSE	3AMN	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MINOR (RTCR)	11/1/2017	11/30/2017		1/11/2018
Total Number of Violations for this Water System:										1
NV0002571	RANCHO VISTA 4	2ANC	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	LEVEL 1 ASSESS, MULTIPLE TC POS (RTCR)	11/2/2018	11/19/2018		11/19/2018
NV0002571	RANCHO VISTA 4	45	0700	GROUNDWATER RULE	GWR	FAILURE ADDRESS DEFICIENCY (GWR)	7/20/2018			
Total Number of Violations for this Water System:										2
NV0003101	RED ROCK FIRE STN AND LAW ENF BLM	03MJ	1040	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2018	12/31/2018		4/3/2019
Total Number of Violations for this Water System:										1
NV0000701	RENO SAHARA TRAILER PARK	52	5000	LEAD & COPPER RULE	LCR	FOLLOW-UP OR ROUTINE TAP M/R (LCR)	1/1/2018	6/1/2018		6/1/2018
Total Number of Violations for this Water System:										1
NV0004029	RITCHIE BROTHERS	45	0700	GROUNDWATER RULE	GWR	FAILURE ADDRESS DEFICIENCY (GWR)	2/16/2017			
NV0004029	RITCHIE BROTHERS	45	0700	GROUNDWATER RULE	GWR	FAILURE ADDRESS DEFICIENCY (GWR)	2/16/2017	8/29/2018		8/29/2018
NV0004029	RITCHIE BROTHERS	45	0700	GROUNDWATER RULE	GWR	FAILURE ADDRESS DEFICIENCY (GWR)	2/16/2017	9/18/2018		9/18/2018

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0004029	RITCHIE BROTHERS	45	0700	GROUNDWATER RULE	GWR	FAILURE ADDRESS DEFICIENCY (GWR)	2/16/2017	9/19/2018		9/19/2018
NV0004029	RITCHIE BROTHERS	45	0700	GROUNDWATER RULE	GWR	FAILURE ADDRESS DEFICIENCY (GWR)	2/16/2017	9/19/2018		9/19/2018
NV0004029	RITCHIE BROTHERS	45	0700	GROUNDWATER RULE	GWR	FAILURE ADDRESS DEFICIENCY (GWR)	2/16/2017	9/19/2018		9/19/2018
NV0004029	RITCHIE BROTHERS	45	0700	GROUNDWATER RULE	GWR	FAILURE ADDRESS DEFICIENCY (GWR)	2/16/2017	9/20/2018		9/20/2018
NV0004029	RITCHIE BROTHERS	S1	1930	TDS	SECONDARIES	STATE MCL EXCEDENCE	7/1/2017	9/30/2017	1140 MG/L	2/5/2018
Total Number of Violations for this Water System:										8
NV0000754	RIVER BEND MHP	S1	1028	IRON	SECONDARIES	STATE MCL EXCEDENCE	7/1/2017	9/30/2017	4.3 MG/L	2/28/2018
Total Number of Violations for this Water System:										1
NV0000068	RIVERVIEW MOBILE HOME PARK	52	5000	LEAD & COPPER RULE	LCR	FOLLOW-UP OR ROUTINE TAP M/R (LCR)	10/1/2017	7/12/2018		12/16/2015
NV0000068	RIVERVIEW MOBILE HOME PARK	52	5000	LEAD & COPPER RULE	LCR	FOLLOW-UP OR ROUTINE TAP M/R (LCR)	10/1/2017	7/12/2018		7/12/2018
Total Number of Violations for this Water System:										2
NV0000767	ROSEMOUNT WATER CO	02	4006	COMBINED URANIUM	RAD	MCL, AVERAGE	4/1/2018	6/30/2018	36 UG/L	
NV0000767	ROSEMOUNT WATER CO	02	4006	COMBINED URANIUM	RAD	MCL, AVERAGE	7/1/2018	9/30/2018	69 UG/L	
NV0000767	ROSEMOUNT WATER CO	02	4006	COMBINED URANIUM	RAD	MCL, AVERAGE	10/1/2018	12/31/2018	46 UG/L	
NV0000767	ROSEMOUNT WATER CO	02	4006	COMBINED URANIUM	RAD	MCL, AVERAGE	10/1/2018	12/31/2018	33 UG/L	
NV0000767	ROSEMOUNT WATER CO	03MJ	CRUR	RADS URANIUM	RAD	MONITORING, ROUTINE MAJOR	7/1/2017	12/31/2017		7/27/2018
NV0000767	ROSEMOUNT WATER CO	03MJ	CRUR	RADS URANIUM	RAD	MONITORING, ROUTINE MAJOR	7/1/2017	12/31/2017		5/28/2018

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0000767	ROSEMOUNT WATER CO	03MJ	CRUR	RADS URANIUM	RAD	MONITORING, ROUTINE MAJOR	7/1/2017	12/31/2017		6/3/2018
NV0000767	ROSEMOUNT WATER CO	03MJ	CRUR	RADS URANIUM	RAD	MONITORING, ROUTINE MAJOR	1/1/2018	6/30/2018		2/8/2019
NV0000767	ROSEMOUNT WATER CO	03MJ	CRUR	RADS URANIUM	RAD	MONITORING, ROUTINE MAJOR	1/1/2018	6/30/2018		2/8/2019
NV0000767	ROSEMOUNT WATER CO	03MJ	CRUR	RADS URANIUM	RAD	MONITORING, ROUTINE MAJOR	1/1/2018	6/30/2018		2/8/2019
NV0000767	ROSEMOUNT WATER CO	03MJ	CRUR	RADS URANIUM	RAD	MONITORING, ROUTINE MAJOR	1/1/2018	6/30/2018		7/21/2018
NV0000767	ROSEMOUNT WATER CO	03MJ	CRUR	RADS URANIUM	RAD	MONITORING, ROUTINE MAJOR	1/1/2018	6/30/2018		
NV0000767	ROSEMOUNT WATER CO	03MJ	CRUR	RADS URANIUM	RAD	MONITORING, ROUTINE MAJOR	1/1/2018	6/30/2018		2/8/2019
NV0000767	ROSEMOUNT WATER CO	03MJ	CRUR	RADS URANIUM	RAD	MONITORING, ROUTINE MAJOR	1/1/2018	6/30/2018		
NV0000767	ROSEMOUNT WATER CO	03MJ	CRUR	RADS URANIUM	RAD	MONITORING, ROUTINE MAJOR	7/1/2018	12/31/2018		
NV0000767	ROSEMOUNT WATER CO	03MJ	CRUR	RADS URANIUM	RAD	MONITORING, ROUTINE MAJOR	7/1/2018	12/31/2018		
NV0000767	ROSEMOUNT WATER CO	03MJ	CRUR	RADS URANIUM	RAD	MONITORING, ROUTINE MAJOR	7/1/2018	12/31/2018		
NV0000767	ROSEMOUNT WATER CO	27MJ	0999	CHLORINE	ST1 DBP	MONITORING, ROUTINE (DBP), MAJOR	4/1/2016	6/30/2016		3/31/2018
NV0000767	ROSEMOUNT WATER CO	27MJ	0999	CHLORINE	ST1 DBP	MONITORING, ROUTINE (DBP), MAJOR	1/1/2017	3/31/2017		3/31/2018
NV0000767	ROSEMOUNT WATER CO	27MJ	CDB2	DBPR STAGE 2	ST2 DBP	MONITORING, ROUTINE (DBP), MAJOR	7/1/2014	6/30/2015		8/27/2018
NV0000767	ROSEMOUNT WATER CO	27MJ	CDB2	DBPR STAGE 2	ST2 DBP	MONITORING, ROUTINE (DBP), MAJOR	7/1/2015	6/30/2016		8/27/2018
NV0000767	ROSEMOUNT WATER CO	27MJ	CDB2	DBPR STAGE 2	ST2 DBP	MONITORING, ROUTINE (DBP), MAJOR	7/1/2016	6/30/2017		8/27/2018
NV0000767	ROSEMOUNT WATER CO	52	5000	LEAD & COPPER RULE	LCR	FOLLOW-UP OR ROUTINE TAP M/R (LCR)	10/1/2017	7/27/2018		7/27/2018

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0000767	ROSEMOUNT WATER CO	75	7500	PUBLIC NOTICE		PUBLIC NOTICE RULE LINKED TO VIOLATION	4/1/2018			
Total Number of Violations for this Water System:										24
NV0004074	ROUND MOUNTAIN PUC	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2017	12/31/2017		1/5/2018
NV0004074	ROUND MOUNTAIN PUC	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2017	12/31/2017		1/5/2018
NV0004074	ROUND MOUNTAIN PUC	27MJ	CDB2	DBPR STAGE 2	ST2 DBP	MONITORING, ROUTINE (DBP), MAJOR	9/1/2014	8/31/2015		2/28/2018
NV0004074	ROUND MOUNTAIN PUC	27MJ	CDB2	DBPR STAGE 2	ST2 DBP	MONITORING, ROUTINE (DBP), MAJOR	1/1/2016	12/31/2016		2/28/2018
NV0004074	ROUND MOUNTAIN PUC	27MJ	CDB2	DBPR STAGE 2	ST2 DBP	MONITORING, ROUTINE (DBP), MAJOR	10/1/2016	9/30/2017		2/28/2018
NV0004074	ROUND MOUNTAIN PUC	52	5000	LEAD & COPPER RULE	LCR	FOLLOW-UP OR ROUTINE TAP M/R (LCR)	10/1/2017	7/9/2018		7/9/2018
Total Number of Violations for this Water System:										6
NV0004112	RUBY 360 LODGE	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	10/1/2018	12/31/2018		1/2/2019
Total Number of Violations for this Water System:										1
NV0002222	RYE PATCH PETROLEUM	2B	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	LEVEL 2 ASSESSMENT, 2ND LEVEL 1(RTCR)	8/5/2017	6/13/2018		6/13/2018
NV0002222	RYE PATCH PETROLEUM	2C	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	CORRECTIVE/EXPEDITED ACTIONS (RTCR)	8/5/2017	6/13/2018		6/13/2018
NV0002222	RYE PATCH PETROLEUM	2C	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	CORRECTIVE/EXPEDITED ACTIONS (RTCR)	12/1/2018	2/3/2019		2/3/2019
NV0002222	RYE PATCH PETROLEUM	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	2/1/2018	2/28/2018		3/28/2018
NV0002222	RYE PATCH PETROLEUM	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	7/1/2018	7/31/2018		8/5/2018
Total Number of Violations for this Water System:										5
NV0002223	RYE PATCH STATE PARK	45	0700	GROUNDWATER RULE	GWR	FAILURE ADDRESS DEFICIENCY (GWR)	8/11/2018			

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
Total Number of Violations for this Water System:										1
NV0005023	RYE PATCH STATE PARK PICNIC AREA	45	0700	GROUNDWATER RULE	GWR	FAILURE ADDRESS DEFICIENCY (GWR)	9/12/2018			
Total Number of Violations for this Water System:										1
NV0001092	RYNDON GAS & FOOD LLC	93	CSC2	SECONDARY IOCS	SECONDARIES	STATE FAILURE TO MONITOR	1/1/2014	12/31/2016		2/8/2018
Total Number of Violations for this Water System:										1
NV0002047	S AND J VENTURES DBA JUNCTION BAR	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	4/1/2018	6/30/2018		7/24/2018
Total Number of Violations for this Water System:										1
NV0002023	SAGE VALLEY MHP	27MJ	0999	CHLORINE	ST1 DBP	MONITORING, ROUTINE (DBP), MAJOR	7/1/2018	9/30/2018		
NV0002023	SAGE VALLEY MHP	27MJ	CDB2	DBPR STAGE 2	ST2 DBP	MONITORING, ROUTINE (DBP), MAJOR	1/1/2018	12/31/2018		
NV0002023	SAGE VALLEY MHP	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	8/1/2018	8/31/2018		8/23/2018
NV0002023	SAGE VALLEY MHP	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	9/1/2018	9/30/2018		10/30/2018
NV0002023	SAGE VALLEY MHP	52	5000	LEAD & COPPER RULE	LCR	FOLLOW-UP OR ROUTINE TAP M/R (LCR)	10/1/2018			
NV0002023	SAGE VALLEY MHP	S1	1032	MANGANESE	SECONDARIES	STATE MCL EXCEDENCE	7/1/2018	9/30/2018	0.52 MG/L	
NV0002023	SAGE VALLEY MHP	S1	1032	MANGANESE	SECONDARIES	STATE MCL EXCEDENCE	10/1/2018	12/31/2018	0.43 MG/L	
Total Number of Violations for this Water System:										7
NV0000872	SAGE VALLEY RV PARK	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	7/1/2018	9/30/2018		8/23/2018
NV0000872	SAGE VALLEY RV PARK	93	1032	MANGANESE	SECONDARIES	STATE FAILURE TO MONITOR	4/1/2018	6/30/2018		
NV0000872	SAGE VALLEY RV PARK	S1	1032	MANGANESE	SECONDARIES	STATE MCL EXCEDENCE	10/1/2015	12/31/2015	3.4 MG/L	10/30/2018

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0000872	SAGE VALLEY RV PARK	S1	1032	MANGANESE	SECONDARIES	STATE MCL EXCEDENCE	1/1/2017	3/31/2017	2.9 MG/L	10/30/2018
NV0000872	SAGE VALLEY RV PARK	S1	1032	MANGANESE	SECONDARIES	STATE MCL EXCEDENCE	4/1/2017	6/30/2017	3.5 MG/L	10/30/2018
NV0000872	SAGE VALLEY RV PARK	S1	1032	MANGANESE	SECONDARIES	STATE MCL EXCEDENCE	7/1/2017	9/30/2017	2.4 MG/L	10/30/2018
NV0000872	SAGE VALLEY RV PARK	S1	1032	MANGANESE	SECONDARIES	STATE MCL EXCEDENCE	1/1/2018	3/31/2018	1.8 MG/L	10/30/2018
Total Number of Violations for this Water System:										7
NV0000746	SAND HARBOR STATE PARK	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2017	12/31/2017		2/8/2018
Total Number of Violations for this Water System:										1
NV0000380	SANDY VALLEY CENTER	3AMJ	3014	E. COLI	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	9/1/2018	9/30/2018		10/16/2018
Total Number of Violations for this Water System:										1
NV0000897	SCHURZ ELEMENTARY SCHOOL	03MJ	CDAS	ARSENIC (AS)	IOC	MONITORING, ROUTINE MAJOR	2/1/2018	2/28/2018		3/22/2018
Total Number of Violations for this Water System:										1
NV0002557	SHARONS	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	4/1/2018	6/30/2018		
NV0002557	SHARONS	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	7/1/2018	9/30/2018		
Total Number of Violations for this Water System:										2
NV0005028	SHOSHONE ESTATES WATER CO INC	02	1005	ARSENIC	IOC	MCL, AVERAGE	1/1/2018	3/31/2018	0.030 MG/L	
NV0005028	SHOSHONE ESTATES WATER CO INC	02	1005	ARSENIC	IOC	MCL, AVERAGE	4/1/2018	6/30/2018	0.030 MG/L	
NV0005028	SHOSHONE ESTATES WATER CO INC	02	1005	ARSENIC	IOC	MCL, AVERAGE	7/1/2018	9/30/2018	.031 MG/L	
NV0005028	SHOSHONE ESTATES WATER CO INC	02	1005	ARSENIC	IOC	MCL, AVERAGE	10/1/2018	12/31/2018	0.031 MG/L	

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0005028	SHOSHONE ESTATES WATER CO INC	71	7000	CONSUMER CONFIDENCE RULE		CCR REPORT	7/1/2018	7/6/2018		7/6/2018
Total Number of Violations for this Water System:										5
NV0004125	SIERRA SAFARI ZOO	3BMJ	3014	E. COLI	RTCR	MONITORING, ADD. ROUTINE, MAJOR (RTCR)	4/1/2018	4/30/2018		5/16/2018
Total Number of Violations for this Water System:										1
NV0004021	SILVER KNOLLS MUTUAL WATER	02	1005	ARSENIC	IOC	MCL, AVERAGE	1/1/2018	3/31/2018	0.011 MG/L	
NV0004021	SILVER KNOLLS MUTUAL WATER	02	1005	ARSENIC	IOC	MCL, AVERAGE	4/1/2018	6/30/2018	0.011 MG/L	
NV0004021	SILVER KNOLLS MUTUAL WATER	02	1005	ARSENIC	IOC	MCL, AVERAGE	7/1/2018	9/30/2018	0.011 MG/L	
NV0004021	SILVER KNOLLS MUTUAL WATER	02	1005	ARSENIC	IOC	MCL, AVERAGE	10/1/2018	12/31/2018	11 UG/L	
NV0004021	SILVER KNOLLS MUTUAL WATER	27MJ	CDB2	DBPR STAGE 2	ST2 DBP	MONITORING, ROUTINE (DBP), MAJOR	1/1/2016	9/30/2018		
NV0004021	SILVER KNOLLS MUTUAL WATER	45	0700	GROUNDWATER RULE	GWR	FAILURE ADDRESS DEFICIENCY (GWR)	3/1/2018			
Total Number of Violations for this Water System:										6
NV0000761	SLIDE MOUNTAIN SKI AREA	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2018	12/31/2018		2/12/2019
Total Number of Violations for this Water System:										1
NV0001140	SLOAN ARMY RESERVE CENTER	S1	1930	TDS	SECONDARIES	STATE MCL EXCEDENCE	1/1/2018	3/31/2018	1030 MG/L	
NV0001140	SLOAN ARMY RESERVE CENTER	S1	1930	TDS	SECONDARIES	STATE MCL EXCEDENCE	4/1/2018	6/30/2018	1030 MG/L	
NV0001140	SLOAN ARMY RESERVE CENTER	S1	1930	TDS	SECONDARIES	STATE MCL EXCEDENCE	7/1/2018	9/30/2018	1050 MG/L	
Total Number of Violations for this Water System:										3
NV0000351	SOUTH CRESTVIEW HOMEOWNERS	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	6/1/2018	6/30/2018		7/17/2018

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
Total Number of Violations for this Water System:										1
NV0002209	SOUTH RUBY CAMPGROUND USFS	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	5/1/2018	5/31/2018		6/26/2018
Total Number of Violations for this Water System:										1
NV0000873	SOUTHFORK STATE PARK AND	45	0700	GROUNDWATER RULE	GWR	FAILURE ADDRESS DEFICIENCY (GWR)	12/8/2017	8/27/2018		8/27/2018
Total Number of Violations for this Water System:										1
NV0004041	SPOONER LAKE STATE PARK	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2017	12/31/2017		3/8/2018
Total Number of Violations for this Water System:										1
NV0001071	SPRING MOUNTAIN RANCH STATE PARK	34MJ	3014	E. COLI	GWR	MONITOR GWR TRIGGERED/ADDITONAL, MAJOR	8/9/2018	8/14/2018		8/14/2018
Total Number of Violations for this Water System:										1
NV0000292	SPRING MOUNTAIN YOUTH CAMP	71	7000	CONSUMER CONFIDENCE RULE		CCR REPORT	7/1/2018	7/30/2018		7/30/2018
Total Number of Violations for this Water System:										1
NV0002124	SPRING VALLEY STATE PARK	93	1032	MANGANESE	SECONDARIES	STATE FAILURE TO MONITOR	1/1/2018	1/31/2018		10/3/2018
NV0002124	SPRING VALLEY STATE PARK	S1	1032	MANGANESE	SECONDARIES	STATE MCL EXCEDENCE	1/1/2018	3/31/2018	0.293 MG/L	
NV0002124	SPRING VALLEY STATE PARK	S1	1032	MANGANESE	SECONDARIES	STATE MCL EXCEDENCE	4/1/2018	6/30/2018	0.27 MG/L	
NV0002124	SPRING VALLEY STATE PARK	S1	1032	MANGANESE	SECONDARIES	STATE MCL EXCEDENCE	7/1/2018	9/30/2018	0.3 MG/L	
NV0002124	SPRING VALLEY STATE PARK	S1	1032	MANGANESE	SECONDARIES	STATE MCL EXCEDENCE	10/1/2018	12/31/2018	0.33 MG/L	
Total Number of Violations for this Water System:										5
NV0004061	SPRINGWOOD EQUESTRIAN CENTER	02	1005	ARSENIC	IOC	MCL, AVERAGE	4/1/2017	6/30/2017	0.021 MG/L	6/4/2018

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0004061	SPRINGWOOD EQUESTRIAN CENTER	02	1005	ARSENIC	IOC	MCL, AVERAGE	7/1/2017	9/30/2017	0.016 MG/L	6/4/2018
NV0004061	SPRINGWOOD EQUESTRIAN CENTER	02	1005	ARSENIC	IOC	MCL, AVERAGE	10/1/2017	12/31/2017	0.016 MG/L	6/4/2018
NV0004061	SPRINGWOOD EQUESTRIAN CENTER	02	1005	ARSENIC	IOC	MCL, AVERAGE	1/1/2018	3/31/2018	0.013 MG/L	6/4/2018
NV0004061	SPRINGWOOD EQUESTRIAN CENTER	52	5000	LEAD & COPPER RULE	LCR	FOLLOW-UP OR ROUTINE TAP M/R (LCR)	10/1/2018			
Total Number of Violations for this Water System:										5
NV0004040	STAGECOACH MARKET	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	7/1/2018	9/30/2018		11/8/2018
Total Number of Violations for this Water System:										1
NV0002598	STAGESTOP RESTAURANT	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	6/1/2018	6/30/2018		7/30/2018
Total Number of Violations for this Water System:										1
NV0000240	STOREY COUNTY WATER DISTRICT	32MJ	LT2D	LT2 FILTER LT10K EC	SWTR	MONITORING, SOURCE (LT2), MAJOR	10/1/2017	10/31/2017		10/30/2018
NV0000240	STOREY COUNTY WATER DISTRICT	32MJ	LT2D	LT2 FILTER LT10K EC	SWTR	MONITORING, SOURCE (LT2), MAJOR	12/1/2017	12/31/2017		10/30/2018
NV0000240	STOREY COUNTY WATER DISTRICT	32MN	LT2D	LT2 FILTER LT10K EC	SWTR	MONITORING, SOURCE (LT2), MINOR	7/1/2017	7/31/2017		10/30/2018
NV0000240	STOREY COUNTY WATER DISTRICT	32MN	LT2D	LT2 FILTER LT10K EC	SWTR	MONITORING, SOURCE (LT2), MINOR	8/1/2017	8/31/2017		10/30/2018
NV0000240	STOREY COUNTY WATER DISTRICT	32MN	LT2D	LT2 FILTER LT10K EC	SWTR	MONITORING, SOURCE (LT2), MINOR	9/1/2017	9/30/2017		10/30/2018
NV0000240	STOREY COUNTY WATER DISTRICT	32MN	LT2D	LT2 FILTER LT10K EC	SWTR	MONITORING, SOURCE (LT2), MINOR	11/1/2017	11/30/2017		10/30/2018
NV0000240	STOREY COUNTY WATER DISTRICT	32MN	LT2D	LT2 FILTER LT10K EC	SWTR	MONITORING, SOURCE (LT2), MINOR	1/1/2018	1/31/2018		10/30/2018
NV0000240	STOREY COUNTY WATER DISTRICT	32MN	LT2D	LT2 FILTER LT10K EC	SWTR	MONITORING, SOURCE (LT2), MINOR	2/1/2018	2/28/2018		10/30/2018

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0000240	STOREY COUNTY WATER DISTRICT	32MN	LT2D	LT2 FILTER LT10K EC	SWTR	MONITORING, SOURCE (LT2), MINOR	3/1/2018	3/31/2018		10/30/2018
NV0000240	STOREY COUNTY WATER DISTRICT	32MN	LT2D	LT2 FILTER LT10K EC	SWTR	MONITORING, SOURCE (LT2), MINOR	4/1/2018	4/30/2018		10/30/2018
Total Number of Violations for this Water System:										10
NV0000123	SUNRISE MOUNTAIN TP	01	1040	NITRATE	IOC	MCL, SINGLE SAMPLE	1/1/2018	3/31/2018	11 MG/L	
NV0000123	SUNRISE MOUNTAIN TP	01	1040	NITRATE	IOC	MCL, SINGLE SAMPLE	4/1/2018	6/30/2018	14 MG/L	
NV0000123	SUNRISE MOUNTAIN TP	02	1005	ARSENIC	IOC	MCL, AVERAGE	1/1/2018	3/31/2018	0.012 MG/L	
NV0000123	SUNRISE MOUNTAIN TP	02	1005	ARSENIC	IOC	MCL, AVERAGE	4/1/2018	6/30/2018	0.011 MG/L	
NV0000123	SUNRISE MOUNTAIN TP	02	1005	ARSENIC	IOC	MCL, AVERAGE	7/1/2018	9/30/2018	0.011 MG/L	
NV0000123	SUNRISE MOUNTAIN TP	3AMJ	3014	E. COLI	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	7/1/2018	7/31/2018		
NV0000123	SUNRISE MOUNTAIN TP	3AMJ	3014	E. COLI	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	8/1/2018	8/31/2018		
Total Number of Violations for this Water System:										7
NV0000765	SUTCLIFFE MOBILE PARK	71	7000	CONSUMER CONFIDENCE RULE		CCR REPORT	7/1/2018	9/27/2018		9/27/2018
Total Number of Violations for this Water System:										1
NV0000329	T AND J INVESTMENTS DBA THE GROVE	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2017	12/31/2017		3/30/2018
NV0000329	T AND J INVESTMENTS DBA THE GROVE	3AMN	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MINOR (RTCR)	10/1/2017	10/31/2017		1/11/2018
Total Number of Violations for this Water System:										2
NV0000913	TAHOE RENO INDUSTRIAL CENTER	3AMN	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MINOR (RTCR)	7/1/2018	7/31/2018		8/31/2018
Total Number of Violations for this Water System:										1

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0002076	TAYLOR CANYON CLUB	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2018	12/31/2018		
NV0002076	TAYLOR CANYON CLUB	2C	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	CORRECTIVE/EXPEDITED ACTIONS (RTCR)	12/1/2018			
NV0002076	TAYLOR CANYON CLUB	93	1028	IRON	SECONDARIES	STATE FAILURE TO MONITOR	1/1/2018	12/31/2018		
NV0002076	TAYLOR CANYON CLUB	93	1032	MANGANESE	SECONDARIES	STATE FAILURE TO MONITOR	1/1/2018	12/31/2018		
Total Number of Violations for this Water System:										4
NV0003035	THE HUBB	45	0700	GROUNDWATER RULE	GWR	FAILURE ADDRESS DEFICIENCY (GWR)	12/17/2016			
Total Number of Violations for this Water System:										1
NV0000727	THE VINE	45	0700	GROUNDWATER RULE	GWR	FAILURE ADDRESS DEFICIENCY (GWR)	3/2/2019			
NV0000727	THE VINE	45	0700	GROUNDWATER RULE	GWR	FAILURE ADDRESS DEFICIENCY (GWR)	3/2/2019			
Total Number of Violations for this Water System:										2
NV0003043	THOMAS CANYON CAMPGROUND USFS	2ANC	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	LEVEL 1 ASSESS, MULTIPLE TC POS (RTCR)	10/14/2018	11/28/2018		11/28/2018
NV0003043	THOMAS CANYON CAMPGROUND USFS	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	5/1/2018	5/31/2018		6/4/2018
Total Number of Violations for this Water System:										2
NV0001139	TIMET CORPORATION	02	2950	TTHM	ST2 DBP	MCL, LRAA	10/1/2017	12/31/2017	0.087 MG/L	11/14/2018
NV0001139	TIMET CORPORATION	02	2950	TTHM	ST2 DBP	MCL, LRAA	1/1/2018	3/31/2018	92 UG/L	11/14/2018
NV0001139	TIMET CORPORATION	02	2950	TTHM	ST2 DBP	MCL, LRAA	4/1/2018	6/30/2018	92 UG/L	11/14/2018
NV0001139	TIMET CORPORATION	02	2950	TTHM	ST2 DBP	MCL, LRAA	7/1/2018	9/30/2018	82.5 UG/L	11/14/2018
Total Number of Violations for this Water System:										4

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0000055	TOLAS WATERWORKS CO OP	S1	1920	ODOR	SECONDARIES	STATE MCL EXCEDENCE	10/1/2017	12/31/2017	8 TON	12/26/2018
NV0000055	TOLAS WATERWORKS CO OP	S1	1920	ODOR	SECONDARIES	STATE MCL EXCEDENCE	1/1/2018	3/31/2018	8 TON	12/26/2018
Total Number of Violations for this Water System:										2
NV0000804	TOLICHA PEAK ELECTRONIC COMBAT	27MJ	CDB2	DBPR STAGE 2	ST2 DBP	MONITORING, ROUTINE (DBP), MAJOR	1/1/2015	9/30/2017		2/28/2018
Total Number of Violations for this Water System:										1
NV0002586	TOP GUN SKATE	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2018	12/31/2018		5/7/2019
NV0002586	TOP GUN SKATE	2ANC	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	LEVEL 1 ASSESS, MULTIPLE TC POS (RTCR)	3/26/2017	6/19/2018		6/19/2018
NV0002586	TOP GUN SKATE	2C	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	CORRECTIVE/EXPEDITED ACTIONS (RTCR)	9/17/2017	6/19/2018		6/19/2018
NV0002586	TOP GUN SKATE	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	11/1/2018	11/30/2018		2/20/2019
NV0002586	TOP GUN SKATE	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	12/1/2018	12/31/2018		2/20/2019
NV0002586	TOP GUN SKATE	93	1032	MANGANESE	SECONDARIES	STATE FAILURE TO MONITOR	7/1/2018	9/30/2018		
NV0002586	TOP GUN SKATE	93	1032	MANGANESE	SECONDARIES	STATE FAILURE TO MONITOR	10/1/2018	12/31/2018		
NV0002586	TOP GUN SKATE	S1	1032	MANGANESE	SECONDARIES	STATE MCL EXCEDENCE	10/1/2015	12/31/2015	1.2 MG/L	4/30/2018
NV0002586	TOP GUN SKATE	S1	1032	MANGANESE	SECONDARIES	STATE MCL EXCEDENCE	1/1/2016	3/31/2016	1.3 MG/L	4/30/2018
NV0002586	TOP GUN SKATE	S1	1032	MANGANESE	SECONDARIES	STATE MCL EXCEDENCE	1/1/2017	3/31/2017	0.6 MG/L	4/30/2018
NV0002586	TOP GUN SKATE	S1	1032	MANGANESE	SECONDARIES	STATE MCL EXCEDENCE	4/1/2017	6/30/2017	1.3 MG/L	4/30/2018
NV0002586	TOP GUN SKATE	S1	1032	MANGANESE	SECONDARIES	STATE MCL EXCEDENCE	7/1/2017	9/30/2017	1.0 MG/L	4/30/2018

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0002586	TOP GUN SKATE	S1	1032	MANGANESE	SECONDARIES	STATE MCL EXCEDENCE	10/1/2017	12/31/2017	0.86 MG/L	4/30/2018
Total Number of Violations for this Water System:										13
NV0000070	TOPAZ LAKE WATER CO INC	02	2987	TETRACHLOROETHYLENE	VOC	MCL, AVERAGE	10/1/2017	12/31/2017	0.010 MG/L	11/13/2018
NV0000070	TOPAZ LAKE WATER CO INC	02	2987	TETRACHLOROETHYLENE	VOC	MCL, AVERAGE	1/1/2018	3/31/2018	0.010 MG/L	11/13/2018
NV0000070	TOPAZ LAKE WATER CO INC	02	2987	TETRACHLOROETHYLENE	VOC	MCL, AVERAGE	4/1/2018	6/30/2018	8.4 UG/L	11/13/2018
NV0000070	TOPAZ LAKE WATER CO INC	02	2987	TETRACHLOROETHYLENE	VOC	MCL, AVERAGE	7/1/2018	9/30/2018	9 UG/L	11/13/2018
Total Number of Violations for this Water System:										4
NV0000239	TOPAZ RANCH ESTATES GID	27MJ	0999	CHLORINE	ST1 DBP	MONITORING, ROUTINE (DBP), MAJOR	7/1/2017	9/30/2017		10/1/2018
NV0000239	TOPAZ RANCH ESTATES GID	27MJ	0999	CHLORINE	ST1 DBP	MONITORING, ROUTINE (DBP), MAJOR	7/1/2017	9/30/2017		10/1/2018
NV0000239	TOPAZ RANCH ESTATES GID	27MJ	CDB2	DBPR STAGE 2	ST2 DBP	MONITORING, ROUTINE (DBP), MAJOR	10/1/2016	9/30/2017		2/28/2018
Total Number of Violations for this Water System:										3
NV0000314	TORREY PINES TINA LN WTR ASSOC	53	5000	LEAD & COPPER RULE	LCR	WATER QUALITY PARAMETER M/R (LCR)	7/1/2017	12/31/2017		6/14/2018
Total Number of Violations for this Water System:										1
NV0000331	TRAILS END GENERAL STORE	45	0700	GROUNDWATER RULE	GWR	FAILURE ADDRESS DEFICIENCY (GWR)	4/6/2016	6/7/2018		6/7/2018
Total Number of Violations for this Water System:										1
NV0001059	TROPICANA RESORT AND CASINO	27MJ	CDB2	DBPR STAGE 2	ST2 DBP	MONITORING, ROUTINE (DBP), MAJOR	12/1/2016	2/28/2017		2/7/2018
Total Number of Violations for this Water System:										1
NV0000978	TRUCKEE CANYON	03MJ	CSOC	SOCS PHASE 2 & 5	SOC	MONITORING, ROUTINE MAJOR	7/1/2017	9/30/2017		8/14/2018

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0000978	TRUCKEE CANYON	03MJ	CVOC	VOCS PHASE 2 & 5	VOC	MONITORING, ROUTINE MAJOR	7/1/2017	9/30/2017		8/14/2018
Total Number of Violations for this Water System:										2
NV0000189	TUSCARORA WATER SYSTEM	27MJ	CDB2	DBPR STAGE 2	ST2 DBP	MONITORING, ROUTINE (DBP), MAJOR	9/1/2016	8/31/2017		2/28/2018
Total Number of Violations for this Water System:										1
NV0001154	UNION PACIFIC RAILROAD	1A	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MCL, E. COLI, POS E COLI (RTCR)	9/1/2018	9/30/2018		11/8/2018
Total Number of Violations for this Water System:										1
NV0001147	URBAN ROOTS	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	1/1/2018	1/31/2018		
Total Number of Violations for this Water System:										1
NV0001145	US ECOLOGY NEVADA	02	1005	ARSENIC	IOC	MCL, AVERAGE	4/1/2017	6/30/2017	0.018 MG/L	11/29/2018
NV0001145	US ECOLOGY NEVADA	02	1005	ARSENIC	IOC	MCL, AVERAGE	7/1/2017	9/30/2017	0.018 MG/L	11/29/2018
NV0001145	US ECOLOGY NEVADA	02	1005	ARSENIC	IOC	MCL, AVERAGE	10/1/2017	12/31/2017	0.019 MG/L	11/29/2018
NV0001145	US ECOLOGY NEVADA	02	1005	ARSENIC	IOC	MCL, AVERAGE	1/1/2018	3/31/2018	0.019 MG/L	11/29/2018
NV0001145	US ECOLOGY NEVADA	02	1005	ARSENIC	IOC	MCL, AVERAGE	4/1/2018	6/30/2018	0.020 MG/L	11/29/2018
NV0001145	US ECOLOGY NEVADA	02	1005	ARSENIC	IOC	MCL, AVERAGE	7/1/2018	9/30/2018	0.015 MG/L	11/29/2018
NV0001145	US ECOLOGY NEVADA	S1	1025	FLUORIDE	SECONDARIES	STATE MCL EXCEDENCE	1/1/2018	3/31/2018	3 MG/L	
NV0001145	US ECOLOGY NEVADA	S1	1025	FLUORIDE	SECONDARIES	STATE MCL EXCEDENCE	4/1/2018	6/30/2018	2.89 MG/L	
Total Number of Violations for this Water System:										8
NV0002112	VALMY PETROLEUM INC	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	12/1/2018	12/31/2018		1/2/2019

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
Total Number of Violations for this Water System:										1
NV0003016	VALMY STATION MOBILE HOME PARK	1A	3014	E. COLI	RTCR	MCL, E. COLI, POS E COLI (RTCR)	6/1/2018	6/30/2018		7/17/2018
NV0003016	VALMY STATION MOBILE HOME PARK	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	4/1/2018	4/30/2018		5/16/2018
Total Number of Violations for this Water System:										2
NV0000773	VERDI MUTUAL WATER COMPANY	45	0700	GROUNDWATER RULE	GWR	FAILURE ADDRESS DEFICIENCY (GWR)	12/29/2016			
Total Number of Violations for this Water System:										1
NV0002556	VFW PAHRUMP POST 10054	93	1930	TDS	SECONDARIES	STATE FAILURE TO MONITOR	1/1/2016	12/31/2016		4/6/2018
NV0002556	VFW PAHRUMP POST 10054	S1	1055	SULFATE	SECONDARIES	STATE MCL EXCEDENCE	1/1/2017	3/31/2017	777 MG/L	4/6/2018
NV0002556	VFW PAHRUMP POST 10054	S1	1055	SULFATE	SECONDARIES	STATE MCL EXCEDENCE	10/1/2017	12/31/2017	690 MG/L	4/6/2018
NV0002556	VFW PAHRUMP POST 10054	S1	1930	TDS	SECONDARIES	STATE MCL EXCEDENCE	1/1/2017	3/31/2017	1250 MG/L	4/6/2018
NV0002556	VFW PAHRUMP POST 10054	S1	1930	TDS	SECONDARIES	STATE MCL EXCEDENCE	4/1/2017	6/30/2017	1600 MG/L	4/6/2018
NV0002556	VFW PAHRUMP POST 10054	S1	1930	TDS	SECONDARIES	STATE MCL EXCEDENCE	10/1/2017	12/31/2017	1700 MG/L	4/6/2018
Total Number of Violations for this Water System:										6
NV0004048	WALKER RIVER RESORT	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	4/1/2018	6/30/2018		8/7/2018
Total Number of Violations for this Water System:										1
NV0004118	WALKER RIVER STATE REC AREA PITCHFORK	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	10/1/2018	10/31/2018		11/27/2018
Total Number of Violations for this Water System:										1
NV0000922	WARD CHARCOAL OVENS STATE PARK	2D	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	STARTUP PROCEDURES TT (RTCR)	5/2/2018	6/8/2018		6/8/2018

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0000922	WARD CHARCOAL OVENS STATE PARK	93	1905	COLOR	SECONDARIES	STATE FAILURE TO MONITOR	5/1/2018	5/31/2018		6/12/2018
NV0000922	WARD CHARCOAL OVENS STATE PARK	93	1905	COLOR	SECONDARIES	STATE FAILURE TO MONITOR	7/1/2018	7/31/2018		
NV0000922	WARD CHARCOAL OVENS STATE PARK	93	1028	IRON	SECONDARIES	STATE FAILURE TO MONITOR	7/1/2018	9/30/2018		
NV0000922	WARD CHARCOAL OVENS STATE PARK	93	1028	IRON	SECONDARIES	STATE FAILURE TO MONITOR	10/1/2018	12/31/2018		
NV0000922	WARD CHARCOAL OVENS STATE PARK	S1	1028	IRON	SECONDARIES	STATE MCL EXCEDENCE	4/1/2018	6/30/2018	1.2 MG/L	
Total Number of Violations for this Water System:										6

NV0000793	WASHOE LAKE STATE PARK	S1	1028	IRON	SECONDARIES	STATE MCL EXCEDENCE	4/1/2017	6/30/2017	0.99 MG/L	6/6/2018
NV0000793	WASHOE LAKE STATE PARK	S1	1028	IRON	SECONDARIES	STATE MCL EXCEDENCE	7/1/2017	9/30/2017	1.5 MG/L	6/6/2018
NV0000793	WASHOE LAKE STATE PARK	S1	1032	MANGANESE	SECONDARIES	STATE MCL EXCEDENCE	4/1/2016	6/30/2016	0.19 MG/L	2/20/2018
NV0000793	WASHOE LAKE STATE PARK	S1	1032	MANGANESE	SECONDARIES	STATE MCL EXCEDENCE	4/1/2017	6/30/2017	0.43 MG/L	6/6/2018
NV0000793	WASHOE LAKE STATE PARK	S1	1032	MANGANESE	SECONDARIES	STATE MCL EXCEDENCE	7/1/2017	9/30/2017	0.34 MG/L	6/6/2018
Total Number of Violations for this Water System:										5

NV0000318	WASHOE LAKE STATE PARK NORTH BOAT	45	0700	GROUNDWATER RULE	GWR	FAILURE ADDRESS DEFICIENCY (GWR)	8/12/2015			
NV0000318	WASHOE LAKE STATE PARK NORTH BOAT	S1	1028	IRON	SECONDARIES	STATE MCL EXCEDENCE	1/1/2018	3/31/2018	1.8 MG/L	
NV0000318	WASHOE LAKE STATE PARK NORTH BOAT	S1	1028	IRON	SECONDARIES	STATE MCL EXCEDENCE	4/1/2018	6/30/2018	1.8 MG/L	
NV0000318	WASHOE LAKE STATE PARK NORTH BOAT	S1	1032	MANGANESE	SECONDARIES	STATE MCL EXCEDENCE	1/1/2018	3/31/2018	0.22 MG/L	
NV0000318	WASHOE LAKE STATE PARK NORTH BOAT	S1	1032	MANGANESE	SECONDARIES	STATE MCL EXCEDENCE	4/1/2018	6/30/2018	0.22 MG/L	
Total Number of Violations for this Water System:										5

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0004113	WASHOE VALLEY CHRISTIAN CHURCH	34MJ	3014	E. COLI	ST2 DBP	MONITOR GWR TRIGGERED/ADDITONAL, MAJOR	11/28/2017	6/28/2018		6/28/2018
NV0004113	WASHOE VALLEY CHRISTIAN CHURCH	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	7/1/2018	9/30/2018		11/7/2018
NV0004113	WASHOE VALLEY CHRISTIAN CHURCH	3BMJ	3014	E. COLI	RTCR	MONITORING, ADD. ROUTINE, MAJOR (RTCR)	12/1/2017	12/31/2017		1/8/2018
NV0004113	WASHOE VALLEY CHRISTIAN CHURCH	45	0700	GROUNDWATER RULE	GWR	FAILURE ADDRESS DEFICIENCY (GWR)	3/30/2018			
Total Number of Violations for this Water System:										4
NV0000709	WEST RENO WATER SYSTEM	45	0700	GROUNDWATER RULE	GWR	FAILURE ADDRESS DEFICIENCY (GWR)	8/1/2018	12/18/2018		12/18/2018
Total Number of Violations for this Water System:										1
NV0002054	WEST VALLEY WATER SYSTEM	03MJ	CDAS	ARSENIC (AS)	IOC	MONITORING, ROUTINE MAJOR	1/1/2018	3/31/2018		5/1/2018
Total Number of Violations for this Water System:										1
NV0000058	WILDES MANOR	02	1005	ARSENIC	IOC	MCL, AVERAGE	1/1/2018	3/31/2018	0.016 MG/L	
NV0000058	WILDES MANOR	02	1005	ARSENIC	IOC	MCL, AVERAGE	4/1/2018	6/30/2018	0.016 MG/L	
NV0000058	WILDES MANOR	03MJ	CDAS	ARSENIC (AS)	IOC	MONITORING, ROUTINE MAJOR	1/1/2018	3/31/2018		
NV0000058	WILDES MANOR	03MJ	CDAS	ARSENIC (AS)	IOC	MONITORING, ROUTINE MAJOR	4/1/2018	6/30/2018		
NV0000058	WILDES MANOR	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	3/1/2018	3/31/2018		
NV0000058	WILDES MANOR	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	4/1/2018	4/30/2018		
Total Number of Violations for this Water System:										6
NV0002080	WILDHORSE RESORT	3AMJ	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MAJOR (RTCR)	10/1/2018	12/31/2018		2/27/2019
Total Number of Violations for this Water System:										1

Water System ID	Water System Name	Vio Type	Analyte Code	Analyte Name	Rule Group	Vio Description	Compliance Period Begin Date	Compliance Period End Date	Vio Result	RTC Date
NV0000255	YERINGTON CITY OF	03MJ	CDAS	ARSENIC (AS)	IOC	MONITORING, ROUTINE MAJOR	4/1/2018	6/30/2018		2/28/2019
NV0000255	YERINGTON CITY OF	03MJ	2039	DI(2-ETHYLHEXYL) PHTHALATE	SOC	MONITORING, ROUTINE MAJOR	1/1/2018	12/31/2018		
NV0000255	YERINGTON CITY OF	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2017	12/31/2017		9/6/2018
NV0000255	YERINGTON CITY OF	03MJ	CNO3	NITRATE	IOC	MONITORING, ROUTINE MAJOR	1/1/2017	12/31/2017		5/25/2018
NV0000255	YERINGTON CITY OF	27MJ	0999	CHLORINE	ST1 DBP	MONITORING, ROUTINE (DBP), MAJOR	1/1/2018	3/31/2018		
NV0000255	YERINGTON CITY OF	27MJ	CDB2	DBPR STAGE 2	ST2 DBP	MONITORING, ROUTINE (DBP), MAJOR	1/1/2018	12/31/2018		
NV0000255	YERINGTON CITY OF	3AMN	8000	REVISED TOTAL COLIFORM RULE (RTCR)	RTCR	MONITORING, ROUTINE, MINOR (RTCR)	2/1/2018	2/28/2018		3/20/2018
NV0000255	YERINGTON CITY OF	52	5000	LEAD & COPPER RULE	LCR	FOLLOW-UP OR ROUTINE TAP M/R (LCR)	10/1/2018			

Total Number of Violations for this Water System: 8

NV0000258	ZEPHYR COVE WATER UTILITY DISTR	52	5000	LEAD & COPPER RULE	LCR	FOLLOW-UP OR ROUTINE TAP M/R (LCR)	10/1/2017	4/30/2018		4/30/2018
-----------	---------------------------------	----	------	--------------------	-----	------------------------------------	-----------	-----------	--	-----------

Total Number of Violations for this Water System: 1

Attachment A

RULE-SPECIFIC VIOLATION CRITERIA FOR THE ANNUAL PUBLIC WATER SYSTEMS COMPLIANCE REPORT¹

Chemical Contaminant Group Maximum Contaminant Level (MCL)

MCL - Single Sample or MCL Average (Violation Types 01 and 02).

Only Community Water Systems can have a MCL for the following contaminant codes: 1025, 4000, 4006, 4010, and 4100.

Both Community and Non-transient Non-community (NTNC) water systems can have an MCL for the following contaminant codes: 2051, 2050, 2046, 2959, 2946, 2931, 2065, 2067, 2010, 2015, 2020, 2383, 2105, 2110, 2306, 2031, 2035, 2039, 2041, 2032, 2033, 2005, 2034, 2274, 2042, 2036, 2040, 2037, 2063, 2990, 2982, 2984, 2976, 2981, 2977, 2980, 2380, 2992, 2989, 2968, 2996, 2987, 2991, 2979, 2955, 2983, 2326, 2964, 2985, 2378, 2969, 1005, 1094, 1010, 1015, 1020, 1035, 1036, 1045, 1074, 1075, 1024, 1085.

All systems can have an MCL for Nitrate (contaminant codes 1038, 1040, and 1041).

Chemical Contaminant Group Monitoring and Reporting (M/R)

M/R - Monitoring, Regular (Violation Types 03 and 04 and Major Indicator Flag = Y).

Only Community Water Systems can have an M/R for the following contaminant codes: 1025, 4000, 4006, 4010, and 4100.

Both Community and NTNC water systems can have an M/R for the following contaminant codes: 2051, 2050, 2046, 2959, 2946, 2931, 2065, 2067, 2010, 2015, 2020, 2383, 2105, 2110, 2306, 2031, 2035, 2039, 2041, 2032, 2033, 2005, 2034, 2274, 2042, 2036, 2040, 2037, 2063, 2990, 2982, 2984, 2976, 2981, 2977, 2980, 2380, 2992, 2989, 2968, 2996, 2987, 2991, 2979, 2955, 2983, 2326, 2964, 2985, 2378, 2969, 2950, 2456, 0999, 1005, 1094, 1010, 1015, 1020, 1035, 1045, 1074, 1075, 1024, 1085.

¹ For violations that extend beyond the calendar year, the violation is counted in each of the calendar years in which it occurred, unless it has returned to compliance prior to the beginning of the calendar year.

All systems can have an M/R for Nitrate (contaminant codes 1038, 1040, and 1041).

Chemical Contaminant Group Treatment Technique (TT)

Both Community and NTNC water systems can have a TT violation for Acrylamide and Epichlorohydrine (Violation type 07, contaminant codes 2265 and 2257).

Total Coliform Rule (TCR) MCLs

Any violation that is either Acute or Monthly (Violation types 21 and 22). The contaminant code for TCR is 3100.

TCR Significant M/R

Any major Routine or Repeat M/R violation (Violation types 23 and 25). The contaminant code for TCR is 3100.

Revised Total Coliform Rule (RTCR) MCLs

Any violation that is either Acute or Monthly (Violation type 1A). The contaminant code for RTCR is 8000.

RTCR Significant M/R

Any major Routine or Repeat M/R violation (Violation types 3A, 3B, 3C, 3D, 4D, 4E, 4F, 5A, and 5B). The contaminant code for RTCR is 8000.

RTCR TT

Violation types (2A, 2B, 2C, and 2D). The contaminant code for RTCR is 8000.

Surface Water Treatment Rule (SWTR) TT

Any TT violation for a filtered system (Violation type 41) and all unfiltered systems who are required to install filtration if at some point during the calendar year they were unfiltered. (Violation type 42 violations - these may not be in your state data systems). The contaminant code for SWTR is 0200.

SWTR Significant M/R

Any Significant surface water M/R violation by a filtered or unfiltered system (Violation Types 36 and 31 and Major Indicator Flag = Y, respectively). The contaminant code for SWTR is 0200.

Turbidity MCL

Any MCL Average violation for an unfiltered system (Violation type 02). The contaminant code for turbidity is 0100.

Turbidity Significant M/R

Any major regular M/R violation for an unfiltered system (Violation type 03 and Major Indicator Flag = Y). The contaminant code for turbidity is 0100.

Lead and Copper Rule (LCR) TT

Any Community or NTNC water system with a TT violation at any time during the calendar year (Violation Types 58, 62 and 65). Note: Violation type 62 has been combined under Violation type 58 in SDWIS.

LCR Significant M/R

Any Community or NTNC water system with a follow-up or routine tap sampling violation (Violation type 52) or any Community or NTNC water system who incurred an initial tap monitoring violation (Violation type 51) during the calendar year, or who incurred the initial tap violation prior to the calendar year, but failed to return to compliance prior to January 1 of the calendar year. Note: a system cannot have more than one initial tap monitoring violation counted in a calendar year.

In general: Count all violations above where any date in the violation compliance period begin and end date range falls within the calendar year **except** those that returned to compliance prior to the first day of the calendar year regardless of current system status.

Note: EPA has changed the state submitted compliance period end date of Violation types 51, 58, 62 and 65 to reflect either the date the violation returned to compliance or the date of 12/31/2015.

Consumer Confidence Report Rule (CCR) Significant Consumer Notification Violations and Public Notification Violations

Any Community water system that completely failed to provide a required consumer confidence report is in violation (Violation type 71). Because the violation continues until the system provides the report, the violation must also be reported in each subsequent year until the system returns to compliance. Public Notification violations are Violation type codes 75 for NPDWR and 76 for other potential health risk situations PN Violation (Non-NPDWR). For the Public Notice Violations the violation must be linked to a specific rule. The contaminant code for IESWTR is 0300. The contaminant codes for Stage 1 DBPR are 1009, 1011, 2456, 2950, 1006, 1008 and 0999.

Interim Enhanced Surface Water Treatment Rule (IESWTR) TT

Any public water system that uses surface water or ground water under the direct influence of surface water (GWUDI) and serving at least 10,000 people with a TT violation (Violations 37, 43, 44, and 47). The contaminant code for IESWTR is 0300. See Section II of the Implementation Guidance for Interim Enhanced Surface Water Treatment Rule (EPA 816-R-01-11, June 2001)

<http://www.epa.gov/safewater/mdbp/ieswtrimplguid.pdf> for additional information

IESWTR Significant Recordkeeping and M/R Violations

Any public water system that uses surface water or GWUDI and serving at least 10,000 people with an M/R violation (Violation 29 and Violation 38 and Major Indicator Flag = Y). The contaminant code for IESWTR is 0300. Any recordkeeping violation where system fails to maintain the results of individual filter monitoring for 3 years. Violation type is 09. The contaminant code is for IESWTR is 0300. See Section II of the Implementation Guidance for Interim Enhanced Surface Water Treatment Rule (EPA 816-R-01-11, June 2001) <http://www.epa.gov/safewater/mdbp/ieswtrimplguid.pdf> for additional information.

Filter Backwash Recycle Rule (FBRR) TT

Public water systems that use surface water or GWUDI, practice conventional or direct filtration, and recycle spent filter backwash, thickener supernatant, or liquids from dewatering processes. The violation code is 40. The contaminant code is 0500. See the Implementation Guide for the Filter Backwash Recycle Rule www.epa.gov/safewater/mdbp/guide_fbrr_ig_fnl_06-16-04.pdf [EPA 816-R-04-006, June 2004] for additional information.

Filter Backwash Recycle Rule (FBRR) M/R and Recordkeeping

Public water systems that use surface water or GWUDI, practice conventional or direct filtration, and recycle spent filter backwash, thickener supernatant, or liquids from dewatering processes. The violation code for M/R is 39 and for recordkeeping is 09. The contaminant code is 0500. See the Implementation Guide for the Filter Backwash Recycle Rule (EPA 816-R-04-006, June 2004) www.epa.gov/safewater/mdbp/guide_fbrr_ig_fnl_06-16-04.pdf for additional information.

Ground Water Rule (GWR)

All systems can have Ground Water Rule violations. The violation code for failure to collect triggered source water samples for E. coli after a TCR positive sample is 34.

Long Term 1 Enhanced Surface Water Treatment Rule (LT1ESWTR) TT

Public water systems that use surface water or GWUDI and serve fewer than 10,000 people. The violation codes are 37 and 47. Like the IESWTR The contaminant code for LT1ESTR the contaminant code is 0300. See Section V of the Long Term Enhanced Surface Water **Treatment** Rule (LT1ESWTR) Implementation Guide for additional information at the website: www.epa.gov/safewater/mdbp/pdfs/lt1eswtr/guidance_lt1_ig.pdf

Stage 1 and 2 Disinfectants and Disinfection Byproducts Rule (Stage 1 DBPR) TT

All CWS and NTNCWS that add a chemical disinfectant in any part of the drinking water treatment process and transient NCWS

using chlorine dioxide with TT violations (Violations 12, 37 and 46). The contaminant codes for Stage 1 DBPR are 0400 and 2920. See Section II of the Implementation Guidance for Stage 1 Disinfectants and Disinfection Byproducts Rule (EPA 816-R-01-12, June 2001) <http://www.epa.gov/safewater/mdbp/s1dbprimplguid.pdf> for additional information.

Stage 1 and 2 DBPR MCL and Maximum Residual Disinfectant Levels (MRDL)

All CWS and NTNCWS that add a chemical disinfectant in any part of the drinking water treatment process and transient NCWS using chlorine dioxide with MCL/MRDL violations (Violations 02 and 11). The contaminant codes for Stage 1 DBPR are 1009, 1011, 2456, 2950, 1006, 1008 and 0999. See Section II of the Implementation Guidance for Stage 1 Disinfectants and Disinfection Byproducts Rule (EPA 816-R-01-12, June 2001) <http://www.epa.gov/safewater/mdbp/s1dbprimplguid.pdf> for additional information.

Stage 1 and 2 DBPR M/R Violations

All CWS and NTNCWS that add a chemical disinfectant in any part of the drinking water treatment process and transient NCWS using chlorine dioxide with M/R violations (Violation 27 and Major Indicator Flag = Y). The contaminant codes for Stage 1 DBPR are 0400, 2920, 1009, 1011, 2456, 2950, 1006, 1008 and 0999. See Section II of the Implementation Guidance for Stage 1 Disinfectants and Disinfection Byproducts Rule (EPA 816-R-01-12, June 2001) at: <http://www.epa.gov/safewater/mdbp/s1dbprimplguid.pdf> for additional information.

Public Notification

The violation code for failure to notify the public after a violation is 06 for IESWTR, LT1ESWTR, and Stage 1 DBPR. The contaminant code for Stage 1 DBPR corresponds with the appropriate MCL/MRDL/TOC (1009, 1011, 2456, 2950, 1006, 1008 and 0999). The contaminant code for IESWTR and LT1ESWTR is 0300. For FBRR the violation code is 75 and the contaminant code is 0500.

Secondary Drinking Water Standard M/R Violations

All Nevada public water systems can have M/R (Violation type 93) for Secondary Drinking Water Standards, which consists of the following contaminant codes: 1002, 1017, 1022, 1028, 1031, 1032, 1050, 1055, 1089, 1095, 1905, 1920, 1925, and 1930.

Secondary Drinking Water Standard MCL Violations

All Nevada public water systems can have MCL average (Violation type S1) for Secondary Drinking Water Standards, which consists of the following contaminant codes: 1002, 1017, 1022, 1028, 1031, 1032, 1050, 1055, 1089, 1095, 1905, 1920, 1925, and 1930.

VIOLATION TYPES

State or EPA HQ	Type Code	VIOLATION NAME	ALTERNATE DESCRIPTION
HQ	01	MAXIMUM CONTAMINANT LEVEL (MCL), SINGLE SAMPLE	Excedence of MAXIMUM CONTAMINANT LEVEL (MCL) per 5-1.52
HQ	02	MAXIMUM CONTAMINANT LEVEL (MCL), AVERAGE, WITHOUT NUMBER OF EXCEDENCE	Excedence of MAXIMUM CONTAMINANT LEVEL (MCL) per 5-1.52
HQ	02	MAXIMUM CONTAMINANT LEVEL (MCL), AVERAGE, WITH NUMBER OF EXCEDENCE	Public Water Supply (PWS) Using Chlorine Dioxide - Chlorite - Average of any 3 sample set exceeds the MAXIMUM CONTAMINANT LEVEL (MCL) of 1.0 mg/L
HQ	03	MONITORING, ROUTINE MAJOR	Failure to monitor in accordance with section 5-1.51(b) and 5-1.52 Tables or perform analysis with approved methods
HQ	04	MONITORING, CONFIRMATION/CHECK MAJOR	No repeat samples were taken in response to a positive monitoring sample result.
HQ	05	NOTIFICATION, STATE	Failure to notify state
HQ	07	TREATMENT TECHNIQUES NON-SURFACE WATER TREATMENT RULE (Non-SWTR)	Failure to maintain free chlorine residual in distribution system.
HQ	08	VARIANCE / EXEMPTION / OTHER COMPLIANCE	Failure to abide by the authorized terms and conditions of a valid variance, waiver, or any other exemption.
HQ	09	RECORD KEEPING	Failure to retain proper records.
HQ	09	RECORD KEEPING FOR INDIVIDUAL FILTER /Filter Backwash Rule (FBR)	Failure to maintain filter monitoring records for 3 years (filter results every 15 minutes)
HQ	1A	E. COLI MCL	E. coli positive routine with insufficient repeat samples, or a combination of E. coli positive and Total Coliform positive results between routine and repeat samples, or Total Coliform positive routine with Total Coliform positive repeat sample not tested for E.coli.
HQ	2A	LEVEL 1 ASSESSMENT TREATMENT TECHNIQUE	Failure to conduct Level 1 assessment.
HQ	2B	LEVEL 2 ASSESSMENT TREATMENT TECHNIQUE	Failure to conduct Level 2 assessment.
HQ	2C	CORRECTIVE ACTIONS/EXPEDITED ACTIONS TREATMENT TECHNIQUE	Failure to complete corrective actions withn the required timeframe when a Level 1 or Level 2 assessment is triggered.
HQ	2D	STARTUP PROCEDURES TREATMENT TECHNIQUE	Failure to complete seasonal startup procedures
HQ	3A	ROUTINE MONITORING	Failure to collect routine samples at appropriate site/frequency.
HQ	3B	ADDITIONAL ROUTINE MONITORING	Failure to collect additional routine samples required the next month after any Total Coliform positive happens in water systems not on a baseline monthly monitoring
HQ	3C	TC SAMPLES (TRIGGERED BY TURBIDITY EXCEEDANCE) MONITORING	Failure to collect required extra total coliform samples due to turbidity exceedance.
HQ	3D	MONITORING VIOLATION DUE TO LAB AND/OR ANALYTICAL ERRORS	Failure to use the required/approved analytical methods, or follow holding times, or sample preparation, or collection methods, or failure to use certified and/or State-approved Laboratory.

VIOLATION TYPES

State or EPA HQ	Type Code	VIOLATION NAME	ALTERNATE DESCRIPTION
HQ	4D	E. COLI POSITIVE NOTIFICATION REPORTING	Failure to notify the State by the end of the day or the end of the next business day (based on State office closure communication procedures) about an E. coli positive compliance sample result.
HQ	4E	E. COLI MCL REPORTING	Failure to provide notification to the State that an E. coli MCL violation happened.
HQ	4F	NOTIFICATION OF VIOLATIONS - ASSESSMENTS, ASSESSMENT FORMS, CORRECTIVE/EXPEDITED ACTIONS REPORTING	Failure to provide notification to the State that violations related to Level 1 and 2 assessments, assessment forms, and corrective actions have happened.
HQ	5A	ERRORS WITH SAMPLE SITING PLAN	Failure to develop Sampling Site Plan or to revise Smapling Site Plan to include a sample collection schedule.
HQ	5B	RTCR RECORD KEEPING VIOLATIONS	Failure to keep records for Level 1 and Level2 assessments and corrective/expedited actions for 5 years, or failure to keep recoreds for 5 years on repest sample results that the State approved and extended the timeframe for sample collection, or failure to keep records on Samplng Site Plan.
HQ	11	MAXIMUM RESIDUAL DISINFECTANT LEVEL (MRDL) - Public Water Supply (PWS) Using Chlorine	Excedence of Maximum Residual Disinfectant Level (MRDL) of 4.0 mg/L (exception if microbial contamination problems in distribution system)
HQ	11	MAXIMUM RESIDUAL DISINFECTANT LEVEL (MRDL) MONITORING	Failure to perform minimum monitoring requirements.
HQ	12	QUALIFIED OPERATOR FAILURE	No certified operator in charge of operation of a water treatment plant.
HQ	13	MAXIMUM RESIDUAL DISINFECTANT LEVEL (MRDL) ACUTE - Public Water Supply (PWS) Using Chlorine Dioxide	ACUTE: If any of 3 required distribution samples taken on day after a daily entry point sample Maximum Residual Disinfectant Level (MRDL) exceeds 0.8 mg/L
HQ	19	MONITOR GWR ASSESSMENT	A system that fails to conduct assessment source water monitoring required by the state according to State-determined requirements for such monitoring [141.130(c)]
HQ	20	FAILURE TO CONSULT/RESPOND	A system that fails to consult with the State within 30 days regarding notice from the State of a significant deficiency, or written notice from a laboratory of a ground water source sample being fecal indicator-positive, or that corrective action is required after a fecal indicator-positive sample result. [141.403(a)(4)]
HQ	21	MAXIMUM CONTAMINANT LEVEL (MCL) - TOTAL COLIFORM RULE (TCR) ACUTE	Excedence of MAXIMUM CONTAMINANT LEVEL (MCL) per 5-1.52 Table 6--Microbiological Contaminants
HQ	22	MAXIMUM CONTAMINANT LEVEL (MCL) - TOTAL COLIFORM RULE (TCR), MONTHLY	Excedence of MAXIMUM CONTAMINANT LEVEL (MCL) per 5-1.52 Table 6--Microbiological Contaminants

VIOLATION TYPES

State or EPA HQ	Type Code	VIOLATION NAME	ALTERNATE DESCRIPTION
HQ	23	MONITORING TOTAL COLIFORM RULE (TCR), ROUTINE MAJOR	Failure to perform Table 11 Microbiological Minimum Monitoring Requirements
HQ	24	MONITORING (TCR), ROUTINE MINOR	A system collects some but not all of the scheduled routine total coliform samples at sites approved in the written sample siting plan according to the determined monitoring frequency. [141.21(a)(1)-(2)]
HQ	25	MONITORING TOTAL COLIFORM RULE (TCR), REPEAT MAJOR	Failure to perform Table 11 Microbiological Minimum Monitoring Requirements
HQ	26	MONITORING (TCR), REPEAT MINOR	A system notified of total coliform positive repeat sample and analyzes some but not all of the total coliform positive samples for fecal coliform/E. coli. [141.32(e)(1)]
HQ	27	MONITORING, ROUTINE DISINFECTION BYPRODUCT RULE (DBP), MAJOR - Bromate Monitoring / Reporting (M/R) - Public Water Supply (PWS) Using Ozone	Failure to collect 100% of required bromate samples
HQ	27	MONITORING, ROUTINE DISINFECTION BYPRODUCT RULE (DBP), MAJOR - Chlorine Monitoring / Reporting (M/R)	Collecting <90% of chlorine samples
HQ	27	MONITORING, ROUTINE DISINFECTION BYPRODUCT RULE (DBP), MAJOR - Total Organic Carbon (TOC) Monitoring / Reporting (M/R) - Surface / Groundwater Under Direct Influence of Surface Water (GUDI) Using Conventional Filtration	Failure to collect source & finished water TOC samples and alkalinity sample
HQ	27	HALOACETIC ACID / TOTAL TRIHALOMETHANE (HAA5/TTHM)- MAJOR Monitoring / Reporting (M/R) - SURFACE WATER / Groundwater Under Direct Influence of Surface Water (GUDI) Greater Than or Equal to 10,000 Population	Collecting <90% of (HAA5/TTHM) samples
HQ	27	HALOACETIC ACID / TOTAL TRIHALOMETHANE (HAA5/TTHM) - MAJOR Monitoring / Reporting (M/R) Surface / Groundwater Under Direct Influence of Surface Water (GUDI) Population between 500 and 9999	Collecting <90% of (HAA5/TTHM) samples
HQ	27	HALOACETIC ACID / TOTAL TRIHALOMETHANE (HAA5/TTHM) - MAJOR Monitoring / Reporting (M/R) - Surface / Groundwater Under Direct Influence of Surface Water (GUDI) < 500	Failure to collect/report at least 1 sample per plant per year during month of warmest water temperature
HQ	27	HALOACETIC ACID / TOTAL TRIHALOMETHANE (HAA5/TTHM) - MAJOR Monitoring / Reporting (M/R) - Groundwater Systems Greater Than or Equal to 10,000 Population	Collecting <90% of (HAA5/TTHM) samples
HQ	27	HALOACETIC ACID / TOTAL TRIHALOMETHANE (HAA5/TTHM) - MAJOR Monitoring / Reporting (M/R) - Groundwater Systems < 10,000 Population	Failure to collect/report all required samples

VIOLATION TYPES

State or EPA HQ	Type Code	VIOLATION NAME	ALTERNATE DESCRIPTION
HQ	27	FAILURE TO HAVE MONITORING PLAN DISINFECTION BYPRODUCT RULE (DBP)	Failure to develop, implement or submit monitoring plan
HQ	28	SANITARY SURVEY COOPERATION FAILURE	A system that does not collect 5 or more routine samples per month and fails to undergo an initial sanitary survey by June 29, 1994, for community water systems, and June 29, 1999 for non-community water systems; or fails to undergo another sanitary survey every five years for community water systems and every 10 years for non-community water systems. [141.21(d)(1)(i)]
HQ	29	FAILURE TO PRODUCE COMPREHENSIVE PERFORMANCE EVALUATION (CPE) - Interim Enhanced Surface Water Treatment Rule (IESWTR)	Failure to produce CPE evaluation documentation
HQ	30	FAILURE TO HAVE MONITORING PLAN (IDSE)	A system that fails to monitor for each quarter that a monitoring result would be used in calculating an LRAA. [141.621(e)]
HQ	30	MONITORING, ROUTINE (IDSE), MAJOR	A system that fails to conduct standard monitoring according to 141.601 or a system specific study that meets the requirements in 141.602. [141.600]
HQ	30	MONITORING, ROUTINE (IDSE), MINOR	Failure to submit an IDSE standard monitoring plan, System Specific Study plan, 40/30 waiver, or submitted plan found to be deficient. [141.600(c);141.601(a); 141.602(a)]
HQ	31	MONITORING, ROUTINE/REPEAT - MAJOR - Surface Water Treatment Rule - UNFILTERED (SWTR - Unfiltered)	Failure to collect < 90% of require samples per monitoring period
HQ	32	FAILURE TO HAVE MONITORING PLAN (LT2)	A system that fails to submit a complete source water monitoring plan, including a sampling schedule and description of sampling location. [141.702(a) & 141.703(f)]
HQ	32	MONITORING, SOURCE (LT2)	A system that fails to collect any source water sample required in accordance with the sampling schedule, sampling location, analytical method, approved laboratory, and reporting requirements of the rule. [141.701 - 141.706]
HQ	34	MONITORING, SOURCE (GWR), MAJOR	Failure to collect triggered source water sample after a Total Coliform Rule positive sample.
HQ	35	FAILURE SUBMIT IDSE/SUBPT V PLAN (DBPR2)	A system that fails to submit an IDSE report or Subpart V monitoring plan, or submitted plan found to be missing required elements. [141.601(c)(1-4); 141.602(b)(1-6); 141.605; and 141.622]
HQ	36	MONITORING, Routine/Repeat MAJOR Surface Water Treatment Rule -FILTER	Failure to collect < 90% of require samples per monitoring period

VIOLATION TYPES

State or EPA HQ	Type Code	VIOLATION NAME	ALTERNATE DESCRIPTION
HQ	37	FAILURE TO PROFILE / CONSULT - Interim Enhanced Surface Water Treatment Rule (IESWTR)	Failure to collect applicability data Treatment Technique (TT) violation
HQ	38	MONITORING, ROUTINE Interim Enhanced Surface Water Treatment Rule (IESWTR), MAJOR - Filtration/Combined Filter Effluent Surface/Groundwater Under Direct Influence of Surface Water (GUDI) >= 10,000 Population with Conventional/Direct Filtration	Collecting <90% of filter effluent samples for turbidity and reporting within 10 days after end of month
HQ	38	MONITORING, ROUTINE Interim Enhanced Surface Water Treatment Rule (IESWTR), MAJOR - Filtration/Combined Filter Effluent - Surface/Groundwater Under Direct Influence of Surface Water (GUDI) Serving >= 10,000 Population with Conventional/Direct Filtration	Failure to report that Public Water Supply (PWS) has conducted all filter monitoring to state within 10 days after end of each month
HQ	39	FAILURE TO SUBMIT PLANT SCHEMATIC (FBR)	A system that fails to notify the State in writing by December 8, 2003 if the system recycles spent filter backwash water, thickener supernatant, or liquids from dewatering processes and/or include a plant schematic and typical recycle flow in the notification. [141.76(b)]
HQ	40	FAILURE TO PROPERLY RECYCLE (FBR)	Failure to meet treatment technique requirements. [141.76(c)]
HQ	41	RESIDUAL DISINFECT CONCENTRATION - Surface Water Treatment Rule (SWTR) Surface or Groundwater Under Direct Influence (Groundwater Under Direct Influence of Surface Water (GUDI)) Serving Less Than 10,000 Population.	Cl ₂ Residual fell below 0.2 mg/l for more than 4 hours.
HQ	41	SINGLE COMBINED FILTER EFFLUENT (SWTR) - Surface or Groundwater Under Direct Influence (Groundwater Under Direct Influence of Surface Water (GUDI) Serving Less Than 10,000 Population.	Failure to maintain turbidity readings below 0.5 NTU in 95% of all measurements performed every 4 hours
HQ	41	MONTHLY COMBINED FILTER EFFLUENT (SWTR) - Surface or Groundwater Under Direct Influence (Groundwater Under Direct Influence of Surface Water (GUDI) Serving Less Than 10,000 Population.	Failure to meet performance standard of 0.5 NTU at the 95th percentile monthly.
HQ	42	FAILURE TO FILTER (SWTR)	Failure to provide filtration on a surface source after 6/29/93, unless avoidance criteria is met.
HQ	42	FAILURE TO PROVIDE GWR TREATMENT	Failure to meet GWR treatment requirements
HQ	42	FAILURE TO PROVIDE LT2 TREATMENT	Failure to meet Long Term 2 treatment requirements

VIOLATION TYPES

State or EPA HQ	Type Code	VIOLATION NAME	ALTERNATE DESCRIPTION
HQ	43	SINGLE COMB. FILTER EFFLUENT Interim Enhanced Surface Water Treatment Rule (IESWTR) Surface/Groundwater Under Direct Influence of Surface Water (GUDI) Greater Than or Equal to 10,000 Population with conventional / direct filtration.	Failure to achieve turbidity <1.0 NTU, in 100% of samples
HQ	43	SINGLE COMB. FILTER EFFLUENT Interim Enhanced Surface Water Treatment Rule (IESWTR) Surface/Groundwater Under Direct Influence of Surface Water (GUDI) Greater Than or Equal to 10,000 Population with alternative filtration.	Failure to achieve turbidity <State set limit, in 100% of samples
HQ	44	MONTHLY COMB. FILTER EFFLUENT Interim Enhanced Surface Water Treatment Rule (IESWTR) - Surface/Groundwater Under Direct Influence of Surface Water (GUDI) Greater Than or Equal to 10,000 Population with conventional or direct filtration	Failure to achieve turbidity <0.3 NTU in 95% of samples
HQ	44	MONTHLY COMB. FILTER EFFLUENT Interim Enhanced Surface Water Treatment Rule (IESWTR) - Surface / Groundwater Under Direct Influence of Surface Water (GUDI) Greater Than or Equal to 10,000 Population with alternative filtration.	Failure to achieve turbidity <State set limit in 95% of samples
HQ	45	FAILURE ADDRESS DEFICIENCY	A system with a significant deficiency that after 120 days of receiving written notification of the significant deficiency from the State fails to: 1) complete corrective action in accordance with any applicable State plan review processes or other State guidance and direction. [141.404(a)(1)]
HQ	46	INADEQUATE DBP PRECURSOR REMOVAL - Surface / Groundwater Under Direct Influence of Surface Water (GUDI) using conventional filtration	Failure to meet DBP precursor removal (TOC)
HQ	47	UNCOVERED STORAGE FACILITY - Interim Enhanced Surface Water Treatment Rule (IESWTR)	Uncovered reservoir without adequate post disinfection.
HQ	48	FAILURE TO ADDRESS CONTAMINATION (GWR)	A system with a fecal indicator positive sample (that has not been invalidated by the State) and after 120 days of receiving notice of the fecal indicator positive sample has failed to: 1) complete corrective action in accordance with any applicable State plan review processes or other State guidance and direction. [141.404(b)(1)]
HQ	51	INITIAL TAP SAMPLING (PB/CU)	Failure to monitor for lead and copper in accordance with 5-1.42
HQ	52	FOLLOW-UP OR ROUTINE TAP Monitoring / Reporting (M/R) (PB/CU)	Failure to monitor for lead and copper in accordance with 5-1.42

VIOLATION TYPES

State or EPA HQ	Type Code	VIOLATION NAME	ALTERNATE DESCRIPTION
HQ	53	WATER QUALITY PARAMETER M/R (LCR)	Failure to collect the required number of WQP samples using correct sampling procedures and conduct analyses using the correct procedures. [141.87(a) - (e)]
HQ	56	INITIAL/FOLLOW-UP/ROUTINE SOWT M/R (LCR)	Failure to collect the required number of source water samples using correct sampling procedures and conduct analyses using the correct procedures in accordance with 141.88(a)(1) - (e)(1). [141.88(a)(1) - (e)(1)]
	57	OCCT/SOWT RECOMMENDATION/STUDY (LCR)	For an SOWT Recommendation violation, failure to submit a SOWT recommendation no later than 180 days after the end of the monitoring period during which the lead or copper action level was exceeded. [141.83(a)(1) & 141.90(d)(1)]
HQ	58	OPTIMAL CORROSION CONTROL TREATMENT / SOURCE WATER TREATMENT (OCCT/SOWT) INSTALLATION DEMONSTRATION	Failure to install and operate Optimal Corrosion Control Treatment (OCCT) or fail to demonstrate that OCCT already is in place.
HQ	59	WQP LEVEL NON-COMPLIANCE (LCR)	Failure to: Maintain OWQP minimum or ranges in accordance with 141.82(g). Also, If you adopted the OWQP compliance method from the LCRMR, the violation definition also includes failure to: Meet daily values for more than 9 days in a 6-month monitoring period. [141.82(g)]
HQ	63	MPL LEVEL NON-COMPLIANCE (LCR)	Failure to meet either State-designated or approved MPL in accordance with 141.83(b)(5).
HQ	64	LEAD SERVICE LINE REPLACEMENT (LCR)	A system which exceeds the lead action level after implementation of applicable corrosion control and/or source water treatment requirements (whichever sampling occurs later) and fails to complete the lead service line replacement requirements. [141.84(a)]
HQ	65	PUBLIC EDUCATION LEAD / COPPER (PB/CU)	Failure to deliver public education materials where lead action level is exceeded.
HQ	71	CONSUMER CONFIDENCE REPORT (CCR)	Failure to provide Consumer Confidence Report
HQ	72	CCR ADEQUACY/AVAILABILITY/CONTENT	Delivery of a CCR that is significantly deficient in content to the extent that the CCR does not meet the requirements of the SDWA and the Federal regulations. [141.205]
HQ	75	PUBLIC NOTICE RULE LINKED TO VIOLATION	Failure to Public Notice Violation of National Primary Drinking Water Regulations (NPDWR)
ST	93	MONITORING, ROUTINE MAJOR	Failure to monitor in accordance with section NAC 445.1.456 or perform analysis with approved methods

VIOLATION TYPES

State or EPA HQ	Type Code	VIOLATION NAME	ALTERNATE DESCRIPTION
ST	S1	MAXIMUM CONTAMINANT LEVEL (MCL), AVERAGE, WITH NUMBER OF EXCEDENCE	Excedence of MAXIMUM CONTAMINANT LEVEL (MCL) per NAC 445A.455