

Annual Compliance Detail Report

Water System ID	Water System Name	Analyte Code	Analyte Name	Type	Compliance Period	RTC Date	County
NV0000735	4TH STREET BISTRO	3100	COLIFORM (TCR)	23	07/01/2012 09/30/2012		WASHOE
Total Number of Violations for This Water System: 1							
NV0002563	A COWBOYS DREAM	3100	COLIFORM (TCR)	23	04/01/2012 06/30/2012	9/28/2012	LINCOLN
Total Number of Violations for This Water System: 1							
NV0000866	AIR SAILING INC GLIDERPORT	3100	COLIFORM (TCR)	23	08/01/2012 08/31/2012		WASHOE
Total Number of Violations for This Water System: 1							
NV0000005	ALAMO SEWER AND WATER GID	2981	1,1,1-TRICHLOROETHANE	03	10/01/2012 12/31/2012		LINCOLN
NV0000005	ALAMO SEWER AND WATER GID	2985	1,1,2-TRICHLOROETHANE	03	10/01/2012 12/31/2012		LINCOLN
NV0000005	ALAMO SEWER AND WATER GID	2977	1,1-DICHLOROETHYLENE	03	10/01/2012 12/31/2012		LINCOLN
NV0000005	ALAMO SEWER AND WATER GID	2378	1,2,4-TRICHLOROBENZENE	03	10/01/2012 12/31/2012		LINCOLN
NV0000005	ALAMO SEWER AND WATER GID	2931	1,2-DIBROMO-3-CHLOROPROPANE	03	10/01/2012 12/31/2012		LINCOLN
NV0000005	ALAMO SEWER AND WATER GID	2980	1,2-DICHLOROETHANE	03	10/01/2012 12/31/2012		LINCOLN
NV0000005	ALAMO SEWER AND WATER GID	2983	1,2-DICHLOROPROPANE	03	10/01/2012 12/31/2012		LINCOLN
NV0000005	ALAMO SEWER AND WATER GID	2110	2,4,5-TP	03	10/01/2012 12/31/2012		LINCOLN
NV0000005	ALAMO SEWER AND WATER GID	2105	2,4-D	03	10/01/2012 12/31/2012		LINCOLN

Water System ID	Water System Name	Analyte Code	Analyte Name	Type	Compliance Period	RTC Date	County
NV000005	ALAMO SEWER AND WATER GID	1005	ARSENIC	02	10/01/2012 12/31/2012		LINCOLN
NV000005	ALAMO SEWER AND WATER GID	1005	ARSENIC	02	07/01/2012 09/30/2012		LINCOLN
NV000005	ALAMO SEWER AND WATER GID	1005	ARSENIC	02	04/01/2012 06/30/2012		LINCOLN
NV000005	ALAMO SEWER AND WATER GID	1005	ARSENIC	02	01/01/2012 03/31/2012		LINCOLN
NV000005	ALAMO SEWER AND WATER GID	2050	ATRAZINE	03	10/01/2012 12/31/2012		LINCOLN
NV000005	ALAMO SEWER AND WATER GID	2990	BENZENE	03	10/01/2012 12/31/2012		LINCOLN
NV000005	ALAMO SEWER AND WATER GID	2306	BENZO(A)PYRENE	03	10/01/2012 12/31/2012		LINCOLN
NV000005	ALAMO SEWER AND WATER GID	2010	BHC-GAMMA	03	10/01/2012 12/31/2012		LINCOLN
NV000005	ALAMO SEWER AND WATER GID	2046	CARBOFURAN	03	10/01/2012 12/31/2012		LINCOLN
NV000005	ALAMO SEWER AND WATER GID	2982	CARBON TETRACHLORIDE	03	10/01/2012 12/31/2012		LINCOLN
NV000005	ALAMO SEWER AND WATER GID	2959	CHLORDANE	03	10/01/2012 12/31/2012		LINCOLN
NV000005	ALAMO SEWER AND WATER GID	2989	CHLOROENZENE	03	10/01/2012 12/31/2012		LINCOLN
NV000005	ALAMO SEWER AND WATER GID	2380	CIS-1,2- DICHLOROETHYLENE	03	10/01/2012 12/31/2012		LINCOLN
NV000005	ALAMO SEWER AND WATER GID	4010	COMBINED RADIUM (-226 & -228)	03	10/01/2012 12/31/2012		LINCOLN
NV000005	ALAMO SEWER AND WATER GID	2031	DALAPON	03	10/01/2012 12/31/2012		LINCOLN
NV000005	ALAMO SEWER AND WATER GID	2035	DI(2-ETHYLHEXYL) ADIPATE	03	10/01/2012 12/31/2012		LINCOLN
NV000005	ALAMO SEWER AND WATER GID	2039	DI(2-ETHYLHEXYL) PHTHALATE	03	10/01/2012 12/31/2012		LINCOLN
NV000005	ALAMO SEWER AND WATER GID	2964	DICHLOROMETHANE	03	10/01/2012 12/31/2012		LINCOLN
NV000005	ALAMO SEWER AND WATER GID	2041	DINOSEB	03	10/01/2012 12/31/2012		LINCOLN
NV000005	ALAMO SEWER AND WATER GID	2032	DIQUAT	03	10/01/2012 12/31/2012		LINCOLN
NV000005	ALAMO SEWER AND WATER GID	2033	ENDOTHALL	03	10/01/2012 12/31/2012		LINCOLN

Water System ID	Water System Name	Analyte Code	Analyte Name	Type	Compliance Period	RTC Date	County
NV0000005	ALAMO SEWER AND WATER GID	2005	ENDRIN	03	10/01/2012 12/31/2012		LINCOLN
NV0000005	ALAMO SEWER AND WATER GID	2992	ETHYLBENZENE	03	10/01/2012 12/31/2012		LINCOLN
NV0000005	ALAMO SEWER AND WATER GID	2946	ETHYLENE DIBROMIDE	03	10/01/2012 12/31/2012		LINCOLN
NV0000005	ALAMO SEWER AND WATER GID	2034	GLYPHOSATE	03	10/01/2012 12/31/2012		LINCOLN
NV0000005	ALAMO SEWER AND WATER GID	4002	GROSS ALPHA, INCL. RADON & U	03	10/01/2012 12/31/2012		LINCOLN
NV0000005	ALAMO SEWER AND WATER GID	2065	HEPTACHLOR	03	10/01/2012 12/31/2012		LINCOLN
NV0000005	ALAMO SEWER AND WATER GID	2067	HEPTACHLOR EPOXIDE	03	10/01/2012 12/31/2012		LINCOLN
NV0000005	ALAMO SEWER AND WATER GID	2274	HEXACHLOROBENZENE	03	10/01/2012 12/31/2012		LINCOLN
NV0000005	ALAMO SEWER AND WATER GID	2042	HEXACHLOROCYCLOPENTADIENE	03	10/01/2012 12/31/2012		LINCOLN
NV0000005	ALAMO SEWER AND WATER GID	2051	LASSO	03	10/01/2012 12/31/2012		LINCOLN
NV0000005	ALAMO SEWER AND WATER GID	2015	METHOXYCHLOR	03	10/01/2012 12/31/2012		LINCOLN
NV0000005	ALAMO SEWER AND WATER GID	1040	NITRATE	03	01/01/2012 12/31/2012		LINCOLN
NV0000005	ALAMO SEWER AND WATER GID	2968	O-DICHLOROBENZENE	03	10/01/2012 12/31/2012		LINCOLN
NV0000005	ALAMO SEWER AND WATER GID	2036	OXAMYL	03	10/01/2012 12/31/2012		LINCOLN
NV0000005	ALAMO SEWER AND WATER GID	2969	P-DICHLOROBENZENE	03	10/01/2012 12/31/2012		LINCOLN
NV0000005	ALAMO SEWER AND WATER GID	2326	PENTACHLOROPHENOL	03	10/01/2012 12/31/2012		LINCOLN
NV0000005	ALAMO SEWER AND WATER GID	2040	PICLORAM	03	10/01/2012 12/31/2012		LINCOLN
NV0000005	ALAMO SEWER AND WATER GID	4020	RADIUM-226	03	10/01/2012 12/31/2012		LINCOLN
NV0000005	ALAMO SEWER AND WATER GID	4030	RADIUM-228	03	10/01/2012 12/31/2012		LINCOLN

Water System ID	Water System Name	Analyte Code	Analyte Name	Type	Compliance Period	RTC Date	County
NV0000005	ALAMO SEWER AND WATER GID	2037	SIMAZINE	03	10/01/2012 12/31/2012		LINCOLN
NV0000005	ALAMO SEWER AND WATER GID	2996	STYRENE	03	10/01/2012 12/31/2012		LINCOLN
NV0000005	ALAMO SEWER AND WATER GID	2987	TETRACHLOROETHYLENE	03	10/01/2012 12/31/2012		LINCOLN
NV0000005	ALAMO SEWER AND WATER GID	2991	TOLUENE	03	10/01/2012 12/31/2012		LINCOLN
NV0000005	ALAMO SEWER AND WATER GID	2383	TOTAL POLYCHLORINATED BIPHENYLS (PCB)	03	10/01/2012 12/31/2012		LINCOLN
NV0000005	ALAMO SEWER AND WATER GID	2020	TOXAPHENE	03	10/01/2012 12/31/2012		LINCOLN
NV0000005	ALAMO SEWER AND WATER GID	2979	TRANS-1,2-DICHLOROETHYLENE	03	10/01/2012 12/31/2012		LINCOLN
NV0000005	ALAMO SEWER AND WATER GID	2984	TRICHLOROETHYLENE	03	10/01/2012 12/31/2012		LINCOLN
NV0000005	ALAMO SEWER AND WATER GID	2976	VINYL CHLORIDE	03	10/01/2012 12/31/2012		LINCOLN
NV0000005	ALAMO SEWER AND WATER GID	2955	XYLENES, TOTAL	03	10/01/2012 12/31/2012		LINCOLN
Total Number of Violations for This Water System: 59							
NV0002141	AREA 51 DEATH VALLEY TRAVEL CENTER	3100	COLIFORM (TCR)	23	01/01/2012 03/31/2012	6/26/2012	NYE
NV0002141	AREA 51 DEATH VALLEY TRAVEL CENTER	3100	COLIFORM (TCR)	23	10/01/2012 12/31/2012	1/30/2013	NYE
Total Number of Violations for This Water System: 2							
NV0005038	BEATTY RV PARK	3100	COLIFORM (TCR)	23	10/01/2012 12/31/2012	3/11/2013	NYE
Total Number of Violations for This Water System: 1							
NV0000369	BIG VALLEY MHP	3100	COLIFORM (TCR)	21	09/01/2012 09/30/2012	10/9/2012	NYE
Total Number of Violations for This Water System: 1							
NV0000092	BLUE DIAMOND WATER CO OP INC	3100	COLIFORM (TCR)	25	10/01/2012 10/31/2012		CLARK

Water System ID	Water System Name	Analyte Code	Analyte Name	Type	Compliance Period	RTC Date	County
Total Number of Violations for This Water System: 1							
NV0000896	BRISTLECONE FAMILY RESOURCES	5000	LEAD & COPPER RULE	52	10/01/2012		WASHOE
Total Number of Violations for This Water System: 1							
NV0000389	BUCKBOARD GENERAL STORE	3100	COLIFORM (TCR)	23	01/01/2012 03/31/2012	5/15/2012	LYON
NV0000389	BUCKBOARD GENERAL STORE	3100	COLIFORM (TCR)	23	10/01/2012 12/31/2012	1/3/2013	LYON
NV0000389	BUCKBOARD GENERAL STORE	1040	NITRATE	03	01/01/2012 12/31/2012		LYON
Total Number of Violations for This Water System: 3							
NV0002538	C VALLEY MHP	3100	COLIFORM (TCR)	21	09/01/2012 09/30/2012	10/1/2012	NYE
Total Number of Violations for This Water System: 1							
NV0001091	CALIFORNIA NATIONAL HISTORIC TRAILS CTR	3100	COLIFORM (TCR)	23	04/01/2012 06/30/2012	7/25/2012	ELKO
Total Number of Violations for This Water System: 1							
NV0002502	CAMP POTOSI CLARK CO	3100	COLIFORM (TCR)	23	07/01/2012 09/30/2012		CLARK
NV0002502	CAMP POTOSI CLARK CO	3100	COLIFORM (TCR)	23	04/01/2012 06/30/2012		CLARK
NV0002502	CAMP POTOSI CLARK CO	1040	NITRATE	03	01/01/2012 12/31/2012		CLARK
Total Number of Violations for This Water System: 3							
NV0000405	CARBERRY SQUARE	3100	COLIFORM (TCR)	23	01/01/2012 03/31/2012	6/5/2012	NYE
NV0000405	CARBERRY SQUARE	3100	COLIFORM (TCR)	23	10/01/2012 12/31/2012	1/9/2013	NYE
NV0000405	CARBERRY SQUARE	1040	NITRATE	03	01/01/2012 12/31/2012	1/13/2013	NYE
Total Number of Violations for This Water System: 3							

Water System ID	Water System Name	Analyte Code	Analyte Name	Type	Compliance Period	RTC Date	County
NV0000015	CARSON CITY PUBLIC WORKS	2981	1,1,1-TRICHLOROETHANE	03	01/01/2012 12/31/2012		CARSON CITY
NV0000015	CARSON CITY PUBLIC WORKS	2985	1,1,2-TRICHLOROETHANE	03	01/01/2012 12/31/2012		CARSON CITY
NV0000015	CARSON CITY PUBLIC WORKS	2977	1,1-DICHLOROETHYLENE	03	01/01/2012 12/31/2012		CARSON CITY
NV0000015	CARSON CITY PUBLIC WORKS	2378	1,2,4-TRICHLOROBENZENE	03	01/01/2012 12/31/2012		CARSON CITY
NV0000015	CARSON CITY PUBLIC WORKS	2980	1,2-DICHLOROETHANE	03	01/01/2012 12/31/2012		CARSON CITY
NV0000015	CARSON CITY PUBLIC WORKS	2983	1,2-DICHLOROPROPANE	03	01/01/2012 12/31/2012		CARSON CITY
NV0000015	CARSON CITY PUBLIC WORKS	2990	BENZENE	03	01/01/2012 12/31/2012		CARSON CITY
NV0000015	CARSON CITY PUBLIC WORKS	2982	CARBON TETRACHLORIDE	03	01/01/2012 12/31/2012		CARSON CITY
NV0000015	CARSON CITY PUBLIC WORKS	2989	CHLOROBENZENE	03	01/01/2012 12/31/2012		CARSON CITY
NV0000015	CARSON CITY PUBLIC WORKS	2380	CIS-1,2-DICHLOROETHYLENE	03	01/01/2012 12/31/2012		CARSON CITY
NV0000015	CARSON CITY PUBLIC WORKS	2964	DICHLOROMETHANE	03	01/01/2012 12/31/2012		CARSON CITY
NV0000015	CARSON CITY PUBLIC WORKS	2992	ETHYLBENZENE	03	01/01/2012 12/31/2012		CARSON CITY
NV0000015	CARSON CITY PUBLIC WORKS	2968	O-DICHLOROBENZENE	03	01/01/2012 12/31/2012		CARSON CITY
NV0000015	CARSON CITY PUBLIC WORKS	2969	P-DICHLOROBENZENE	03	01/01/2012 12/31/2012		CARSON CITY
NV0000015	CARSON CITY PUBLIC WORKS	2996	STYRENE	03	01/01/2012 12/31/2012		CARSON CITY
NV0000015	CARSON CITY PUBLIC WORKS	2987	TETRACHLOROETHYLENE	03	01/01/2012 12/31/2012		CARSON CITY
NV0000015	CARSON CITY PUBLIC WORKS	2991	TOLUENE	03	01/01/2012 12/31/2012		CARSON CITY

Water System ID	Water System Name	Analyte Code	Analyte Name	Type	Compliance Period	RTC Date	County
NV0000015	CARSON CITY PUBLIC WORKS	2979	TRANS-1,2-DICHLOROETHYLENE	03	01/01/2012 12/31/2012		CARSON CITY
NV0000015	CARSON CITY PUBLIC WORKS	2984	TRICHLOROETHYLENE	03	01/01/2012 12/31/2012		CARSON CITY
NV0000015	CARSON CITY PUBLIC WORKS	2976	VINYL CHLORIDE	03	01/01/2012 12/31/2012		CARSON CITY
NV0000015	CARSON CITY PUBLIC WORKS	2955	XYLENES, TOTAL	03	07/01/2012 09/30/2012		CARSON CITY
Total Number of Violations for This Water System: 21							
NV0003068	CARSON RIVER ESTATES	0999	CHLORINE	27	04/01/2012 06/30/2012		CHURCHILL
Total Number of Violations for This Water System: 1							
NV0002140	CARVERS CAFE	3100	COLIFORM (TCR)	23	07/01/2012 09/30/2012	10/30/2012	NYE
Total Number of Violations for This Water System: 1							
NV0000301	CAVE SPRINGS WATER SYSTEM NPS	3100	COLIFORM (TCR)	23	11/01/2012 11/30/2012	12/27/2012	WHITE PINE
Total Number of Violations for This Water System: 1							
NV0000364	CERTAIN TEED GYPSUM	0999	CHLORINE	27	07/01/2012 09/30/2012	12/31/2012	CLARK
NV0000364	CERTAIN TEED GYPSUM	3100	COLIFORM (TCR)	23	07/01/2012 09/30/2012		CLARK
Total Number of Violations for This Water System: 2							
NV0003060	CHERRY PATCH LOVE RANCH	3100	COLIFORM (TCR)	23	10/01/2012 12/31/2012	1/30/2013	NYE
Total Number of Violations for This Water System: 1							
NV0004079	CHUCKS CIRCLE C MARKET	1040	NITRATE	03	01/01/2012 12/31/2012		WASHOE
Total Number of Violations for This Water System: 1							
NV0005020	CHURCHILL BUTTE COMPLEX	3100	COLIFORM (TCR)	22	03/01/2012 03/31/2012	4/2/2012	LYON

Water System ID	Water System Name	Analyte Code	Analyte Name	Type	Compliance Period	RTC Date	County
Total Number of Violations for This Water System: 1							
NV0001109	CITY CENTER RESIDENCES	7000	CONSUMER CONFIDENCE RULE	71	07/01/2012		CLARK
Total Number of Violations for This Water System: 1							
NV0005057	COLD CREEK MHP	3100	COLIFORM (TCR)	22	10/01/2012 10/31/2012	11/1/2012	WHITE PINE
Total Number of Violations for This Water System: 1							
NV0002017	COLD SPRINGS STATION	3100	COLIFORM (TCR)	23	01/01/2012 03/31/2012	4/23/2012	CHURCHILL
Total Number of Violations for This Water System: 1							
NV0000277	CONESTOGA MHP	1040	NITRATE	03	01/01/2012 12/31/2012		WASHOE
Total Number of Violations for This Water System: 1							
NV0001024	CORN CREEK FIELD STATION	3100	COLIFORM (TCR)	23	01/01/2012 03/31/2012	4/3/2012	CLARK
Total Number of Violations for This Water System: 1							
NV0000017	COTTONWOOD MHP	3100	COLIFORM (TCR)	23	01/01/2012 01/31/2012	2/28/2012	CARSON CITY
NV0000017	COTTONWOOD MHP	3100	COLIFORM (TCR)	23	04/01/2012 04/30/2012	5/30/2012	CARSON CITY
NV0000017	COTTONWOOD MHP	3100	COLIFORM (TCR)	23	12/01/2012 12/31/2012	1/29/2013	CARSON CITY
Total Number of Violations for This Water System: 3							
NV0000385	COYOTE CORNER III	3100	COLIFORM (TCR)	23	01/01/2012 03/31/2012	4/30/2012	NYE
Total Number of Violations for This Water System: 1							
NV0002565	COYOTE CORNER MARKET	3100	COLIFORM (TCR)	23	01/01/2012 03/31/2012	4/30/2012	NYE
Total Number of Violations for This Water System: 1							

Water System ID	Water System Name	Analyte Code	Analyte Name	Type	Compliance Period	RTC Date	County
NV0000193	CRYSTAL TP	1005	ARSENIC	02	07/01/2012 09/30/2012	11/22/2012	WASHOE
NV0000193	CRYSTAL TP	1005	ARSENIC	02	04/01/2012 06/30/2012	11/22/2012	WASHOE
NV0000193	CRYSTAL TP	1005	ARSENIC	02	01/01/2012 03/31/2012	11/22/2012	WASHOE
NV0000193	CRYSTAL TP	3100	COLIFORM (TCR)	23	04/01/2012 04/30/2012		WASHOE
NV0000193	CRYSTAL TP	3100	COLIFORM (TCR)	23	01/01/2012 01/31/2012		WASHOE
Total Number of Violations for This Water System: 5							
NV0000881	CUCINA DELLA NONNA	3100	COLIFORM (TCR)	22	07/01/2012 07/31/2012	8/30/2012	LYON
NV0000881	CUCINA DELLA NONNA	3100	COLIFORM (TCR)	23	04/01/2012 06/30/2012	7/30/2012	LYON
NV0000881	CUCINA DELLA NONNA	3100	COLIFORM (TCR)	23	10/01/2012 12/31/2012	1/11/2013	LYON
NV0000881	CUCINA DELLA NONNA	1040	NITRATE	03	01/01/2012 12/31/2012	1/13/2013	LYON
Total Number of Violations for This Water System: 4							
NV0000719	DAVIS CREEK PARK	1040	NITRATE	03	01/01/2012 12/31/2012	3/6/2013	WASHOE
Total Number of Violations for This Water System: 1							
NV0000001	DENIO JUNCTION	1040	NITRATE	03	01/01/2012 12/31/2012		HUMBOLDT
Total Number of Violations for This Water System: 1							
NV0002196	DESERT CENTER PLAZA	1040	NITRATE	03	01/01/2012 12/31/2012	6/5/2013	NYE
Total Number of Violations for This Water System: 1							
NV0000149	DESERT PARADISE MHP	1005	ARSENIC	02	10/01/2012 12/31/2012		CLARK
NV0000149	DESERT PARADISE MHP	1005	ARSENIC	02	07/01/2012 09/30/2012		CLARK
NV0000149	DESERT PARADISE MHP	1005	ARSENIC	02	04/01/2012 06/30/2012		CLARK

Water System ID	Water System Name	Analyte Code	Analyte Name	Type	Compliance Period	RTC Date	County
NV0000149	DESERT PARADISE MHP	1005	ARSENIC	02	01/01/2012 03/31/2012		CLARK
NV0000149	DESERT PARADISE MIHP	3100	COLIFORM (TCR)	22	07/01/2012 07/31/2012	9/18/2012	CLARK
NV0000149	DESERT PARADISE MIHP	3100	COLIFORM (TCR)	22	06/01/2012 06/30/2012	9/18/2012	CLARK
Total Number of Violations for This Water System: 6							
NV0002043	DOUGLAS COUNTY LAMPE PARK	3014	E. COLI	34	11/28/2012 12/11/2012	12/11/2012	DOUGLAS
Total Number of Violations for This Water System: 1							
NV0000949	DOVETAIL RANCH	3100	COLIFORM (TCR)	22	10/01/2012 10/31/2012	11/14/2012	ELKO
NV0000949	DOVETAIL RANCH	3100	COLIFORM (TCR)	23	04/01/2012 06/30/2012	7/26/2012	ELKO
NV0000949	DOVETAIL RANCH	3100	COLIFORM (TCR)	23	01/01/2012 03/31/2012	7/26/2012	ELKO
NV0000949	DOVETAIL RANCH	1040	NITRATE	03	01/01/2012 12/31/2012	5/13/2013	ELKO
Total Number of Violations for This Water System: 4							
NV0000809	DUTCHMAN ACRES	3100	COLIFORM (TCR)	23	03/01/2012 03/31/2012	4/25/2012	PERSHING
NV0000809	DUTCHMAN ACRES	3100	COLIFORM (TCR)	23	06/01/2012 06/30/2012	7/30/2012	PERSHING
NV0000809	DUTCHMAN ACRES	3100	COLIFORM (TCR)	23	09/01/2012 09/30/2012	10/24/2012	PERSHING
NV0000809	DUTCHMAN ACRES	5000	LEAD & COPPER RULE	52	10/01/2012		PERSHING
NV0000809	DUTCHMAN ACRES	1040	NITRATE	03	01/01/2012 12/31/2012		PERSHING
NV0000809	DUTCHMAN ACRES	1052	SODIUM	03	01/01/2010 12/31/2012		PERSHING
Total Number of Violations for This Water System: 6							
NV0000916	DYER BAR AND CAFE	3100	COLIFORM (TCR)	23	04/01/2012 06/30/2012	9/27/2012	ESMERALDA
NV0000916	DYER BAR AND CAFE	3100	COLIFORM (TCR)	23	10/01/2012 12/31/2012	3/19/2013	ESMERALDA

Water System ID	Water System Name	Analyte Code	Analyte Name	Type	Compliance Period	RTC Date	County
NV0000916	DYER BAR AND CAFE	1040	NITRATE	03	01/01/2012 12/31/2012		ESMERALDA
Total Number of Violations for This Water System: 3							
NV0003075	EAGLE PICHIER MINERALS	3100	COLIFORM (TCR)	22	04/01/2012 04/30/2012	5/15/2012	STOREY
Total Number of Violations for This Water System: 1							
NV0000188	EAGLE VALLEY RESORT PAT AND JOHNS	3100	COLIFORM (TCR)	23	07/01/2012 09/30/2012	10/10/2012	LINCOLN
Total Number of Violations for This Water System: 1							
NV0003098	EAST 50 BAR	3100	COLIFORM (TCR)	23	01/01/2012 03/31/2012	5/23/2012	LYON
NV0003098	EAST 50 BAR	3100	COLIFORM (TCR)	23	07/01/2012 09/30/2012	11/14/2012	LYON
Total Number of Violations for This Water System: 2							
NV0000271	ELK POINT COUNTRY CLUB	4006	COMBINED URANIUM	03	07/01/2012 09/30/2012		DOUGLAS
Total Number of Violations for This Water System: 1							
NV0002075	ELKO RV PARK AT RYNDON	3100	COLIFORM (TCR)	22	09/01/2012 09/30/2012	10/24/2012	ELKO
Total Number of Violations for This Water System: 1							
NV0004083	FLY CONSERVATION CAMP NDOC	3100	COLIFORM (TCR)	23	01/01/2012 03/31/2012	5/2/2012	WHITE PINE
Total Number of Violations for This Water System: 1							
NV0000109	EQUESTRIAN ESTATES CO OP WATER ASSOC	1005	ARSENIC	02	10/01/2012 12/31/2012		CLARK
NV0000109	EQUESTRIAN ESTATES CO OP WATER ASSOC	1005	ARSENIC	02	07/01/2012 09/30/2012		CLARK
NV0000109	EQUESTRIAN ESTATES CO OP WATER ASSOC	1005	ARSENIC	02	04/01/2012 06/30/2012		CLARK

Water System ID	Water System Name	Analyte Code	Analyte Name	Type	Compliance Period	RTC Date	County
NV0000109	EQUESTRIAN ESTATES CO OP WATER ASSOC	1005	ARSENIC	02	01/01/2012 03/31/2012		CLARK
NV0000109	EQUESTRIAN ESTATES CO OP WATER ASSOC	3100	COLIFORM (TCR)	23	03/01/2012 03/31/2012		CLARK

Total Number of Violations for This Water System: 5

NV0002552	ESCAPEE CO OP OF NEVADA	4010	COMBINED RADIUM (-226 & -228)	03	10/01/2012 12/31/2012		NYE
NV0002552	ESCAPEE CO OP OF NEVADA	4010	COMBINED RADIUM (-226 & -228)	03	07/01/2012 09/30/2012		NYE
NV0002552	ESCAPEE CO OP OF NEVADA	4006	COMBINED URANIUM	03	10/01/2012 12/31/2012		NYE
NV0002552	ESCAPEE CO OP OF NEVADA	4006	COMBINED URANIUM	03	07/01/2012 09/30/2012		NYE
NV0002552	ESCAPEE CO OP OF NEVADA	4002	GROSS ALPHA, INCL. RADON & U	03	10/01/2012 12/31/2012		NYE
NV0002552	ESCAPEE CO OP OF NEVADA	4002	GROSS ALPHA, INCL. RADON & U	03	07/01/2012 09/30/2012		NYE
NV0002552	ESCAPEE CO OP OF NEVADA	1040	NITRATE	03	01/01/2012 03/31/2012	5/14/2012	NYE
NV0002552	ESCAPEE CO OP OF NEVADA	4020	RADIUM-226	03	10/01/2012 12/31/2012		NYE
NV0002552	ESCAPEE CO OP OF NEVADA	4020	RADIUM-226	03	07/01/2012 09/30/2012		NYE
NV0002552	ESCAPEE CO OP OF NEVADA	4030	RADIUM-228	03	10/01/2012 12/31/2012		NYE
NV0002552	ESCAPEE CO OP OF NEVADA	4030	RADIUM-228	03	07/01/2012 09/30/2012		NYE

Total Number of Violations for This Water System: 11

NV0000249	F AND H T P	1040	NITRATE	01	07/01/2012 09/30/2012		HUMBOLDT
NV0000249	F AND H T P	1040	NITRATE	02	10/01/2012 12/31/2012		HUMBOLDT
NV0000249	F AND H T P	1040	NITRATE	04	09/22/2012 10/18/2012		HUMBOLDT
NV0000249	F AND H T P	7500	PUBLIC NOTICE	75	09/22/2012		HUMBOLDT

Total Number of Violations for This Water System: 4

Water System ID	Water System Name	Analyte Code	Analyte Name	Type	Compliance Period	RTC Date	County
NV0002540	FAIRGROUNDS/SUNRISE ESTATES	2981	1,1,1-TRICHLOROETHANE	03	01/01/2012 12/31/2012		DOUGLAS
NV0002540	FAIRGROUNDS/SUNRISE ESTATES	2985	1,1,2-TRICHLOROETHANE	03	01/01/2012 12/31/2012		DOUGLAS
NV0002540	FAIRGROUNDS/SUNRISE ESTATES	2977	1,1-DICHLOROETHYLENE	03	01/01/2012 12/31/2012		DOUGLAS
NV0002540	FAIRGROUNDS/SUNRISE ESTATES	2378	1,2,4-TRICHLOROBENZENE	03	01/01/2012 12/31/2012		DOUGLAS
NV0002540	FAIRGROUNDS/SUNRISE ESTATES	2980	1,2-DICHLOROETHANE	03	01/01/2012 12/31/2012		DOUGLAS
NV0002540	FAIRGROUNDS/SUNRISE ESTATES	2983	1,2-DICHLOROPROPANE	03	01/01/2012 12/31/2012		DOUGLAS
NV0002540	FAIRGROUNDS/SUNRISE ESTATES	2990	BENZENE	03	01/01/2012 12/31/2012		DOUGLAS
NV0002540	FAIRGROUNDS/SUNRISE ESTATES	2982	CARBON TETRACHLORIDE	03	01/01/2012 12/31/2012		DOUGLAS
NV0002540	FAIRGROUNDS/SUNRISE ESTATES	2989	CHLOROBENZENE	03	01/01/2012 12/31/2012		DOUGLAS
NV0002540	FAIRGROUNDS/SUNRISE ESTATES	2380	CIS-1,2-DICHLOROETHYLENE	03	01/01/2012 12/31/2012		DOUGLAS
NV0002540	FAIRGROUNDS/SUNRISE ESTATES	3100	COLIFORM (TCR)	23	10/01/2012 10/31/2012	11/27/2012	DOUGLAS
NV0002540	FAIRGROUNDS/SUNRISE ESTATES	2964	DICHLOROMETHANE	03	01/01/2012 12/31/2012		DOUGLAS
NV0002540	FAIRGROUNDS/SUNRISE ESTATES	2992	ETHYLBENZENE	03	01/01/2012 12/31/2012		DOUGLAS
NV0002540	FAIRGROUNDS/SUNRISE ESTATES	2968	O-DICHLOROBENZENE	03	01/01/2012 12/31/2012		DOUGLAS
NV0002540	FAIRGROUNDS/SUNRISE ESTATES	2969	P-DICHLOROBENZENE	03	01/01/2012 12/31/2012		DOUGLAS
NV0002540	FAIRGROUNDS/SUNRISE ESTATES	2996	STYRENE	03	01/01/2012 12/31/2012		DOUGLAS
NV0002540	FAIRGROUNDS/SUNRISE ESTATES	2987	TETRACHLOROETHYLENE	03	01/01/2012 12/31/2012		DOUGLAS

Water System ID	Water System Name	Analyte Code	Analyte Name	Type	Compliance Period	RTC Date	County
NV0002540	FAIRGROUNDS/SUNRISE ESTATES	2991	TOLUENE	03	01/01/2012 12/31/2012		DOUGLAS
NV0002540	FAIRGROUNDS/SUNRISE ESTATES	2979	TRANS-1,2-DICHLOROETHYLENE	03	01/01/2012 12/31/2012		DOUGLAS
NV0002540	FAIRGROUNDS/SUNRISE ESTATES	2984	TRICHLOROETHYLENE	03	01/01/2012 12/31/2012		DOUGLAS
NV0002540	FAIRGROUNDS/SUNRISE ESTATES	2976	VINYL CHLORIDE	03	01/01/2012 12/31/2012		DOUGLAS
NV0002540	FAIRGROUNDS/SUNRISE ESTATES	2955	XYLENES, TOTAL	03	01/01/2012 12/31/2012		DOUGLAS
Total Number of Violations for This Water System: 22							
NV0002016	FALLON GOLF COURSE	3100	COLIFORM (TCR)	23	04/01/2012 06/30/2012	7/19/2012	CHURCHILL
NV0002016	FALLON GOLF COURSE	1040	NITRATE	03	01/01/2012 12/31/2012	5/17/2013	CHURCHILL
Total Number of Violations for This Water System: 2							
NV0002594	FALLON LIVESTOCK EXCHANGE	3100	COLIFORM (TCR)	23	01/01/2012 03/31/2012	5/7/2012	CHURCHILL
Total Number of Violations for This Water System: 1							
NV0000959	FOOTHILL WATER SYSTEM	2981	1,1,1-TRICHLOROETHANE	03	07/01/2012 09/30/2012		DOUGLAS
NV0000959	FOOTHILL WATER SYSTEM	2985	1,1,2-TRICHLOROETHANE	03	07/01/2012 09/30/2012		DOUGLAS
NV0000959	FOOTHILL WATER SYSTEM	2977	1,1-DICHLOROETHYLENE	03	07/01/2012 09/30/2012		DOUGLAS
NV0000959	FOOTHILL WATER SYSTEM	2378	1,2,4-TRICHLOROBENZENE	03	07/01/2012 09/30/2012		DOUGLAS
NV0000959	FOOTHILL WATER SYSTEM	2931	1,2-DIBROMO-3-CHLOROPROPANE	03	07/01/2012 09/30/2012		DOUGLAS
NV0000959	FOOTHILL WATER SYSTEM	2931	1,2-DIBROMO-3-CHLOROPROPANE	03	04/01/2012 06/30/2012		DOUGLAS

Water System ID	Water System Name	Analyte Code	Analyte Name	Type	Compliance Period	RTC Date	County
NV0000959	FOOTHILL WATER SYSTEM	2980	1,2-DICHLOROETHANE	03	07/01/2012 09/30/2012		DOUGLAS
NV0000959	FOOTHILL WATER SYSTEM	2983	1,2-DICHLOROPROPANE	03	07/01/2012 09/30/2012		DOUGLAS
NV0000959	FOOTHILL WATER SYSTEM	2110	2,4,5-TP	03	07/01/2012 09/30/2012		DOUGLAS
NV0000959	FOOTHILL WATER SYSTEM	2110	2,4,5-TP	03	04/01/2012 06/30/2012		DOUGLAS
NV0000959	FOOTHILL WATER SYSTEM	2105	2,4-D	03	07/01/2012 09/30/2012		DOUGLAS
NV0000959	FOOTHILL WATER SYSTEM	2105	2,4-D	03	04/01/2012 06/30/2012		DOUGLAS
NV0000959	FOOTHILL WATER SYSTEM	2050	ATRAZINE	03	07/01/2012 09/30/2012		DOUGLAS
NV0000959	FOOTHILL WATER SYSTEM	2050	ATRAZINE	03	04/01/2012 06/30/2012		DOUGLAS
NV0000959	FOOTHILL WATER SYSTEM	2990	BENZENE	03	07/01/2012 09/30/2012		DOUGLAS
NV0000959	FOOTHILL WATER SYSTEM	2306	BENZO(A)PYRENE	03	07/01/2012 09/30/2012		DOUGLAS
NV0000959	FOOTHILL WATER SYSTEM	2306	BENZO(A)PYRENE	03	04/01/2012 06/30/2012		DOUGLAS
NV0000959	FOOTHILL WATER SYSTEM	2010	BHC-GAMMA	03	07/01/2012 09/30/2012		DOUGLAS
NV0000959	FOOTHILL WATER SYSTEM	2010	BHC-GAMMA	03	04/01/2012 06/30/2012		DOUGLAS
NV0000959	FOOTHILL WATER SYSTEM	2046	CARBOFURAN	03	07/01/2012 09/30/2012		DOUGLAS
NV0000959	FOOTHILL WATER SYSTEM	2046	CARBOFURAN	03	04/01/2012 06/30/2012		DOUGLAS
NV0000959	FOOTHILL WATER SYSTEM	2982	CARBON TETRACHLORIDE	03	07/01/2012 09/30/2012		DOUGLAS
NV0000959	FOOTHILL WATER SYSTEM	2959	CHLORDANE	03	07/01/2012 09/30/2012		DOUGLAS
NV0000959	FOOTHILL WATER SYSTEM	2959	CHLORDANE	03	04/01/2012 06/30/2012		DOUGLAS
NV0000959	FOOTHILL WATER SYSTEM	2989	CHLOROBENZENE	03	07/01/2012 09/30/2012		DOUGLAS
NV0000959	FOOTHILL WATER SYSTEM	2380	CIS-1,2-DICHLOROETHYLENE	03	07/01/2012 09/30/2012		DOUGLAS
NV0000959	FOOTHILL WATER SYSTEM	4010	COMBINED RADIUM (-226 & -228)	03	07/01/2012 09/30/2012		DOUGLAS

Water System ID	Water System Name	Analyte Code	Analyte Name	Type	Compliance Period	RTC Date	County
NV0000959	FOOTHILL WATER SYSTEM	4006	COMBINED URANIUM	03	07/01/2012 09/30/2012		DOUGLAS
NV0000959	FOOTHILL WATER SYSTEM	2031	DALAPON	03	07/01/2012 09/30/2012		DOUGLAS
NV0000959	FOOTHILL WATER SYSTEM	2031	DALAPON	03	04/01/2012 06/30/2012		DOUGLAS
NV0000959	FOOTHILL WATER SYSTEM	2035	DI(2-ETHYLHEXYL) ADIPATE	03	07/01/2012 09/30/2012		DOUGLAS
NV0000959	FOOTHILL WATER SYSTEM	2035	DI(2-ETHYLHEXYL) ADIPATE	03	04/01/2012 06/30/2012		DOUGLAS
NV0000959	FOOTHILL WATER SYSTEM	2039	DI(2-ETHYLHEXYL) PHTHALATE	03	07/01/2012 09/30/2012		DOUGLAS
NV0000959	FOOTHILL WATER SYSTEM	2039	DI(2-ETHYLHEXYL) PHTHALATE	03	04/01/2012 06/30/2012		DOUGLAS
NV0000959	FOOTHILL WATER SYSTEM	2964	DICHLOROMETHANE	03	07/01/2012 09/30/2012		DOUGLAS
NV0000959	FOOTHILL WATER SYSTEM	2041	DINOSEB	03	07/01/2012 09/30/2012		DOUGLAS
NV0000959	FOOTHILL WATER SYSTEM	2041	DINOSEB	03	04/01/2012 06/30/2012		DOUGLAS
NV0000959	FOOTHILL WATER SYSTEM	2032	DIQUAT	03	07/01/2012 09/30/2012		DOUGLAS
NV0000959	FOOTHILL WATER SYSTEM	2032	DIQUAT	03	04/01/2012 06/30/2012		DOUGLAS
NV0000959	FOOTHILL WATER SYSTEM	2033	ENDOTHALL	03	07/01/2012 09/30/2012		DOUGLAS
NV0000959	FOOTHILL WATER SYSTEM	2033	ENDOTHALL	03	04/01/2012 06/30/2012		DOUGLAS
NV0000959	FOOTHILL WATER SYSTEM	2005	ENDRIN	03	07/01/2012 09/30/2012		DOUGLAS
NV0000959	FOOTHILL WATER SYSTEM	2005	ENDRIN	03	04/01/2012 06/30/2012		DOUGLAS
NV0000959	FOOTHILL WATER SYSTEM	2992	ETHYLBENZENE	03	07/01/2012 09/30/2012		DOUGLAS
NV0000959	FOOTHILL WATER SYSTEM	2946	ETHYLENE DIBROMIDE	03	07/01/2012 09/30/2012		DOUGLAS
NV0000959	FOOTHILL WATER SYSTEM	2946	ETHYLENE DIBROMIDE	03	04/01/2012 06/30/2012		DOUGLAS
NV0000959	FOOTHILL WATER SYSTEM	2034	GLYPHOSATE	03	07/01/2012 09/30/2012		DOUGLAS
NV0000959	FOOTHILL WATER SYSTEM	2034	GLYPHOSATE	03	04/01/2012 06/30/2012		DOUGLAS

Water System ID	Water System Name	Analyte Code	Analyte Name	Type	Compliance Period	RTC Date	County
NV0000959	FOOTHILL WATER SYSTEM	4002	GROSS ALPHA, INCL. RADON & U	03	07/01/2012 09/30/2012		DOUGLAS
NV0000959	FOOTHILL WATER SYSTEM	2065	HEPTACHLOR	03	07/01/2012 09/30/2012		DOUGLAS
NV0000959	FOOTHILL WATER SYSTEM	2065	HEPTACHLOR	03	04/01/2012 06/30/2012		DOUGLAS
NV0000959	FOOTHILL WATER SYSTEM	2067	HEPTACHLOR EPOXIDE	03	07/01/2012 09/30/2012		DOUGLAS
NV0000959	FOOTHILL WATER SYSTEM	2067	HEPTACHLOR EPOXIDE	03	04/01/2012 06/30/2012		DOUGLAS
NV0000959	FOOTHILL WATER SYSTEM	2274	HEXACHLOROBENZENE	03	07/01/2012 09/30/2012		DOUGLAS
NV0000959	FOOTHILL WATER SYSTEM	2274	HEXACHLOROBENZENE	03	04/01/2012 06/30/2012		DOUGLAS
NV0000959	FOOTHILL WATER SYSTEM	2042	HEXACHLOROCYCLOPENTADIENE	03	07/01/2012 09/30/2012		DOUGLAS
NV0000959	FOOTHILL WATER SYSTEM	2042	HEXACHLOROCYCLOPENTADIENE	03	04/01/2012 06/30/2012		DOUGLAS
NV0000959	FOOTHILL WATER SYSTEM	2051	LASSO	03	07/01/2012 09/30/2012		DOUGLAS
NV0000959	FOOTHILL WATER SYSTEM	2051	LASSO	03	04/01/2012 06/30/2012		DOUGLAS
NV0000959	FOOTHILL WATER SYSTEM	2015	METHOXYCHLOR	03	07/01/2012 09/30/2012		DOUGLAS
NV0000959	FOOTHILL WATER SYSTEM	2015	METHOXYCHLOR	03	04/01/2012 06/30/2012		DOUGLAS
NV0000959	FOOTHILL WATER SYSTEM	2968	O-DICHLOROBENZENE	03	07/01/2012 09/30/2012		DOUGLAS
NV0000959	FOOTHILL WATER SYSTEM	2036	OXAMYL	03	07/01/2012 09/30/2012		DOUGLAS
NV0000959	FOOTHILL WATER SYSTEM	2036	OXAMYL	03	04/01/2012 06/30/2012		DOUGLAS
NV0000959	FOOTHILL WATER SYSTEM	2969	P-DICHLOROBENZENE	03	07/01/2012 09/30/2012		DOUGLAS
NV0000959	FOOTHILL WATER SYSTEM	2326	PENTACHLOROPHENOL	03	07/01/2012 09/30/2012		DOUGLAS

Water System ID	Water System Name	Analyte Code	Analyte Name	Type	Compliance Period	RTC Date	County
NV0000959	FOOTHILL WATER SYSTEM	2326	PENTACHLOROPHENOL	03	04/01/2012 06/30/2012		DOUGLAS
NV0000959	FOOTHILL WATER SYSTEM	2040	PICLORAM	03	07/01/2012 09/30/2012		DOUGLAS
NV0000959	FOOTHILL WATER SYSTEM	2040	PICLORAM	03	04/01/2012 06/30/2012		DOUGLAS
NV0000959	FOOTHILL WATER SYSTEM	4020	RADIUM-226	03	07/01/2012 09/30/2012		DOUGLAS
NV0000959	FOOTHILL WATER SYSTEM	4030	RADIUM-228	03	07/01/2012 09/30/2012		DOUGLAS
NV0000959	FOOTHILL WATER SYSTEM	2037	SIMAZINE	03	07/01/2012 09/30/2012		DOUGLAS
NV0000959	FOOTHILL WATER SYSTEM	2037	SIMAZINE	03	04/01/2012 06/30/2012		DOUGLAS
NV0000959	FOOTHILL WATER SYSTEM	2996	STYRENE	03	07/01/2012 09/30/2012		DOUGLAS
NV0000959	FOOTHILL WATER SYSTEM	2987	TETRACHLOROETHYLENE	03	07/01/2012 09/30/2012		DOUGLAS
NV0000959	FOOTHILL WATER SYSTEM	2991	TOLUENE	03	07/01/2012 09/30/2012		DOUGLAS
NV0000959	FOOTHILL WATER SYSTEM	2383	TOTAL POLYCHLORINATED BIPHENYLS (PCB)	03	07/01/2012 09/30/2012		DOUGLAS
NV0000959	FOOTHILL WATER SYSTEM	2383	TOTAL POLYCHLORINATED BIPHENYLS (PCB)	03	04/01/2012 06/30/2012		DOUGLAS
NV0000959	FOOTHILL WATER SYSTEM	2020	TOXAPHENE	03	07/01/2012 09/30/2012		DOUGLAS
NV0000959	FOOTHILL WATER SYSTEM	2020	TOXAPHENE	03	04/01/2012 06/30/2012		DOUGLAS
NV0000959	FOOTHILL WATER SYSTEM	2979	TRANS-1,2-DICHLOROETHYLENE	03	07/01/2012 09/30/2012		DOUGLAS
NV0000959	FOOTHILL WATER SYSTEM	2984	TRICHLOROETHYLENE	03	07/01/2012 09/30/2012		DOUGLAS
NV0000959	FOOTHILL WATER SYSTEM	2976	VINYL CHLORIDE	03	07/01/2012 09/30/2012		DOUGLAS
NV0000959	FOOTHILL WATER SYSTEM	2955	XYLENES, TOTAL	03	07/01/2012 09/30/2012		DOUGLAS

Total Number of Violations for This Water System: 84

NV0000155	FORT AMARGOSA RV PARK	1040	NITRATE	03	01/01/2012 12/31/2012	5/7/2013	NYE
-----------	-----------------------	------	---------	----	-----------------------	----------	-----

Water System ID	Water System Name	Analyte Code	Analyte Name	Type	Compliance Period	RTC Date	County
Total Number of Violations for This Water System: 1							
NV0000147	FRONTIER VILLAGE MIIP CL	1005	ARSENIC	02	10/01/2012 12/31/2012		CLARK
NV0000147	FRONTIER VILLAGE MIIP CL	1005	ARSENIC	02	07/01/2012 09/30/2012		CLARK
NV0000147	FRONTIER VILLAGE MIIP CL	1005	ARSENIC	02	04/01/2012 06/30/2012		CLARK
NV0000147	FRONTIER VILLAGE MHP CL	1005	ARSENIC	02	01/01/2012 03/31/2012		CLARK
NV0000147	FRONTIER VILLAGE MHP CL	1005	ARSENIC	03	01/01/2012 03/31/2012	5/15/2012	CLARK
NV0000147	FRONTIER VILLAGE MHP CL	0999	CHLORINE	27	01/01/2012 03/31/2012	4/4/2013	CLARK
NV0000147	FRONTIER VILLAGE MHP CL	3100	COLIFORM (TCR)	23	02/01/2012 02/29/2012		CLARK
Total Number of Violations for This Water System: 7							
NV0000065	GARDNERVILLE TOWN WATER	3100	COLIFORM (TCR)	22	12/01/2012 12/31/2012	1/8/2013	DOUGLAS
Total Number of Violations for This Water System: 1							
NV0002587	GAS STORE WEST	3100	COLIFORM (TCR)	23	01/01/2012 03/31/2012	4/10/2012	CHURCHILL
Total Number of Violations for This Water System: 1							
NV0000327	GAYE HAVEN CARE HOME	1040	NITRATE	03	04/01/2012 06/30/2012	9/10/2012	CLARK
Total Number of Violations for This Water System: 1							
NV0000372	GEORGIA PACIFIC GYPSUM LLC	3100	COLIFORM (TCR)	23	10/01/2012 12/31/2012		CLARK
Total Number of Violations for This Water System: 1							
NV0000356	GLENBROOK HOMEOWNERS ASSOCIATION	2456	TOTAL HALOACETIC ACIDS (HAAS)	27	10/01/2012 12/31/2012		DOUGLAS
NV0000356	GLENBROOK HOMEOWNERS ASSOCIATION	2950	TTIM	27	10/01/2012 12/31/2012		DOUGLAS

Water System ID	Water System Name	Analyte Code	Analyte Name	Type	Compliance Period	RTC Date	County
Total Number of Violations for This Water System: 2							
NV0000072	GOLDFIELD TOWN WATER	1005	ARSENIC	02	01/01/2012 03/31/2012		ESMERALDA
NV0000072	GOLDFIELD TOWN WATER	1005	ARSENIC	03	06/01/2012 06/30/2012		ESMERALDA
NV0000072	GOLDFIELD TOWN WATER	1005	ARSENIC	03	04/01/2012 04/30/2012		ESMERALDA
NV0000072	GOLDFIELD TOWN WATER	3100	COLIFORM (TCR)	23	11/01/2012 11/30/2012	12/18/2012	ESMERALDA
NV0000072	GOLDFIELD TOWN WATER	4006	COMBINED URANIUM	03	01/01/2007 12/31/2012		ESMERALDA
NV0000072	GOLDFIELD TOWN WATER	4002	GROSS ALPHA, INCL. RADON & U	03	01/01/2007 12/31/2012		ESMERALDA
NV0000072	GOLDFIELD TOWN WATER	1040	NITRATE	03	01/01/2012 12/31/2012		ESMERALDA
Total Number of Violations for This Water System: 7							
NV0002202	GRANITE CONSTRUCTION	5000	LEAD & COPPER RULE	51	07/01/2012		WASHOE
Total Number of Violations for This Water System: 1							
NV0001083	HACIENDA HOTEL AND CASINO	2950	TTHM	02	01/01/2012 03/31/2012	5/11/2012	CLARK
Total Number of Violations for This Water System: 1							
NV0000357	HAWTHORNE ARMY AMMO DEPOT	1927	ALKALINITY, TOTAL	27	09/01/2012 09/30/2012		MINERAL
NV0000357	HAWTHORNE ARMY AMMO DEPOT	2920	CARBON, TOTAL	27	07/01/2012 09/30/2012		MINERAL
NV0000357	HAWTHORNE ARMY AMMO DEPOT	4006	COMBINED URANIUM	03	01/01/2007 12/31/2012		MINERAL
NV0000357	HAWTHORNE ARMY AMMO DEPOT	2950	TTHM	02	10/01/2012 12/31/2012		MINERAL
Total Number of Violations for This Water System: 4							
NV0002046	HOLBROOK STATION RV AND MHP	1005	ARSENIC	02	10/01/2012 12/31/2012		DOUGLAS

Water System ID	Water System Name	Analyte Code	Analyte Name	Type	Compliance Period	RTC Date	County
NV0002046	HOLBROOK STATION RV AND MHHP	1005	ARSENIC	02	07/01/2012 09/30/2012		DOUGLAS
NV0002046	HOLBROOK STATION RV AND MHHP	1005	ARSENIC	02	04/01/2012 06/30/2012		DOUGLAS
NV0002046	HOLBROOK STATION RV AND MHHP	1005	ARSENIC	02	01/01/2012 03/31/2012		DOUGLAS
NV0002046	HOLBROOK STATION RV AND MHHP	1005	ARSENIC	03	07/01/2012 09/30/2012		DOUGLAS
NV0002046	HOLBROOK STATION RV AND MHHP	1005	ARSENIC	03	04/01/2012 06/30/2012		DOUGLAS
NV0002046	HOLBROOK STATION RV AND MHHP	1005	ARSENIC	03	01/01/2012 03/31/2012		DOUGLAS
Total Number of Violations for This Water System: 7							
NV0000376	HOYE PLAZA	3100	COLIFORM (TCR)	23	01/01/2012 03/31/2012	1/8/2013	LYON
NV0000376	HOYE PLAZA	1040	NITRATE	03	01/01/2012 12/31/2012	1/8/2013	LYON
Total Number of Violations for This Water System: 2							
NV0000355	INDIAN HILLS GID	3100	COLIFORM (TCR)	21	08/01/2012 08/31/2012	9/4/2012	DOUGLAS
Total Number of Violations for This Water System: 1							
NV0000980	JOHNNYS ROADHOUSE LLC	3100	COLIFORM (TCR)	23	07/01/2012 09/30/2012	10/4/2012	DOUGLAS
Total Number of Violations for This Water System: 1							
NV0002024	KENNAMETAL INC	3100	COLIFORM (TCR)	23	10/01/2012 12/31/2012	1/25/2013	CHURCHILL
Total Number of Violations for This Water System: 1							
NV0002121	KERSHAW RYAN STATE PARK	3100	COLIFORM (TCR)	22	01/01/2012 01/31/2012	2/14/2012	LINCOLN
NV0002121	KERSHAW RYAN STATE PARK	3100	COLIFORM (TCR)	22	01/01/2012 01/31/2012	4/17/2012	LINCOLN
NV0002121	KERSHAW RYAN STATE PARK	3100	COLIFORM (TCR)	22	01/01/2012 01/31/2012	5/15/2012	LINCOLN
Total Number of Violations for This Water System: 3							

Water System ID	Water System Name	Analyte Code	Analyte Name	Type	Compliance Period	RTC Date	County
NV0000932	KEYSTONE CENTER	3100	COLIFORM (TCR)	21	07/01/2012 07/31/2012	2/13/2013	CLARK
NV0000932	KEYSTONE CENTER	3100	COLIFORM (TCR)	22	08/01/2012 08/31/2012	1/9/2013	CLARK
NV0000932	KEYSTONE CENTER	3100	COLIFORM (TCR)	22	07/01/2012 07/31/2012	1/9/2013	CLARK
NV0000932	KEYSTONE CENTER	3100	COLIFORM (TCR)	23	04/01/2012 06/30/2012	7/11/2012	CLARK
NV0000932	KEYSTONE CENTER	3100	COLIFORM (TCR)	23	10/01/2012 10/31/2012	11/30/2012	CLARK
NV0000932	KEYSTONE CENTER	3100	COLIFORM (TCR)	23	09/01/2012 09/30/2012	11/30/2012	CLARK
NV0000932	KEYSTONE CENTER	3100	COLIFORM (TCR)	23	12/01/2012 12/31/2012	1/9/2013	CLARK
NV0000932	KEYSTONE CENTER	3100	COLIFORM (TCR)	23	11/01/2012 11/30/2012	1/9/2013	CLARK
NV0000932	KEYSTONE CENTER	1040	NITRATE	03	01/01/2012 12/31/2012	2/13/2013	CLARK
Total Number of Violations for This Water System: 9							
NV0002053	LA FERME RESTAURANT	1040	NITRATE	03	01/01/2012 12/31/2012	5/7/2013	DOUGLAS
Total Number of Violations for This Water System: 1							
NV0000928	LAMOILLE VALLEY PLAZA	1005	ARSENIC	02	10/01/2012 12/31/2012		ELKO
NV0000928	LAMOILLE VALLEY PLAZA	1005	ARSENIC	02	07/01/2012 09/30/2012		ELKO
NV0000928	LAMOILLE VALLEY PLAZA	1005	ARSENIC	02	04/01/2012 06/30/2012		ELKO
NV0000928	LAMOILLE VALLEY PLAZA	1005	ARSENIC	02	01/01/2012 03/31/2012		ELKO
Total Number of Violations for This Water System: 4							
NV0000202	LEMMON VALLEY WATER COMPANY	4006	COMBINED URANIUM	03	01/01/2007 12/31/2012		WASHOE
Total Number of Violations for This Water System: 1							
NV0002192	LITTLE A LE INN	3100	COLIFORM (TCR)	22	10/01/2012 10/31/2012	11/26/2012	LINCOLN
Total Number of Violations for This Water System: 1							

Water System ID	Water System Name	Analyte Code	Analyte Name	Type	Compliance Period	RTC Date	County
NV0002050	LOGAN CREEK ESTATES GID	1040	NITRATE	03	01/01/2012 12/31/2012		DOUGLAS
Total Number of Violations for This Water System: 1							
NV0004096	LONE MOUNTAIN STATION	3100	COLIFORM (TCR)	23	04/01/2012 06/30/2012	8/21/2012	ELKO
NV0004096	LONE MOUNTAIN STATION	3100	COLIFORM (TCR)	23	10/01/2012 12/31/2012	2/20/2013	ELKO
Total Number of Violations for This Water System: 2							
NV0000871	LONGSTREET INN AND CASINO	1005	ARSENIC	03	04/01/2012 06/30/2012	7/9/2012	NYE
Total Number of Violations for This Water System: 1							
NV0000392	LOVELL CANYON RESIDENTIAL LLC	3100	COLIFORM (TCR)	23	07/01/2012 09/30/2012		CLARK
Total Number of Violations for This Water System: 1							
NV0000979	LUND SCHOOL	3100	COLIFORM (TCR)	22	07/01/2012 07/31/2012	8/2/2012	WHITE PINE
Total Number of Violations for This Water System: 1							
NV0005019	MABELS BAR	3100	COLIFORM (TCR)	23	10/01/2012 12/31/2012	1/30/2013	NYE
Total Number of Violations for This Water System: 1							
NV0000165	MANHATTAN TOWN WATER	3100	COLIFORM (TCR)	22	08/01/2012 08/31/2012	9/3/2012	NYE
Total Number of Violations for This Water System: 1							
NV0000074	MINA LUNING WATER SYSTEM	1005	ARSENIC	03	01/01/2012 03/31/2012		MINERAL
NV0000074	MINA LUNING WATER SYSTEM	4006	COMBINED URANIUM	03	01/01/2007 12/31/2012		MINERAL
NV0000074	MINA LUNING WATER SYSTEM	4002	GROSS ALPHA, INCL. RADON & U	03	01/01/2007 12/31/2012		MINERAL
Total Number of Violations for This Water System: 3							

Water System ID	Water System Name	Analyte Code	Analyte Name	Type	Compliance Period	RTC Date	County
NV0002142	MOOSE LODGE 808	3100	COLIFORM (TCR)	21	04/01/2012 04/30/2012	7/9/2012	NYE
NV0002142	MOOSE LODGE 808	3100	COLIFORM (TCR)	22	05/01/2012 05/31/2012	7/9/2012	NYE
Total Number of Violations for This Water System: 2							
NV0001082	MOUNTAIN SPRINGS BAR INC	3100	COLIFORM (TCR)	23	01/01/2012 03/31/2012		CLARK
Total Number of Violations for This Water System: 1							
NV0000876	NARCONON NEVADA RAINBOW CANYON	3100	COLIFORM (TCR)	23	04/01/2012 04/30/2012	5/30/2012	LINCOLN
NV0000876	NARCONON NEVADA RAINBOW CANYON	3100	COLIFORM (TCR)	23	04/01/2012 04/30/2012	6/18/2012	LINCOLN
Total Number of Violations for This Water System: 2							
NV0001054	NDOT BUTTON POINT ROADSIDE PARK RP808HU	3100	COLIFORM (TCR)	23	04/01/2012 06/30/2012	7/12/2012	HUMBOLDT
Total Number of Violations for This Water System: 1							
NV0002160	NDOT COSGRAVE ROADSIDE PARK RP804PE	3100	COLIFORM (TCR)	23	04/01/2012 06/30/2012	7/12/2012	PERSHING
Total Number of Violations for This Water System: 1							
NV0000943	NDOT SUNNYSIDE ROADSIDE PARK RP810NY	3100	COLIFORM (TCR)	23	07/01/2012 09/30/2012	10/2/2012	NYE
Total Number of Violations for This Water System: 1							
NV0002102	NDOT VALMY ROADSIDE PARK RP809IU	3100	COLIFORM (TCR)	23	04/01/2012 06/30/2012	7/12/2012	HUMBOLDT
Total Number of Violations for This Water System: 1							
NV0002014	NEVADA LIVESTOCK MARKETING	3100	COLIFORM (TCR)	23	01/01/2012 03/31/2012	4/10/2012	CHURCHILL
Total Number of Violations for This Water System: 1							

Water System ID	Water System Name	Analyte Code	Analyte Name	Type	Compliance Period	RTC Date	County
NV0002506	NPS CALLVILLE BAY	1024	CYANIDE	03	01/01/2012 12/31/2012		CLARK
Total Number of Violations for This Water System: 1							
NV0002503	NPS ECHO BAY	1024	CYANIDE	03	01/01/2012 12/31/2012		CLARK
NV0002503	NPS ECHO BAY	2950	TTHM	02	04/01/2012 06/30/2012	9/19/2012	CLARK
NV0002503	NPS ECHO BAY	2950	TTHM	02	01/01/2012 03/31/2012	9/19/2012	CLARK
Total Number of Violations for This Water System: 3							
NV0000140	OAKRIDGE APARTMENTS	0999	CHLORINE	27	04/01/2012 06/30/2012		CLARK
NV0000140	OAKRIDGE APARTMENTS	3100	COLIFORM (TCR)	23	06/01/2012 06/30/2012		CLARK
NV0000140	OAKRIDGE APARTMENTS	3100	COLIFORM (TCR)	23	05/01/2012 05/31/2012		CLARK
NV0000140	OAKRIDGE APARTMENTS	7000	CONSUMER CONFIDENCE RULE	71	07/01/2012		CLARK
Total Number of Violations for This Water System: 4							
NV0000921	OASIS SPRINGS	3100	COLIFORM (TCR)	22	07/01/2012 07/31/2012	8/2/2012	CHURCHILL
Total Number of Violations for This Water System: 1							
NV0000705	OLD 395 STATION	3100	COLIFORM (TCR)	23	08/01/2012 08/31/2012		WASHOE
Total Number of Violations for This Water System: 1							
NV0000303	OLD RIVER WATER COMPANY	1005	ARSENIC	02	10/01/2012 12/31/2012		CHURCHILL
NV0000303	OLD RIVER WATER COMPANY	1005	ARSENIC	02	07/01/2012 09/30/2012		CHURCHILL
NV0000303	OLD RIVER WATER COMPANY	1005	ARSENIC	02	04/01/2012 06/30/2012		CHURCHILL
NV0000303	OLD RIVER WATER COMPANY	1005	ARSENIC	02	01/01/2012 03/31/2012		CHURCHILL
Total Number of Violations for This Water System: 4							

Water System ID	Water System Name	Analyte Code	Analyte Name	Type	Compliance Period	RTC Date	County
NV0001105	ORCHARD VALLEY MARKET	3100	COLIFORM (TCR)	23	07/01/2012 09/30/2012	10/23/2012	NYE
Total Number of Violations for This Water System: 1							
NV0003035	OUR BAR	3100	COLIFORM (TCR)	25	01/01/2012 01/31/2012		NYE
NV0003035	OUR BAR	3014	E. COLI	34	01/10/2012 01/17/2012		NYE
Total Number of Violations for This Water System: 2							
NV0000819	PALM GARDENS WATER CO OP	0999	CHLORINE	27	10/01/2012 12/31/2012		CLARK
NV0000819	PALM GARDENS WATER CO OP	3100	COLIFORM (TCR)	23	06/01/2012 06/30/2012	7/31/2012	CLARK
NV0000819	PALM GARDENS WATER CO OP	1025	FLUORIDE	03	11/01/2012 11/30/2012	6/26/2013	CLARK
NV0000819	PALM GARDENS WATER CO OP	1025	FLUORIDE	03	10/01/2012 10/31/2012	6/26/2013	CLARK
NV0000819	PALM GARDENS WATER CO OP	1025	FLUORIDE	03	08/01/2012 08/31/2012	6/26/2013	CLARK
NV0000819	PALM GARDENS WATER CO OP	1025	FLUORIDE	03	07/01/2012 07/31/2012	6/26/2013	CLARK
NV0000819	PALM GARDENS WATER CO OP	1025	FLUORIDE	03	06/01/2012 06/30/2012	6/26/2013	CLARK
NV0000819	PALM GARDENS WATER CO OP	1025	FLUORIDE	03	05/01/2012 05/31/2012	6/26/2013	CLARK
NV0000819	PALM GARDENS WATER CO OP	1025	FLUORIDE	03	04/01/2012 04/30/2012	6/26/2013	CLARK
Total Number of Violations for This Water System: 9							
NV0002186	PARADISE VALLEY ELEMENTARY	3100	COLIFORM (TCR)	23	01/01/2012 03/31/2012	4/3/2012	HUMBOLDT
Total Number of Violations for This Water System: 1							
NV0002064	PETES TRAILER COURT	3100	COLIFORM (TCR)	22	06/01/2012 06/30/2012	7/25/2012	ELKO
Total Number of Violations for This Water System: 1							
NV0001012	PIONEER SALOON	1040	NITRATE	03	01/01/2012 12/31/2012	1/11/2013	CLARK

Water System ID	Water System Name	Analyte Code	Analyte Name	Type	Compliance Period	RTC Date	County
Total Number of Violations for This Water System: 1							
NV0001069	RANCHO HOUSE	3100	COLIFORM (TCR)	23	04/01/2012 06/30/2012	9/19/2012	CLARK
Total Number of Violations for This Water System: 1							
NV0002571	RANCHO VISTA 4	2981	1,1,1-TRICHLOROETHANE	03	10/01/2012 12/31/2012		NYE
NV0002571	RANCHO VISTA 4	2985	1,1,2-TRICHLOROETHANE	03	10/01/2012 12/31/2012		NYE
NV0002571	RANCHO VISTA 4	2977	1,1-DICHLOROETHYLENE	03	10/01/2012 12/31/2012		NYE
NV0002571	RANCHO VISTA 4	2378	1,2,4-TRICHLOROBENZENE	03	10/01/2012 12/31/2012		NYE
NV0002571	RANCHO VISTA 4	2931	1,2-DIBROMO-3-CHLOROPROPANE	03	10/01/2012 12/31/2012		NYE
NV0002571	RANCHO VISTA 4	2980	1,2-DICHLOROETHANE	03	10/01/2012 12/31/2012		NYE
NV0002571	RANCHO VISTA 4	2983	1,2-DICHLOROPROPANE	03	10/01/2012 12/31/2012		NYE
NV0002571	RANCHO VISTA 4	2110	2,4,5-TP	03	10/01/2012 12/31/2012		NYE
NV0002571	RANCHO VISTA 4	2105	2,4-D	03	10/01/2012 12/31/2012		NYE
NV0002571	RANCHO VISTA 4	1074	ANTIMONY, TOTAL	03	01/01/2012 12/31/2012		NYE
NV0002571	RANCHO VISTA 4	1005	ARSENIC	03	01/01/2012 12/31/2012		NYE
NV0002571	RANCHO VISTA 4	2050	ATRAZINE	03	10/01/2012 12/31/2012		NYE
NV0002571	RANCHO VISTA 4	1010	BARIIUM	03	01/01/2012 12/31/2012		NYE
NV0002571	RANCHO VISTA 4	2990	BENZENE	03	10/01/2012 12/31/2012		NYE
NV0002571	RANCHO VISTA 4	2306	BENZO(A)PYRENE	03	10/01/2012 12/31/2012		NYE

Water System ID	Water System Name	Analyte Code	Analyte Name	Type	Compliance Period	RTC Date	County
NV0002571	RANCHO VISTA 4	1075	BERYLLIUM, TOTAL	03	01/01/2012 12/31/2012		NYE
NV0002571	RANCHO VISTA 4	2010	BHC-GAMMA	03	10/01/2012 12/31/2012		NYE
NV0002571	RANCHO VISTA 4	1015	CADMIUM	03	01/01/2012 12/31/2012		NYE
NV0002571	RANCHO VISTA 4	2046	CARBOFURAN	03	10/01/2012 12/31/2012		NYE
NV0002571	RANCHO VISTA 4	2982	CARBON TETRACHLORIDE	03	10/01/2012 12/31/2012		NYE
NV0002571	RANCHO VISTA 4	2959	CHLORDANE	03	10/01/2012 12/31/2012		NYE
NV0002571	RANCHO VISTA 4	2989	CHLOROBENZENE	03	10/01/2012 12/31/2012		NYE
NV0002571	RANCHO VISTA 4	1020	CHROMIUM	03	01/01/2012 12/31/2012		NYE
NV0002571	RANCHO VISTA 4	2380	CIS-1,2- DICHLOROETHYLENE	03	10/01/2012 12/31/2012		NYE
NV0002571	RANCHO VISTA 4	4010	COMBINED RADIUM (-226 & -228)	03	10/01/2012 12/31/2012		NYE
NV0002571	RANCHO VISTA 4	4006	COMBINED URANIUM	03	10/01/2012 12/31/2012		NYE
NV0002571	RANCHO VISTA 4	1024	CYANIDE	03	01/01/2012 12/31/2012		NYE
NV0002571	RANCHO VISTA 4	2031	DALAPON	03	10/01/2012 12/31/2012		NYE
NV0002571	RANCHO VISTA 4	2035	DI(2-ETHYLHEXYL) ADIPATE	03	10/01/2012 12/31/2012		NYE
NV0002571	RANCHO VISTA 4	2039	DI(2-ETHYLHEXYL) PHTHALATE	03	10/01/2012 12/31/2012		NYE
NV0002571	RANCHO VISTA 4	2964	DICHLOROMETHANE	03	10/01/2012 12/31/2012		NYE
NV0002571	RANCHO VISTA 4	2041	DINOSEB	03	10/01/2012 12/31/2012		NYE
NV0002571	RANCHO VISTA 4	2032	DIQUAT	03	10/01/2012 12/31/2012		NYE
NV0002571	RANCHO VISTA 4	2033	ENDOTHALL	03	10/01/2012 12/31/2012		NYE
NV0002571	RANCHO VISTA 4	2005	ENDRIN	03	10/01/2012 12/31/2012		NYE

Water System ID	Water System Name	Analyte Code	Analyte Name	Type	Compliance Period	RTC Date	County
NV0002571	RANCHO VISTA 4	2992	ETHYLBENZENE	03	10/01/2012 12/31/2012		NYE
NV0002571	RANCHO VISTA 4	2946	ETHYLENE DIBROMIDE	03	10/01/2012 12/31/2012		NYE
NV0002571	RANCHO VISTA 4	1025	FLUORIDE	03	01/01/2012 12/31/2012		NYE
NV0002571	RANCHO VISTA 4	2034	GLYPHOSATE	03	10/01/2012 12/31/2012		NYE
NV0002571	RANCHO VISTA 4	4002	GROSS ALPHA, INCL. RADON & U	03	10/01/2012 12/31/2012		NYE
NV0002571	RANCHO VISTA 4	2065	HEPTACHLOR	03	10/01/2012 12/31/2012		NYE
NV0002571	RANCHO VISTA 4	2067	HEPTACHLOR EPOXIDE	03	10/01/2012 12/31/2012		NYE
NV0002571	RANCHO VISTA 4	2274	HEXACHLOROBENZENE	03	10/01/2012 12/31/2012		NYE
NV0002571	RANCHO VISTA 4	2042	HEXACHLOROCYCLOPENTADIENE	03	10/01/2012 12/31/2012		NYE
NV0002571	RANCHO VISTA 4	2051	LASSO	03	10/01/2012 12/31/2012		NYE
NV0002571	RANCHO VISTA 4	1035	MERCURY	03	01/01/2012 12/31/2012		NYE
NV0002571	RANCHO VISTA 4	2015	METHOXYCHLOR	03	10/01/2012 12/31/2012		NYE
NV0002571	RANCHO VISTA 4	1036	NICKEL	03	01/01/2012 12/31/2012		NYE
NV0002571	RANCHO VISTA 4	1040	NITRATE	03	01/01/2012 12/31/2012		NYE
NV0002571	RANCHO VISTA 4	1040	NITRATE	03	01/01/2012 12/31/2012	2/14/2013	NYE
NV0002571	RANCHO VISTA 4	1041	NITRITE	03	01/01/2012 12/31/2012		NYE
NV0002571	RANCHO VISTA 4	2968	O-DICHLOROBENZENE	03	10/01/2012 12/31/2012		NYE
NV0002571	RANCHO VISTA 4	2036	OXAMYL	03	10/01/2012 12/31/2012		NYE
NV0002571	RANCHO VISTA 4	2969	P-DICHLOROBENZENE	03	10/01/2012 12/31/2012		NYE

Water System ID	Water System Name	Analyte Code	Analyte Name	Type	Compliance Period	RTC Date	County
NV0002571	RANCHO VISTA 4	2326	PENTACHLOROPHENOL	03	10/01/2012 12/31/2012		NYE
NV0002571	RANCHO VISTA 4	2040	PICLORAM	03	10/01/2012 12/31/2012		NYE
NV0002571	RANCHO VISTA 4	4020	RADIUM-226	03	10/01/2012 12/31/2012		NYE
NV0002571	RANCHO VISTA 4	4030	RADIUM-228	03	10/01/2012 12/31/2012		NYE
NV0002571	RANCHO VISTA 4	1045	SELENIUM	03	01/01/2012 12/31/2012		NYE
NV0002571	RANCHO VISTA 4	2037	SIMAZINE	03	10/01/2012 12/31/2012		NYE
NV0002571	RANCHO VISTA 4	1052	SODIUM	03	01/01/2012 12/31/2012		NYE
NV0002571	RANCHO VISTA 4	2996	STYRENE	03	10/01/2012 12/31/2012		NYE
NV0002571	RANCHO VISTA 4	2987	TETRACHLOROETHYLENE	03	10/01/2012 12/31/2012		NYE
NV0002571	RANCHO VISTA 4	1085	THALLIUM, TOTAL	03	01/01/2012 12/31/2012		NYE
NV0002571	RANCHO VISTA 4	2991	TOLUENE	03	10/01/2012 12/31/2012		NYE
NV0002571	RANCHO VISTA 4	2383	TOTAL POLYCHLORINATED BIPHENYLS (PCB)	03	10/01/2012 12/31/2012		NYE
NV0002571	RANCHO VISTA 4	2020	TOXAPHENE	03	10/01/2012 12/31/2012		NYE
NV0002571	RANCHO VISTA 4	2979	TRANS-1,2-DICHLOROETHYLENE	03	10/01/2012 12/31/2012		NYE
NV0002571	RANCHO VISTA 4	2984	TRICHLOROETHYLENE	03	10/01/2012 12/31/2012		NYE
NV0002571	RANCHO VISTA 4	2976	VINYL CHLORIDE	03	10/01/2012 12/31/2012		NYE
NV0002571	RANCHO VISTA 4	2955	XYLENES, TOTAL	03	10/01/2012 12/31/2012		NYE

Total Number of Violations for This Water System: 71

NV0000701	RENO SAHARA TRAILER PARK	5000	LEAD & COPPER RULE	52	10/01/2012		WASHOE
-----------	--------------------------	------	--------------------	----	------------	--	--------

Total Number of Violations for This Water System: 1

Water System ID	Water System Name	Analyte Code	Analyte Name	Type	Compliance Period	RTC Date	County
NV0000319	ROARK ESTATES WATER ASSOC	1005	ARSENIC	02	10/01/2012 12/31/2012		CLARK
NV0000319	ROARK ESTATES WATER ASSOC	1005	ARSENIC	02	07/01/2012 09/30/2012		CLARK
NV0000319	ROARK ESTATES WATER ASSOC	1005	ARSENIC	02	04/01/2012 06/30/2012		CLARK
NV0000319	ROARK ESTATES WATER ASSOC	1005	ARSENIC	02	01/01/2012 03/31/2012		CLARK
Total Number of Violations for This Water System: 4							
NV0000767	ROSEMOUNT WATER CO	4006	COMBINED URANIUM	02	10/01/2012 12/31/2012		WASHOE
NV0000767	ROSEMOUNT WATER CO	4006	COMBINED URANIUM	02	07/01/2012 09/30/2012		WASHOE
NV0000767	ROSEMOUNT WATER CO	4006	COMBINED URANIUM	02	04/01/2012 06/30/2012		WASHOE
NV0000767	ROSEMOUNT WATER CO	4006	COMBINED URANIUM	02	01/01/2012 03/31/2012		WASHOE
NV0000767	ROSEMOUNT WATER CO	1052	SODIUM	03	01/01/2010 12/31/2012		WASHOE
Total Number of Violations for This Water System: 5							
NV0000951	ROSIES PLACE	3100	COLIFORM (TCR)	23	07/01/2012 09/30/2012	10/30/2012	LYON
Total Number of Violations for This Water System: 1							
NV0000904	RUBY LAKE RESORT	3100	COLIFORM (TCR)	23	10/01/2012 12/31/2012	2/12/2013	ELKO
NV0000904	RUBY LAKE RESORT	1040	NITRATE	03	01/01/2012 12/31/2012		ELKO
Total Number of Violations for This Water System: 2							
NV0002222	RYE PATCH TRAVEL CENTER INC	3100	COLIFORM (TCR)	23	10/01/2012 12/31/2012	2/14/2013	PERSHING
NV0002222	RYE PATCH TRAVEL CENTER INC	3100	COLIFORM (TCR)	23	07/01/2012 09/30/2012	2/14/2013	PERSHING
Total Number of Violations for This Water System: 2							
NV0002566	SAGE SCHOOLS	0999	CHLORINE	27	10/01/2012 12/31/2012		ELKO

Water System ID	Water System Name	Analyte Code	Analyte Name	Type	Compliance Period	RTC Date	County
NV0002566	SAGE SCHOOLS	0999	CHLORINE	27	07/01/2012 09/30/2012		ELKO
Total Number of Violations for This Water System: 2							
NV0002023	SAGE VALLEY MHP	3100	COLIFORM (TCR)	23	08/01/2012 08/31/2012	9/18/2012	CHURCHILL
NV0002023	SAGE VALLEY MHP	3100	COLIFORM (TCR)	23	11/01/2012 11/30/2012	12/19/2012	CHURCHILL
NV0002023	SAGE VALLEY MHP	7000	CONSUMER CONFIDENCE RULE	71	07/01/2012		CHURCHILL
NV0002023	SAGE VALLEY MHP	2456	TOTAL HALOACETIC ACIDS (HAA5)	27	01/01/2012 12/31/2012		CHURCHILL
NV0002023	SAGE VALLEY MHP	2950	THM	27	01/01/2012 12/31/2012		CHURCHILL
Total Number of Violations for This Water System: 5							
NV0001096	SANDERS WINERY	3100	COLIFORM (TCR)	23	04/01/2012 06/30/2012	7/2/2012	NYE
Total Number of Violations for This Water System: 1							
NV0000306	SANDWINDS RESTAURANT SPORTS BAR	3100	COLIFORM (TCR)	23	04/01/2012 06/30/2012	7/23/2012	CHURCHILL
Total Number of Violations for This Water System: 1							
NV0000317	SANDY VALLEY LIBRARY COMM CTR	3100	COLIFORM (TCR)	23	07/01/2012 09/30/2012		CLARK
Total Number of Violations for This Water System: 1							
NV0000358	SHELLBOURNE STATION	1040	NITRATE	03	01/01/2012 12/31/2012		WHITE PINE
Total Number of Violations for This Water System: 1							
NV0000897	SCHURZ ELEMENTARY SCHOOL	1005	ARSENIC	03	12/01/2012 12/31/2012		MINERAL
NV0000897	SCHURZ ELEMENTARY SCHOOL	1005	ARSENIC	03	10/01/2012 10/31/2012		MINERAL
Total Number of Violations for This Water System: 2							

Water System ID	Water System Name	Analyte Code	Analyte Name	Type	Compliance Period	RTC Date	County
NV000858	SHERRYS STEAKHOUSE	3100	COLIFORM (TCR)	23	01/01/2012 03/31/2012	4/3/2012	LYON
Total Number of Violations for This Water System: 1							
NV0005028	SHOSHONE ESTATES WATER COMPANY	1005	ARSENIC	02	10/01/2012 12/31/2012		NYE
NV0005028	SHOSHONE ESTATES WATER COMPANY	1005	ARSENIC	02	07/01/2012 09/30/2012		NYE
NV0005028	SHOSHONE ESTATES WATER COMPANY	1005	ARSENIC	02	04/01/2012 06/30/2012		NYE
NV0005028	SHOSHONE ESTATES WATER COMPANY	1005	ARSENIC	02	01/01/2012 03/31/2012		NYE
NV0005028	SHOSHONE ESTATES WATER COMPANY	3100	COLIFORM (TCR)	23	10/01/2012 10/31/2012	11/5/2012	NYE
Total Number of Violations for This Water System: 5							
NV0000931	SIERRA COUNTRY ESTATES	3100	COLIFORM (TCR)	23	07/01/2012 07/31/2012	8/15/2012	DOUGLAS
NV0000931	SIERRA COUNTRY ESTATES	3100	COLIFORM (TCR)	23	12/01/2012 12/31/2012	5/30/2013	DOUGLAS
NV0000931	SIERRA COUNTRY ESTATES	5000	LEAD & COPPER RULE	51	01/01/2013		DOUGLAS
NV0000931	SIERRA COUNTRY ESTATES	5000	LEAD & COPPER RULE	51	07/01/2012		DOUGLAS
NV0000931	SIERRA COUNTRY ESTATES	5000	LEAD & COPPER RULE	65	01/01/2013		DOUGLAS
NV0000931	SIERRA COUNTRY ESTATES	5000	LEAD & COPPER RULE	65	07/01/2012		DOUGLAS
NV0000931	SIERRA COUNTRY ESTATES	5000	LEAD & COPPER RULE	65	01/01/2012		DOUGLAS
Total Number of Violations for This Water System: 7							
NV0004021	SILVER KNOLLS MUTUAL WATER COMPANY	1005	ARSENIC	03	07/01/2012 09/30/2012		WASHOE
Total Number of Violations for This Water System: 1							
NV0002581	SKIPS MINI MARKET	3100	COLIFORM (TCR)	22	07/01/2012 07/31/2012	8/2/2012	CHURCHILL

Water System ID	Water System Name	Analyte Code	Analyte Name	Type	Compliance Period	RTC Date	County
Total Number of Violations for This Water System: 1							
NV0001099	SLOAN TRANSFER STATION	3100	COLIFORM (TCR)	23	01/01/2012 03/31/2012		CLARK
Total Number of Violations for This Water System: 1							
NV0000929	SONIC BURGER	3100	COLIFORM (TCR)	23	04/01/2012 06/30/2012	7/5/2012	CHURCHILL
NV0000929	SONIC BURGER	3100	COLIFORM (TCR)	23	10/01/2012 12/31/2012	1/4/2013	CHURCHILL
NV0000929	SONIC BURGER	1040	NITRATE	03	01/01/2012 12/31/2012		CHURCHILL
Total Number of Violations for This Water System: 3							
NV0000215	SOUTH TRUCKEE MEADOWS GID	1052	SODIUM	03	01/01/2010 12/31/2012		WASHOE
Total Number of Violations for This Water System: 1							
NV0005062	SOUTHERN DESERT CORRECTIONAL CTR NDOC	2981	1,1,1- TRICHLOROETHANE	03	04/01/2012 06/30/2012		CLARK
NV0005062	SOUTHERN DESERT CORRECTIONAL CTR NDOC	2985	1,1,2- TRICHLOROETHANE	03	04/01/2012 06/30/2012		CLARK
NV0005062	SOUTHERN DESERT CORRECTIONAL CTR NDOC	2977	1,1- DICHLOROETHYLENE	03	04/01/2012 06/30/2012		CLARK
NV0005062	SOUTHERN DESERT CORRECTIONAL CTR NDOC	2378	1,2,4- TRICHLOROBENZENE	03	04/01/2012 06/30/2012		CLARK
NV0005062	SOUTHERN DESERT CORRECTIONAL CTR NDOC	2980	1,2- DICHLOROETHANE	03	04/01/2012 06/30/2012		CLARK
NV0005062	SOUTHERN DESERT CORRECTIONAL CTR NDOC	2983	1,2- DICHLOROPROPANE	03	04/01/2012 06/30/2012		CLARK
NV0005062	SOUTHERN DESERT CORRECTIONAL CTR NDOC	2990	BENZENE	03	04/01/2012 06/30/2012		CLARK
NV0005062	SOUTHERN DESERT CORRECTIONAL CTR NDOC	2982	CARBON TETRACHLORIDE	03	04/01/2012 06/30/2012		CLARK

Water System ID	Water System Name	Analyte Code	Analyte Name	Type	Compliance Period	RTC Date	County
NV0005062	SOUTHERN DESERT CORRECTIONAL CTR NDOC	2989	CHLOROBENZENE	03	04/01/2012 06/30/2012		CLARK
NV0005062	SOUTHERN DESERT CORRECTIONAL CTR NDOC	2380	CIS-1,2- DICHLOROETHYLENE	03	04/01/2012 06/30/2012		CLARK
NV0005062	SOUTHERN DESERT CORRECTIONAL CTR NDOC	4010	COMBINED RADIUM (-226 & -228)	03	04/01/2012 06/30/2012		CLARK
NV0005062	SOUTHERN DESERT CORRECTIONAL CTR NDOC	4006	COMBINED URANIUM	03	04/01/2012 06/30/2012		CLARK
NV0005062	SOUTHERN DESERT CORRECTIONAL CTR NDOC	2964	DICHLOROMETHANE	03	04/01/2012 06/30/2012		CLARK
NV0005062	SOUTHERN DESERT CORRECTIONAL CTR NDOC	2992	ETHYLBENZENE	03	04/01/2012 06/30/2012		CLARK
NV0005062	SOUTHERN DESERT CORRECTIONAL CTR NDOC	4002	GROSS ALPHA, INCL. RADON & U	03	04/01/2012 06/30/2012		CLARK
NV0005062	SOUTHERN DESERT CORRECTIONAL CTR NDOC	2968	O- DICHLOROBENZENE	03	04/01/2012 06/30/2012		CLARK
NV0005062	SOUTHERN DESERT CORRECTIONAL CTR NDOC	2969	P- DICHLOROBENZENE	03	04/01/2012 06/30/2012		CLARK
NV0005062	SOUTHERN DESERT CORRECTIONAL CTR NDOC	4020	RADIUM-226	03	04/01/2012 06/30/2012		CLARK
NV0005062	SOUTHERN DESERT CORRECTIONAL CTR NDOC	4030	RADIUM-228	03	04/01/2012 06/30/2012		CLARK
NV0005062	SOUTHERN DESERT CORRECTIONAL CTR NDOC	2996	STYRENE	03	04/01/2012 06/30/2012		CLARK
NV0005062	SOUTHERN DESERT CORRECTIONAL CTR NDOC	2987	TETRACHLOROETHYLENE	03	04/01/2012 06/30/2012		CLARK
NV0005062	SOUTHERN DESERT CORRECTIONAL CTR NDOC	2991	TOLUENE	03	04/01/2012 06/30/2012		CLARK
NV0005062	SOUTHERN DESERT CORRECTIONAL CTR NDOC	2979	TRANS-1,2- DICHLOROETHYLENE	03	04/01/2012 06/30/2012		CLARK

Water System ID	Water System Name	Analyte Code	Analyte Name	Type	Compliance Period	RTC Date	County
NV0005062	SOUTHERN DESERT CORRECTIONAL CTR NDOC	2984	TRICHLOROETHYLENE	03	04/01/2012 06/30/2012		CLARK
NV0005062	SOUTHERN DESERT CORRECTIONAL CTR NDOC	2976	VINYL CHLORIDE	03	04/01/2012 06/30/2012		CLARK
NV0005062	SOUTHERN DESERT CORRECTIONAL CTR NDOC	2955	XYLENES, TOTAL	03	04/01/2012 06/30/2012		CLARK
Total Number of Violations for This Water System: 26							
NV0004071	SPENCER W KIMBALL SCOUT RESERVATION	1040	NITRATE	03	01/01/2012 12/31/2012		CLARK
Total Number of Violations for This Water System: 1							
NV0005027	SPRING CREEK MHP	1005	ARSENIC	02	01/01/2012 03/31/2012	7/18/2012	ELKO
Total Number of Violations for This Water System: 1							
NV0001071	SPRING MOUNTAIN RANCH STATE PARK	1040	NITRATE	03	01/01/2012 12/31/2012		CLARK
Total Number of Violations for This Water System: 1							
NV0002124	SPRING VALLEY STATE PARK	3100	COLIFORM (TCR)	22	09/01/2012 09/30/2012	10/8/2012	LINCOLN
Total Number of Violations for This Water System: 1							
NV0002178	STAGE STOP CAFE	3100	COLIFORM (TCR)	23	10/01/2012 12/31/2012	3/26/2013	WHITE PINE
NV0002178	STAGE STOP CAFE	1040	NITRATE	03	01/01/2012 12/31/2012		WHITE PINE
Total Number of Violations for This Water System: 2							
NV0002608	STAGECOACH COUNTRY MARKET	3100	COLIFORM (TCR)	22	07/01/2012 07/31/2012	8/13/2012	LYON
NV0002608	STAGECOACH COUNTRY MARKET	3100	COLIFORM (TCR)	22	06/01/2012 06/30/2012	8/13/2012	LYON
NV0002608	STAGECOACH COUNTRY MARKET	3100	COLIFORM (TCR)	22	05/01/2012 05/31/2012	8/13/2012	LYON
NV0002608	STAGECOACH COUNTRY MARKET	3100	COLIFORM (TCR)	23	01/01/2012 03/31/2012	5/3/2012	LYON

Water System ID	Water System Name	Analyte Code	Analyte Name	Type	Compliance Period	RTC Date	County
Total Number of Violations for This Water System: 4							
NV0002598	STAGESTOP RESTAURANT	3100	COLIFORM (TCR)	23	10/01/2012 12/31/2012	1/9/2013	NYE
Total Number of Violations for This Water System: 1							
NV0000808	STONE HOUSE COUNTRY INN	3100	COLIFORM (TCR)	23	10/01/2012 12/31/2012	1/29/2013	HUMBOLDT
NV0000808	STONE HOUSE COUNTRY INN	3100	COLIFORM (TCR)	23	07/01/2012 09/30/2012	1/29/2013	HUMBOLDT
Total Number of Violations for This Water System: 2							
NV0000240	STOREY COUNTY WATER DISTRICT	1927	ALKALINITY, TOTAL	27	10/01/2012 10/31/2012		STOREY
NV0000240	STOREY COUNTY WATER DISTRICT	1927	ALKALINITY, TOTAL	27	09/01/2012 09/30/2012		STOREY
NV0000240	STOREY COUNTY WATER DISTRICT	1927	ALKALINITY, TOTAL	27	08/01/2012 08/31/2012		STOREY
NV0000240	STOREY COUNTY WATER DISTRICT	1927	ALKALINITY, TOTAL	27	07/01/2012 07/31/2012		STOREY
NV0000240	STOREY COUNTY WATER DISTRICT	1927	ALKALINITY, TOTAL	27	06/01/2012 06/30/2012		STOREY
NV0000240	STOREY COUNTY WATER DISTRICT	1927	ALKALINITY, TOTAL	27	05/01/2012 05/31/2012		STOREY
NV0000240	STOREY COUNTY WATER DISTRICT	1927	ALKALINITY, TOTAL	27	04/01/2012 04/30/2012		STOREY
Total Number of Violations for This Water System: 7							
NV0000123	SUNRISE MOUNTAIN TP	3100	COLIFORM (TCR)	25	05/01/2012 05/31/2012	6/25/2012	CLARK
NV0000123	SUNRISE MOUNTAIN TP	7000	CONSUMER CONFIDENCE RULE	71	07/01/2012		CLARK
NV0000123	SUNRISE MOUNTAIN TP	3014	E. COLI	34	05/17/2012 06/25/2012	6/25/2012	CLARK
NV0000123	SUNRISE MOUNTAIN TP	1040	NITRATE	03	04/01/2012 06/30/2012	8/15/2012	CLARK

Water System ID	Water System Name	Analyte Code	Analyte Name	Type	Compliance Period	RTC Date	County
NV0000123	SUNRISE MOUNTAIN TP	1040	NITRATE	03	01/01/2012 03/31/2012	8/15/2012	CLARK

Total Number of Violations for This Water System: 5

NV0000765	SUTCLIFFE MOBILE PARK	1005	ARSENIC	03	04/01/2012 06/30/2012		WASHOE
NV0000765	SUTCLIFFE MOBILE PARK	1005	ARSENIC	03	01/01/2012 03/31/2012		WASHOE
NV0000765	SUTCLIFFE MOBILE PARK	4010	COMBINED RADIUM (-226 & -228)	03	07/01/2012 09/30/2012		WASHOE
NV0000765	SUTCLIFFE MOBILE PARK	4010	COMBINED RADIUM (-226 & -228)	03	04/01/2012 06/30/2012		WASHOE
NV0000765	SUTCLIFFE MOBILE PARK	4010	COMBINED RADIUM (-226 & -228)	03	01/01/2012 03/31/2012		WASHOE
NV0000765	SUTCLIFFE MOBILE PARK	4006	COMBINED URANIUM	03	07/01/2012 09/30/2012		WASHOE
NV0000765	SUTCLIFFE MOBILE PARK	4006	COMBINED URANIUM	03	04/01/2012 06/30/2012		WASHOE
NV0000765	SUTCLIFFE MOBILE PARK	4006	COMBINED URANIUM	03	01/01/2012 03/31/2012		WASHOE
NV0000765	SUTCLIFFE MOBILE PARK	4002	GROSS ALPHA, INCL. RADON & U	03	07/01/2012 09/30/2012		WASHOE
NV0000765	SUTCLIFFE MOBILE PARK	4002	GROSS ALPHA, INCL. RADON & U	03	04/01/2012 06/30/2012		WASHOE
NV0000765	SUTCLIFFE MOBILE PARK	4002	GROSS ALPHA, INCL. RADON & U	03	01/01/2012 03/31/2012		WASHOE
NV0000765	SUTCLIFFE MOBILE PARK	4020	RADIUM-226	03	07/01/2012 09/30/2012		WASHOE
NV0000765	SUTCLIFFE MOBILE PARK	4020	RADIUM-226	03	04/01/2012 06/30/2012		WASHOE
NV0000765	SUTCLIFFE MOBILE PARK	4020	RADIUM-226	03	01/01/2012 03/31/2012		WASHOE
NV0000765	SUTCLIFFE MOBILE PARK	4030	RADIUM-228	03	07/01/2012 09/30/2012		WASHOE
NV0000765	SUTCLIFFE MOBILE PARK	4030	RADIUM-228	03	04/01/2012 06/30/2012		WASHOE
NV0000765	SUTCLIFFE MOBILE PARK	4030	RADIUM-228	03	01/01/2012 03/31/2012		WASHOE

Total Number of Violations for This Water System: 17

Water System ID	Water System Name	Analyte Code	Analyte Name	Type	Compliance Period	RTC Date	County
NV0002076	TAYLOR CANYON CLUB	3100	COLIFORM (TCR)	23	01/01/2012 03/31/2012	6/26/2012	ELKO
NV0002076	TAYLOR CANYON CLUB	3100	COLIFORM (TCR)	23	10/01/2012 12/31/2012	3/19/2013	ELKO
NV0002076	TAYLOR CANYON CLUB	1040	NITRATE	03	01/01/2012 12/31/2012		ELKO
Total Number of Violations for This Water System: 3							
NV0004076	THE LODGE AT GALENA	3100	COLIFORM (TCR)	23	07/01/2012 09/30/2012		WASHOE
NV0004076	THE LODGE AT GALENA	3100	COLIFORM (TCR)	23	01/01/2012 03/31/2012		WASHOE
Total Number of Violations for This Water System: 2							
NV0000055	TOLAS WATERWORKS CO OP	1005	ARSENIC	02	10/01/2012 12/31/2012		CHURCHILL
NV0000055	TOLAS WATERWORKS CO OP	1005	ARSENIC	02	07/01/2012 09/30/2012		CHURCHILL
NV0000055	TOLAS WATERWORKS CO OP	1005	ARSENIC	02	04/01/2012 06/30/2012		CHURCHILL
NV0000055	TOLAS WATERWORKS CO OP	1005	ARSENIC	02	01/01/2012 03/31/2012		CHURCHILL
Total Number of Violations for This Water System: 4							
NV0002518	TOPAZ SUMMIT SPRING	3100	COLIFORM (TCR)	23	04/01/2012 06/30/2012	7/24/2012	DOUGLAS
NV0002518	TOPAZ SUMMIT SPRING	1040	NITRATE	03	01/01/2012 12/31/2012		DOUGLAS
Total Number of Violations for This Water System: 2							
NV0000168	TOWN OF MINDEN	3100	COLIFORM (TCR)	22	09/01/2012 09/30/2012	10/1/2012	DOUGLAS
Total Number of Violations for This Water System: 1							
NV0001059	TROPICANA RESORT AND CASINO	0999	CHLORINE	27	01/01/2012 03/31/2012		CLARK
Total Number of Violations for This Water System: 1							
NV0000827	TUMBLEWEED TAVERN	3100	COLIFORM (TCR)	23	12/01/2012 12/31/2012	2/11/2013	NYE

Water System ID	Water System Name	Analyte Code	Analyte Name	Type	Compliance Period	RTC Date	County
Total Number of Violations for This Water System: 1							
NV0003072	TURN 3 RV PARK AND STORE	3100	COLIFORM (TCR)	23	07/01/2012 09/30/2012	10/17/2012	PERSHING
Total Number of Violations for This Water System: 1							
NV0002586	UNCLE BRUCES SKATING RINK	3100	COLIFORM (TCR)	23	10/01/2012 12/31/2012	1/7/2013	CHURCHILL
NV0002586	UNCLE BRUCES SKATING RINK	1040	NITRATE	03	01/01/2012 12/31/2012	1/17/2013	CHURCHILL
Total Number of Violations for This Water System: 2							
NV0001075	VALLEY OF FIRE STATE PARK	1040	NITRATE	03	01/01/2012 12/31/2012		CLARK
Total Number of Violations for This Water System: 1							
NV0000805	VALLEY VIEW RV PARK	3100	COLIFORM (TCR)	22	12/01/2012 12/31/2012	1/28/2013	ELKO
NV0000805	VALLEY VIEW RV PARK	3100	COLIFORM (TCR)	22	11/01/2012 11/30/2012	1/28/2013	ELKO
NV0000805	VALLEY VIEW RV PARK	3100	COLIFORM (TCR)	22	10/01/2012 10/31/2012	1/28/2013	ELKO
NV0000805	VALLEY VIEW RV PARK	3100	COLIFORM (TCR)	22	09/01/2012 09/30/2012	1/28/2013	ELKO
Total Number of Violations for This Water System: 4							
NV0003016	VALMY STATION MOBILE HOME PARK	3100	COLIFORM (TCR)	22	05/01/2012 05/31/2012	6/27/2012	HUMBOLDT
Total Number of Violations for This Water System: 1							
NV0005061	VERDI BUSINESS PARK WATER CO OP	1005	ARSENIC	02	10/01/2012 12/31/2012		WASHOE
NV0005061	VERDI BUSINESS PARK WATER CO OP	1005	ARSENIC	02	07/01/2012 09/30/2012		WASHOE
NV0005061	VERDI BUSINESS PARK WATER CO OP	1005	ARSENIC	02	04/01/2012 06/30/2012		WASHOE
NV0005061	VERDI BUSINESS PARK WATER CO OP	1005	ARSENIC	02	01/01/2012 03/31/2012		WASHOE
Total Number of Violations for This Water System: 4							

Water System ID	Water System Name	Analyte Code	Analyte Name	Type	Compliance Period	RTC Date	County
NV0002543	VIRGIN VALLEY CAMPGROUND	3100	COLIFORM (TCR)	23	04/01/2012 06/30/2012	8/9/2012	HUMBOLDT
Total Number of Violations for This Water System: 1							
NV0004048	WALKER RIVER RESORT	3100	COLIFORM (TCR)	23	04/01/2012 06/30/2012	7/23/2012	LYON
Total Number of Violations for This Water System: 1							
NV0000727	WASHOE GRILL	3100	COLIFORM (TCR)	23	02/01/2012 02/29/2012		WASHOE
Total Number of Violations for This Water System: 1							
NV0000280	WEBB MOBILE HOME PARK	3100	COLIFORM (TCR)	21	05/01/2012 05/31/2012	6/17/2012	WASHOE
NV0000280	WEBB MOBILE HOME PARK	4006	COMBINED URANIUM	03	01/01/2007 12/31/2012		WASHOE
NV0000280	WEBB MOBILE HOME PARK	1040	NITRATE	03	01/01/2012 12/31/2012		WASHOE
NV0000280	WEBB MOBILE HOME PARK	1052	SODIUM	03	01/01/2010 12/31/2012		WASHOE
Total Number of Violations for This Water System: 4							
NV0000058	WILDES MANOR	1005	ARSENIC	02	10/01/2012 12/31/2012		CHURCHILL
NV0000058	WILDES MANOR	1005	ARSENIC	02	07/01/2012 09/30/2012		CHURCHILL
NV0000058	WILDES MANOR	1005	ARSENIC	02	04/01/2012 06/30/2012		CHURCHILL
NV0000058	WILDES MANOR	1005	ARSENIC	02	01/01/2012 03/31/2012		CHURCHILL
NV0000058	WILDES MANOR	3100	COLIFORM (TCR)	22	08/01/2012 08/31/2012	9/17/2012	CHURCHILL
NV0000058	WILDES MANOR	3100	COLIFORM (TCR)	23	12/01/2012 12/31/2012	1/21/2013	CHURCHILL
NV0000058	WILDES MANOR	7500	PUBLIC NOTICE	75	07/30/2012		CHURCHILL
NV0000058	WILDES MANOR	7500	PUBLIC NOTICE	75	07/01/2012		CHURCHILL
NV0000058	WILDES MANOR	7500	PUBLIC NOTICE	75	05/25/2012		CHURCHILL
Total Number of Violations for This Water System: 9							

Water System ID	Water System Name	Analyte Code	Analyte Name	Type	Compliance Period	RTC Date	County
NV0002211	WILSON RESERVOIR BLM CAMPGROUND	3100	COLIFORM (TCR)	22	06/01/2012 06/30/2012		ELKO
Total Number of Violations for This Water System: 1							
NV0000399	WINDMILL RIDGE RESTAURANT AND LODGE	1040	NITRATE	01	10/01/2012 12/31/2012		LINCOLN
Total Number of Violations for This Water System: 1							
NV0000255	YERINGTON CITY OF	2981	1,1,1-TRICHLOROETHANE	03	04/01/2012 06/30/2012		LYON
NV0000255	YERINGTON CITY OF	2985	1,1,2-TRICHLOROETHANE	03	04/01/2012 06/30/2012		LYON
NV0000255	YERINGTON CITY OF	2977	1,1-DICHLOROETHYLENE	03	04/01/2012 06/30/2012		LYON
NV0000255	YERINGTON CITY OF	2378	1,2,4-TRICHLOROBENZENE	03	04/01/2012 06/30/2012		LYON
NV0000255	YERINGTON CITY OF	2980	1,2-DICHLOROETHANE	03	04/01/2012 06/30/2012		LYON
NV0000255	YERINGTON CITY OF	2983	1,2-DICHLOROPROPANE	03	04/01/2012 06/30/2012		LYON
NV0000255	YERINGTON CITY OF	1005	ARSENIC	03	10/01/2012 10/31/2012		LYON
NV0000255	YERINGTON CITY OF	1005	ARSENIC	03	07/01/2012 09/30/2012		LYON
NV0000255	YERINGTON CITY OF	2990	BENZENE	03	04/01/2012 06/30/2012		LYON
NV0000255	YERINGTON CITY OF	2982	CARBON TETRACHLORIDE	03	04/01/2012 06/30/2012		LYON
NV0000255	YERINGTON CITY OF	0999	CHLORINE	27	07/01/2012 09/30/2012		LYON
NV0000255	YERINGTON CITY OF	2989	CHLOROBENZENE	03	04/01/2012 06/30/2012		LYON
NV0000255	YERINGTON CITY OF	2380	CIS-1,2-DICHLOROETHYLENE	03	04/01/2012 06/30/2012		LYON

Water System ID	Water System Name	Analyte Code	Analyte Name	Type	Compliance Period	RTC Date	County
NV0000255	YERINGTON CITY OF	4010	COMBINED RADIUM (-226 & -228)	03	04/01/2012 06/30/2012		LYON
NV0000255	YERINGTON CITY OF	4006	COMBINED URANIUM	03	04/01/2012 06/30/2012		LYON
NV0000255	YERINGTON CITY OF	2039	DI(2-ETHYLHEXYL) PHTHALATE	03	01/01/2012 12/31/2012		LYON
NV0000255	YERINGTON CITY OF	2964	DICHLOROMETHANE	03	04/01/2012 06/30/2012		LYON
NV0000255	YERINGTON CITY OF	2992	ETHYLBENZENE	03	04/01/2012 06/30/2012		LYON
NV0000255	YERINGTON CITY OF	4002	GROSS ALPHA, INCL. RADON & U	03	04/01/2012 06/30/2012		LYON
NV0000255	YERINGTON CITY OF	1040	NITRATE	03	01/01/2012 12/31/2012		LYON
NV0000255	YERINGTON CITY OF	2968	O- DICHLOROBENZENE	03	04/01/2012 06/30/2012		LYON
NV0000255	YERINGTON CITY OF	2969	P- DICHLOROBENZENE	03	04/01/2012 06/30/2012		LYON
NV0000255	YERINGTON CITY OF	4020	RADIUM-226	03	04/01/2012 06/30/2012		LYON
NV0000255	YERINGTON CITY OF	4030	RADIUM-228	03	04/01/2012 06/30/2012		LYON
NV0000255	YERINGTON CITY OF	2996	STYRENE	03	04/01/2012 06/30/2012		LYON
NV0000255	YERINGTON CITY OF	2987	TETRACHLOROETHYLENE	03	04/01/2012 06/30/2012		LYON
NV0000255	YERINGTON CITY OF	2991	TOLUENE	03	04/01/2012 06/30/2012		LYON
NV0000255	YERINGTON CITY OF	2979	TRANS-1,2- DICHLOROETHYLENE	03	04/01/2012 06/30/2012		LYON
NV0000255	YERINGTON CITY OF	2984	TRICHLOROETHYLENE	03	04/01/2012 06/30/2012		LYON
NV0000255	YERINGTON CITY OF	2976	VINYL CHLORIDE	03	04/01/2012 06/30/2012		LYON
NV0000255	YERINGTON CITY OF	2955	XYLENES, TOTAL	03	04/01/2012 06/30/2012		LYON

Water System ID	Water System Name	Analyte Code	Analyte Name	Type	Compliance Period	RTC Date	County
Total Number of Violations for This Water System: 31							
NV0002059	ZEPHYR COVE LODGE AND RESORT	5000	LEAD & COPPER RULE	52	10/01/2012		DOUGLAS
Total Number of Violations for This Water System: 1							
NV0000258	ZEPHYR COVE WATER UTILITY DISTR	0200	SWTR	41	04/01/2012 04/30/2012	4/16/2012	DOUGLAS
NV0000258	ZEPHYR COVE WATER UTILITY DISTR	0200	SWTR	41	03/01/2012 03/31/2012	4/16/2012	DOUGLAS
Total Number of Violations for This Water System: 2							
Total Number of Water Systems with one or more Violations for selected reporting interval:				161			
Total Number Violations for all Water Systems for selected reporting interval:				661			

Attachment A

RULE-SPECIFIC VIOLATION CRITERIA FOR THE ANNUAL PUBLIC WATER SYSTEMS COMPLIANCE REPORT¹

Chemical Contaminant Group Maximum Contaminant Level (MCL)

MCL - Single Sample or MCL Average (Violation Types 01 and 02).

Only Community Water Systems can have a MCL for the following contaminant codes: 1025, 4000, 4006, 4010, and 4100.

Both Community and Non-transient Non-community (NTNC) water systems can have an MCL for the following contaminant codes: 2051, 2050, 2046, 2959, 2946, 2931, 2065, 2067, 2010, 2015, 2020, 2383, 2105, 2110, 2306, 2031, 2035, 2039, 2041, 2032, 2033, 2005, 2034, 2274, 2042, 2036, 2040, 2037, 2063, 2990, 2982, 2984, 2976, 2981, 2977, 2980, 2380, 2992, 2989, 2968, 2996, 2987, 2991, 2979, 2955, 2983, 2326, 2964, 2985, 2378, 2969, 1005, 1094, 1010, 1015, 1020, 1035, 1036, 1045, 1074, 1075, 1024, 1085.

All systems can have an MCL for Nitrate (contaminant codes 1038, 1040, and 1041).

Chemical Contaminant Group Monitoring and Reporting (M/R)

M/R - Monitoring, Regular (Violation Types 03 and 04 and Major Indicator Flag = Y).

Only Community Water Systems can have an M/R for the following contaminant codes: 1025, 4000, 4006, 4010, and 4100.

¹ For violations that extend beyond the calendar year, the violation is counted in each of the calendar years in which it occurred, unless it has returned to compliance prior to the beginning of the calendar year.

Both Community and NTNC water systems can have an M/R for the following contaminant codes: 2051, 2050, 2046, 2959, 2946, 2931, 2065, 2067, 2010, 2015, 2020, 2383, 2105, 2110, 2306, 2031, 2035, 2039, 2041, 2032, 2033, 2005, 2034, 2274, 2042, 2036, 2040, 2037, 2063, 2990, 2982, 2984, 2976, 2981, 2977, 2980, 2380, 2992, 2989, 2968, 2996, 2987, 2991, 2979, 2955, 2983, 2326, 2964, 2985, 2378, 2969, 2950, 2456, 0999, 1005, 1094, 1010, 1015, 1020, 1035, 1045, 1074, 1075, 1024, 1085.

All systems can have an M/R for Nitrate (contaminant codes 1038, 1040, and 1041).

Chemical Contaminant Group Treatment Technique (TT)

Both Community and NTNC water systems can have a TT violation for Acrylamide and Epichlorohydrine (Violation type 07, contaminant codes 2265 and 2257).

Total Coliform Rule (TCR) MCLs

Any violation that is either Acute or Monthly (Violation types 21 and 22). The contaminant code for TCR is 3100.

TCR Significant M/R

Any major Routine or Repeat M/R violation (Violation types 23 and 25). The contaminant code for TCR is 3100.

Surface Water Treatment Rule (SWTR) TT

Any TT violation for a filtered system (Violation type 41) and all unfiltered systems who are required to install filtration if at some point during the calendar year they were unfiltered. (Violation type 42 violations - these may not be in your state data systems). The contaminant code for SWTR is 0200.

SWTR Significant M/R

Any Significant surface water M/R violation by a filtered or unfiltered system (Violation Types 36 and 31 and Major Indicator Flag = Y, respectively). The contaminant code for SWTR is 0200.

Turbidity MCL

Any MCL Average violation for an unfiltered system (Violation type 02). The contaminant code for turbidity is 0100.

Turbidity Significant M/R

Any major regular M/R violation for an unfiltered system (Violation type 03 and Major Indicator Flag = Y). The contaminant code for turbidity is 0100.

Lead and Copper Rule (LCR) TT

Any Community or NTNC water system with a TT violation at any time during the calendar year (Violation Types 58, 62 and 65).
Note: Violation type 62 has been combined under Violation type 58 in SDWIS.

LCR Significant M/R

Any Community or NTNC water system with a follow-up or routine tap sampling violation (Violation type 52) or any Community or NTNC water system who incurred an initial tap monitoring violation (Violation type 51) during the calendar year, or who incurred the initial tap violation prior to the calendar year, but failed to return to compliance prior to January 1 of the calendar year. Note: a system cannot have more than one initial tap monitoring violation counted in a calendar year.

In general: Count all violations above where any date in the violation compliance period begin and end date range falls within the calendar year **except** those that returned to compliance prior to the first day of the calendar year regardless of current system status.

Note: EPA has changed the state submitted compliance period end date of Violation types 51, 58, 62 and 65 to reflect either the date the violation returned to compliance or the date of 12/31/2015.

Consumer Confidence Report Rule (CCR) Significant Consumer Notification Violations and Public Notification Violations

Any Community water system that completely failed to provide a required consumer confidence report is in violation (Violation type 71). Because the violation continues until the system provides the report, the violation must also be reported in each subsequent year until the system returns to compliance. Public Notification violations are Violation type codes 75 for NPDWR and 76 for other potential health risk situations PN Violation (Non-NPDWR). For the Public Notice Violations the violation must be linked to a specific rule. The contaminant code for IESWTR is 0300. The contaminant codes for Stage 1 DBPR are 1009, 1011, 2456, 2950, 1006, 1008 and 0999.

Interim Enhanced Surface Water Treatment Rule (IESWTR) TT

Any public water system that uses surface water or ground water under the direct influence of surface water (GWUDI) and serving at least 10,000 people with a TT violation (Violations 37, 43, 44, and 47). The contaminant code for IESWTR is 0300. See Section II of the Implementation Guidance for Interim Enhanced Surface Water Treatment Rule (EPA 816-R-01-11, June 2001) <http://www.epa.gov/safewater/mdbp/ieswtrimplguid.pdf> for additional information

IESWTR Significant Recordkeeping and M/R Violations

Any public water system that uses surface water or GWUDI and serving at least 10,000 people with an M/R violation (Violation 29

and Violation 38 and Major Indicator Flag = Y). The contaminant code for IESWTR is 0300. Any recordkeeping violation where system fails to maintain the results of individual filter monitoring for 3 years. Violation type is 09. The contaminant code is for IESWTR is 0300. See Section II of the Implementation Guidance for Interim Enhanced Surface Water Treatment Rule (EPA 816-R-01-11, June 2001) <http://www.epa.gov/safewater/mdbp/ieswtrimplguid.pdf> for additional information.

Filter Backwash Recycle Rule (FBRR) TT

Public water systems that use surface water or GWUDI, practice conventional or direct filtration, and recycle spent filter backwash, thickener supernatant, or liquids from dewatering processes. The violation code is 40. The contaminant code is 0500. See the Implementation Guide for the Filter Backwash Recycle Rule www.epa.gov/safewater/mdbp/guide_fbrr_ig_fnl_06-16-04.pdf [EPA 816-R-04-006, June 2004] for additional information.

Filter Backwash Recycle Rule (FBRR) M/R and Recordkeeping

Public water systems that use surface water or GWUDI, practice conventional or direct filtration, and recycle spent filter backwash, thickener supernatant, or liquids from dewatering processes. The violation code for M/R is 39 and for recordkeeping is 09. The contaminant code is 0500. See the Implementation Guide for the Filter Backwash Recycle Rule (EPA 816-R-04-006, June 2004) www.epa.gov/safewater/mdbp/guide_fbrr_ig_fnl_06-16-04.pdf for additional information.

Ground Water Rule (GWR)

All systems can have Ground Water Rule violations. The violation code for failure to collect triggered source water samples for E. coli after a TCR positive sample is 34.

Long Term 1 Enhanced Surface Water Treatment Rule (LT1ESWTR) TT

Public water systems that use surface water or GWUDI and serve fewer than 10,000 people. The violation codes are 37 and 47. Like the IESWTR The contaminant code for LT1ESTR the contaminant code is 0300. See Section V of the Long Term Enhanced Surface Water Treatment Rule (LT1ESWTR) Implementation Guide for additional information at the website: www.epa.gov/safewater/mdbp/pdfs/lt1eswtr/guidance_lt1_ig.pdf

Stage 1 Disinfectants and Disinfection Byproducts Rule (Stage 1 DBPR) TT

All CWS and NTNCWS that add a chemical disinfectant in any part of the drinking water treatment process and transient NCWS using chlorine dioxide with TT violations (Violations 12, 37 and 46). The contaminant codes for Stage 1 DBPR are 0400 and 2920. See Section II of the Implementation Guidance for Stage 1 Disinfectants and Disinfection Byproducts Rule (EPA 816-R-01-12, June 2001) <http://www.epa.gov/safewater/mdbp/s1dbprimplguid.pdf> for additional information.

Stage 1 DBPR MCL and Maximum Residual Disinfectant Levels (MRDL)

All CWS and NTNCWS that add a chemical disinfectant in any part of the drinking water treatment process and transient NCWS using chlorine dioxide with MCL/MRDL violations (Violations 02 and 11). The contaminant codes for Stage 1 DBPR are 1009, 1011, 2456, 2950, 1006, 1008 and 0999. See Section II of the Implementation Guidance for Stage 1 Disinfectants and Disinfection Byproducts Rule (EPA 816-R-01-12, June 2001) <http://www.epa.gov/safewater/mdbp/s1dbprimplguid.pdf> for additional information.

Stage 1 DBPR M/R Violations

All CWS and NTNCWS that add a chemical disinfectant in any part of the drinking water treatment process and transient NCWS using chlorine dioxide with M/R violations (Violation 27 and Major Indicator Flag = Y). The contaminant codes for Stage 1 DBPR are 0400, 2920, 1009, 1011, 2456, 2950, 1006, 1008 and 0999. See Section II of the Implementation Guidance for Stage 1 Disinfectants and Disinfection Byproducts Rule (EPA 816-R-01-12, June 2001) at: <http://www.epa.gov/safewater/mdbp/s1dbprimplguid.pdf> for additional information.

Public Notification

The violation code for failure to notify the public after a violation is 06 for IESWTR, LT1ESWTR, and Stage 1 DBPR. The contaminant code for Stage 1 DBPR corresponds with the appropriate MCL/MRDL/TOC (1009, 1011, 2456, 2950, 1006, 1008 and 0999). The contaminant code for IESWTR and LT1ESWTR is 0300. For FBRR the violation code is 75 and the contaminant code is 0500.

VIOLATION TYPES

Type Code	VIOLATION NAME	ALTERNATE DESCRIPTION
01	MAXIMUM CONTAMINANT LEVEL (MCL), SINGLE SAMPLE	Excedence of MAXIMUM CONTAMINANT LEVEL (MCL) per 5-1.52
02	MAXIMUM CONTAMINANT LEVEL (MCL), AVERAGE, WITHOUT NUMBER OF EXCEDENCE	Excedence of MAXIMUM CONTAMINANT LEVEL (MCL) per 5-1.52
02	MAXIMUM CONTAMINANT LEVEL (MCL), AVERAGE, WITH NUMBER OF EXCEDENCE	Public Water Supply (PWS) Using Chlorine Dioxide - Chlorite - Average of any 3 sample set exceeds the MAXIMUM CONTAMINANT LEVEL (MCL) of 1.0 mg/L
03	MONITORING, ROUTINE MAJOR	Failure to monitor in accordance with section 5-1.51(b) and 5-1.52 Tables or perform analysis with approved methods
04	MONITORING, CONFIRMATION/CHECK MAJOR	No repeat samples were taken in response to a positive monitoring sample result.
05	NOTIFICATION, STATE	Failure to notify state
07	TREATMENT TECHNIQUES NON-SURFACE WATER TREATMENT RULE (Non-SWTR)	Failure to maintain free chlorine residual in distribution system.
08	VARIANCE / EXEMPTION / OTHER COMPLIANCE	Failure to abide by the authorized terms and conditions of a valid variance, waiver, or any other exemption.
09	RECORD KEEPING	Failure to retain proper records.
09	RECORD KEEPING FOR INDIVIDUAL FILTER /Filter Backwash Rule (FBR)	Failure to maintain filter monitoring records for 3 years (filter results every 15 minutes)
11	MAXIMUM RESIDUAL DISINFECTANT LEVEL (MRDL) - Public Water Supply (PWS) Using Chlorine	Excedence of Maximum Residual Disinfectant Level (MRDL) of 4.0 mg/L (exception if microbial contamination problems in distribution system)
11	MAXIMUM RESIDUAL DISINFECTANT LEVEL (MRDL) MONITORING	Failure to perform minimum monitoring requirements.
12	QUALIFIED OPERATOR FAILURE	No certified operator in charge of operation of a water treatment plant.
13	MAXIMUM RESIDUAL DISINFECTANT LEVEL (MRDL) ACUTE - Public Water Supply (PWS) Using Chlorine Dioxide	ACUTE: If any of 3 required distribution samples taken on day after a daily entry point sample Maximum Residual Disinfectant Level (MRDL) exceeds 0.8 mg/L
19	MONITOR GWR ASSESSMENT	A system that fails to conduct assessment source water monitoring required by the state according to State-determined requirements for such monitoring [141.130(c)]
20	FAILURE TO CONSULT/RESPOND	A system that fails to consult with the State within 30 days regarding notice from the State of a significant deficiency, or written notice from a laboratory of a ground water source sample being fecal indicator-positive, or that corrective action is required after a fecal indicator-positive sample result. [141.403(a)(4)]
21	MAXIMUM CONTAMINANT LEVEL (MCL) - TOTAL COLIFORM RULE (TCR) ACUTE	Excedence of MAXIMUM CONTAMINANT LEVEL (MCL) per 5-1.52 Table 6--Microbiological Contaminants

VIOLATION TYPES

Type Code	VIOLATION NAME	ALTERNATE DESCRIPTION
22	MAXIMUM CONTAMINANT LEVEL (MCL) - TOTAL COLIFORM RULE (TCR), MONTHLY	Excedence of MAXIMUM CONTAMINANT LEVEL (MCL) per 5-1.52 Table 6--Microbiological Contaminants
23	MONITORING TOTAL COLIFORM RULE (TCR), ROUTINE MAJOR	Failure to perform Table 11 Microbiological Minimum Monitoring Requirements
24	MONITORING (TCR), ROUTINE MINOR	A system collects some but not all of the scheduled routine total coliform samples at sites approved in the written sample siting plan according to the determined monitoring frequency. [141.21(a)(1)-(2)]
25	MONITORING TOTAL COLIFORM RULE (TCR), REPEAT MAJOR	Failure to perform Table 11 Microbiological Minimum Monitoring Requirements
26	MONITORING (TCR), REPEAT MINOR	A system notified of total coliform positive repeat sample and analyzes some but not all of the total coliform positive samples for fecal coliform/E. coli. [141.32(e)(1)]
27	MONITORING, ROUTINE DISINFECTION BYPRODUCT RULE (DBP), MAJOR - Bromate Monitoring / Reporting (M/R) - Public Water Supply (PWS) Using Ozone	Failure to collect 100% of required bromate samples
27	MONITORING, ROUTINE DISINFECTION BYPRODUCT RULE (DBP), MAJOR - Chlorine Monitoring / Reporting (M/R)	Collecting <90% of chlorine samples
27	MONITORING, ROUTINE DISINFECTION BYPRODUCT RULE (DBP), MAJOR - Total Organic Carbon (TOC) Monitoring / Reporting (M/R) - Surface / Groundwater Under Direct Influence of Surface Water (GUDI) Using Conventional Filtration	Failure to collect source & finished water TOC samples and alkalinity sample
27	HALOACETIC ACID / TOTAL TRIHALOMETHANE (HAA5/TTHM)-MAJOR Monitoring / Reporting (M/R) - SURFACE WATER / Groundwater Under Direct Influence of Surface Water (GUDI) Greater Than or Equal to 10,000 Population	Collecting <90% of (HAA5/TTHM) samples
27	HALOACETIC ACID / TOTAL TRIHALOMETHANE (HAA5/TTHM) - MAJOR Monitoring / Reporting (M/R) Surface / Groundwater Under Direct Influence of Surface Water (GUDI) Population between 500 and 9999	Collecting <90% of (HAA5/TTHM) samples
27	HALOACETIC ACID / TOTAL TRIHALOMETHANE (HAA5/TTHM) - MAJOR Monitoring / Reporting (M/R) - Surface / Groundwater Under Direct Influence of Surface Water (GUDI) < 500	Failure to collect/report at least 1 sample per plant per year during month of warmest water temperature
27	HALOACETIC ACID / TOTAL TRIHALOMETHANE (HAA5/TTHM) - MAJOR Monitoring / Reporting (M/R) - Groundwater Systems Greater Than or Equal to 10,000 Population	Collecting <90% of (HAA5/TTHM) samples

VIOLATION TYPES

Type Code	VIOLATION NAME	ALTERNATE DESCRIPTION
27	HALOACETIC ACID / TOTAL TRIHALOMETHANE (HAA5/TTHM) - MAJOR Monitoring / Reporting (M/R) - Groundwater Systems < 10,000 Population	Failure to collect/report all required samples
27	FAILURE TO HAVE MONITORING PLAN DISINFECTION BYPRODUCT RULE (DBP)	Failure to develop, implement or submit monitoring plan
28	SANITARY SURVEY COOPERATION FAILURE	A system that does not collect 5 or more routine samples per month and fails to undergo an initial sanitary survey by June 29, 1994, for community water systems, and June 29, 1999 for non-community water systems; or fails to undergo another sanitary survey every five years for community water systems and every 10 years for non-community water systems. [141.21(d)(1)(i)]
29	FAILURE TO PRODUCE COMPREHENSIVE PERFORMANCE EVALUATION (CPE) - Interim Enhanced Surface Water Treatment Rule (IESWTR)	Failure to produce CPE evaluation documentation
30	FAILURE TO HAVE MONITORING PLAN (IDSE)	A system that fails to monitor for each quarter that a monitoring result would be used in calculating an LRAA. [141.621(e)]
30	MONITORING, ROUTINE (IDSE), MAJOR	A system that fails to conduct standard monitoring according to 141.601 or a system specific study that meets the requirements in 141.602. [141.600]
30	MONITORING, ROUTINE (IDSE), MINOR	Failure to submit an IDSE standard monitoring plan, System Specific Study plan, 40/30 waiver, or submitted plan found to be deficient. [141.600(c);141.601(a); 141.602(a)]
31	MONITORING, ROUTINE/REPEAT - MAJOR - Surface Water Treatment Rule - UNFILTERED (SWTR - Unfiltered)	Failure to collect < 90% of require samples per monitoring period
32	FAILURE TO HAVE MONITORING PLAN (LT2)	A system that fails to submit a complete source water monitoring plan, including a sampling schedule and description of sampling location. [141.702(a) & 141.703(f)]
32	MONITORING, SOURCE (LT2)	A system that fails to collect any source water sample required in accordance with the sampling schedule, sampling location, analytical method, approved laboratory, and reporting requirements of the rule. [141.701 - 141.706]
34	MONITORING, SOURCE (GWR), MAJOR	Failure to collect triggered source water sample after a Total Coliform Rule positive sample.

VIOLATION TYPES

Type Code	VIOLATION NAME	ALTERNATE DESCRIPTION
35	FAILURE SUBMIT IDSE/SUBPT V PLAN (DBPR2)	A system that fails to submit an IDSE report or Subpart V monitoring plan, or submitted plan found to be missing required elements. [141.601(c)(1-4); 141.602(b)(1-6); 141.605; and 141.622]
36	MONITORING, Routine/Repeat MAJOR Surface Water Treatment Rule - FILTER	Failure to collect < 90% of require samples per monitoring period
37	FAILURE TO PROFILE / CONSULT - Interim Enhanced Surface Water Treatment Rule (IESWTR)	Failure to collect applicability data Treatment Technique (TT) violation
38	MONITORING, ROUTINE Interim Enhanced Surface Water Treatment Rule (IESWTR), MAJOR - Filtration/Combined Filter Effluent Surface/Groundwater Under Direct Influence of Surface Water (GUDI) >= 10,000 Population with Conventional/Direct Filtration	Collecting <90% of filter effluent samples for turbidity and reporting within 10 days after end of month
38	MONITORING, ROUTINE Interim Enhanced Surface Water Treatment Rule (IESWTR), MAJOR - Filtration/Combined Filter Effluent - Surface/Groundwater Under Direct Influence of Surface Water (GUDI) Serving >= 10,000 Population with Conventional/Direct Filtration	Failure to report that Public Water Supply (PWS) has conducted all filter monitoring to state within 10 days after end of each month
39	FAILURE TO SUBMIT PLANT SCHEMATIC (FBR)	A system that fails to notify the State in writing by December 8, 2003 if the system recycles spent filter backwash water, thickener supernatant, or liquids from dewatering processes and/or include a plant schematic and typical recycle flow in the notification. [141.76(b)]
40	FAILURE TO PROPERLY RECYCLE (FBR)	Failure to meet treatment technique requirements. [141.76(c)]
41	RESIDUAL DISINFECT CONCENTRATION - Surface Water Treatment Rule (SWTR) Surface or Groundwater Under Direct Influence (Groundwater Under Direct Influence of Surface Water (GUDI)) Serving Less Than 10,000 Population.	Cl ₂ Residual fell below 0.2 mg/l for more than 4 hours.
41	SINGLE COMBINED FILTER EFFLUENT (SWTR) - Surface or Groundwater Under Direct Influence (Groundwater Under Direct Influence of Surface Water (GUDI) Serving Less Than 10,000 Population.	Failure to maintain turbidity readings below 0.5 NTU in 95% of all measurements performed every 4 hours
41	MONTHLY COMBINED FILTER EFFLUENT (SWTR) - Surface or Groundwater Under Direct Influence (Groundwater Under Direct Influence of Surface Water (GUDI) Serving Less Than 10,000 Population.	Failure to meet performance standard of 0.5 NTU at the 95th percentile monthly.
42	FAILURE TO FILTER (SWTR)	Failure to provide filtration on a surface source after 6/29/93, unless avoidance criteria is met.
42	FAILURE TO PROVIDE GWR TREATMENT	Failure to meet GWR treatment requirements

VIOLATION TYPES

Type Code	VIOLATION NAME	ALTERNATE DESCRIPTION
42	FAILURE TO PROVIDE LT2 TREATMENT	Failure to meet Long Term 2 treatment requirements
43	SINGLE COMB. FILTER EFFLUENT Interim Enhanced Surface Water Treatment Rule (IESWTR) Surface/Groundwater Under Direct Influence of Surface Water (GUDI) Greater Than or Equal to 10,000 Population with conventional / direct filtration.	Failure to achieve turbidity <1.0 NTU, in 100% of samples
43	SINGLE COMB. FILTER EFFLUENT Interim Enhanced Surface Water Treatment Rule (IESWTR) Surface/Groundwater Under Direct Influence of Surface Water (GUDI) Greater Than or Equal to 10,000 Population with alternative filtration.	Failure to achieve turbidity <State set limit, in 100% of samples
44	MONTHLY COMB. FILTER EFFLUENT Interim Enhanced Surface Water Treatment Rule (IESWTR) - Surface/Groundwater Under Direct Influence of Surface Water (GUDI) Greater Than or Equal to 10,000 Population with conventional or direct filtration	Failure to achieve turbidity <0.3 NTU in 95% of samples
44	MONTHLY COMB. FILTER EFFLUENT Interim Enhanced Surface Water Treatment Rule (IESWTR) - Surface / Groundwater Under Direct Influence of Surface Water (GUDI) Greater Than or Equal to 10,000 Population with alternative filtration.	Failure to achieve turbidity <State set limit in 95% of samples
45	FAILURE ADDRESS DEFICIENCY	A system with a significant deficiency that after 120 days of receiving written notification of the significant deficiency from the State fails to: 1) complete corrective action in accordance with any applicable State plan review processes or other State guidance and direction. [141.404(a)(1)]
46	INADEQUATE DBP PRECURSOR REMOVAL - Surface / Groundwater Under Direct Influence of Surface Water (GUDI) using conventional filtration	Failure to meet DBP precursor removal (TOC)
47	UNCOVERED STORAGE FACILITY - Interim Enhanced Surface Water Treatment Rule (IESWTR)	Uncovered reservoir without adequate post disinfection.
48	FAILURE TO ADDRESS CONTAMINATION (GWR)	A system with a fecal indicator positive sample (that has not been invalidated by the State) and after 120 days of receiving notice of the fecal indicator positive sample has failed to: 1) complete corrective action in accordance with any applicable State plan review processes or other State guidance and direction. [141.404(h)(1)]
51	INITIAL TAP SAMPLING (PB/CU)	Failure to monitor for lead and copper in accordance with 5-1.42
52	FOLLOW-UP OR ROUTINE TAP Monitoring / Reporting (M/R) (PB/CU)	Failure to monitor for lead and copper in accordance with 5-1.42

VIOLATION TYPES

Type Code	VIOLATION NAME	ALTERNATE DESCRIPTION
53	WATER QUALITY PARAMETER M/R (LCR)	Failure to collect the required number of WQP samples using correct sampling procedures and conduct analyses using the correct procedures. [141.87(a) - (e)]
56	INITIAL/FOLLOW-UP/ROUTINE SOWT M/R (LCR)	Failure to collect the required number of source water samples using correct sampling procedures and conduct analyses using the correct procedures in accordance with 141.88(a)(1) - (e)(1). [141.88(a)(1) - (e)(1)]
57	OCCT/SOWT RECOMMENDATION/STUDY (LCR)	For an SOWT Recommendation violation, failure to submit a SOWT recommendation no later than 180 days after the end of the monitoring period during which the lead or copper action level was exceeded. [141.83(a)(1) & 141.90(d)(1)]
58	OPTIMAL CORROSION CONTROL TREATMENT / SOURCE WATER TREATMENT (OCCT/SOWT) INSTALLATION DEMONSTRATION	Failure to install and operate Optimal Corrosion Control Treatment (OCCT) or fail to demonstrate that OCCT already is in place.
59	WQP LEVEL NON-COMPLIANCE (LCR)	Failure to: Maintain OWQP minimum or ranges in accordance with 141.82(g). Also, If you adopted the OWQP compliance method from the LCRMR, the violation definition also includes failure to: Meet daily values for more than 9 days in a 6-month monitoring period. [141.82(g)]
63	MPL LEVEL NON-COMPLIANCE (LCR)	Failure to meet either State-designated or approved MPL in accordance with 141.83(b)(5).
64	LEAD SERVICE LINE REPLACEMENT (LCR)	A system which exceeds the lead action level after implementation of applicable corrosion control and/or source water treatment requirements (whichever sampling occurs later) and fails to complete the lead service line replacement requirements. [141.84(a)]
65	PUBLIC EDUCATION LEAD / COPPER (PB/CU)	Failure to deliver public education materials where lead action level is exceeded.
71	CONSUMER CONFIDENCE REPORT (CCR)	Failure to provide Consumer Confidence Report
72	CCR ADEQUACY/AVAILABILITY/CONTENT	Delivery of a CCR that is significantly deficient in content to the extent that the CCR does not meet the requirements of the SDWA and the Federal regulations. [141.205]
75	PUBLIC NOTICE RULE LINKED TO VIOLATION	Failure to Public Notice Violation of National Primary Drinking Water Regulations (NPDWR)