

**Public Record – Summary Information For Regulated Underground Storage Tanks (USTs)  
Nevada Division of Environmental Protection (NDEP)**

**Date Posted To Web : February 3, 2014**

**General Information :**

Total Number of Regulated UST Facilities : 1,279

Total Number Regulated of USTs : 3,786

**Summary of Information For On-Site Inspections :**

Number of UST Facilities Inspected : 1,156

Inspection Period Dates : October 1, 2012 through September 30, 2013

Percent Compliance (SOC Combined measure) : 77.2 %

---

**Note :** The above tank and facility numbers were produced from NDEP's UST-FITS database. UST information is provided on a notification form (EPA 7530-1) collected from the facility's owner/operator or authorized representative. Significant Operational Compliance (SOC) for on-site inspections is determined using the September 2003 EPA memorandum "Significant Operational Compliance Performance Measures for the Underground Storage Tank Program". Compliance inspections are conducted by NDEP staff in rural counties, the Southern Nevada Health District staff in Clark County, and the Washoe County District Health Department staff in Washoe County.

Please click on the following link for each UST implementing agency's contact information: [http://ndep.nv.gov/bca/file/contacts\\_0608.pdf](http://ndep.nv.gov/bca/file/contacts_0608.pdf)

**Summary Information for Releases :**

Number of Confirmed Releases : 11 (At 11 UST Facilities)

Release Reporting Period Dates : October 1, 2012 through September 30, 2013

**Summary Information For Release Sources And Causes :**

Source			Cause													
			Spill		Overfill		Phys/Mech Damage **		Corrosion		Install Problem		Other		Unknown	
#	%	#	%	#	%	#	%	#	%	#	%	#	%	#	%	
Tank	5	45%	0	0%	0	0%	5	100%	0	0%	0	0%	0	0%	0	0%
Piping	1	9%	0	0%	0	0%	0	0%	0	0%	0	0%	0	0%	1	100%
Dispenser	0	0%	0	0%	0	0%	0	0%	0	0%	0	0%	0	0%	0	0%
STP *	0	0%	0	0%	0	0%	0	0%	0	0%	0	0%	0	0%	0	0%
Delivery Problem	0	0%	0	0%	0	0%	0	0%	0	0%	0	0%	0	0%	0	0%
Other	1	9%	1	100%	0	0%	0	0%	0	0%	0	0%	0	0%	0	0%
Unknown	4	36%	0	0%	0	0%	0	0%	0	0%	0	0%	0	0%	4	100%
Totals	11	100%	1	9%	0	0%	5	45%	0	0%	0	0%	0	0%	5	45%

(# = Number; Source % = Percent of source total number; Cause % = Percent of individual source (i.e. spill, overfill, etc.))

\* STP = Submersible turbine pump/sump area; \*\* Physical/Mechanical Damage

**Note :** Release source/causes data for the referenced reporting period were collected using NDEP’s Release Data Gathering forms, Project Tracking (PT) database, Nevada Petroleum Fund coverage applications, and information provided in reports from the facility owner/operators and consultants.

Please click on the following link for NDEP database information and LUST file review procedures: [http://ndep.nv.gov/admin/env\\_info\\_request.htm](http://ndep.nv.gov/admin/env_info_request.htm)