

# **TRANSIENT NON COMMUNITY PUBLIC WATER SYSTEMS**

## **SECONDARY DRINKING WATER STANDARDS**

### **ONE EVERY THREE YEARS**

- ❖ **CHLORIDE**
- ❖ **COLOR**
- ❖ **COPPER**
- ❖ **FOAMING AGENTS (MBAS)**
- ❖ **IRON**
- ❖ **MAGNESIUM**
- ❖ **MANGANESE**
- ❖ **ODOR**
- ❖ **PH**
- ❖ **SULFATE**
- ❖ **TOTAL DISSOLVED SOLIDS (TDS)**
- ❖ **ZINC**
- ❖ **ALUMINUM**
- ❖ **SILVER**

## **PRIMARY DRINKING WATER STANDARDS**

- ❖ **NITRATE ANNUALLY**
- ❖ **NITRITE ONE EVERY THREE YEARS**
  
- ❖ **COLIFORM BACTERIA EVERY THREE MONTHS**