



STATE OF NEVADA

Department of Conservation & Natural Resources

Brian Sandoval, Governor

Leo M. Drozdoff, P.E., Director

DIVISION OF ENVIRONMENTAL PROTECTION

Colleen Cripps, Ph.D., Administrator

FACTSHEET (pursuant to NAC 445A.236)

Permittee Name: NATIONAL PARK SERVICE - LAKE MEAD
601 NEVADA WAY
BOULDER CITY, NV - 89005

Permit Number: NS0050011

Location: NPS - BOULDER BEACH WASTEWATER TREATMENT SYSTEM, CLARK
FLYCATCHER ROAD, BOULDER BEACH, NV - 89005
LATITUDE: 36.053056, LONGITUDE: -114.8250
TOWNSHIP: 22S, RANGE: 64E, SECTION: 09, 10

Outfall / Well Num	Outfall / Well Name	Location Type	Well Log Num	Outfall City	Outfall State	Outfall Zip	Outfall County	Latitude	Longitude	Receiving Water
001	INFLUENT METER (MAIN LIFT STATION)	Internal Outfall		BOULDER CITY	NV	89005	CLARK	36.043611	-114.807222	TREATMENT PONDS
002	CONCRETE LINED PORTABLE WASTE RECEIVING BASIN	Internal Outfall		BOULDER CITY	NV	89005	CLARK	36.053333	-114.825278	TREATMENT PONDS
003	SUM OF TOTAL FLOW RECEIVED	Sum		BOULDER CITY	NV	89005	CLARK	36.053056	-114.8250	TREATMENT PONDS
004	PERCOLATION/EVAPORATION BASINS	Surface Disposal Site		BOULDER CITY	NV	89005	CLARK	36.051944	-114.823056	GROUNDWATER
005	MONITORING WELL	Monitoring Well		BOULDER CITY	NV	89005	CLARK	36.051944	-114.823056	GROUNDWATER

General:

The National Park Service owns and operates the Boulder Beach Wastewater Treatment System (BBWTS), an aerated partial-mix pond treatment plant located near Boulder Harbor in the Lake Mead National Recreation Area. The treatment plant is designed to receive and treat a 30-day average flow of 0.040 million gallons per day (MGD) and a daily maximum flow of 0.130 MGD. BBWTS includes a force main system, six lift stations, an aerated 1.27-acre asphalt-lined primary treatment pond (pond #1), a 1.13-acre asphalt-lined secondary treatment pond (pond #2), a 2.07-acre percolation/evaporation basin (pond #3), and a 1.8-acre percolation/evaporation basin (pond #4). BBWTS is also equipped with a pretreatment system designed to receive vault/portable toilet waste. The pretreatment system includes a concrete lined receiving basin, an auger screw press, and an aeration unit. The renewed permit will require the installation of one down-gradient monitoring well and the implementation of a quarterly groundwater monitoring program.

Wastewater from residential, commercial, and recreational facilities in the Boulder Beach and Hemenway Harbor areas flows through ponds #1 and #2 in series. Treated effluent flows to ponds #3 and #4 for percolation/evaporation.

Concessioner owned or operated collection systems are considered part of the NPS treatment system and may require standards of oversight.

Discharge Characteristics:

During the term of the previous permit, which began on January 16, 2008, low flows to the treatment system resulted in no discharge to the percolation/evaporation basins.

Receiving Water:

Receiving water is groundwater of the State via percolation. No groundwater information was provided with the application.

Summary of Changes From Previous Permit:

In order to maintain consistency with current NDEP policy, and the monitoring requirements of similar treatment facilities, the following permit changes have been made:

1. The requirement to measure the amount of vault/portable toilet waste discharged to the treatment facility has been added to this permit.
2. The requirement to report the sum of the total influent (domestic wastewater plus vault/portable toilet waste) discharged to the treatment plant has been added to this permit.
3. The requirement to monitor the amount of total nitrogen in the treated effluent has been added to this permit.
4. The requirement to monitor effluent biochemical oxygen demand (BOD) has been removed and replaced with a requirement to monitor effluent carbonaceous biochemical oxygen demand (CBOD).
5. The requirement to install and begin sampling one down-gradient monitoring well has been added to this permit.
6. The requirement to monitor sewage influent for BOD and total suspended solids has been removed from this permit. This requirement is applicable to facilities that require an NPDES permit.
7. The requirement to monitor the amount of dissolved oxygen in the effluent has been removed from this permit. The discharge is not to surface water.
8. The monitoring frequency for pH has been changed from weekly to quarterly. This frequency is consistent with the monitoring frequency for BOD, TSS, and total nitrogen.
9. The requirement to report the pond liquid level has been removed from this permit. The Permittee is required to maintain the freeboard depths outlined in Section B.PB.10. of the permit.
10. Due to a new Permit naming convention at NDEP, Bureau of Water Pollution Control, the permit ID has been changed from NEV50011 to NS0050011. This change does not reflect a change in the type of permit being issued.

Proposed Effluent Limitations:

The Division proposes the following permit limitations and monitoring requirements:

WWTP Discharge Limitations Table for Sample Location 001 (Internal Outfall) To Be Reported Monthly^[1]

Parameter	Discharge Limitations			Monitoring Requirements			
	Base	Quantity	Concentration	Monitoring Loc	Sample Loc	Measurement Frequency	Sample Type
Flow rate	30 Day Average	M&R Million Gallons per Day (Mgal/d)		Raw Sewage Influent	001	Continuous	METER
Flow rate	Daily Maximum	M&R Million Gallons per Day (Mgal/d)		Raw Sewage Influent	001	Continuous	METER

Notes (WWTP Discharge Limitations Table):

1. Measure and report the total flow to the treatment ponds from the main lift station each month.

WWTP Discharge Limitations Table for Sample Location 002 (Internal Outfall) To Be Reported Monthly^[1]

Parameter	Discharge Limitations			Monitoring Requirements			
	Base	Quantity	Concentration	Monitoring Loc	Sample Loc	Measurement Frequency	Sample Type
Flow rate	Daily Maximum	M&R Million Gallons per Day (Mgal/d)		See Footnote ^[2]	002	Continuous	METER
Flow rate	30 Day Average	M&R Million Gallons per Day (Mgal/d)		See Footnote ^[2]	002	Continuous	METER

Notes (WWTP Discharge Limitations Table):

1. Measure and report the total flow to the treatment ponds from the concrete lined portable waste receiving basin each month.
2. Discharge from pump truck.

WWTP Discharge Limitations Table for Sample Location 003 (Sum) To Be Reported Monthly^[1]

Parameter	Discharge Limitations			Monitoring Requirements			
	Base	Quantity	Concentration	Monitoring Loc	Sample Loc	Measurement Frequency	S a m p l e Type
Flow rate	30 Day Average	<= 0.040 Million Gallons per Day (Mgal/d)		Raw Sewage Influent	003	Continuous	SUMATN
Flow rate	Daily Maximum	<= 0.130 Million Gallons per Day (Mgal/d)		Raw Sewage Influent	003	Continuous	SUMATN

Notes (WWTP Discharge Limitations Table):

1. Measure and report the sum of total flow from the main lift station and the concrete lined portable waste receiving basin to the treatment ponds each month.

Groundwater Monitoring Wells Table for Sample Location 005 (Monitoring Well) To Be Reported Quarterly^{[1][2]}

Parameter	Discharge Limitations			Monitoring Requirements			
	Base	Quantity	Concentration	Monitoring Loc	Sample Loc	Measurement Frequency	S a m p l e Type
Solids, total dissolved	Value		M&R Milligrams per Liter (mg/L)	Groundwater	005	Quarterly	DISCRT
Depth to water level ft below landsurface	Value	M&R Feet (ft)		Groundwater	005	Quarterly	VISUAL
Chloride (as Cl)	Value		M&R Milligrams per Liter (mg/L)	Groundwater	005	Quarterly	DISCRT
Nitrogen, total	Value		< 10.0 Milligrams per Liter (mg/L)	Groundwater	005	Quarterly	DISCRT

Notes (Groundwater Monitoring Wells Table):

1. Groundwater monitoring shall commence upon completion of the new down-gradient monitoring well.
2. If the down-gradient monitoring well has not yet been installed enter "Not Installed" on the DMR for that quarter.

Ponds / Rapid Infiltration Basins for Sample Location 004 (Surface Disposal Site) To Be Reported Quarterly^[1]

Parameter	Discharge Limitations			Monitoring Requirements			
	Base	Quantity	Concentration	Monitoring Loc	Sample Loc	Measurement Frequency	Sample Type
BOD, carbonaceous, 05 day, 20 C	Value		<= 45 Milligrams per Liter (mg/L)	Effluent Gross	004	Quarterly	DISCRT
pH, maximum	Maximum Value ^[2]		<= 9.0 Standard Units (SU)	Effluent Gross	004	Quarterly	DISCRT
Nitrogen, total	Value		M&R Milligrams per Liter (mg/L)	Effluent Gross	004	Quarterly	DISCRT
Solids, total suspended	Value		<= 90 Milligrams per Liter (mg/L)	Effluent Gross	004	Quarterly	DISCRT
pH, minimum	Minimum Value ^[2]		>= 6.0 Standard Units (SU)	Effluent Gross	004	Quarterly	DISCRT

Notes (Ponds / Rapid Infiltration Basins):

1. If no discharge takes place from this outfall during the reporting period, enter "No Discharge" on the DMR for this outfall.
2. If fewer than two samples are taken during the monitoring period, enter the single result as both the minimum and maximum value.

Rationale for Permit Requirements:

Monitoring is required to ensure that the treatment plant capacity is not exceeded, to assess the quality of the effluent being discharged, and to monitor groundwater quality.

Fecal Coliform:

No coliform limits have been set.

Total Residual Chlorine:

The effluent is not required to be disinfected.

WET Testing:

Whole Effluent Toxicity testing is not required.

Special Conditions:

SA – Special Approvals / Conditions Table

Item #	Description
1	All lift stations shall be equipped with alarms indicating wet well high water and delivery line low pressure conditions.

Flow:

The applicant has requested a 30-day average flow of 0.040 MGD and a daily maximum flow of 0.130 MGD. During the previous 12-month reporting period, July 2012 through June 2013, the average daily flow received was 0.018 MGD. A maximum daily flow of 0.034 MGD was reported one time during this period.

Corrective Action Sites:

There are no NDEP Bureau of Corrective Actions remediation sites within a one-mile radius of this facility.

Wellhead Protection Program:

This facility is not located within a Drinking Water Protection Area or a Wellhead Protection Area established for any well sources.

Schedule of Compliance:

SOC – Schedule of Compliance Table

Item #	Description	Due Date
1	The Permittee shall submit two (2) copies of an updated Operation and Maintenance (O&M) Manual for review and approval by the Division. The O&M Manual shall be prepared by a Nevada Registered Professional Engineer or other Division-approved qualified person. If no updates or revisions are required, the Permittee shall submit a letter by the due date stating that there have been no changes to the previously approved O&M Manual. ^[1]	3/31/2014
2	The Permittee shall submit plans and specifications to the Division for the installation of a new down-gradient monitoring well (MW-1). The monitoring well shall be designed in accordance with NDEP Water Technical Sheet No. WTS-4: A Guidance Document for the Design and Construction of Groundwater Monitoring Wells for Use at Wastewater Treatment Facilities. Following monitoring well installation, the Permittee shall begin quarterly sampling.	3/31/2014

Notes (Schedule of Compliance Table):

1. O&M Manuals prepared by Nevada Registered Professional Engineers must be signed and stamped in accordance with NAC 625.610.

Deliverable Schedule:

DLV– Deliverable Schedule for Reports, Plans, and Other Submittals

Item #	Description	Interval	First Scheduled Due Date
1	Discharge Monitoring Reports	Quarterly	1/28/2014
3	Annual Reports	Annually	1/28/2014

Procedures for Public Comment:

The Notice of the Division's intent to reissue a permit authorizing the facility to discharge to groundwater of the State of Nevada subject to the conditions contained within the permit, is being sent to the **Las Vegas Review Journal** for publication. The notice is being mailed to interested persons on our mailing list. Anyone wishing to comment on the proposed permit can do so in writing until 5:00 P.M. **12/6/2013**, a period of 30 days following the date of the public notice. The comment period can be extended at the discretion of the Administrator.

A public hearing on the proposed determination can be requested by the applicant, any affected State, any affected interstate agency, the Regional Administrator of EPA Region IX or any interested agency, person or group of persons. The request must be filed within the comment period and must indicate the interest of the person filing the request and the reasons why a hearing is warranted. Any public hearing determined by the Administrator to be held must be conducted in the geographical area of the proposed discharge or any other area the Administrator determined to be appropriate. All public hearings must be conducted to

accordance with NAC 445A.238.

The final determination of the Administrator may be appealed to the State Environmental Commission pursuant to NRS 445A.650.

Proposed Determination:

The Division has made the tentative determination to issue / re-issue the proposed 5-year permit.

Prepared by: **Arthur B. Marr III**

Date: **10/31/2013**

Title: **P.E.**