



## Bureau of Air Pollution Control

901 SOUTH STEWART STREET SUITE 4001  
CARSON CITY, NEVADA 89701-5249  
p: 775-687-9349 • [ndep.nv.gov/air](http://ndep.nv.gov/air)

**Facility ID No. A2652**

**Permit No. AP7374-4772**

### CLASS II AIR QUALITY OPERATING PERMIT

**Issued to:** MECP1 RENO 1, LLC (HEREINAFTER REFERRED TO AS PERMITTEE)

**Mailing Address:** 3000 USA PARKWAY, McCARRAN, NEVADA 89437

**Physical Address:** 3000 USA PARKWAY, McCARRAN, NEVADA 89437

**Driving Directions:** FROM SPARKS, NEVADA, TAKE INTERSTATE 80 EAST. TAKE THE EXIT FOR STATE ROUTE 439 SOUTH (USA PARKWAY). THE FACILITY WILL BE ON THE RIGHT IN APPROXIMATELY 4 MILES.

**General Facility Location:** SECTION 11, T 19 N, R 22 E, MDB&M

HA 83 – TRACY SEGMENT / STOREY COUNTY

NORTH 4,378,111 M, EAST 286,838 M, UTM ZONE 11, NAD 83

**Emission Unit List:**

**A. System 1 – Diesel-Fired Emergency Generator**

S2.001	Diesel-Fired Emergency Generator 1 (4,706 HP, Caterpillar, C175-16, mfd > 2024)
S2.002	Diesel-Fired Emergency Generator 2 (4,706 HP, Caterpillar, C175-16, mfd > 2024)
S2.003	Diesel-Fired Emergency Generator 3 (4,706 HP, Caterpillar, C175-16, mfd > 2024)
S2.004	Diesel-Fired Emergency Generator 4 (4,706 HP, Caterpillar, C175-16, mfd > 2024)
S2.005	Diesel-Fired Emergency Generator 5 (4,706 HP, Caterpillar, C175-16, mfd > 2024)
S2.006	Diesel-Fired Emergency Generator 6 (4,706 HP, Caterpillar, C175-16, mfd > 2024)
S2.007	Diesel-Fired Emergency Generator 7 (4,706 HP, Caterpillar, C175-16, mfd > 2024)
S2.008	Diesel-Fired Emergency Generator 8 (4,706 HP, Caterpillar, C175-16, mfd > 2024)
S2.009	Diesel-Fired Emergency Generator 9 (4,706 HP, Caterpillar, C175-16, mfd > 2024)
S2.010	Diesel-Fired Emergency Generator 10 (4,706 HP, Caterpillar, C175-16, mfd > 2024)
S2.011	Diesel-Fired Emergency Generator 11 (4,706 HP, Caterpillar, C175-16, mfd > 2024)
S2.012	Diesel-Fired Emergency Generator 12 (4,706 HP, Caterpillar, C175-16, mfd > 2024)
S2.013	Diesel-Fired Emergency Generator 13 (4,706 HP, Caterpillar, C175-16, mfd > 2024)
S2.014	Diesel-Fired Emergency Generator 14 (4,706 HP, Caterpillar, C175-16, mfd > 2024)
S2.015	Diesel-Fired Emergency Generator 15 (4,706 HP, Caterpillar, C175-16, mfd > 2024)
S2.016	Diesel-Fired Emergency Generator 16 (4,706 HP, Caterpillar, C175-16, mfd > 2024)
S2.017	Diesel-Fired Emergency Generator 17 (4,706 HP, Caterpillar, C175-16, mfd > 2024)
S2.018	Diesel-Fired Emergency Generator 18 (4,706 HP, Caterpillar, C175-16, mfd > 2024)
S2.019	Diesel-Fired Emergency Generator 19 (4,706 HP, Caterpillar, C175-16, mfd > 2024)
S2.020	Diesel-Fired Emergency Generator 20 (4,706 HP, Caterpillar, C175-16, mfd > 2024)
S2.021	Diesel-Fired Emergency Generator 21 (4,706 HP, Caterpillar, C175-16, mfd > 2024)
S2.022	Diesel-Fired Emergency Generator 22 (4,706 HP, Caterpillar, C175-16, mfd > 2024)
S2.023	Diesel-Fired Emergency Generator 23 (4,706 HP, Caterpillar, C175-16, mfd > 2024)
S2.024	Diesel-Fired Emergency Generator 24 (4,706 HP, Caterpillar, C175-16, mfd > 2024)
S2.025	Diesel-Fired Emergency Generator 25 (4,706 HP, Caterpillar, C175-16, mfd > 2024)
S2.026	Diesel-Fired Emergency Generator 26 (4,706 HP, Caterpillar, C175-16, mfd > 2024)
S2.027	Diesel-Fired Emergency Generator 27 (4,706 HP, Caterpillar, C175-16, mfd > 2024)
S2.028	Diesel-Fired Emergency Generator 28 (4,706 HP, Caterpillar, C175-16, mfd > 2024)
S2.029	Diesel-Fired Emergency Generator 29 (4,706 HP, Caterpillar, C175-16, mfd > 2024)
S2.030	Diesel-Fired Emergency Generator 30 (4,706 HP, Caterpillar, C175-16, mfd > 2024)
S2.031	Diesel-Fired Emergency Generator 31 (4,706 HP, Caterpillar, C175-16, mfd > 2024)
S2.032	Diesel-Fired Emergency Generator 32 (4,706 HP, Caterpillar, C175-16, mfd > 2024)
S2.033	Diesel-Fired Emergency Generator 33 (4,706 HP, Caterpillar, C175-16, mfd > 2024)
S2.034	Diesel-Fired Emergency Generator 34 (4,706 HP, Caterpillar, C175-16, mfd > 2024)
S2.035	Diesel-Fired Emergency Generator 35 (4,706 HP, Caterpillar, C175-16, mfd > 2024)
S2.036	Diesel-Fired Emergency Generator 36 (4,706 HP, Caterpillar, C175-16, mfd > 2024)
S2.037	Diesel-Fired Emergency Generator 37 (4,706 HP, Caterpillar, C175-16, mfd > 2024)
S2.038	Diesel-Fired Emergency Generator 38 (4,706 HP, Caterpillar, C175-16, mfd > 2024)



Facility ID No. A2652

Permit No. AP7374-4772

## CLASS II AIR QUALITY OPERATING PERMIT

Issued to: MECP1 RENO, LLC – RNO1 (AS PERMITTEE)

## Emission Unit List: (continued)

## A. System 1 – Diesel-Fired Emergency Generator (continued)

S2.039	Diesel-Fired Emergency Generator 39 (4,706 HP, Caterpillar, C175-16, mfd > 2024)
S2.040	Diesel-Fired Emergency Generator 40 (4,706 HP, Caterpillar, C175-16, mfd > 2024)
S2.041	Diesel-Fired Emergency Generator 41 (4,706 HP, Caterpillar, C175-16, mfd > 2024)
S2.042	Diesel-Fired Emergency Generator 42 (4,706 HP, Caterpillar, C175-16, mfd > 2024)
S2.043	Diesel-Fired Emergency Generator 43 (4,706 HP, Caterpillar, C175-16, mfd > 2024)
S2.044	Diesel-Fired Emergency Generator 44 (4,706 HP, Caterpillar, C175-16, mfd > 2024)
S2.045	Diesel-Fired Emergency Generator 45 (4,706 HP, Caterpillar, C175-16, mfd > 2024)
S2.046	Diesel-Fired Emergency Generator 46 (4,706 HP, Caterpillar, C175-16, mfd > 2024)
S2.047	Diesel-Fired Emergency Generator 47 (4,706 HP, Caterpillar, C175-16, mfd > 2024)
S2.048	Diesel-Fired Emergency Generator 48 (4,706 HP, Caterpillar, C175-16, mfd > 2024)
S2.049	Diesel-Fired Emergency Generator 49 (4,706 HP, Caterpillar, C175-16, mfd > 2024)
S2.050	Diesel-Fired Emergency Generator 50 (4,706 HP, Caterpillar, C175-16, mfd > 2024)
S2.051	Diesel-Fired Emergency Generator 51 (4,706 HP, Caterpillar, C175-16, mfd > 2024)
S2.052	Diesel-Fired Emergency Generator 52 (4,706 HP, Caterpillar, C175-16, mfd > 2024)
S2.053	Diesel-Fired Emergency Generator 53 (4,706 HP, Caterpillar, C175-16, mfd > 2024)
S2.054	Diesel-Fired Emergency Generator 54 (4,706 HP, Caterpillar, C175-16, mfd > 2024)
S2.055	Diesel-Fired Emergency Generator 55 (4,706 HP, Caterpillar, C175-16, mfd > 2024)
S2.056	Diesel-Fired Emergency Generator 56 (4,706 HP, Caterpillar, C175-16, mfd > 2024)
S2.057	Diesel-Fired Emergency Generator 57 (4,706 HP, Caterpillar, C175-16, mfd > 2024)
S2.058	Diesel-Fired Emergency Generator 58 (4,706 HP, Caterpillar, C175-16, mfd > 2024)
S2.059	Diesel-Fired Emergency Generator 59 (4,706 HP, Caterpillar, C175-16, mfd > 2024)
S2.060	Diesel-Fired Emergency Generator 60 (4,706 HP, Caterpillar, C175-16, mfd > 2024)
S2.061	Diesel-Fired Emergency Generator 61 (4,706 HP, Caterpillar, C175-16, mfd > 2024)
S2.062	Diesel-Fired Emergency Generator 62 (4,706 HP, Caterpillar, C175-16, mfd > 2024)
S2.063	Diesel-Fired Emergency Generator 63 (4,706 HP, Caterpillar, C175-16, mfd > 2024)
S2.064	Diesel-Fired Emergency Generator 64 (4,706 HP, Caterpillar, C175-16, mfd > 2024)
S2.065	Diesel-Fired Emergency Generator 65 (4,706 HP, Caterpillar, C175-16, mfd > 2024)
S2.066	Diesel-Fired Emergency Generator 66 (4,706 HP, Caterpillar, C175-16, mfd > 2024)
S2.067	Diesel-Fired Emergency Generator 67 (4,706 HP, Caterpillar, C175-16, mfd > 2024)
S2.068	Diesel-Fired Emergency Generator 68 (4,706 HP, Caterpillar, C175-16, mfd > 2024)
S2.069	Diesel-Fired Emergency Generator 69 (4,706 HP, Caterpillar, C175-16, mfd > 2024)
S2.070	Diesel-Fired Emergency Generator 70 (4,706 HP, Caterpillar, C175-16, mfd > 2024)
S2.071	Diesel-Fired Emergency Generator 71 (4,706 HP, Caterpillar, C175-16, mfd > 2024)
S2.072	Diesel-Fired Emergency Generator 72 (4,706 HP, Caterpillar, C175-16, mfd > 2024)
S2.073	Diesel-Fired Emergency Generator 73 (4,706 HP, Caterpillar, C175-16, mfd > 2024)
S2.074	Diesel-Fired Emergency Generator 74 (4,706 HP, Caterpillar, C175-16, mfd > 2024)
S2.075	Diesel-Fired Emergency Generator 75 (4,706 HP, Caterpillar, C175-16, mfd > 2024)
S2.076	Diesel-Fired Emergency Generator 76 (4,706 HP, Caterpillar, C175-16, mfd > 2024)
S2.077	Diesel-Fired Emergency Generator 77 (4,706 HP, Caterpillar, C175-16, mfd > 2024)
S2.078	Diesel-Fired Emergency Generator 78 (4,706 HP, Caterpillar, C175-16, mfd > 2024)
S2.079	Diesel-Fired Emergency Generator 79 (4,706 HP, Caterpillar, C175-16, mfd > 2024)
S2.080	Diesel-Fired Emergency Generator 80 (4,706 HP, Caterpillar, C175-16, mfd > 2024)
S2.081	Diesel-Fired Emergency Generator 81 (4,706 HP, Caterpillar, C175-16, mfd > 2024)
S2.082	Diesel-Fired Emergency Generator 82 (4,706 HP, Caterpillar, C175-16, mfd > 2024)
S2.083	Diesel-Fired Emergency Generator 83 (4,706 HP, Caterpillar, C175-16, mfd > 2024)
S2.084	Diesel-Fired Emergency Generator 84 (4,706 HP, Caterpillar, C175-16, mfd > 2024)
S2.085	Diesel-Fired Emergency Generator 85 (4,706 HP, Caterpillar, C175-16, mfd > 2024)
S2.086	Diesel-Fired Emergency Generator 86 (4,706 HP, Caterpillar, C175-16, mfd > 2024)
S2.087	Diesel-Fired Emergency Generator 87 (4,706 HP, Caterpillar, C175-16, mfd > 2024)
S2.088	Diesel-Fired Emergency Generator 88 (4,706 HP, Caterpillar, C175-16, mfd > 2024)



Issued to: MECP1 RENO, LLC – RNO1 (AS PERMITTEE)

**Emission Unit List: (continued)**

**A. System 1 – Diesel-Fired Emergency Generator (continued)**

S2.089 Diesel-Fired Emergency Generator 89 (4,706 HP, Caterpillar, C175-16, mfd > 2024)  
S2.090 Diesel-Fired Emergency Generator 90 (4,706 HP, Caterpillar, C175-16, mfd > 2024)  
S2.091 Diesel-Fired Emergency Generator 91 (4,706 HP, Caterpillar, C175-16, mfd > 2024)  
S2.092 Diesel-Fired Emergency Generator 92 (4,706 HP, Caterpillar, C175-16, mfd > 2024)  
S2.093 Diesel-Fired Emergency Generator 93 (4,706 HP, Caterpillar, C175-16, mfd > 2024)  
S2.094 Diesel-Fired Emergency Generator 94 (4,706 HP, Caterpillar, C175-16, mfd > 2024)  
S2.095 Diesel-Fired Emergency Generator 95 (4,706 HP, Caterpillar, C175-16, mfd > 2024)  
S2.096 Diesel-Fired Emergency Generator 96 (4,706 HP, Caterpillar, C175-16, mfd > 2024)  
S2.097 Diesel-Fired Emergency Generator 97 (4,706 HP, Caterpillar, C175-16, mfd > 2024)  
S2.098 Diesel-Fired Emergency Generator 98 (4,706 HP, Caterpillar, C175-16, mfd > 2024)  
S2.099 Diesel-Fired Emergency Generator 99 (4,706 HP, Caterpillar, C175-16, mfd > 2024)  
S2.100 Diesel-Fired Emergency Generator 100 (4,706 HP, Caterpillar, C175-16, mfd > 2024)  
S2.101 Diesel-Fired Emergency Generator 101 (4,706 HP, Caterpillar, C175-16, mfd > 2024)  
S2.102 Diesel-Fired Emergency Generator 102 (4,706 HP, Caterpillar, C175-16, mfd > 2024)  
S2.103 Diesel-Fired Emergency Generator 103 (4,706 HP, Caterpillar, C175-16, mfd > 2024)  
S2.104 Diesel-Fired Emergency Generator 104 (4,706 HP, Caterpillar, C175-16, mfd > 2024)  
S2.105 Diesel-Fired Emergency Generator 105 (4,706 HP, Caterpillar, C175-16, mfd > 2024)  
S2.106 Diesel-Fired Emergency Generator 106 (4,706 HP, Caterpillar, C175-16, mfd > 2024)  
S2.107 Diesel-Fired Emergency Generator 107 (4,706 HP, Caterpillar, C175-16, mfd > 2024)  
S2.108 Diesel-Fired Emergency Generator 108 (4,706 HP, Caterpillar, C175-16, mfd > 2024)  
S2.109 Diesel-Fired Emergency Generator 109 (4,706 HP, Caterpillar, C175-16, mfd > 2024)  
S2.110 Diesel-Fired Emergency Generator 110 (4,706 HP, Caterpillar, C175-16, mfd > 2024)  
S2.111 Diesel-Fired Emergency Generator 111 (4,706 HP, Caterpillar, C175-16, mfd > 2024)  
S2.112 Diesel-Fired Emergency Generator 112 (4,706 HP, Caterpillar, C175-16, mfd > 2024)  
S2.113 Diesel-Fired Emergency Generator 113 (4,706 HP, Caterpillar, C175-16, mfd > 2024)  
S2.114 Diesel-Fired Emergency Generator 114 (4,706 HP, Caterpillar, C175-16, mfd > 2024)  
S2.115 Diesel-Fired Emergency Generator 115 (4,706 HP, Caterpillar, C175-16, mfd > 2024)  
S2.116 Diesel-Fired Emergency Generator 116 (4,706 HP, Caterpillar, C175-16, mfd > 2024)  
S2.117 Diesel-Fired Emergency Generator 117 (4,706 HP, Caterpillar, C175-16, mfd > 2024)  
S2.118 Diesel-Fired Emergency Generator 118 (4,706 HP, Caterpillar, C175-16, mfd > 2024)  
S2.119 Diesel-Fired Emergency Generator 119 (4,706 HP, Caterpillar, C175-16, mfd > 2024)  
S2.120 Diesel-Fired Emergency Generator 120 (4,706 HP, Caterpillar, C175-16, mfd > 2024)  
S2.121 Diesel-Fired Emergency Generator 121 (4,706 HP, Caterpillar, C175-16, mfd > 2024)  
S2.122 Diesel-Fired Emergency Generator 122 (4,706 HP, Caterpillar, C175-16, mfd > 2024)  
S2.123 Diesel-Fired Emergency Generator 123 (4,706 HP, Caterpillar, C175-16, mfd > 2024)  
S2.124 Diesel-Fired Emergency Generator 124 (4,706 HP, Caterpillar, C175-16, mfd > 2024)  
S2.125 Diesel-Fired Emergency Generator 125 (4,706 HP, Caterpillar, C175-16, mfd > 2024)  
S2.126 Diesel-Fired Emergency Generator 126 (4,706 HP, Caterpillar, C175-16, mfd > 2024)

**B. System 2 – Diesel-Fired Fire Pumps**

S2.127 Diesel-Fired Fire Pump 1 (197 HP, Clarke, JU6H-UFADP8, mfd. >2024)  
S2.128 Diesel-Fired Fire Pump 2 (197 HP, Clarke, JU6H-UFADP8, mfd. >2024)

\*\*\*\*End of Emission Unit List\*\*\*\*



**Issued to:** MECP1 RENO, LLC – RNO1 (AS PERMITTEE)

## **Section I. General Provisions**

**A. Prohibited acts; penalty; establishment of violation; request for prosecution (NRS 445B.470) (State Only Requirement)**

1. A person shall not knowingly:
  - a. Violate any applicable provision, the terms or conditions of any permit or any provision for the filing of information;
  - b. Fail to pay any fee;
  - c. Falsify any material statement, representation or certification in any notice or report; or
  - d. Render inaccurate any monitoring device or method, required pursuant to the provisions of NRS 445B.100 to 445B.450, inclusive, or 445B.470 to 445B.640, inclusive, or any regulation adopted pursuant to those provisions.
2. Any person who violates any provision of subsection 1 shall be punished by a fine of not more than \$10,000 for each day of the violation.
3. The burden of proof and degree of knowledge required to establish a violation of subsection 1 are the same as those required by 42 U.S.C. § 7413(c), as that section existed on October 1, 1993.
4. If, in the judgment of the Director of the Department or the Director's designee, any person is engaged in any act or practice which constitutes a criminal offense pursuant to NRS 445B.100 to 445B.640, inclusive, the Director of the Department or the designee may request that the Attorney General or the district attorney of the county in which the criminal offense is alleged to have occurred institute by indictment or information a criminal prosecution of the person.
5. If, in the judgment of the control officer of a local air pollution control board, any person is engaged in such an act or practice, the control officer may request that the district attorney of the county in which the criminal offense is alleged to have occurred institute by indictment or information a criminal prosecution of the person.

**B. Visible emissions: Maximum opacity; determination and monitoring of opacity (NAC 445B.22017)**

*(Federally Enforceable SIP Requirement)*

1. Except as otherwise provided in this section and NAC 445B.2202, no owner or operator may cause or permit the discharge into the atmosphere from any emission unit which is of an opacity equal to or greater than 20 percent. Opacity must be determined by one of the following methods:
  - a. If opacity is determined by a visual measurement, it must be determined as set forth in Reference Method 9 in Appendix A of 40 CFR Part 60.
  - b. If a source uses a continuous monitoring system for the measurement of opacity, the data must be reduced to 6-minute averages as set forth in 40 CFR 60.13(h).
2. The provisions of this section and NAC 445B.2202 do not apply to that part of the opacity that consists of uncombined water. The burden of proof to establish the application of this exemption is upon the person seeking to come within the exemption.
3. If the provisions of 40 CFR Part 60, Subpart D or Da apply to an emission unit, the emission unit must be allowed one 6-minute period per hour of not more than 27 percent opacity as set forth in 40 CFR 60.42(a)(2) and 40 CFR 60.42a(b).
4. The continuous monitoring system for monitoring opacity at a facility must be operated and maintained by the owner or operator specified in the permit for the facility in accordance with NAC 445B.256 to 445B.267, inclusive.

**C. Visible emissions: Exceptions for stationary sources (NAC 445B.2202) (Federally Enforceable SIP Requirement)**

The provisions of NAC 445B.22017 do not apply to:

1. Smoke from the open burning described in NAC 445B.22067;
2. Smoke discharged in the course of training air pollution control inspectors to observe visible emissions, if the facility has written approval of the Commission;
3. Emissions from an incinerator as set forth in NAC 445B.2207; or
4. Emissions of stationary diesel-powered engines during warm-up for not longer than 15 minutes to achieve operating temperatures.



**Issued to:** MECP1 RENO, LLC – RNO1 (AS PERMITTEE)

## **Section I. General Provisions (continued)**

**D. Odors (NAC 445B.22087) (*State Only Requirement*)**

1. No person may discharge or cause to be discharged, from any stationary source, any material or regulated air pollutant which is or tends to be offensive to the senses, injurious or detrimental to health and safety, or which in any way interferes with or prevents the comfortable enjoyment of life or property.
2. The Director shall investigate an odor when 30 percent or more of a sample of the people exposed to it believe it to be objectionable in usual places of occupancy. The sample must be at least 20 people or 75 percent of those exposed if fewer than 20 people are exposed.
3. The Director shall deem the odor to be a violation if he or she is able to make two odor measurements within a period of 1 hour. These measurements must be separated by at least 15 minutes. An odor measurement consists of a detectable odor after the odorous air has been diluted with eight or more volumes of odor-free air.

**E. Prohibited Conduct: Concealment of Emissions (NAC 445B.225) (*Federally Enforceable SIP Requirement*)**

No person may install, construct or use any device which conceals any emission without reducing the total release of regulated air pollutants to the atmosphere.

**F. Prohibited conduct: Operation of source without required equipment; removal or modification of required equipment; modification of required procedure (NAC 445B.227) (*Federally Enforceable SIP Requirement*)**

Except as otherwise provided in NAC 445B.001 to 445B.390, inclusive, no person may:

1. Operate a stationary source of air pollution unless the control equipment for air pollution which is required by applicable requirements or conditions of this Operating Permit is installed and operating.
2. Disconnect, alter, modify or remove any of the control equipment for air pollution or modify any procedure required by an applicable requirement or condition of the permit.

**G. Excess Emissions (NAC 445B.232) (*State Only Requirement*)**

1. Scheduled maintenance or testing or scheduled repairs which may result in excess emissions of regulated air pollutants prohibited by NAC 445B.001 to 445B.390, inclusive, must be approved in advance by the Director and performed during a time designated by the Director as being favorable for atmospheric ventilation.
2. Each owner or operator shall notify the Director of the proposed time and expected duration at least 30 days before any scheduled maintenance or testing which may result in excess emissions of regulated air pollutants prohibited by NAC 445B.001 to 445B.390, inclusive. The scheduled maintenance or testing must not be conducted unless the scheduled maintenance or testing is approved pursuant to subsection 1.
3. Each owner or operator shall notify the Director of the proposed time and expected duration at least 24 hours before any scheduled repairs which may result in excess emissions of regulated air pollutants prohibited by NAC 445B.001 to 445B.390, inclusive. The scheduled repairs must not be conducted unless the scheduled repairs are approved pursuant to subsection 1.
4. Each owner or operator shall notify the Director of any excess emissions within 24 hours after any malfunction or upset of the process equipment or equipment for controlling pollution or during start-up or shutdown of that equipment.



**Issued to:** MECP1 RENO, LLC – RNO1 (AS PERMITTEE)

## **Section I. General Provisions (continued)**

### **G. Excess Emissions (NAC 445B.232) (*State Only Requirement*) (continued)**

5. Each owner or operator shall provide the Director, within 15 days after any malfunction, upset, start-up, shutdown or human error which results in excess emissions, sufficient information to enable the Director to determine the seriousness of the excess emissions. The information must include at least the following:
  - a. The identity of the stack or other point of emission, or both, where the excess emissions occurred.
  - b. The estimated magnitude of the excess emissions expressed in opacity or in the units of the applicable limitation on emission and the operating data and methods used in estimating the magnitude of the excess emissions.
  - c. The time and duration of the excess emissions.
  - d. The identity of the equipment causing the excess emissions.
  - e. If the excess emissions were the result of a malfunction, the steps taken to remedy the malfunction and the steps taken or planned to prevent the recurrence of the malfunction.
  - f. The steps taken to limit the excess emissions.
  - g. Documentation that the equipment for controlling air pollution, process equipment or processes were at all times maintained and operated, to a maximum extent practicable, in a manner consistent with good practice for minimizing emissions.
6. Each owner or operator shall ensure that any notification or related information submitted to the Director pursuant to this section is provided in a format specified by the Director.

### **H. Testing and Sampling (NAC 445B.252) (*Federally Enforceable SIP Requirement*)**

1. To determine compliance with NAC 445B.001 to 445B.390, inclusive, before the approval or the continuance of an operating permit or similar class of permits, the Director may either conduct or order the owner of any stationary source to conduct or have conducted such testing and sampling as the Director determines necessary. Testing and sampling or either of them must be conducted and the results submitted to the Director within 60 days after achieving the maximum rate of production at which the affected facility will be operated, but not later than 180 days after initial start-up of the facility and at such other times as may be required by the Director.
2. Tests of performance must be conducted and data reduced in accordance with the methods and procedures of the test contained in each applicable subsection of this section unless the Director:
  - a. Specifies or approves, in specific cases, the use of a method of reference with minor changes in methodology;
  - b. Approves the use of an equivalent method;
  - c. Approves the use of an alternative method, the results of which the Director has determined to be adequate for indicating whether a specific stationary source is in compliance; or
  - d. Waives the requirement for tests of performance because the owner or operator of a stationary source has demonstrated by other means to the Director's satisfaction that the affected facility is in compliance with the standard.
3. Tests of performance must be conducted under such conditions as the Director specifies to the operator of the plant based on representative performance of the affected facility. The owner or operator shall make available to the Director such records as may be necessary to determine the conditions of the performance test. Operations during periods of startup, shutdown and malfunction must not constitute representative conditions of a performance test unless otherwise specified in the applicable standard.
4. The owner or operator of an affected facility shall give notice to the Director 30 days before the test of performance to allow the Director to have an observer present. A written testing procedure for the test of performance must be submitted to the Director at least 30 days before the test of performance to allow the Director to review the proposed testing procedures.
5. Each test of performance must consist of at least three separate runs using the applicable method for that test. Each run must be conducted for the time and under the conditions specified in the applicable standard. For the purpose of determining compliance with an applicable standard, the arithmetic means of results of the runs apply. In the event of forced shutdown, failure of an irreplaceable portion of the sampling train, extreme meteorological conditions or other circumstances with less than three valid samples being obtained, compliance may be determined using the arithmetic mean of the results of the other two runs upon the Director's approval.
6. All testing and sampling will be performed in accordance with recognized methods and as specified by the Director.



**Issued to:** MECP1 RENO, LLC – RNO1 (AS PERMITTEE)

## **Section I. General Provisions (continued)**

### **H. Testing and Sampling (NAC 445B.252) (*Federally Enforceable SIP Requirement*) (continued)**

7. The cost of all testing and sampling and the cost of all sampling holes, scaffolding, electric power and other pertinent allied facilities as may be required and specified in writing by the Director must be provided and paid for by the owner of the stationary source.
8. All information and analytical results of testing and sampling must be certified as to their truth and accuracy and as to their compliance with all provisions of these regulations, and copies of these results must be provided to the Director no later than 60 days after the testing or sampling, or both.
9. Notwithstanding the provisions of subsection 2, the Director shall not approve an alternative method or equivalent method to determine compliance with a standard or emission limitation contained in Part 60, 61 or 63 of Title 40 of the Code of Federal Regulations for:
  - a. An emission unit that is subject to a testing requirement pursuant to Part 60, 61 or 63 of Title 40 of the Code of Federal Regulations; or
  - b. An affected source.

### **I. Permit Revision (NAC 445B.287(1)(b)) (*Federally Enforceable SIP Requirement*)**

If a stationary source is a Class II source, a revision of the operating permit or the permit to construct is required pursuant to the requirements of NAC 445B.3465 before the stationary source may be modified.

### **J. Violations: Acts constituting; notice (NAC 445B.275) (*Federally Enforceable SIP Requirement*)**

1. Failure to comply with any requirement of NAC 445B.001 to 445B.390, inclusive, any applicable requirement or any condition of an operating permit constitutes a violation. As required by NRS 445B.450, the Director shall issue a written notice of an alleged violation to any owner or operator for any violation, including, but not limited to:
  - a. Failure to apply for and obtain an operating permit;
  - b. Failure to construct a stationary source in accordance with the application for an operating permit as approved by the Director;
  - c. Failure to construct or operate a stationary source in accordance with any condition of an operating permit;
  - d. Commencing construction or modification of a stationary source without applying for and receiving an operating permit or a modification of an operating permit as required by NAC 445B.001 to 445B.3477, inclusive, or a mercury operating permit to construct as required by NAC 445B.3611 to 445B.3689, inclusive;
  - e. Failure to comply with any requirement for recordkeeping, monitoring, reporting or compliance certification contained in an operating permit; or
  - f. Failure to pay fees as required by NAC 445B.327 or 445B.3689.
2. The written notice must specify the provision of NAC 445B.001 to 445B.390, inclusive, the condition of the operating permit or the applicable requirement that is being violated.
3. Written notice shall be deemed to have been served if delivered to the person to whom addressed or if sent by registered or certified mail to the last known address of the person.

### **K. Operating permits: Imposition of more stringent standards for emissions (NAC 445B.305)**

*(Federally Enforceable SIP Requirement)*

1. The Director may impose standards for emissions on a proposed stationary source that are more stringent than those found in NAC 445B.001 to 445B.390, inclusive, as a condition of approving an operating permit for the proposed stationary source.



Issued to: MECP1 RENO, LLC – RNO1 (AS PERMITTEE)

## Section I. General Provisions (continued)

L. Contents of operating permits: Exception for operating permits to construct; required conditions (NAC 445B.315) (Federally Enforceable SIP Requirement)

1. Notwithstanding any provision of this section to the contrary, the provisions of this section do not apply to operating permits to construct.
2. The Director shall cite the legal authority for each condition contained in an operating permit.
3. An operating permit must contain the following conditions:
  - a. The term of the operating permit is 5 years.
  - b. The holder of the operating permit shall retain records of all required monitoring data and supporting information for 5 years after the date of the sample collection, measurement, report or analysis. Supporting information includes all records regarding calibration and maintenance of the monitoring equipment and all original strip-chart recordings for continuous monitoring instrumentation.
  - c. Each of the conditions and requirements of the operating permit is severable, and if any are held invalid, the remaining conditions and requirements continue in effect.
  - d. The holder of the operating permit shall comply with all conditions of the operating permit. Any noncompliance constitutes a violation and is a ground for:
    - (1) An action for noncompliance;
    - (2) Revising, revoking, reopening and revising, or terminating the operating permit by the Director; or
    - (3) Denial of an application for a renewal of the operating permit by the Director.
  - e. The need to halt or reduce activity to maintain compliance with the conditions of the operating permit is not a defense to noncompliance with any condition of the operating permit.
  - f. The Director may revise, revoke and reissue, reopen and revise, or terminate the operating permit for cause.
  - g. The operating permit does not convey any property rights or any exclusive privilege.
  - h. The holder of the operating permit shall provide the Director, in writing and within a reasonable time, with any information that the Director requests to determine whether cause exists for revising, revoking and reissuing, reopening and revising, or terminating the operating permit, or to determine compliance with the conditions of the operating permit.
  - i. The holder of the operating permit shall pay fees to the Director in accordance with the provisions set forth in NAC 445B.327 and 445B.331.
  - j. The holder of the operating permit shall allow the Director or any authorized representative, upon presentation of credentials, to:
    - (1) Enter upon the premises of the holder of the operating permit where:
      - (a) The stationary source is located;
      - (b) Activity related to emissions is conducted; or
      - (c) Records are kept pursuant to the conditions of the operating permit;
    - (2) Have access to and copy, during normal business hours, any records that are kept pursuant to the conditions of the operating permit;
    - (3) Inspect, at reasonable times, any facilities, practices, operations or equipment, including any equipment for monitoring or controlling air pollution, that are regulated or required pursuant to the operating permit; and
    - (4) Sample or monitor, at reasonable times, substances or parameters to determine compliance with the conditions of the operating permit or applicable requirements.
  - k. A responsible official of the stationary source shall certify that, based on information and belief formed after a reasonable inquiry, the statements made in any document required to be submitted by any condition of the operating permit are true, accurate and complete.



**Issued to:** MECP1 RENO, LLC – RNO1 (AS PERMITTEE)

## **Section I. General Provisions (continued)**

**M. Operating permits: Revocation and reissuance (NAC 445B.3265) (*State Only Requirement*)**

1. An operating permit may be revoked if the control equipment is not operating.
2. An operating permit may be revoked by the Director upon determining that there has been a violation of NAC 445B.001 to 445B.390, inclusive, or the provisions of 40 CFR 52.21, or 40 CFR Part 60 or 61, Prevention of Significant Deterioration, New Source Performance Standards, and National Emission Standards for Hazardous Air Pollutants, adopted by reference in NAC 445B.221.
3. The revocation is effective 10 days after the service of a written notice, unless a hearing is requested.
4. To reissue a revoked operating permit, the holder of the revoked permit must file a new application with the Director, accompanied by the fee for an initial operating permit as specified in NAC 445B.327. An environmental review of the stationary source must be conducted as though construction had not yet commenced.

**N. Required contents of permit (NAC 445B.346) (*Federally Enforceable SIP Requirement*)**

In addition to the conditions set forth in NAC 445B.315, Class II operating permits must contain, as applicable:

1. Emission limitations and standards, including those operational requirements and limitations that ensure compliance with the conditions of the operating permit.
2. All requirements for monitoring, testing and reporting that apply to the stationary source.
3. A requirement that the owner or operator of the stationary source promptly report any deviations from any requirements of the operating permit.
4. The terms and conditions for any reasonably anticipated alternative operating scenarios identified by the owner or operator of the stationary source in his or her application and approved by the Director. Such terms and conditions must require the owner or operator to keep a contemporaneous log of changes from one alternative operating scenario to another.
5. A schedule of compliance for stationary sources that are not in compliance with any applicable requirement or NAC 445B.001 to 445B.390, inclusive:
  - a. Semiannual progress reports and a schedule of dates for achieving milestones;
  - b. Prior notice of and explanations for missed deadlines; and
  - c. Any preventive or corrective measures taken.

\*\*\*\*End of General Provisions\*\*\*\*



**Issued to:** MECP1 RENO, LLC – RNO1 (AS PERMITTEE)

## **Section II. General Monitoring, Recordkeeping, and Reporting Conditions**

**A. Records Retention (NAC 445B.315(3)(b)) (*Federally Enforceable SIP Requirement*)**

The holder of the operating permit shall retain records of all required monitoring data and supporting information for 5 years after the date of the sample collection, measurement, report or analysis. Supporting information includes all records regarding calibration and maintenance of the monitoring equipment and all original strip-chart recordings for continuous monitoring instrumentation.

**B. Deviations (NAC 445B.346(3)) (*Federally Enforceable SIP Requirement*)**

Under the authority of NAC 445B.346(3), and in addition to the conditions set forth in NAC 445B.315, the owner or operator of the stationary source shall promptly report to the Director any deviations from the requirements of the operating permit. The report to the Director shall include the probable cause of all deviations and any action taken to correct the deviations. For the operating permit, prompt is defined as submittal of a report within 15 days of the deviation. This definition does not alter any reporting requirements as established for reporting of excess emissions as required under NAC 445B.232 as reproduced in **Section I.G.**  
**E-mail notifications to:** [aircompliance@ndep.nv.gov](mailto:aircompliance@ndep.nv.gov)

**C. Yearly Reports (NAC 445B.315(3)(h), NAC 445B.346(2)) (*Federally Enforceable SIP Requirement*)**

Under the authority of NAC 445B.315(3)(h) and NAC 445B.346(2) the Permittee will submit yearly reports including, but not limited to, throughput, production, fuel consumption, hours of operation, emissions and supporting documentation to support the calculation of annual emissions. These reports and supporting documentation (if applicable) will be submitted via the State and Local Emissions Inventory System (SLEIS) maintained by the Bureau of Air Quality Planning for all emission units/systems specified. The completed report must be submitted to the Bureau of Air Quality Planning no later than March 1 annually for the preceding calendar year.

**\*\*\*\*End of General Monitoring, Recordkeeping, and Reporting Conditions\*\*\*\***



**Issued to:** MECP1 RENO, LLC – RNO1 (AS PERMITTEE)

**Section III. General Construction Conditions**

**A. Notification (NAC 445B.250; NAC 445B.346(2)) (*Federally Enforceable SIP Requirement*)**

Under the authority of NAC 445B.250 and NAC 445B.346; the Director shall be notified in writing of the following for **S2.001 through S2.128**:

1. The date construction (or reconstruction as defined under NAC 445B.247) of the affected facility is commenced, postmarked no later than 30 days after such date. This requirement shall not apply in the case of mass-produced facilities which are purchased in completed form.
2. The anticipated date of initial startup of an affected facility, postmarked no more than 60 days and no less than 30 days prior to such date.
3. The actual date of initial startup of the affected facility, postmarked within 15 days after such date.
4. The date upon which demonstration of the continuous monitoring system performance commences in accordance with NAC 445B.256 to 445B.267, inclusive. Notification must be postmarked not less than 30 days before such date.

**\*\*\*\*End of General Construction Conditions\*\*\*\***



Issued to: MECP1 RENO, LLC – RNO1 (AS PERMITTEE)

#### Section IV. Specific Construction Requirements

A. Initial Opacity Compliance Demonstration and Initial Performance Tests (NAC 445B.22017, NAC 445B.252, NAC 445B.346(2)) (Federally Enforceable SIP Requirement)

- Under the authority of NAC 445B.22017, NAC 445B.252, and NAC 445B.346, the Permittee, upon issuance of this operating permit, shall conduct initial opacity compliance demonstrations and/or initial performance tests within 60 days after achieving the maximum production rate at which the affected facility will be operated, but not later than 180 days after initial startup. The Permittee shall follow the test methods and procedures referenced in Table IV-1 and Table IV-2 below:

**Table IV-1: Initial Opacity Compliance Demonstration**

System	Emission Unit(s)	Pollutant To Be Tested	Testing Methods/Procedures
System 1 – Diesel-Fired Emergency Generators	S2.001 through S2.126	Opacity	Method 9 in Appendix A of 40 CFR Part 60 shall be used to determine opacity. Opacity observations shall be conducted concurrently with the applicable performance test. The minimum total time of observations shall be six minutes (24 consecutive observations recorded at 15 second intervals), unless otherwise specified by an applicable subpart.
System 2 – Diesel-Fired Fire Pumps	S2.127 and S2.128		

**Table IV-2: Initial Performance Tests**

System	Emission Unit(s)	Pollutants To Be Tested	Testing Methods/Procedures
System 1 – Diesel-Fired Emergency Generators	Two (2) generators from S2.001 through S2.126	PM	Method 5 in Appendix A of 40 CFR Part 60 shall be used to determine PM emissions. The sample volume for each test run shall be at least 1.7 dscm (60 dscf). Test runs must be conducted for up to two hours in an effort to collect this minimum sample.
		PM <sub>10</sub> /PM <sub>2.5</sub>	Method 201A and Method 202 in Appendix M of 40 CFR Part 51 shall be used to determine PM <sub>10</sub> and PM <sub>2.5</sub> emissions. The sample time and sample volume collected for each test run shall be sufficient to collect enough mass to weigh accurately. The Method 201A and 202 test required in this section may be replaced by a Method 5 in Appendix A of 40 CFR Part 60 and Method 202 in Appendix M of 40 CFR Part 51 test. All particulate captured in the Method 5 and Method 202 test performed under this provision shall be considered PM <sub>2.5</sub> for determination of compliance.
		SO <sub>2</sub>	Method 6C in Appendix A of 40 CFR Part 60 shall be used to determine the sulfur dioxide concentration. Each test will be run for a minimum of one hour.
		NO <sub>x</sub>	Method 7E in Appendix A of 40 CFR Part 60 shall be used to determine the nitrogen oxides concentration. Each test will be run for a minimum of one hour.
		CO	Method 10 in Appendix A of 40 CFR Part 60 shall be used to determine the carbon monoxide concentration. Each test will be run for a minimum of one hour.
		VOC	Method 25A in Appendix A of 40 CFR Part 60 shall be used to determine the volatile organic compound concentration. Method 18 in Appendix A of 40 CFR Part 60 or Method 320 in Appendix A of CFR Part 63 may be used in conjunction with Method 25A to break out the organic compounds that are not considered VOC's by definition per 40 CFR 51.100(s). Each Method 25A test will be run for a minimum of one hour.



**Issued to:** MECP1 RENO, LLC – RNO1 (AS PERMITTEE)

#### **Section IV. Specific Construction Requirements (continued)**

A. Initial Opacity Compliance Demonstration and Initial Performance Tests (NAC 445B.22017, NAC 445B.252, NAC 445B.346(2)) (Federally Enforceable SIP Requirement) (continued)

2. All initial opacity compliance demonstrations and initial performance tests must comply with the advance notification, protocol review, operational conditions, reporting, and other requirements of **Section I.H. Testing and Sampling** (NAC 445B.252) of this operating permit. Material sampling must be conducted in accordance with protocols approved by the Director. All initial performance test results shall be based on the arithmetic average of three valid runs. (NAC 445B.252(5))
3. Testing shall be conducted on the exhaust stack (post controls).
4. Initial opacity compliance demonstrations and initial performance tests, as specified in Table IV-1 and Table IV-2 above, must be conducted under such conditions as the Director specifies to the operator of the plant based on representative performance of the affected facility. The Permittee shall make available to the Director such records as may be necessary to determine the conditions of the initial opacity compliance demonstrations and initial performance tests. Operations during periods of startup, shutdown and malfunction must not constitute representative conditions of the initial opacity compliance demonstrations and initial performance tests unless otherwise specified in the applicable standard. (NAC 445B.252(3))
5. The Permittee shall give notice to the Director 30 days before the initial opacity compliance demonstrations and initial performance tests to allow the Director to have an observer present. A written testing procedure must be submitted to the Director at least 30 days before the initial opacity compliance demonstrations and initial performance tests to allow the Director to review the proposed testing procedures. (NAC 445B.252(4) and 40 CFR Part 60.7(a)(6))
6. Within 60 days after completing the initial opacity compliance demonstrations and initial performance tests contained in Table IV-1 and Table IV-2 of this section, the Permittee shall furnish the Director a written report of the results. All information and analytical results of testing and sampling must be certified as to the truth and accuracy and as to their compliance with NAC 445B.001 to 445B.3689, inclusive. (NAC 445B.252(8))
7. Initial opacity compliance demonstrations and initial performance tests required under this section that are conducted below the maximum allowable throughput, shall be subject to the Director's review to determine if the throughputs during the initial opacity compliance demonstrations and initial performance tests were sufficient to provide adequate compliance demonstration. Should the Director determine that the initial opacity compliance demonstrations and initial performance tests do not provide adequate compliance demonstration, the Director may require additional testing.

**\*\*\*\*End of Specific Construction Requirements\*\*\*\***



Issued to: MECP1 RENO, LLC – RNO1 (AS PERMITTEE)

### Section V. Specific Operating Conditions

#### A. Emission Units S2.001 through S2.126

System 1 – Diesel-Fired Emergency Generators		Location UTM (Zone 11, NAD 83)	
		m North	m East
S2.001	Diesel-Fired Emergency Generator 1 (4,706 HP, Caterpillar, C175-16, mfd > 2024)	4,377,826	286,590
S2.002	Diesel-Fired Emergency Generator 2 (4,706 HP, Caterpillar, C175-16, mfd > 2024)	4,377,828	286,593
S2.003	Diesel-Fired Emergency Generator 3 (4,706 HP, Caterpillar, C175-16, mfd > 2024)	4,377,831	286,600
S2.004	Diesel-Fired Emergency Generator 4 (4,706 HP, Caterpillar, C175-16, mfd > 2024)	4,377,833	286,603
S2.005	Diesel-Fired Emergency Generator 5 (4,706 HP, Caterpillar, C175-16, mfd > 2024)	4,377,836	286,609
S2.006	Diesel-Fired Emergency Generator 6 (4,706 HP, Caterpillar, C175-16, mfd > 2024)	4,377,838	286,613
S2.007	Diesel-Fired Emergency Generator 7 (4,706 HP, Caterpillar, C175-16, mfd > 2024)	4,377,840	286,619
S2.008	Diesel-Fired Emergency Generator 8 (4,706 HP, Caterpillar, C175-16, mfd > 2024)	4,377,843	286,623
S2.009	Diesel-Fired Emergency Generator 9 (4,706 HP, Caterpillar, C175-16, mfd > 2024)	4,377,846	286,630
S2.010	Diesel-Fired Emergency Generator 10 (4,706 HP, Caterpillar, C175-16, mfd > 2024)	4,377,847	286,633
S2.011	Diesel-Fired Emergency Generator 11 (4,706 HP, Caterpillar, C175-16, mfd > 2024)	4,377,850	286,639
S2.012	Diesel-Fired Emergency Generator 12 (4,706 HP, Caterpillar, C175-16, mfd > 2024)	4,377,852	286,643
S2.013	Diesel-Fired Emergency Generator 13 (4,706 HP, Caterpillar, C175-16, mfd > 2024)	4,377,855	286,649
S2.014	Diesel-Fired Emergency Generator 14 (4,706 HP, Caterpillar, C175-16, mfd > 2024)	4,377,857	286,652
S2.015	Diesel-Fired Emergency Generator 15 (4,706 HP, Caterpillar, C175-16, mfd > 2024)	4,377,868	286,675
S2.016	Diesel-Fired Emergency Generator 16 (4,706 HP, Caterpillar, C175-16, mfd > 2024)	4,377,870	286,678
S2.017	Diesel-Fired Emergency Generator 17 (4,706 HP, Caterpillar, C175-16, mfd > 2024)	4,377,873	286,684
S2.018	Diesel-Fired Emergency Generator 18 (4,706 HP, Caterpillar, C175-16, mfd > 2024)	4,377,875	286,688
S2.019	Diesel-Fired Emergency Generator 19 (4,706 HP, Caterpillar, C175-16, mfd > 2024)	4,377,878	286,694
S2.020	Diesel-Fired Emergency Generator 20 (4,706 HP, Caterpillar, C175-16, mfd > 2024)	4,377,879	286,698
S2.021	Diesel-Fired Emergency Generator 21 (4,706 HP, Caterpillar, C175-16, mfd > 2024)	4,377,883	286,698
S2.022	Diesel-Fired Emergency Generator 22 (4,706 HP, Caterpillar, C175-16, mfd > 2024)	4,377,884	286,708



Facility ID No. A2652

Permit No. AP7374-4772

## CLASS II AIR QUALITY OPERATING PERMIT

Issued to: MECP1 RENO, LLC – RNO1 (AS PERMITTEE)

**Section V. Specific Operating Conditions (continued)****A. Emission Units S2.001 through S2.126 (continued)**

S2.023	Diesel-Fired Emergency Generator 23 (4,706 HP, Caterpillar, C175-16, mfd > 2024)	4,377,887	286,714
S2.024	Diesel-Fired Emergency Generator 24 (4,706 HP, Caterpillar, C175-16, mfd > 2024)	4,377,889	286,718
S2.025	Diesel-Fired Emergency Generator 25 (4,706 HP, Caterpillar, C175-16, mfd > 2024)	4,377,892	286,724
S2.026	Diesel-Fired Emergency Generator 26 (4,706 HP, Caterpillar, C175-16, mfd > 2024)	4,377,894	286,727
S2.027	Diesel-Fired Emergency Generator 27 (4,706 HP, Caterpillar, C175-16, mfd > 2024)	4,377,897	286,734
S2.028	Diesel-Fired Emergency Generator 28 (4,706 HP, Caterpillar, C175-16, mfd > 2024)	4,377,899	286,737
S2.029	Diesel-Fired Emergency Generator 29 (4,706 HP, Caterpillar, C175-16, mfd > 2024)	4,377,910	286,760
S2.030	Diesel-Fired Emergency Generator 30 (4,706 HP, Caterpillar, C175-16, mfd > 2024)	4,377,912	286,763
S2.031	Diesel-Fired Emergency Generator 31 (4,706 HP, Caterpillar, C175-16, mfd > 2024)	4,377,915	286,769
S2.032	Diesel-Fired Emergency Generator 32 (4,706 HP, Caterpillar, C175-16, mfd > 2024)	4,377,917	286,773
S2.033	Diesel-Fired Emergency Generator 33 (4,706 HP, Caterpillar, C175-16, mfd > 2024)	4,377,920	286,779
S2.034	Diesel-Fired Emergency Generator 34 (4,706 HP, Caterpillar, C175-16, mfd > 2024)	4,377,922	286,783
S2.035	Diesel-Fired Emergency Generator 35 (4,706 HP, Caterpillar, C175-16, mfd > 2024)	4,377,925	286,789
S2.036	Diesel-Fired Emergency Generator 36 (4,706 HP, Caterpillar, C175-16, mfd > 2024)	4,377,926	286,793
S2.037	Diesel-Fired Emergency Generator 37 (4,706 HP, Caterpillar, C175-16, mfd > 2024)	4,377,930	286,799
S2.038	Diesel-Fired Emergency Generator 38 (4,706 HP, Caterpillar, C175-16, mfd > 2024)	4,377,931	286,803
S2.039	Diesel-Fired Emergency Generator 39 (4,706 HP, Caterpillar, C175-16, mfd > 2024)	4,377,934	286,809
S2.040	Diesel-Fired Emergency Generator 40 (4,706 HP, Caterpillar, C175-16, mfd > 2024)	4,377,936	286,813
S2.041	Diesel-Fired Emergency Generator 41 (4,706 HP, Caterpillar, C175-16, mfd > 2024)	4,377,939	286,819
S2.042	Diesel-Fired Emergency Generator 42 (4,706 HP, Caterpillar, C175-16, mfd > 2024)	4,377,941	286,823
S2.043	Diesel-Fired Emergency Generator 43 (4,706 HP, Caterpillar, C175-16, mfd > 2024)	4,377,918	286,679
S2.044	Diesel-Fired Emergency Generator 44 (4,706 HP, Caterpillar, C175-16, mfd > 2024)	4,377,919	286,683
S2.045	Diesel-Fired Emergency Generator 45 (4,706 HP, Caterpillar, C175-16, mfd > 2024)	4,377,923	286,690



Issued to: MECP1 RENO, LLC – RNO1 (AS PERMITTEE)

### Section V. Specific Operating Conditions (continued)

#### A. Emission Units S2.001 through S2.126 (continued)

S2.046	Diesel-Fired Emergency Generator 46 (4,706 HP, Caterpillar, C175-16, mfd > 2024)	4,377,925	286,693
S2.047	Diesel-Fired Emergency Generator 47 (4,706 HP, Caterpillar, C175-16, mfd > 2024)	4,377,928	286,701
S2.048	Diesel-Fired Emergency Generator 48 (4,706 HP, Caterpillar, C175-16, mfd > 2024)	4,377,931	286,705
S2.049	Diesel-Fired Emergency Generator 49 (4,706 HP, Caterpillar, C175-16, mfd > 2024)	4,377,934	286,712
S2.050	Diesel-Fired Emergency Generator 50 (4,706 HP, Caterpillar, C175-16, mfd > 2024)	4,377,936	286,715
S2.051	Diesel-Fired Emergency Generator 51 (4,706 HP, Caterpillar, C175-16, mfd > 2024)	4,377,939	286,723
S2.052	Diesel-Fired Emergency Generator 52 (4,706 HP, Caterpillar, C175-16, mfd > 2024)	4,377,941	286,726
S2.053	Diesel-Fired Emergency Generator 53 (4,706 HP, Caterpillar, C175-16, mfd > 2024)	4,377,945	286,734
S2.054	Diesel-Fired Emergency Generator 54 (4,706 HP, Caterpillar, C175-16, mfd > 2024)	4,377,946	286,737
S2.055	Diesel-Fired Emergency Generator 55 (4,706 HP, Caterpillar, C175-16, mfd > 2024)	4,377,950	286,744
S2.056	Diesel-Fired Emergency Generator 56 (4,706 HP, Caterpillar, C175-16, mfd > 2024)	4,377,952	286,748
S2.057	Diesel-Fired Emergency Generator 57 (4,706 HP, Caterpillar, C175-16, mfd > 2024)	4,377,960	286,764
S2.058	Diesel-Fired Emergency Generator 58 (4,706 HP, Caterpillar, C175-16, mfd > 2024)	4,377,961	286,767
S2.059	Diesel-Fired Emergency Generator 59 (4,706 HP, Caterpillar, C175-16, mfd > 2024)	4,377,965	286,775
S2.060	Diesel-Fired Emergency Generator 60 (4,706 HP, Caterpillar, C175-16, mfd > 2024)	4,377,967	286,778
S2.061	Diesel-Fired Emergency Generator 61 (4,706 HP, Caterpillar, C175-16, mfd > 2024)	4,377,970	286,786
S2.062	Diesel-Fired Emergency Generator 62 (4,706 HP, Caterpillar, C175-16, mfd > 2024)	4,377,972	286,789
S2.063	Diesel-Fired Emergency Generator 63 (4,706 HP, Caterpillar, C175-16, mfd > 2024)	4,377,976	286,797
S2.064	Diesel-Fired Emergency Generator 64 (4,706 HP, Caterpillar, C175-16, mfd > 2024)	4,377,978	286,800
S2.065	Diesel-Fired Emergency Generator 65 (4,706 HP, Caterpillar, C175-16, mfd > 2024)	4,377,981	286,808
S2.066	Diesel-Fired Emergency Generator 66 (4,706 HP, Caterpillar, C175-16, mfd > 2024)	4,377,983	286,811
S2.067	Diesel-Fired Emergency Generator 67 (4,706 HP, Caterpillar, C175-16, mfd > 2024)	4,377,987	286,818
S2.068	Diesel-Fired Emergency Generator 68 (4,706 HP, Caterpillar, C175-16, mfd > 2024)	4,377,988	286,822



Issued to: MECP1 RENO, LLC – RNO1 (AS PERMITTEE)

### Section V. Specific Operating Conditions (continued)

#### A. Emission Units S2.001 through S2.126 (continued)

S2.069	Diesel-Fired Emergency Generator 69 (4,706 HP, Caterpillar, C175-16, mfd > 2024)	4,377,992	286,829
S2.070	Diesel-Fired Emergency Generator 70 (4,706 HP, Caterpillar, C175-16, mfd > 2024)	4,377,994	286,833
S2.071	Diesel-Fired Emergency Generator 71 (4,706 HP, Caterpillar, C175-16, mfd > 2024)	4,378,002	286,849
S2.072	Diesel-Fired Emergency Generator 72 (4,706 HP, Caterpillar, C175-16, mfd > 2024)	4,378,003	286,852
S2.073	Diesel-Fired Emergency Generator 73 (4,706 HP, Caterpillar, C175-16, mfd > 2024)	4,378,007	286,860
S2.074	Diesel-Fired Emergency Generator 74 (4,706 HP, Caterpillar, C175-16, mfd > 2024)	4,378,009	286,863
S2.075	Diesel-Fired Emergency Generator 75 (4,706 HP, Caterpillar, C175-16, mfd > 2024)	4,378,013	286,871
S2.076	Diesel-Fired Emergency Generator 76 (4,706 HP, Caterpillar, C175-16, mfd > 2024)	4,378,014	286,874
S2.077	Diesel-Fired Emergency Generator 77 (4,706 HP, Caterpillar, C175-16, mfd > 2024)	4,378,018	286,882
S2.078	Diesel-Fired Emergency Generator 78 (4,706 HP, Caterpillar, C175-16, mfd > 2024)	4,378,020	286,885
S2.079	Diesel-Fired Emergency Generator 79 (4,706 HP, Caterpillar, C175-16, mfd > 2024)	4,378,023	286,892
S2.080	Diesel-Fired Emergency Generator 80 (4,706 HP, Caterpillar, C175-16, mfd > 2024)	4,378,025	286,896
S2.081	Diesel-Fired Emergency Generator 81 (4,706 HP, Caterpillar, C175-16, mfd > 2024)	4,378,029	286,903
S2.082	Diesel-Fired Emergency Generator 82 (4,706 HP, Caterpillar, C175-16, mfd > 2024)	4,378,031	286,907
S2.083	Diesel-Fired Emergency Generator 83 (4,706 HP, Caterpillar, C175-16, mfd > 2024)	4,378,034	286,914
S2.084	Diesel-Fired Emergency Generator 84 (4,706 HP, Caterpillar, C175-16, mfd > 2024)	4,378,036	286,918
S2.085	Diesel-Fired Emergency Generator 85 (4,706 HP, Caterpillar, C175-16, mfd > 2024)	4,377,792	286,425
S2.086	Diesel-Fired Emergency Generator 86 (4,706 HP, Caterpillar, C175-16, mfd > 2024)	4,377,793	286,428
S2.087	Diesel-Fired Emergency Generator 87 (4,706 HP, Caterpillar, C175-16, mfd > 2024)	4,377,797	286,436
S2.088	Diesel-Fired Emergency Generator 88 (4,706 HP, Caterpillar, C175-16, mfd > 2024)	4,377,799	286,440
S2.089	Diesel-Fired Emergency Generator 89 (4,706 HP, Caterpillar, C175-16, mfd > 2024)	4,377,802	286,447
S2.090	Diesel-Fired Emergency Generator 90 (4,706 HP, Caterpillar, C175-16, mfd > 2024)	4,377,804	286,450
S2.091	Diesel-Fired Emergency Generator 91 (4,706 HP, Caterpillar, C175-16, mfd > 2024)	4,377,808	286,458



Issued to: MECP1 RENO, LLC – RNO1 (AS PERMITTEE)

### Section V. Specific Operating Conditions (continued)

#### A. Emission Units S2.001 through S2.126 (continued)

S2.092	Diesel-Fired Emergency Generator 92 (4,706 HP, Caterpillar, C175-16, mfd > 2024)	4,377,810	286,461
S2.093	Diesel-Fired Emergency Generator 93 (4,706 HP, Caterpillar, C175-16, mfd > 2024)	4,377,813	286,469
S2.094	Diesel-Fired Emergency Generator 94 (4,706 HP, Caterpillar, C175-16, mfd > 2024)	4,377,815	286,472
S2.095	Diesel-Fired Emergency Generator 95 (4,706 HP, Caterpillar, C175-16, mfd > 2024)	4,377,819	286,479
S2.096	Diesel-Fired Emergency Generator 96 (4,706 HP, Caterpillar, C175-16, mfd > 2024)	4,377,820	286,483
S2.097	Diesel-Fired Emergency Generator 97 (4,706 HP, Caterpillar, C175-16, mfd > 2024)	4,377,824	286,490
S2.098	Diesel-Fired Emergency Generator 98 (4,706 HP, Caterpillar, C175-16, mfd > 2024)	4,377,826	286,494
S2.099	Diesel-Fired Emergency Generator 99 (4,706 HP, Caterpillar, C175-16, mfd > 2024)	4,377,834	286,510
S2.100	Diesel-Fired Emergency Generator 100 (4,706 HP, Caterpillar, C175-16, mfd > 2024)	4,377,835	286,513
S2.101	Diesel-Fired Emergency Generator 101 (4,706 HP, Caterpillar, C175-16, mfd > 2024)	4,377,839	286,521
S2.102	Diesel-Fired Emergency Generator 102 (4,706 HP, Caterpillar, C175-16, mfd > 2024)	4,377,841	286,524
S2.103	Diesel-Fired Emergency Generator 103 (4,706 HP, Caterpillar, C175-16, mfd > 2024)	4,377,844	286,532
S2.104	Diesel-Fired Emergency Generator 104 (4,706 HP, Caterpillar, C175-16, mfd > 2024)	4,377,846	286,535
S2.105	Diesel-Fired Emergency Generator 105 (4,706 HP, Caterpillar, C175-16, mfd > 2024)	4,377,850	286,543
S2.106	Diesel-Fired Emergency Generator 106 (4,706 HP, Caterpillar, C175-16, mfd > 2024)	4,377,852	286,546
S2.107	Diesel-Fired Emergency Generator 107 (4,706 HP, Caterpillar, C175-16, mfd > 2024)	4,377,855	286,553
S2.108	Diesel-Fired Emergency Generator 108 (4,706 HP, Caterpillar, C175-16, mfd > 2024)	4,377,857	286,557
S2.109	Diesel-Fired Emergency Generator 109 (4,706 HP, Caterpillar, C175-16, mfd > 2024)	4,377,861	286,564
S2.110	Diesel-Fired Emergency Generator 110 (4,706 HP, Caterpillar, C175-16, mfd > 2024)	4,377,863	286,568
S2.111	Diesel-Fired Emergency Generator 111 (4,706 HP, Caterpillar, C175-16, mfd > 2024)	4,377,866	286,575
S2.112	Diesel-Fired Emergency Generator 112 (4,706 HP, Caterpillar, C175-16, mfd > 2024)	4,377,868	286,579
S2.113	Diesel-Fired Emergency Generator 113 (4,706 HP, Caterpillar, C175-16, mfd > 2024)	4,377,876	286,595
S2.114	Diesel-Fired Emergency Generator 114 (4,706 HP, Caterpillar, C175-16, mfd > 2024)	4,377,878	286,598



Issued to: MECP1 RENO, LLC – RNO1 (AS PERMITTEE)

### Section V. Specific Operating Conditions (continued)

#### A. Emission Units S2.001 through S2.126 (continued)

S2.115	Diesel-Fired Emergency Generator 115 (4,706 HP, Caterpillar, C175-16, mfd > 2024)	4,377,881	286,606
S2.116	Diesel-Fired Emergency Generator 116 (4,706 HP, Caterpillar, C175-16, mfd > 2024)	4,377,883	286,609
S2.117	Diesel-Fired Emergency Generator 117 (4,706 HP, Caterpillar, C175-16, mfd > 2024)	4,377,887	286,617
S2.118	Diesel-Fired Emergency Generator 118 (4,706 HP, Caterpillar, C175-16, mfd > 2024)	4,377,888	286,620
S2.119	Diesel-Fired Emergency Generator 119 (4,706 HP, Caterpillar, C175-16, mfd > 2024)	4,377,892	286,627
S2.120	Diesel-Fired Emergency Generator 120 (4,706 HP, Caterpillar, C175-16, mfd > 2024)	4,377,894	286,631
S2.121	Diesel-Fired Emergency Generator 121 (4,706 HP, Caterpillar, C175-16, mfd > 2024)	4,377,897	286,638
S2.122	Diesel-Fired Emergency Generator 122 (4,706 HP, Caterpillar, C175-16, mfd > 2024)	4,377,899	286,642
S2.123	Diesel-Fired Emergency Generator 123 (4,706 HP, Caterpillar, C175-16, mfd > 2024)	4,377,903	286,649
S2.124	Diesel-Fired Emergency Generator 124 (4,706 HP, Caterpillar, C175-16, mfd > 2024)	4,377,905	286,653
S2.125	Diesel-Fired Emergency Generator 125 (4,706 HP, Caterpillar, C175-16, mfd > 2024)	4,377,908	286,660
S2.126	Diesel-Fired Emergency Generator 126 (4,706 HP, Caterpillar, C175-16, mfd > 2024)	4,377,910	286,664

1. Air Pollution Control Equipment (NAC 445B.346(1)) (Federally Enforceable SIP Requirement)
  - a. **S2.001 through S2.126, each**, are controlled by an emission control system that consists of **selective catalytic reduction (SCR)**, **diesel particulate filters (DPF)**, and **diesel oxidation catalysts (DOC)** for the control of nitrogen oxides (NOx), particulate matter (PM), volatile organic compounds (VOC), and carbon monoxide (CO).
  - b. **S2.001 through S2.126, each**, are considered controlled only if:
    - (1) The catalyst bed temperature is at least **800 °F**; and
    - (2) The diesel particulate filters are at or above **650 °F**
  - c. Descriptive Stack Parameters  
Stack Height: 31.67 feet  
Stack Diameter: 2.00 feet  
Stack Temperature: 920.0 °F
2. Operating Parameters (NAC 445B.346(1)) (Federally Enforceable SIP Requirement)
  - a. **S2.001 through S2.126, each**, may consume only **diesel**.
  - b. The sulfur content shall not exceed **0.0015** percent.
  - c. The maximum allowable fuel consumption rate for **S2.001 through S2.126, each**, shall not exceed **219.8 gallons** per any one-hour period.
  - d. The maximum allowable fuel consumption rate for **S2.001 through S2.126, combined**, shall not exceed **498,506.0 gallons** per year of non-emergency use during uncontrolled operations.
  - e. The maximum allowable fuel consumption rate for **S2.001 through S2.126, combined**, shall not exceed **971,494.0 gallons** per year of non-emergency use during controlled operations.



Issued to: MECP1 RENO, LLC – RNO1 (AS PERMITTEE)

## Section V. Specific Operating Conditions (continued)

### A. Emission Units S2.001 through S2.126 (continued)

2. Operating Parameters (NAC 445B.346(1)) (*Federally Enforceable SIP Requirement*) (continued)
  - f. Hours
    - (1) **S2.001 through S2.126, each**, may operate a total of **11** hours per day.
    - (2) **S2.001 through S2.126, each**, may operate a maximum of **100** hours per year of non-emergency use. There is no time limit on operation in emergency situations.
    - (3) For non-emergency use, **S2.001 through S2.126, each**, may operate from **7 AM to 6 PM** only. There is no hour of day limit during emergency situations.
  - g. For up to six days per year, up to **14** generators may be operated simultaneously for non-emergency use.
  - h. For the remaining days of the year, up to **3** generators may be operated simultaneously for non-emergency use.
  3. Emission Limits (NAC 445B.305, NAC 445B.346(1), NAC 445B. 22017) (*Federally Enforceable SIP Requirement*)
    - a. The Permittee, upon issuance of this operating permit, shall not discharge or cause the discharge into the atmosphere from **S2.001 through S2.126** the following pollutants in excess of the following specified limits during **uncontrolled operations**:
      - (1) The discharge of **PM** (particulate matter) to the atmosphere shall not exceed **1.62** pounds per hour, **each**, nor more than **1.83** tons per year, **combined**.
      - (2) The discharge of **PM<sub>10</sub>** (particulate matter less than or equal to 10 microns in diameter) to the atmosphere shall not exceed **1.62** pounds per hour, **each**, nor more than **1.83** tons per year, **combined**.
      - (3) The discharge of **PM<sub>2.5</sub>** (particulate matter less than or equal to 2.5 microns in diameter) to the atmosphere shall not exceed **1.62** pounds per hour, **each**, nor more than **1.83** tons per year, **combined**.
      - (4) The discharge of **SO<sub>2</sub>** (sulfur dioxide) to the atmosphere shall not exceed **0.046** pounds per hour, **each**, nor more than **0.052** tons per year, **combined**.
      - (5) The discharge of **NO<sub>x</sub>** (oxides of nitrogen) to the atmosphere shall not exceed **72.94** pounds per hour, **each**, nor more than **82.71** tons per year, **combined**.
      - (6) The discharge of **CO** (carbon monoxide) to the atmosphere shall not exceed **27.18** pounds per hour, **each**, nor more than **30.82** tons per year, **combined**.
      - (7) The discharge of **VOCs** (volatile organic compounds) to the atmosphere shall not exceed **3.16** pounds per hour, **each**, nor more than **3.58** tons per year, **combined**.
    - b. The Permittee, upon issuance of this operating permit, shall not discharge or cause the discharge into the atmosphere from **S2.001 through S2.126** the following pollutants in excess of the following specified limits during **controlled operations**:
      - (1) The discharge of **PM** (particulate matter) to the atmosphere shall not exceed **0.32** pounds per hour, **each**.
      - (2) The discharge of **PM<sub>10</sub>** (particulate matter less than or equal to 10 microns in diameter) to the atmosphere shall not exceed **1.62** pounds per hour, **each**.
      - (3) The discharge of **PM<sub>2.5</sub>** (particulate matter less than or equal to 2.5 microns in diameter) to the atmosphere shall not exceed **1.62** pounds per hour, **each**.
      - (4) The discharge of **SO<sub>2</sub>** (sulfur dioxide) to the atmosphere shall not exceed **0.046** pounds per hour, **each**.
      - (5) The discharge of **NO<sub>x</sub>** (oxides of nitrogen) to the atmosphere shall not exceed **7.29** pounds per hour, **each**.
      - (6) The discharge of **CO** (carbon monoxide) to the atmosphere shall not exceed **5.44** pounds per hour, **each**.
      - (7) The discharge of **VOCs** (volatile organic compounds) to the atmosphere shall not exceed **1.26** pounds per hour, **each**.



Issued to: MECP1 RENO, LLC – RNO1 (AS PERMITTEE)

## Section V. Specific Operating Conditions (continued)

### A. Emission Units S2.001 through S2.126 (continued)

3. Emission Limits (NAC 445B.305, NAC 445B.346(1), NAC 445B. 22017) (*Federally Enforceable SIP Requirement*)  
(continued)
  - c. The Permittee, upon issuance of this operating permit, shall not discharge or cause the discharge into the atmosphere from **S2.001 through S2.126, combined**, the following pollutants in excess of the following specified limits during **controlled and uncontrolled operations, combined**:
    - (1) The discharge of **PM** (particulate matter) to the atmosphere shall not exceed **2.55** tons per year.
    - (2) The discharge of **PM<sub>10</sub>** (particulate matter less than or equal to 10 microns in diameter) to the atmosphere shall not exceed **5.41** tons per year.
    - (3) The discharge of **PM<sub>2.5</sub>** (particulate matter less than or equal to 2.5 microns in diameter) to the atmosphere shall not exceed **5.41** tons per year.
    - (4) The discharge of **SO<sub>2</sub>** (sulfur dioxide) to the atmosphere shall not exceed **0.15** tons per year.
    - (5) The discharge of **NO<sub>x</sub>** (oxides of nitrogen) to the atmosphere shall not exceed **98.83** tons per year.
    - (6) The discharge of **CO** (carbon monoxide) to the atmosphere shall not exceed **42.84** tons per year.
    - (7) The discharge of **VOCs** (volatile organic compounds) to the atmosphere shall not exceed **6.37** tons per year.
  - d. The opacity from **S2.001 through S2.126, each**, shall not equal or exceed **20** percent.
4. Monitoring, Recordkeeping, and Reporting (NAC 445B.346(2)) (*Federally Enforceable SIP Requirement*)  
The Permittee, upon the issuance of this operating permit, shall maintain, in a contemporaneous log, the monitoring and recordkeeping specified in this section. All records in the log must be identified with the calendar date of the record. All specified records shall be entered into the log at the end of the shift, end of the day of operation, or the end of the final day of operation for the month, as appropriate.
  - a. Monitor and record the times at which operations start and stop as well as the total daily hours of operation for **S2.001 through S2.126, each**. The Permittee shall note which hours of operation are emergency hours, and which hours of operation are hours for non-emergency use. The Permittee shall also note which hours of operation are controlled operations, and which hours are uncontrolled operations.
  - b. Monitor and record the temperature of each corresponding catalyst bed for **S2.001 through S2.126, each**, on an hourly basis. The Permittee shall use the recorded temperature to adequately categorize which hours of operation are controlled, and which hours of operation are uncontrolled.
  - c. Monitor and record the consumption rate of **diesel** during non-emergency operations on a monthly basis for **S2.001 through S2.126, each**, (in **gallons**) for both uncontrolled and controlled operations. The monthly uncontrolled consumption rate shall be calculated either by the maximum fuel consumption rate provided on the manufacturer's specification sheet, to be kept onsite with records, or by use of a fuel flow meter.
  - d. Monitor and record the total yearly consumption rate, for **S2.001 through S2.126, combined**, in gallons per year for both uncontrolled and controlled operations during non-emergency operations. The annual consumption shall be determined as the sum of the monthly consumption rates for the year for all previous months of that year.
  - e. Monitor and record the total yearly non-emergency hours of operation of **S2.001 through S2.126, each**, per year. The annual hours of operation shall be determined at the end of each month as the sum of the monthly hours of operation for all previous months of that year.
  - f. Keep on site, and make available upon request, documentation demonstrating that the sulfur content of the **diesel** consumed in **S2.001 through S2.126, each**, shall not exceed the limit set forth in **A.2.b.** of this section.
  - g. The Permittee, upon issuance of this operating permit, shall maintain records of the occurrence and duration of any startup, shutdown, or malfunction in the operation of an affected facility; any malfunction of the air pollution control equipment; or any periods during which a continuous monitoring system or monitoring device is inoperative. (40 CFR 60.7(b))



**Issued to:** MECP1 RENO, LLC – RNO1 (AS PERMITTEE)

## **Section V. Specific Operating Conditions (continued)**

### **A. Emission Units S2.001 through S2.126 (continued)**

#### **5. Performance Testing (NAC 445B.346(2))**

The Permittee, upon issuance of this operating permit, shall conduct annual performance testing within 90 days of the anniversary date of the previous initial performance testing or annual performance testing, and annually thereafter, in accordance with the following:

- a. The Permittee shall test two (2) generators during every annual performance test. The two generators being tested cannot have been previously used by the Permittee for performance testing purposes.
- b. All opacity compliance demonstrations and performance tests must comply with the advance notification, protocol review, operational conditions, reporting, and other requirements of Section I.H. Testing and Sampling (NAC 445B.252) of this operating permit. All performance test results shall be based on the arithmetic average of three valid runs (NAC 445B.252(5)).
- c. Testing shall be conducted on the exhaust stack (post controls).
- d. Method 5 in Appendix A of 40 CFR Part 60 shall be used to determine PM emissions. The sample volume for each test run shall be at least 1.7 dscm (60 dscf). Test runs must be conducted for up to two hours in an effort to collect this minimum sample.
- e. Method 201A and Method 202 in Appendix M of 40 CFR Part 51 shall be used to determine PM10 and PM2.5 emissions. The sample time and sample volume collected for each test run shall be sufficient to collect enough mass to weigh accurately.
- f. The Method 201A and 202 test required in this section may be replaced by a Method 5 in Appendix A of 40 CFR Part 60 and Method 202 in Appendix M of 40 CFR Part 51 test. All particulate captured in the Method 5 and Method 202 test performed under this provision shall be considered PM2.5 for determination of compliance.
- g. Method 6C in Appendix A of 40 CFR Part 60 shall be used to determine the sulfur dioxide concentration. Each test will be run for a minimum of one hour.
- h. Method 7E in Appendix A of 40 CFR Part 60 shall be used to determine the nitrogen oxides concentration. Each test will be run for a minimum of one hour.
- i. Method 9 in Appendix A of 40 CFR Part 60 shall be used to determine opacity. Opacity observations shall be conducted concurrently with the applicable performance test. The minimum total time of observations shall be six minutes (24 consecutive observations recorded at 15 second intervals), unless otherwise specified by an applicable subpart.
- j. Method 10 in Appendix A of 40 CFR Part 60 shall be used to determine the carbon monoxide concentration. Each test will be run for a minimum of one hour.
- k. Method 25A in Appendix A of 40 CFR Part 60 shall be used to determine the volatile organic compound concentration. Method 18 in Appendix A of 40 CFR Part 60 or Method 320 in Appendix A of CFR Part 63 may be used in conjunction with Method 25A to break out the organic compounds that are not considered VOC's by definition per 40 CFR 51.100(s). Each Method 25A test will be run for a minimum of one hour.
- l. After five (5) years, the Permittee may contact the director to determine if reduced frequency of testing is warranted.



Issued to: MECP1 RENO, LLC – RNO1 (AS PERMITTEE)

## Section V. Specific Operating Conditions (continued)

### A. Emission Units S2.001 through S2.126 (continued)

6. Federal Requirements (NAC 445B.346(2), NAC 445B.252(1)) (*Federally Enforceable SIP Requirement*)  
New Source Performance Standards (NSPS) – 40 CFR Part 60 Subpart IIII – Standards of Performance for Stationary Compression Ignition Internal Combustion Engines

- a. Emissions Standards (40 CFR 60.4205)  
The Permittee must comply with the emission standards for new non-road CI (compression ignition) ICE (internal combustion engine) in 40 CR 60.4202, for all pollutants, for the same model year and maximum engine power for their 2007 model year and later emergency stationary CI ICE. (40 CFR 60.4205(b))
  - (1) For a 2011 model year and later Tier 2 non-road engine with a rated power greater than 2,237 kW (3,000 hp): (40 CFR 60.4202(b)(2), 40 CFR 1039 Appendix I)
    - (a) The discharge of PM to the atmosphere shall not exceed **0.20** gram/kW-hr.
    - (b) The discharge of CO to the atmosphere shall not exceed **3.5** grams/kW-hr.
    - (c) The discharge of NMHC (non-methane hydrocarbon) + NOx to the atmosphere shall not exceed **6.4** grams/kW-hr.
  - (2) Exhaust opacity must not exceed: (40 CFR 60.4202(a)(2), 40 CFR 1039.105(b))
    - (a) 20 percent during acceleration mode;
    - (b) 15 percent during the lugging mode; and
    - (c) 50 percent during the peaks in either the acceleration or lugging modes.
- b. Fuel Requirements (40 CFR 60.4207)  
The Permittee must meet the following diesel requirements for non-road engine: (40 CFR 60.4207(b), 40 CFR 1090.305)
  - (1) Sulfur content to be 15 parts per million (ppm) maximum.
  - (2) A minimum cetane index of 40; or
  - (3) A maximum aromatic content of 35 volume percent.
- c. Monitoring Requirements (40 CFR 60.4209)  
If the CI ICE does not meet the standards applicable to non-emergency engines, the Permittee must install a non-resettable hour meter prior to startup of the engine. (40 CFR 60.4209(a))
- d. Compliance Requirements (40 CFR 60.4206, 40 CFR 60.4211)
  - (1) The Permittee must operate and maintain stationary CI ICE that achieve the emission standards as required in 40 CFR 60.4205 over the entire life of the engine. (40 CFR 60.4206)
  - (2) The Permittee must operate and maintain the stationary CI internal combustion engine and control device according to the manufacturer's emission-related written instructions; change only those emission-related settings that are permitted by the manufacturer; and meet the requirements of 40 CFR Part 1068, except as permitted in **A.5.d.(5)** of this section. (40 CFR 60.4211(a))
  - (3) The engine must be installed and configured according to the manufacturer's emission-related specifications, except as permitted in **A.5.d.(5)** of this section. (40 CFR 60.4211(c))



Issued to: MECP1 RENO, LLC – RNO1 (AS PERMITTEE)

## Section V. Specific Operating Conditions (continued)

### A. Emission Units S2.001 through S2.126 (continued)

6. Federal Requirements (NAC 445B.346(2), NAC 445B.252(1)) (*Federally Enforceable SIP Requirement*)  
New Source Performance Standards (NSPS) – 40 CFR Part 60 Subpart IIII – Standards of Performance for Stationary Compression Ignition Internal Combustion Engines (continued)

d. Compliance Requirements (40 CFR 60.4206, 40 CFR 60.4211)

(4) In order for the engine to be considered an emergency stationary ICE under this subpart, any operation other than emergency operation, maintenance and testing, emergency demand response, and operation in non-emergency situations for 50 hours per year, as described in paragraphs **A.5.d.(4)(a) through (c)** of this section, is prohibited. If the Permittee do not operate the engine according to the requirements in paragraphs **A.5.d.(4)(a) through (c)** of this section, the engine will not be considered an emergency engine under this subpart and must meet all requirements for non-emergency engines. (40 CFR 60.4211(f))

(a) There is no time limit on the use of emergency stationary ICE in emergency situations. (40 CFR 60.4211(f)(1))

(b) The Permittee may operate the Permittee's emergency stationary ICE for any combination of the purposes specified in paragraphs **A.5.d.(4)(b)** of this section for a maximum of 100 hours per calendar year. Any operation for non-emergency situations as allowed by paragraph **A.5.d.(4)(c)** of this section counts as part of the 100 hours per calendar year. (40 CFR 60.4211(f)(2))

i. Emergency stationary ICE may be operated for maintenance checks and readiness testing, provided that the tests are recommended by federal, state or local government, the manufacturer, the vendor, the regional transmission organization or equivalent balancing authority and transmission operator, or the insurance company associated with the engine. The owner or operator may petition the Administrator for approval of additional hours to be used for maintenance checks and readiness testing, but a petition is not required if the owner or operator maintains records indicating that federal, state, or local standards require maintenance and testing of emergency ICE beyond 100 hours per calendar year. (40 CFR 60.4211(f)(2)(i))

(c) Emergency stationary ICE may be operated for up to 50 hours per calendar year in non-emergency situations. The 50 hours of operation in non-emergency situations are counted as part of the 100 hours per calendar year for maintenance and testing and emergency demand response provided in paragraph **A.5.d.(4)(b)** of this section. Except as provided in paragraph **A.5.d.(4)(c)** of this section, the 50 hours per calendar year for non-emergency situations cannot be used for peak shaving or non-emergency demand response, or to generate income for a facility to an electric grid or otherwise supply power as part of a financial arrangement with another entity. (40 CFR 60.4211(f)(3))

i. The 50 hours per year for non-emergency situations can be used to supply power as part of a financial arrangement with another entity if all of the conditions in 40 CFR 60.4211(f)(3)(i)(A) through (E) are met. (40 CFR 60.4211(f)(3)(i))

(5) If the Permittee does not install, configure, operate, and maintain the Permittee's engine and control device according to the manufacturer's emission-related written instructions, or the Permittee change emission-related settings in a way that is not permitted by the manufacturer, the Permittee must demonstrate compliance as follows: (40 CFR 4211(g))

(a) For CI ICE greater than 500 hp, the Permittee must keep a maintenance plan and records of conducted maintenance and must, to the extent practicable, maintain and operate the engine in a manner consistent with good air pollution control practice for minimizing emissions. In addition, the Permittee must conduct an initial performance test to demonstrate compliance with the applicable emission standards within 1 year of startup, or within 1 year after an engine and control device is no longer installed, configured, operated, and maintained in accordance with the manufacturer's emission-related written instructions, or within 1 year after the Permittee change emission-related settings in a way that is not permitted by the manufacturer. The Permittee must conduct subsequent performance testing every 8,760 hours of engine operation or 3 years, whichever comes first, thereafter to demonstrate compliance with the applicable emission standards. (40 CFR 60.4211(g)(3))



**Issued to:** MECP1 RENO, LLC – RNO1 (AS PERMITTEE)

**Section V. Specific Operating Conditions (continued)****A. Emission Units S2.001 through S2.126 (continued)**

6. Federal Requirements (NAC 445B.346(2), NAC 445B.252(1)) (*Federally Enforceable SIP Requirement*)  
New Source Performance Standards (NSPS) – 40 CFR Part 60 Subpart IIII – Standards of Performance for Stationary  
Compression Ignition Internal Combustion Engines (continued)

e. National Emission Standards for Hazardous Air Pollutants for Source Categories – 40 CFR Part 63, Subpart ZZZZ –  
Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines:  
If the compression ignition engine meets the requirements of 40 CFR Part 60 Subpart IIII, 40 CFR Part 63 Subpart  
ZZZZ requirements are also met. (40 CFR Part 63.6590(c))



Issued to: MECP1 RENO, LLC – RNO1 (AS PERMITTEE)

## Section V. Specific Operating Conditions (continued)

### B. Emission Units S2.127 and S2.128

System 2 – Diesel-Fired Fire Pumps		Location UTM (Zone 11, NAD 83)	
		m North	m East
S2.127	Diesel-Fired Fire Pump 1 (197 HP, Clarke, JU6H-UFADP8, mfd. >2024)	4,377,762	286,396
S2.128	Diesel-Fired Fire Pump 2 (197 HP, Clarke, JU6H-UFADP8, mfd. >2024)	4,377,761	286,408

1. Air Pollution Control Equipment (NAC 445B.346(1)) (*Federally Enforceable SIP Requirement*)
  - a. **S2.127 and S2.128, each**, have no add-on controls.
  - b. Descriptive Stack Parameters  
Stack Height: 12.0 feet  
Stack Diameter: 0.50 feet  
Stack Temperature: 945 °F
2. Operating Parameters (NAC 445B.346(1)) (*Federally Enforceable SIP Requirement*)
  - a. **S2.127 and S2.128, each**, may consume only **diesel**.
  - b. The sulfur content shall not exceed **0.0015** percent.
  - c. The maximum allowable fuel consumption rate for **S2.127 and S2.128, each**, shall not exceed **11.2 gallons** per any one-hour period, nor more than **1,120 gallons** per year of non-emergency use.
  - d. Hours
    - (1) **S2.127 and S2.128, each**, may operate a total of **24** hours per day.
    - (2) **S2.127 and S2.128, each**, may operate a maximum of **100** hours per year of non-emergency use. There is no time limit on operation in emergency situations.
3. Emission Limits (NAC 445B.305, NAC 445B.346(1), NAC 445B. 22017) (*Federally Enforceable SIP Requirement*)  
The Permittee, upon issuance of this operating permit, shall not discharge or cause the discharge into the atmosphere from **S2.127 and S2.128, each**, the following pollutants in excess of the following specified limits:
  - a. The discharge of **PM** (particulate matter) to the atmosphere shall not exceed **0.065** pounds per hour, nor more than **0.0033** tons per year.
  - b. The discharge of **PM<sub>10</sub>** (particulate matter less than or equal to 10 microns in diameter) to the atmosphere shall not exceed **0.065** pounds per hour, nor more than **0.0033** tons per year.
  - c. The discharge of **PM<sub>2.5</sub>** (particulate matter less than or equal to 2.5 microns in diameter) to the atmosphere shall not exceed **0.065** pounds per hour, nor more than **0.0033** tons per year.
  - d. The discharge of **SO<sub>2</sub>** (sulfur dioxide) to the atmosphere shall not exceed **0.40** pounds per hour, nor more than **0.020** tons per year.
  - e. The discharge of **NO<sub>x</sub>** (oxides of nitrogen) to the atmosphere shall not exceed **1.30** pounds per hour, nor more than **0.065** tons per year.
  - f. The discharge of **CO** (carbon monoxide) to the atmosphere shall not exceed **1.13** pounds per hour, nor more than **0.057** tons per year.
  - g. The discharge of **VOCs** (volatile organic compounds) to the atmosphere shall not exceed **0.50** pounds per hour, nor more than **0.025** tons per year.
  - h. The opacity from **S2.127 and S2.128, each**, shall not equal or exceed **20** percent.



Issued to: MECP1 RENO, LLC – RNO1 (AS PERMITTEE)

## Section V. Specific Operating Conditions (continued)

### B. Emission Units S2.127 and S2.128 (continued)

#### 4. Monitoring, Recordkeeping, and Reporting (NAC 445B.346(2)) (*Federally Enforceable SIP Requirement*)

The Permittee, upon the issuance of this operating permit, shall maintain, in a contemporaneous log, the monitoring and recordkeeping specified in this section. All records in the log must be identified with the calendar date of the record. All specified records shall be entered into the log at the end of the shift, end of the day of operation, or the end of the final day of operation for the month, as appropriate.

- a. Monitor and record the total daily hours of operation for **S2.127 and S2.128, each**, for each day of operation. The Permittee shall note which hours of operation are emergency hours, and which hours of operation are hours for non-emergency use.
- b. Monitor and record the consumption rate of **ultra-low sulfur diesel** on a monthly basis for **S2.127 and S2.128, each**, (in **gallons**) either by the maximum fuel consumption rate provided on the manufacturer's specification sheet, to be kept onsite with records, or by use of a continuous non-contact liquid level sensor.
- c. Monitor and record the total yearly consumption rate during non-emergency operations in gallons per year. The annual consumption shall be determined as the sum of the monthly consumption rates for the year for all previous months of that year.
- d. Monitor and record the total yearly non-emergency hours of operation of **S2.127 and S2.128, each**, per year. The annual non-emergency hours of operation shall be determined at the end of each month as the sum of the monthly non-emergency hours of operation for all previous months of that year.
- e. Keep on site, and make available upon request, documentation demonstrating that the sulfur content of the **diesel** consumed in **S2.127 and S2.128, each**, shall not exceed the limit set forth in **B.2.b.** of this section.
- f. The Permittee, upon issuance of this operating permit, shall maintain records of the occurrence and duration of any startup, shutdown, or malfunction in the operation of an affected facility; any malfunction of the air pollution control equipment; or any periods during which a continuous monitoring system or monitoring device is inoperative. (40 CFR 60.7(b))

#### 5. Federal Requirements (NAC 445B.346(2), NAC 445B.252(1)) (*Federally Enforceable SIP Requirement*)

##### New Source Performance Standards (NSPS) – 40 CFR Part 60 Subpart IIII – Standards of Performance for Stationary Compression Ignition Internal Combustion Engines

###### a. Emissions Standards (40 CFR 60.4202, 40 CFR 60.4205)

The Permittee must comply with the emission standards in Table 4 of 40 CFR Part 60 Subpart IIII, for all pollutants, for the same model year and National Fire Protection Association (NFPA) maximum engine power. (40 CFR 60.4202(d), 40 CFR 60.4205(c))

- (1) For a **2009** model year and later stationary fire pump engine with a maximum engine power of **130 ≤kW≤ 225 (175 ≤hp≤ 300)** and less than 30 liters per cylinder: (40 CFR 60.4202(d), 40 CFR 4205(c), Table 4)
  - (a) The discharge of PM to the atmosphere shall not exceed **0.20** gram/kW-hr (**0.15** gram/hp-hr).
  - (b) The discharge of non-methane hydrocarbon (NMHC) + NO<sub>x</sub> to the atmosphere shall not exceed **4.0** grams/kW-hr (**3.0** grams/hp-hr).
  - (c) The discharge of carbon monoxide (CO) to the atmosphere shall not exceed **3.5** grams/kW-hr (**2.6** gram/hp-hr).

###### b. Fuel Requirements (40 CFR 60.4207)

The Permittee must meet the following diesel requirements for non-road engine: (40 CFR 60.4207(b), 40 CFR 1090.305)

- (1) Sulfur content to be 15 parts per million (ppm) maximum.
- (2) A minimum cetane index of 40; or
- (3) A maximum aromatic content of 35 volume percent.

###### c. Monitoring Requirements (40 CFR 60.4209)

If the CI ICE does not meet the standards applicable to non-emergency engines, the Permittee must install a non-resettable hour meter prior to startup of the engine. (40 CFR 60.4209(a))



Issued to: MECP1 RENO, LLC – RNO1 (AS PERMITTEE)

## Section V. Specific Operating Conditions (continued)

### B. Emission Units S2.127 and S2.128 (continued)

5. Federal Requirements (NAC 445B.346(2), NAC 445B.252(1)) (*Federally Enforceable SIP Requirement*)  
New Source Performance Standards (NSPS) – 40 CFR Part 60 Subpart IIII – Standards of Performance for Stationary Compression Ignition Internal Combustion Engines (continued)

d. Compliance Requirements (40 CFR 60.4206, 40 CFR 60.4211)

- (1) The Permittee must operate and maintain stationary CI ICE that achieve the emission standards as required in 40 CFR 60.4205 over the entire life of the engine. (40 CFR 60.4206)
- (2) The Permittee must operate and maintain the stationary CI internal combustion engine and control device according to the manufacturer's emission-related written instructions; change only those emission-related settings that are permitted by the manufacturer; and meet the requirements of 40 CFR Part 1068, except as permitted in **B.5.d.(5)** of this section. (40 CFR 60.4211(a))
- (3) The engine must be installed and configured according to the manufacturer's emission-related specifications, except as permitted in **B.5.d.(5)** of this section. (40 CFR 60.4211(c))
- (4) In order for the engine to be considered an emergency stationary ICE under this subpart, any operation other than emergency operation, maintenance and testing, emergency demand response, and operation in non-emergency situations for 50 hours per year, as described in paragraphs **B.5.d.(4)(a) through (c)** of this section, is prohibited. If the Permittee do not operate the engine according to the requirements in paragraphs **B.5.d.(4)(a) through (c)** of this section, the engine will not be considered an emergency engine under this subpart and must meet all requirements for non-emergency engines. (40 CFR 60.4211(f))
  - (a) There is no time limit on the use of emergency stationary ICE in emergency situations. (40 CFR 60.4211(f)(1))
  - (b) The Permittee may operate the Permittee's emergency stationary ICE for any combination of the purposes specified in paragraphs **B.5.d.(4)(b)** of this section for a maximum of 100 hours per calendar year. Any operation for non-emergency situations as allowed by paragraph **B.5.d.(4)(c)** of this section counts as part of the 100 hours per calendar year. (40 CFR 60.4211(f)(2))
    - i. Emergency stationary ICE may be operated for maintenance checks and readiness testing, provided that the tests are recommended by federal, state or local government, the manufacturer, the vendor, the regional transmission organization or equivalent balancing authority and transmission operator, or the insurance company associated with the engine. The owner or operator may petition the Administrator for approval of additional hours to be used for maintenance checks and readiness testing, but a petition is not required if the owner or operator maintains records indicating that federal, state, or local standards require maintenance and testing of emergency ICE beyond 100 hours per calendar year. (40 CFR 60.4211(f)(2)(i))
  - (c) Emergency stationary ICE may be operated for up to 50 hours per calendar year in non-emergency situations. The 50 hours of operation in non-emergency situations are counted as part of the 100 hours per calendar year for maintenance and testing and emergency demand response provided in paragraph **B.5.d.(4)(b)** of this section. Except as provided in paragraph **B.5.d.(4)(c)** of this section, the 50 hours per calendar year for non-emergency situations cannot be used for peak shaving or non-emergency demand response, or to generate income for a facility to an electric grid or otherwise supply power as part of a financial arrangement with another entity. (40 CFR 60.4211(f)(3))
    - i. The 50 hours per year for non-emergency situations can be used to supply power as part of a financial arrangement with another entity if all of the conditions in 40 CFR 60.4211(f)(3)(i)(A) through (E) are met. (40 CFR 60.4211(f)(3)(i))



**Issued to:** MECP1 RENO, LLC – RNO1 (AS PERMITTEE)

## **Section V. Specific Operating Conditions (continued)**

### **B. Emission Units S2.127 and S2.128 (continued)**

5. Federal Requirements (NAC 445B.346(2), NAC 445B.252(1)) (*Federally Enforceable SIP Requirement*)  
New Source Performance Standards (NSPS) – 40 CFR Part 60 Subpart IIII – Standards of Performance for Stationary Compression Ignition Internal Combustion Engines (continued)
  - d. Compliance Requirements (40 CFR 60.4206, 40 CFR 60.4211) (continued)
    - (5) If the Permittee does not install, configure, operate, and maintain the Permittee's engine and control device according to the manufacturer's emission-related written instructions, or the Permittee change emission-related settings in a way that is not permitted by the manufacturer, the Permittee must demonstrate compliance as follows: (40 CFR 4211(g))
      - (a) For CI ICE greater than or equal to 100 HP and less than or equal to 500 hp, the Permittee must keep a maintenance plan and records of conducted maintenance and must, to the extent practicable, maintain and operate the engine in a manner consistent with good air pollution control practice for minimizing emissions. In addition, the Permittee must conduct an initial performance test to demonstrate compliance with the applicable emission standards within 1 year of startup, or within 1 year after an engine and control device is no longer installed, configured, operated, and maintained in accordance with the manufacturer's emission-related written instructions, or within 1 year after the Permittee change emission-related settings in a way that is not permitted by the manufacturer. (40 CFR 60.4211(g)(2))

- e. National Emission Standards for Hazardous Air Pollutants for Source Categories – 40 CFR Part 63, Subpart ZZZZ – Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines:  
If the compression ignition engine meets the requirements of 40 CFR Part 60 Subpart IIII, 40 CFR Part 63 Subpart ZZZZ requirements are also met. (40 CFR Part 63.6590(c))

\*\*\*\*End of Specific Operating Conditions\*\*\*\*



**Facility ID No. A2652**

**Permit No. AP7374-4772**

**CLASS II AIR QUALITY OPERATING PERMIT**

**Issued to:** MECP1 RENO, LLC – RNO1 (AS PERMITTEE)

**Section VI. Emission Caps**

A. Not Applicable

\*\*\*\*\*End of Emission Caps\*\*\*\*\*

DRAFT



**Issued to:** MECP1 RENO, LLC – RNO1 (AS PERMITTEE)

## **Section VII. Surface Area Disturbance Conditions**

The surface area disturbance for **RNO1** is **56.26** acres.

**A. Fugitive Dust (NAC 445B.22037) (*Federally Enforceable SIP Requirement*)**

1. No person may cause or permit the handling, transporting or storing of any material in a manner which allows or may allow controllable particulate matter to become airborne.
2. Except as otherwise provided in subsection 4, no person may cause or permit the construction, repair, demolition, or use of unpaved or untreated areas without first putting into effect an ongoing program using the best practical methods to prevent particulate matter from becoming airborne. As used in this subsection, “best practical methods” includes, but is not limited to, paving, chemical stabilization, watering, phased construction and revegetation.
3. Except as otherwise provided in subsection 4, no person may disturb or cover 5 acres or more of land or its topsoil until he has obtained an operating permit for surface area disturbance to clear, excavate, or level the land or to deposit any foreign material to fill or cover the land.
4. The provisions of subsections 2 and 3 do not apply to:
  - a. Agricultural activities occurring on agricultural land; or
  - b. Surface disturbances authorized by a permit issued pursuant to NRS 519A.180 which occur on land which is not less than 5 acres or more than 20 acres.

**\*\*\*\*End of Surface Area Disturbance Conditions\*\*\*\***



Nevada Department of Conservation and Natural Resources • Division of Environmental Protection

**Bureau of Air Pollution Control**

**Facility ID No. A2652**

**Permit No. AP7374-4772**

**CLASS II AIR QUALITY OPERATING PERMIT**

**Issued to:** MECP1 RENO, LLC – RNO1 (AS PERMITTEE)

**Section VIII. Schedules of Compliance**

A. Not Applicable

\*\*\*\*\*End of Schedule of Compliance \*\*\*\*\*

DRAFT

**Facility ID No. A2652****Permit No. AP7374-4772****CLASS II AIR QUALITY OPERATING PERMIT****Issued to:** MECP1 RENO, LLC – RNO1 (AS PERMITTEE)**Section IX. Amendments****This permit:**

1. Is non-transferable. (NAC 445B.287.3) (*Federally Enforceable SIP Requirement*)
2. Will be posted conspicuously at or near the stationary source. (NAC 445B.318.5) (*Federally Enforceable SIP Requirement*)
3. Will expire and be subject to renewal five (5) years from: **Date** .  
(NAC 445B.315) (*Federally Enforceable SIP Requirement*)
4. A completed application for renewal of an operating permit must be submitted to the Director on the form provided by him with the appropriate fee at least 70 calendar days before the expiration date of this operating permit. (NAC 445B.3473.2) (*Federally Enforceable SIP Requirement*)
5. Any person aggrieved by a final decision of the Department may, not later than 10 days after notice of the action of the Department, appeal the decision by filing a request for a hearing before the Commission on a form 3\* with the State Environmental Commission, 901 South Stewart Street, Suite 4001, Carson City, Nevada 89701-5249.  
\*(See adopting agency for form.) (NAC 445B.890) (*State Only Requirement*)

**THIS PERMIT EXPIRES ON:** **Date** \_\_\_\_\_**Signature:** \_\_\_\_\_**Issued by:** Tanya Soleta, P.E.  
Supervisor, Permitting Branch  
Bureau of Air Pollution Control**Phone:** (775) 687- 9540    **Date:** **Date** \_\_\_\_\_

## Class II Insignificant Activities List

Appended to Permit #AP7374-4772

Emission Unit #	Emission Unit Description
IA1.001	Diesel Tank 1
IA1.002	Diesel Tank 2

DRAFT