

STATE OF NEVADA PETROLEUM FUND
ABOVEGROUND TANK INSPECTION FORM

Facility I.D.#: _____ Facility Name: _____ Facility Address: _____

Tank Number: _____ Product in Tank: _____ (e.g., Reg. UL, Premium, Diesel, etc.) Tank Capacity (gal.): _____

All aboveground storage tanks (ASTs) that are enrolled in the State of Nevada Petroleum Fund must be visually inspected by the AST operator at least once a month (NAC 445C.250(2)). The results of such inspections must be recorded on this form or another form approved by the Nevada Division of Environmental Protection (NDEP) and made available to NDEP upon request. Inspection records must be kept for at least 3 years (NAC 445C.250(6)). **Leaking components should be immediately repaired or replaced and identified in the Comments column. Refer to Page 2 of this form for release or suspected release reporting requirements.**

DATE (mo/day/yr)	INITIALS OF PERSON WHO INSPECTED TANK	EVIDENCE OF CORROSION, CRACKS, LEAKS, OR SPILLS?					COMMENTS If "Yes" to any question, please describe below. Also, identify any items repaired or replaced to prevent additional corrosion, cracks, leaks, or spills.
		ON SOIL, CONCRETE, OR PAVING? (Yes/No)	ON TANK SURFACE? (Yes/No)	ON PIPING OR VALVES? (Yes/No)	ON PUMPS? (Yes/No)	SECONDARY CONTAINMENT COMPROMISED (Yes, No, or N/A)	

*This form must be filled out for each AST system registered in the Petroleum Fund

A petroleum product release to the environment must be reported to the NDEP Spill Hotline by the end of the first working day after initial discovery in accordance with NAC 445A.347, if:

- 1) Petroleum is confirmed to have released to surface water or groundwater (regardless of quantity), or
- 2) The discovery of petroleum released to soil is greater than or equal to 3 cubic yards, or
- 3) A spill has occurred and the quantity of petroleum product spilled is greater than 25 gallons.

A suspected release of petroleum product to the environment must be reported to the NDEP Spill Hotline or Petroleum Fund staff by the end of the first working day after initial discovery in accordance with Board Policy Resolution 2017-01, if:

- 1) Petroleum product is observed to be leaking from the system during visual inspection of the tank or other aboveground components and product has saturated soil adjacent to the tank system, or
- 2) Annual testing of underground piping associated with an AST indicates a “Fail” result.

To report a spill to NDEP, please use the following website: <https://nevadaenvironmentalactivities.ndep.nv.gov/Default.aspx> or call the NDEP Spill Hotline at **888-331-6337**. For additional questions regarding the above form or suspected releases, Petroleum Fund staff can be reached at (775) 687-9368 between the hours of 8:00 am to 5:00 pm, Monday through Friday.