

Facility Address: _____

Facility I.D.#: _____

Year of Record: _____

STATE OF NEVADA PETROLEUM FUND
ABOVEGROUND TANK INSPECTION FORM

Tank Number: _____ Product in Tank: _____ (i.e. gasoline, diesel, etc.) Tank Volume (gal.) _____

All aboveground storage tanks (ASTs) that are enrolled in the State of Nevada Petroleum Fund must be visually inspected by the AST operator at least once a month (NAC 590.740(2)). The results of such inspections must be recorded on this form or another form approved by the Nevada Division of Environmental Protection (NDEP) and available to NDEP upon request for at least 3 years (NAC 590.750(5)).

A petroleum product release must be reported to the NDEP Spill Hotline by the end of the first working day after initial discovery (NAC 445A.347) if:

- 1) Petroleum is released to surface water or groundwater (regardless of quantity), or
- 2) The discovery of petroleum released to soils is greater than or equal to 3 cubic yards or is due to a spill greater than 25 gallons of product.

Leaking components should be immediately repaired or replaced, and identified in the comments section below.

During business hours (8am-5pm) report a release to the NDEP Spill Hotline at **(775) 687-9485** or **888-331-6337**.

After business hours report a release to the NV Highway Patrol at **(775) 687-2830**.

DATE	PERSON WHO INSPECTED TANK	EVIDENCE OF CORROSION, CRACKS, LEAKS, OR SPILLS?						COMMENTS If yes to any question, please describe. Also, identify any items repaired or replaced.
		ON SOIL, CONCRETE, OR PAVING? (Yes/No)	ON TANK SURFACE? (Yes/No)	ON PIPING? (Yes/No)	ON PUMPS? (Yes/No)	ON VALVES? (Yes/No)	SECONDARY CONTAINMENT (Yes, No, or N/A)	