

**Public Record – Summary Information For Regulated Underground Storage Tanks (USTs)
Nevada Division of Environmental Protection (NDEP)**

Date Posted To Web: May 22, 2018

General Information:

Total Number of UST Facilities : 1,428

Total Number of USTs : 3,758

Summary of Information For On-Site Inspections:

Number of UST Facilities Inspected : 922

Inspection Period Dates : October 1, 2016 through September 30, 2017

Percent Compliance (SOC Combined measure) : 76.9 %

Note : The above tank and facility numbers were produced from NDEP's UST-FITS database. UST information is provided on a notification form (EPA 7530-1) collected from the facility's owner/operator or authorized representative. Significant Operational Compliance (SOC) for on-site inspections is determined using the September 2003 EPA memorandum "Significant Operational Compliance Performance Measures for the Underground Storage Tank Program". Compliance inspections are conducted by NDEP staff in rural counties, the Southern Nevada Health District staff in Clark County, and the Washoe County District Health Department staff in Washoe County.

Please click on the following link for each UST implementing agency's contact information: http://ndep.nv.gov/bca/file/contacts_0608.pdf

Summary Information for Releases:

Number of Confirmed Releases : 10 (At 10 UST Facilities)

Release Reporting Period Dates : October 1, 2016 through September 30, 2017

Summary Information For Release Sources And Causes:

Source			Cause													
			Spill		Overfill		Phys/Mech Damage **		Corrosion		Install Problem		Other		Unknown	
#	%	#	%	#	%	#	%	#	%	#	%	#	%	#	%	
Tank	5	50%	0	0%	0	0%	0	0%	0	0%	0	0%	0	0%	5	100%
Piping	2	20%	0	0%	0	0%	0	0%	0	0%	0	0%	0	0%	2	100%
Dispenser	2	20%	0	0%	0	0%	0	0%	0	0%	0	0%	0	0%	2	100%
STP *	0	0%	0	0%	0	0%	0	0%	0	0%	0	0%	0	0%	0	0%
Delivery Problem	0	0%	0	0%	0	0%	0	0%	0	0%	0	0%	0	0%	0	0%
Other	0	0%	0	0%	0	0%	0	0%	0	0%	0	0%	0	0%	0	0%
Unknown	1	10%	0	0%	0	0%	0	0%	0	0%	0	0%	0	0%	1	100%
Totals	10	100%	0	0%	0	0%	0	0%	0	0%	0	0%	0	0%	10	100%

(# = Number; Source % = Percent of source total number; Cause % = Percent of individual source (i.e. spill, overfill, etc.))

* STP = Submersible turbine pump/sump area; ** Physical/Mechanical Damage

Note : Release source/causes data for the referenced reporting period were collected using NDEP’s Project Tracking (PT) database and Nevada Petroleum Fund coverage applications.

Please click on the following link for NDEP database information and LUST file review procedures: http://ndep.nv.gov/admin/env_info_request.htm