Public Record – Summary Information For Regulated Underground Storage Tanks (USTs) Nevada Division of Environmental Protection (NDEP)

Date Posted To Web: December 18, 2023

General Information:

Total Number of UST Facilities: 1,346

Total Number of USTs: 4,124

Summary of Information For On-Site Inspections:

Number of UST Facilities Inspected: 1263

Inspection Period Dates: October 1, 2022 through September 30, 2023

Percent Compliance (TCR Combined measure): 25%

Note: The above tank and facility numbers were produced from NDEP's Database. Compliance inspections are conducted by NDEP staff in rural counties, the Southern Nevada Health District staff in Clark County, and the Washoe County District Health Department staff in Washoe County.

Please click on the following link for each UST implementing agency's contact information: http://ndep.nv.gov/bca/file/contacts_0608.pdf

Summary Information for Releases:

Number of Confirmed Releases: 6 (At 6 UST Facilities)

Release Reporting Period Dates: October 1, 2022 through September 30, 2023

Summary Information For Release Sources And Causes:

Source			Spill		Overfill		Phys/Mech Damage **		Corrosion		Install Problem		Other		Unknown	
	#	%	#	%	#	%	#	%	#	%	#	%	#	%	#	%
Tank	0	0%	0	0%	0	0%	0	0%	0	0%	0	0%	0	0%	0	0%
Piping	0	0%	0	0%	0	0%	0	0%	0	0%	0	0%	0	0%	0	0%
Dispenser	0	0%	0	0%	0	0%	0	0%	0	0%	0	0%	0	0%	0	0%
STP *	0	0%	0	0%	0	0%	3	0%	0	0%	0	0%	0	0%	0	0%
Delivery Problem	0	0%	0	0%	1	0%	0	0%	0	0%	0	0%	0	0%	0	0%
Other	0	0%	0	0%	0	0%	0	0%	0	0%	0	0%	0	0%	0	0%
Unknown	6	100%	0	0%	0	0%	0	0%	0	0%	0	0%	0	0%	6	100%
Totals	6	100%	0	0%	0	0%	0	0%	0	0%	0	0%	0	0%	6	100%

^{(# =} Number; Source % = Percent of source total number; Cause % = Percent of individual source (i.e. spill, overfill, etc.))

Note: Release source/causes data for the referenced reporting period were collected using NDEP's Project Tracking (PT) database and Nevada Petroleum Fund coverage applications.

Please click on the following link for NDEP database information and LUST file review procedures: http://ndep.nv.gov/admin/env_info_request.htm

^{*} STP = Submersible turbine pump/sump area; ** Physical/Mechanical Damage