

## Nevada Public Water Systems in Non-Compliance with Primary Drinking Water Standards

### Acronyms:

AL	Action Level (for Lead or Copper)
C	Community public water system
MCL	Maximum Contaminant Level
Mg/L	Milligrams per liter
NTNC	Non-Transient, Non-Community public water system
PWS	Public Water System
TNC	Transient, Non-Community public water system

Below are tables showing twenty-two (22) public water systems (PWSs) that are currently non-compliant with primary drinking water standards or are above the Action Level for lead or copper.

**E. coli (EC):** One (1) water system is currently out of compliance with Revised Total Coliform Rule (RTCR). EC+ means that multiple samples detected coliform, and one or more samples also detected E. coli. The system is required to issue a Boil Water Order.

PWS ID	PWS Name	County	PWS Type	Population	Violation Type
NV0000381	Black Rock Station	Washoe	TNC	25	E. Coli. MCL

**Nitrate:** One (1) water system is out of compliance with the Nitrate MCL of 10mg/L. Nitrate MCL is based on the highest sample value within the most recent quarter.

PWS ID	PWS Name	County	PWS Type	Population	Nitrate mg/L
NV0002517	Star Point MHP RV Park	Pershing	TNC	25	14

**Lead:** One (1) water system is out of compliance with the Lead Action Level (0.015 mg/L, 90<sup>th</sup> percentile standard). The Lead Action Level (AL) is not the same as a Maximum Contaminant Level (MCL). Exceeding the AL requires follow up investigation and action.

PWS ID	PWS Name	County	PWS Type	Population	Lead 90th Percentile mg/L
NV0005011	Red Rock Canyon Visitor Center BLM	Clark	NTNC	1744	0.0164

**Copper:** One (1) water system is currently out of compliance with the Copper Action Level (1.3 mg/L, 90<sup>th</sup> percentile standard). The Copper Action Level (AL) is not the same as a Maximum Contaminant Level (MCL). Exceeding the AL requires follow up investigation and action.

PWS ID	PWS Name	County	PWS Type	Population	Copper 90th Percentile mg/L
NV0001175	Flamingo Las Vegas Hotel and Casino	Clark	NTNC	9421	1.4

**Uranium:** One (1) water system is out of compliance with the Uranium MCL (0.030 mg/L, Running Annual Average (RAA)).

PWS ID	PWS Name	County	PWS Type	Population	Uranium RAA mg/L
NV0000767	Rosemount Water Co	Washoe	C	54	0.031
					0.053

**Arsenic:** Four (4) water systems are out of compliance with the Arsenic MCL (0.010 mg/L, Running Annual Average (RAA)).

PWS ID	PWS Name	County	PWS Type	Population	Arsenic RAA mg/L
NV0002190	Amargosa Elementary School	Nye	NTNC	200	0.014
NV0001000	Lhoist North America	Clark	NTNC	136	0.012
NV0005028	Shoshone Estates Water Company, Inc	Nye	C	240	0.027
NV0004021	Silver Knolls Mutual Water Company <sup>i</sup>	Washoe	C	120	0.013

---

<sup>i</sup> NV0004021 has an arsenic MCL exceedance and a treatment technique violation.

**Total Coliform Rule:** Three (3) water systems are out of compliance with the Revised Total Coliform Rule (RTCR). “Corrective/expedited action” means the water system failed to resolve sanitary defect(s) related to coliform within the required timeframe.

PWS ID	PWS Name	County	PWS Type	Population	Violation Type
NV0000881	Dayton Tap House LLC	Lyon	TNC	50	Corrective/Expedited Action (RTCR)
NV0000303	Old River Water Company	Churchill	C	300	Corrective/Expedited Action (RTCR)
NV0002186	Paradise Valley Elementary	Humboldt	NTNC	35	Corrective/Expedited Action (RTCR)

**Sanitary Survey:** Eleven (11) water systems are out of compliance with the Ground Water Rule (GWR) treatment technique requirements. “Failure to address significant deficiency” means the water system failed to complete required maintenance or repairs within the required time frame following an inspection. If left unaddressed, the identified significant deficiencies have a potential to affect public health.

PWS ID	PWS Name	County	PWS Type	Population	GWR violation Type
NV0000147	Bermuda Palms Management LLC	Clark	C	60	Failure to address significant deficiency
NV0000323	Blue Diamond Rainbow SW Plaza Water	Clark	NTNC	1871	Failure to address significant deficiency
NV0000955	Blue Diamond Travel Center H325	Clark	TNC	33	Failure to address significant deficiency
NV0002538	C Valley MHP	Nye	C	54	Failure to address significant deficiency
NV0000426	Desert Sunrise Water Users Assoc	Clark	C	25	Failure to address multiple significant deficiencies
NV0000109	Equestrian Estates Co Op Water Assoc	Clark	C	108	Failure to address multiple significant deficiencies

PWS ID	PWS Name	County	PWS Type	Population	GWR violation Type
NV0000088	Jackpot Water System	Elko	C	1240	Failure to address significant deficiency
NV0000170	Mountain City Water and Sewer	Elko	C	30	Failure to address significant deficiency
NV0000319	Roark Estates Water Assoc	Clark	C	60	Failure to address significant deficiency
NV0004102	Sandy Valley Meetinghouse LDS	Clark	TNC	25	Failure to address multiple significant deficiencies
NV0004021	Silver Knolls Mutual Water Company	Washoe	C	120	Failure to address significant deficiency

## Nevada Public Water Systems in Non-Compliance with Secondary Drinking Water Standards

### Acronyms:

C	Community public water system
CU	Color Units
SMCL	Secondary Maximum Contaminant Level
Mg/L	Milligrams per liter
NTNC	Non-Transient, Non-Community public water system
PWS	Public Water System
TDS	Total Dissolved Solids
TNC	Transient, Non-Community public water system
TON	Threshold Odor Number

Twelve (12) water systems are out of compliance for specific SMCL parameters.

PWS ID	PWS Name	County	PWS Type	Population	SMCL Standard	PWS Value
NV0000009	Beatty Water and Sanitation District	Nye	C	1024	Fluoride 2.0 mg/L	2.3 mg/L
NV0003068	Carson River Estates	Churchill	C	90	Odor 3.0 TON	17 TON
NV0000035	Grandview Terrace Water District	Washoe	C	328	Manganese 0.1 mg/L	0.2 mg/L
NV0000158	Incline Village GID	Washoe	C	9313	Odor 3.0 TON	12.4 TON
					pH 6.5-8.5	8.7 pH
NV0001178	Isabella Pearl Mine	Mineral	NTNC	65	Iron 0.6 mg/L	0.7 mg/L
NV0002071	Jiggs Bar	Elko	TNC	25	Manganese 0.1 mg/L	0.2 mg/L
NV0000717	Pyramid Lake Lodge	Washoe	TNC	25	pH 6.5-8.5	8.8 pH

PWS ID	PWS Name	County	PWS Type	Population	SMCL Standard	PWS Value
NV0002023	Sage Valley MHP LLC	Churchill	C	188	Manganese 0.1 mg/L	0.3 mg/L
NV0001096	Sanders Winery	Nye	TNC	25	TDS 1000 mg/L	1100 mg/L
NV0000922	Ward Charcoal Ovens State Park	White Pine	TNC	25	Iron 0.6 mg/L	1.7 mg/L
NV0003046	Ward Mountain Campground USFS	White Pine	TNC	600	Iron 0.6 mg/L	4.5 mg/L
NV0000255	Yerington City of	Lyon	C	5050	Odor 3.0 TON	6.0 TON