

SAMPLE

DISINFECTANT RESIDUAL DATA QUARTERLY REPORT

PUBLIC WATER SYSTEM NAME: ABC Water Company

PUBLIC WATER SYSTEM ID: NV0011111

| | | | | |
|-------------------------|---|--------------------------------|--|---|
| | 2009 | | | |
| QUARTER (Circle One) | ONE January, February, March | TWO April, May, June | THREE July, August, September | FOUR October, November, December |

| First Month of Quarter: Monthly Summary | | | |
|---|---------|--|-----|
| Month: | January | | |
| Number of Samples Taken | 3 | AVERAGE of all disinfectant residuals for this month | 0.9 |

| Second Month of Quarter: Monthly Summary | | | |
|--|----------|--|------|
| Month: | February | | |
| Number of Samples Taken | 3 | AVERAGE of all disinfectant residuals for this month | 0.85 |

| Third Month of Quarter: Monthly Summary | | | |
|---|-------|--|-----|
| Month: | March | | |
| Number of Samples Taken | 3 | AVERAGE of all disinfectant residuals for this month | 0.8 |

| Quarterly Summary | | | |
|--|------|--|------|
| Total Number of Samples Taken for this Quarter | 9 | AVERAGE of all disinfectant residuals for this quarter | 0.85 |
| HIGHEST Residual for this quarter | 0.95 | | |

| Running Annual Average Summary ¹ | | | | |
|---|---|--------|--------|--------|
| Quarter | A | B | C | D |
| Year-Quarter | 2009-1 | 2008-2 | 2008-3 | 2008-4 |
| Average for quarter | 0.85 | 1.1 | 0.95 | 0.75 |
| Running Annual Average (RAA) | $(A+B+C+D)/4 = (0.85+1.1+0.95+0.75)/4 = 0.91$ | | | |

1- Running annual average is the average of the last 12 months of monthly averages and will be computed after 12 months of data are available.

Signature: _____

Date: _____

Print Name: _____

Phone Number: _____

Mail To: Division of Environmental Protection
Bureau of Safe Drinking Water
901 South Stewart Street, Suite 4001
Carson City, NV 89701

Form Due by the 10th of April, July, October, and January